



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

William J. Museler
Site Vice President
Watts Bar Nuclear Plant

JAN 04 1994

CDR-50-390
CDR-50-391

10 CFR 50.55(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of)
Tennessee Valley Authority) Docket Nos. 50-390
50-391

WATTS BAR NUCLEAR PLANT (WBN) UNITS 1 AND 2 - CONSTRUCTION DEFICIENCY REPORT
(CDR) 50-390, 391/91-36 - POTENTIAL COMMON MODE FAILURE OF VITAL CONTROL
POWER SYSTEM SUPPLIES - COMMITMENT CLARIFICATION

The purpose of this letter is to provide a clarification of a commitment made to NRC in the subject construction deficiency report. A final report for the subject deficiency was submitted to NRC on December 16, 1991. On October 27, 1992, TVA clarified a commitment made in the final report. The clarified commitment read, "TVA currently plans to add cooling from the "A" Train HVAC System to the "B" Train 480 volt board rooms and from the "B" Train HVAC System to the "A" Train 480 volt board rooms."

TVA has determined that the "A" Train 480 volt board rooms do not contain safety-related "B" Train equipment and do not require cooling from the "B" Train HVAC System. Cooling from the "A" Train HVAC System will still be provided to the "B" Train 480 volt board rooms.

If you have any questions, please telephone P. L. Pace at (615) 365-1824.

Very truly yours,

William J. Museler

cc: See page 2

110045

9401120274 940104
PDR ADOCK 05000390
S PDR

JE27 1/0

U.S. Nuclear Regulatory Commission
Page 2

JAN 04 1994

cc: INPO Record Center
700 Galleria Parkway
Atlanta, Georgia 30339

NRC Resident Inspector
Watts Bar Nuclear Plant
Rt. 2, P.O. Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323