

U.S. NUCLEAR REGULATORY COMMISSION
 OPERATIONS CENTER

EVENT NOTIFICATION WORKSHEET

NOTIFICATION TIME 1820 9/25	FACILITY OR ORGANIZATION LMTD BAR UNIT 1/2	UNIT D C PACE	CALLER'S NAME D C PACE	CALL BACK # : ENS or 1615 1361 - 1824
EVENT TIME & ZONE NA	EVENT DATE 8/22/94	1-Hr Non-Emergency 10 CFR 50.72(b)(1)		(i) Lost Offsite Comm.
POWER/MODE BEFORE NA	POWER/MODE AFTER NA	(ii)(A) ES Required S/D	(ii)(B) ES Distribution	(i) For
EVENT CLASSIFICATIONS GENERAL EMERGENCY SITE AREA EMERGENCY ALERT UNUSUAL EVENT 50.72 NON-EMERGENCY PHYSICAL SECURITY (72.71) TRANSPORTATION 70.405 MATERIAL/EXPOSURE X OTHER 10 CFR 50.55c		(iii) Degraded Condition	(iii)(A) Unaltered Condition	(ii) Toxic Gas
		(iii)(B) Outside Design Basis	(iii)(C) Not Covered by OPR/EP	(ii) Rad Release
		(iv) Earthquake	(iv) Flood	(ii) On Hammering Safe Op.
		(v) Hurricane	(v) Lightning	4-Hr Non-Emergency 10 CFR 50.72(b)(2)
		(vi) Tornado	(vi)(A) Air Release > 2X App B	(i) Degraded While S/D
		(vii) On Natural Phenomenon	(vii)(B) BWR Capability	(i) RPS Activation (scram)
		(viii) ECCS Discharge to RCS	(viii)(C) Control of Rad Release	(i) ESF Activation
		(ix) Loss ENS	(ix)(D) Accident Mitigation	(i) Self S/D Capability
		(x) Loss Emergency Assignment	(x)(A) Air Release > 2X App B	(i) BWR Capability
			(x)(B) Lie Release > 2X App B	(i) Control of Rad Release
			(x)(C) Offsite Medical	(i) Accident Mitigation
			(x)(D) Offsite Notification	(i) Air Release > 2X App B
				(i) Lie Release > 2X App B
				(i) Offsite Medical
				(i) Offsite Notification

DESCRIPTION

Between 8/22 and 8/25/94, NRC and QC inspectors identified slope discrepancies on 6 of 8 Essential Raw Cooling Water Pumps' motor bearing cooling lines. It is suspected they were moved out of slope tolerance by personnel interaction. In the event of freezing conditions, the normally self-draining supply or drain lines could freeze on idle pumps such that sufficient pumps may not be available when called on for Design Basis Events, if the conditions had not been corrected. The ERCW system is required in Design Basis Events to transfer heat from components important to safety to the ultimate heat sink. Under the above worst case freezing conditions, the safety function could not be confirmed.

Reference: CDR 94-14
 Corrective Action Document: WBPER940485

9411010180 941025
 PDR ADDCK 05000390
 S PDR

NOTIFICATIONS	YES	NO	WILL BE	ARE THERE ORIGINAL OR NOT UNDERSTOOD?	YES	NO
NRC RESIDENT	✓				YES	NO
STATE		✓		DID ALL SYSTEMS FUNCTION AS REQUIRED?	YES	NO
LOCAL		✓		NA		
OTHER GOV AGENCIES		✓		MODE OF OPERATION	NA	
MEDIA PRESS RELEASE		✓		UNITS CORRECTED	NA	
				ESTIMATE FOR RESTART DATE	NA	
				ADDITIONAL INFO ON BACK?		

IF 27
 011