



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

OCT 17 1995

CDR 390/79-43-03
CDR 391/79-36-03

10 CFR 50.55(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

WATTS BAR NUCLEAR PLANT (WBN) UNITS 1 AND 2 - UNDETECTABLE FAILURE
IN THE SOLID STATE PROTECTION SYSTEM P-4 SIGNAL - NONCONFORMANCE
REPORT (NCR) NEB 79-4 AND NEB 79-5 - SUPPLEMENT TO FINAL REPORT

The purpose of this letter is to revise the commitment made in
TVA's letter to NRC dated December 20, 1979, which provided TVA's
final report under 10 CFR 50.55(e) for the subject deficiency.
This deficiency was originally reported to NRC by Westinghouse
Corporation under 10 CFR Part 21 in a letter dated November 7,
1979.

ORIGINAL COMMITMENT (Reference: NCO920043242)

"TVA will revise the appropriate procedures to require tests to
verify the P-4 contact status following automatic reactor trip or
any condition requiring opening of the reactor trip breakers. The
test will be repeated following reclosure of the reactor trip
breakers and prior to rod withdrawal." (Applicable in all plant
modes.)

REVISED COMMITMENT

TVA will revise the appropriate procedures to require tests to
verify the P-4 contact status following automatic reactor trip or
any condition requiring opening of the reactor trip breakers. The
test will be repeated following reclosure of the reactor trip
breakers and prior to rod withdrawal. (Applicable in plant modes
1, 2, and 3 only.)

JEAN 1/0

9510260014 951017
PDR ADOCK 05000390
S PDR

U.S. Nuclear Regulatory Commission
Page 2


OCT 17 1995

JUSTIFICATION FOR REVISED COMMITMENT

The original commitment required testing of the P-4 contact status in modes where the P-4 status was not applicable. The final draft of the WBN Technical Specifications, Surveillance Requirement 3.3.2.11, for the Reactor Trip, P-4, Engineered Safety Feature Actuation System Interlocks (Table 3.3.2-1) is currently applicable in Modes 1, 2, and 3 only.

If you should have any questions, please contact P. L. Pace at (423) 365-1824.

Sincerely,



P. R. Barón
Nuclear Assurance
and Licensing Manager (Acting)

cc: NRC Resident Inspector
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323