



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

MAR 25 1996

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the
Tennessee Valley Authority

) Docket Nos. 50-390
)

WATTS BAR NUCLEAR PLANT (WBN) - UNIT 1 - FACILITY OPERATING
LICENSE NPF-90 - LICENSEE EVENT REPORTS (LERS) 50-390/96006 AND
50-390/96007

Enclosure 1 contains LER 50-390/96006 which details the failure to maintain the containment sump screen door in a closed position while in Mode 4. Submittal of this report is in accordance with 10 CFR 50.73(a)(2)(v). Enclosure 2 contains LER 50-390/96007 which details the failure to maintain the divider barrier hatch in a closed position while in Mode 4. Submittal of this report is in accordance with 10 CFR 50.73(a)(2)(i).

Sincerely,

D. V. Kehoe
Nuclear Assurance
and Licensing Manager

Enclosures
cc: See page 2

290024
9603290264 960325
PDR ADOCK 05000390
S PDR

JE221

U.S. Nuclear Regulatory Commission
Page 2

MAR 25 1996

cc (Enclosures):

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5957

NRC Resident Inspector
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Enclosure 1
LER 50-390/96006