



Tennessee Valley Authority Post Office Box 2000 Spring City Tennessee 37381

APR 25 1996

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of) Docket No. 50-390
Tennessee Valley Authority)

WATTS BAR NUCLEAR PLANT (WBN) - UNIT 1 FACILITY OPERATING LICENSE
NPF-90 - LICENSEE EVENT REPORT (LER) 50-390/96010 - MISPOSITION OF
EMERGENCY GAS TREATMENT SYSTEM (EGTS) HANDSWITCHES

The purpose of this letter is to provide the subject LER. The enclosed report provides details regarding the misposition of the EGTS handswitches discovered on March 26, 1996.

This condition was initially reported under 10 CFR 50.72(b)(2)(iii)(D) due to the initial assumption that both EGTS trains were inoperable. However, that report was withdrawn on April 24, 1996, after it was determined that only one train was inoperable. During TVA's investigation, however, it was determined that at the time of discovery this condition had exceeded the Limiting Condition for Operation (LCO) 3.6.9.A time requirement which is reportable. Therefore, submittal of this report is in accordance with 10 CFR 50.73(a)(2)(i)(B).

If you should have any questions, please contact P. L. Pace at (423) 365-1824.

Sincerely,

D. V. Kehoe
Nuclear Assurance
and Licensing Manager

Enclosure

cc: See page 2

9605060054 960425
PDR ADOCK 05000390
S PDR

U.S. Nuclear Regulatory Commission

Page 2

APR 25 1996

cc (Enclosure):

NRC Resident Inspector
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

ENCLOSURE