

Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

Richard T. Purcell  
Site Vice President, Watts Bar Nuclear Plant

SEP 24 1998

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of ) Docket No. 50-390  
Tennessee Valley Authority )

WATTS BAR NUCLEAR PLANT (WBN) - UNIT 1 - FACILITY OPERATING  
LICENSE NPF-90 - LICENSEE EVENT REPORT (LER) 50-390/98003

The enclosed report provides details regarding an event in which both trains of the Control Room Emergency Air Temperature Control System (CREATCS) were rendered inoperable for six minutes. This resulted in a mandatory entry into Technical Specification 3.0.3. Submittal of the report regarding this event is in accordance with 10 CFR 50.73(a)(2)(i)(B).

If you should have any questions, please contact P. L. Pace at (423) 365-1824.

Sincerely,



R. T. Purcell

Enclosure

cc: See page 2

9809300143 980924  
PDR ADOCK 05000390  
S PDR

11  
IL 22

U.S. Nuclear Regulatory Commission

Page 2

SEP 24 1998

cc (Enclosure):

NRC Resident Inspector  
Watts Bar Nuclear Plant  
1260 Nuclear Plant Road  
Spring City, Tennessee 37381

Mr. Robert E. Martin, Senior Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission  
Region II  
Atlanta Federal Center  
61 Forsyth St., SW, Suite 23T85  
Atlanta, Georgia 30303