

AUG 10 1994

*Official copy*

Docket Nos. 50-390, 50-391  
License Nos. CPPR-91, CPPR-92

Tennessee Valley Authority  
ATTN: Mr. Oliver D. Kingsley, Jr.  
President, TVA Nuclear and  
Chief Nuclear Officer  
6A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Gentlemen:

SUBJECT: MEETING SUMMARY - WATTS BAR UNITS 1 AND 2

This letter refers to the meeting conducted at the Watts Bar site on July 6, 1994. The meeting was at your request to discuss changes TVA proposes to make to the preoperational test program, as described in Chapter 14 of the FSAR. Enclosure 1 is a list of the individuals who attended the meeting and Enclosure 2 is the meeting agenda. TVA formally docketed the handout material in a memo of July 14, 1994, to the NRC. It is our opinion that this meeting was beneficial and provided a better understanding of TVA's activities.

Should you have any questions concerning this letter, please contact me.

Sincerely,

Original Signed By:  
J. P. Jaudon

Johns P. Jaudon, Acting Deputy Director  
Division of Reactor Projects

Enclosures:

1. List of Attendees
2. Meeting Agenda

cc w/encls: (See page 2)

200078

9408290056 940810  
PDR ADDCK 05000390  
A PDR

IE45

AUG 10 1994

Tennessee Valley Authority

2

cc w/encls:

Mr. Craven Crowell, Chairman  
Tennessee Valley Authority  
ET 12A  
400 West Summit Hill Drive  
Knoxville, TN 37902

Mr. W. H. Kennoy, Director  
Tennessee Valley Authority  
ET 12A  
400 West Summit Hill Drive  
Knoxville, TN 37902

Mr. Johnny H. Hayes, Director  
Tennessee Valley Authority  
ET 12A  
400 West Summit Hill Drive  
Knoxville, TN 37902

Dr. Mark O. Medford, Vice Pres.  
Engineering and Technical Services  
Tennessee Valley Authority  
3B Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. D. E. Nunn, Vice President  
New Plant Completion  
Tennessee Valley Authority  
3B Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. J. A. Scalice, Site Vice Pres.  
Watts Bar Nuclear Plant  
Tennessee Valley Authority  
P. O. Box 2000  
Spring City, TN 37381

General Counsel  
Tennessee Valley Authority  
ET 11H

400 West Summit Hill Drive  
Knoxville, TN 37902

Mr. R. W. Huston, Manager  
Nuclear Licensing and  
Regulatory Affairs  
4G Blue Ridge  
1101 Market Street  
Chattanooga, TN 37402-2801

Mr. B. S. Schofield  
Site Licensing Manager  
Watts Bar Nuclear Plant  
Tennessee Valley Authority  
P. O. Box 2000  
Spring City, TN 37381

TVA Representative  
Tennessee Valley Authority  
11921 Rockville Pike  
Suite 402  
Rockville, MD 20852

Mr. M. H. Mobley, Director  
Division of Radiological Health  
3rd Floor, L and C Annex  
401 Church Street  
Nashville, TN 37243-1532

The Honorable Robert Aikman  
County Executive  
Rhea County Courthouse  
Dayton, TN 37321

The Honorable Garland Lanksford  
County Executive  
Meigs County Courthouse  
Decatur, TN 37322

Danielle Droitsch  
Energy Project  
The Foundation for Global  
Sustainability  
P. O. Box 1101  
Knoxville, TN 37901

Mr. Bill Harris  
Route 1, Box 26  
Ten Mile, TN 37880

bcc w/encls: (See page 3)

AUG 10 1994

Tennessee Valley Authority

3

bcc w/encls:

S. D. Ebnetter, ORA/RII

E. W. Merschoff, DRP/RII

A. F. Gibson, DRS/RII

J. P. Stohr, DRSS/RII

F. J. Hebdon, NRR

G. C. Lainas, NRR

A. P. Hodgdon, OGC

B. K. Keeling, GPA/CA

RII Coordinator, OEDO

P. S. Tam, NRR

NRC Document Control Desk

NRC Resident Inspector

U.S. Nuclear Regulatory Commission

Route 2, Box 700

Spring City, TN 37381

SEND	OFC	DRP/RII				
TO	NAME	CJulian:wg				
PDR?	DATE	08/10/94	/ /94	/ /94	/ /94	/ /94
Yes	No	COPY?	Yes	No	Yes	No

OFFICIAL RECORD COPY

DOCUMENT NAME: G:\SEC48\MEET706.SUM

ENCLOSURE 1

LIST OF ATTENDEES

Name

Title

NRC Staff

J. P. Jaudon	Deputy Director, Division of Reactor Projects (DRP), Region II (RII)
C. A. Julian	Branch Chief, Watts Bar (WB) Operations Branch, DRP, RII
P. A. Taylor	Reactor Inspector, DRP, RII
K. E. Ivey	Resident Inspector, DRP, RII
P. S. Tam	Senior Project Manager, Office of Nuclear Reactor Regulation (NRR)
J. D. Peralta	Operations Engineer, NRR
R. A. Gramm	Section Chief Quality Assurance, NRR

TVA Staff

B. S. Schofield	Site Licensing Manager, Tennessee Valley Authority (TVA)
C. Touchstone	Licensing Engineer, TVA
T. L. Porter	Licensing SP Project Manager, TVA
M. W. Herlihy	Startup Engineer, TVA
G. Ondriska	Startup Test Program (SUT) TVA
W. S. Delk	Reactor Engineer, TVA
R. L. Warren	Reactor Engineer, Power Asc. Testing, TVA
K. E. Schaus	Assessment Manager, TVA
F. A. Koontz	Lead Mech/Nucl. Engineer, TVA
D. Koehl	Technical Support Manager, TVA
M. Bajestanj	SUT, Manager, TVA
J. Vorsees	Reg. Licensing Manager, TVA

ENCLOSURE 2

**TVA/NRC MEETING JULY 6, 1994**  
**FSAR CHAPTER 14 - TEST PROGRAM**  
**AGENDA**

- I. Introduction TVA - Bruce Schofield
  
- II. Status of FSAR Chapter 14
  - ~~Preop Phase (Table 14.2-1)~~ ——— ——— — TVA - Masoud Bajestani
  - Power Ascension Phase (Table 14.2-2) TVA - Whiting Delk
  - Schedule for next Amendment (Am 88) TVA - John Vorees
  
- III. Discussion of proposed changes
  - A. Preop Phase (Table 14.2-1) TVA - Masoud Bajestani
  - B. Power Ascension Phase (Table 14.2-2) TVA - Whiting Delk
  
- IV. NRC Comments

FASR Chapter 14 Change Packages Since Amendment 84/86

Change Pkg	Approved by TVA?	Summary
1068	Yes	Preop - Clarify that Post Accident Sampling Facility (PASF) testing does not include analysis/time measurements
1073	Yes	Preop - Clarification for loss of control air testing
1079	Yes	Preop - Deletion of abstracts where alternate testing will be performed instead of PTIs; also includes clarification of some abstracts:
1080	Yes	Preop - Similar to 1079
1089	Yes	Power Ascension - Clarification to 8 test abstracts
1089 S1-3	Yes	Power Ascension - Supplements to 1080
1096	Yes	Preop - Clarifies 2 abstracts; deletes load testing of Common Station Service Transformers (CSSTs) based on transformer capacity
1097	Yes	Preop - Clarifications for Containment Integrated Leak Rate Test (CILRT) in Ch 6 and 14.

Total Number of affected test abstracts: Preop - app. 23 of 61; Power Ascension - 8 of 35 (no deletions)