

DRAFT

DRAFT

Comments on FAQ 07-0039 (B-2 & B-3 Tables)

1. Multiple Spurious Actuations and Recovery Actions are not fully addressed.
2. New B.2.2.1 Section needs to reflect FAQ 06-0011 changes for III.G.3 areas.
3. The deleted B.2.2.1 section removes the direction for inadequate exemption/deviation bases to be entered into the corrective action program, plus all the attended requirements for enforcement discretion.
4. NFPA 805 requires fire hazards to be identified on a fire area by fire area basis, should this be included somewhere in the B-2 Table.

DRAFT

DRAFT