

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: March 1996

DOCKET NO: 50/390
 UNIT NAME: WBN-1
 DATE: 4/2/96
 COMPLETED BY: L. Parscale
 TELEPHONE: (423) 365-2335

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
6	960328	S	78.4	B	3	N/A	N/A	N/A	On March 28, 1996, at approximately 1735 EST with the unit at approximately 30 percent reactor power, a loss of offsite test was conducted as part of the Power Ascension Test Program. A turbine and reactor trip were initiated as a result of this test. The plant functioned as expected and was stabilized in mode 3. However, on March 31, 1996, with the unit in mode 3 and during control rod withdrawal operators opened the reactor trip breakers when control bank D position on the insertion computer and the control board did not agree. The cause of this event was determined to be result of a computer card component failure and a faulty step counter. (Licensee Event Report 390/96012)

¹F: Forced
 S: Scheduled

²Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continuation of Existing Outage
 5-Reduction
 9-Other

⁴Exhibit G - Instructions
 for Preparation of Data
 Entry sheets for Licensee
 Event Report (LER) File
 (NUREG - 1022)

⁵Exhibit 1-Same Source

9605220397 960515
 PDR ADOCK 05000390
 R PDR