

ENCLOSURE 3

TENNESSEE VALLEY AUTHORITY
WATTS BAR NUCLEAR PLANT UNIT 1

JUNE 1996
MONTHLY OPERATING REPORT
TO THE
NUCLEAR REGULATORY COMMISSION

CORRECTED PAGES IN THE APRIL 1996 REPORT

UNIT 1
DOCKET NUMBER 50-390
LICENSE NUMBER NPF-90

9607230200 960715
PDR ADOCK 05000390
R PDR

OPERATING DATA REPORT

DOCKET NO. 50-390
 DATE 7/15/96
 COMPLETED BY R. Tolley
 TELEPHONE (423) 365-3550

NOTES

OPERATING STATUS

1. Unit Name: Watts Bar Unit One
2. Reporting Period: April 1996
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1269.8
5. Design Electrical Rating (Net MWe): 1160
6. Maximum Dependable Capacity (Gross MWe): 1166
7. Maximum Dependable Capacity (Net MWe): 1125
8. If Changes Occur in Capacity Ratings (Item Numbers 3 through 7) Since Last Report, Give Reasons:
N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons for Restrictions, If Any: _____

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	<u>719.0</u>	<u>1759.0</u>	<u>1759.0</u>
12. Number of Hours Reactor Was Critical	<u>559.6</u>	<u>1122.6*</u>	<u>1122.6*</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>460.5</u>	<u>842.7</u>	<u>842.7</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWh)	<u>999,029</u>	<u>1,487,468*</u>	<u>1,487,468*</u>
17. Gross Electrical Energy Generated (MWh)	<u>329,990</u>	<u>456,159</u>	<u>456,159</u>
18. Net Electrical Energy Generated (MWh)	<u>304,851</u>	<u>392,880</u>	<u>392,880</u>
19. Unit Service Factor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
20. Unit Availability Factor	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
21. Unit Capacity Factor (Using MDC Net)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
22. Unit Capacity Factor (Using DER Net)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
23. Unit Forced Outage Rate	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):
May 14, 1996 - Power Ascension Test Program for approximately 6 days
October 19, 1996 - Mid-Cycle Surveillance Instruction (SI) Outage for approximately 23-30 days

25. If Shut Down at End of Report Period, Estimated Date of Startup: May 1, 1996

*Revised data to delete credit for hours/megawatts earned prior to initial electrical generation. Data had been provided for information in the February 1996 Monthly Operating Report.