

**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
Subcommittee on ESBWR Design Certification

Docket Number: (n/a)

PROCESS USING ADAMS  
TEMPLATE: ACRS/ACNW-005  
SUNSI REVIEW COMPLETE

Location: Rockville, Maryland

Date: Thursday, November 15, 2007

Work Order No.: NRC-1866

Pages 1-368

**ORIGINAL**

NEAL R. GROSS AND CO., INC.  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

ACRS OFFICE COPY  
RETAIN FOR THE LIFE OF THE COMMITTEE

TROY

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

November 15, 2007

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on November 15, 2007, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1 UNITED STATES OF AMERICA  
2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)  
5 SUB-COMMITTEE ON ESBWR DESIGN CERTIFICATION

6 + + + + +

7 THURSDAY,

8 NOVEMBER 15, 2007

9 + + + + +

10 The meeting was convened in Room T-2B3 of  
11 Two White Flint North, 11545 Rockville Pike,  
12 Rockville, Maryland, at 8:30 a.m., Dr. Michael  
13 Corradini, Chairman, presiding.

14 ACRS MEMBERS PRESENT:

15 MICHAEL CORRADINI, Chairman

16 JOHN D. SIEBER

17 MARIO V. BONACA

18 GEORGE APOSTOLAKIS

19 OTTO L. MAYNARD

20 DENNIS C. BLEY

21 JOHN W. STETKAR

22 WILLIAM J. SHACK

23 SAID ABDEL-KHALIK

24 SAM J. ARMIJO

25

1     NRC STAFF PRESENT:  
2     AMY CUBBAGE  
3     ERIC OESTERLE  
4     R. FOSTER  
5     M. COMAR  
6     JORGE HERNANDEZ  
7     YAMIR DIAZ-CASTILLO  
8     CHANG LI  
9     MUHAMMED SHUABHI  
10    DAVID SHUM  
11    ROBERT RADLINSKI  
12    KIM GRUSS  
13    EDWIN FORREST  
14    AMAR PAL  
15    ERIC OESTERLE  
16    GEORGE GEORGIEV  
17    ROBERT DAVIS  
18    ROCKY FOSTER  
19    RICHARD PELTON  
20    BRUCE MUSICKO  
21    DAN BARSE  
22    AL TARDIFF  
23    MANNY COMAR  
24    CRAIG HARBUCK  
25    MICHAEL MARSHALL



1     ALSO PRESENT:

2     JIM KINSEY

3     MICHAEL ARCARO

4     JOHN GELS

5     ARTHUR ALFORD

6     LARRY TUCKER

7     HUGH UPTON

8     GARY MILLER

9     WAYNE MARTINO

10    MIKE SILVA

11    PETER JORDAN

12    GARY ANTHONY

13    RUSS KUSIC

14    ALAN BEARD

15    DAN WILLIAMSON

16

17

18

19

20

21

22

23

24

25

TABLE OF CONTENTS

	<u>Page No.</u>
Opening Remarks . . . . .	5
DCD Chapter 9, "Auxiliary Systems"	
GEH Jim Kinsey . . . . .	7
SER With Open Items for Chapter 9	
NRO, Amy Cubbage . . . . .	60
HVAC Systems	
NRC, Ed Forrest . . . . .	109
Fire Protection	
NRC, Bob RadLinski . . . . .	126
DCD Chapter 10, "Steam and Power Conversion System"	
GEH, Gary Anthony . . . . .	148
SER with Open Items for Chapter 10	
NRO, Eric Oesterie . . . . .	181
DCD Chapter 13 "Conduct of Operations"	
GEH, Alan Beard . . . . .	211
SER With Open Items for Chapter 13	
R. Foster, NRO . . . . .	231
DCD Chapter 16, "Technical Specifications,	
GEH, Jim Kinsey . . . . .	262
SER with Open Items for Chapter 16	
M. Comar, NRO . . . . .	300
Subcommittee Discussion . . . . .	338

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIRMAN CORRADINI: The meeting will come to order. This is the meeting of the ESBWR Subcommittee. My name is Mike Corradini, Chair of the subcommittee. Other ACRS members in attendance are Said Abdel-Khalik, Sam Armijo, George Apostolakis, Dennis Bley, Mario Bonaca, Otto Maynard, Jack Sieber, and John Stetkar. Graham Wallis and Tom Kress are also attending as consultants for the subcommittee.

Gary Hammer, of the ACRS staff, is the Designated Federal Officer for this meeting.

The purpose of the meeting is to review and discuss the safety evaluation report with open items for several chapters of the ESBWR design certification. We will hear presentations from the NRC's Office of New Reactors and G.E./Hitachi Nuclear Energy Americas, LLC.

The subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions as appropriate for deliberation by the full committee.

The rules for participation in today's meeting have been announced as part of the notice of this meeting, previously published in the Federal

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Register. Portions of the meeting may be closed for  
2 discussion of unclassified safeguards and proprietary  
3 information.

4 We received no written comments or  
5 requests for time to make oral statements from members  
6 of the public regarding today's meeting.

7 A transcript of the meeting is being kept  
8 and will be made available as stated in the Federal  
9 Register notice. Therefore, we request that  
10 participants in this meeting use microphones located  
11 throughout the meeting room when addressing the  
12 subcommittee. The participants should first identify  
13 themselves, speak with sufficient clarity and volume  
14 so that they may be readily heard.

15 Before we proceed with the meeting, a  
16 couple of notes to the subcommittee and consultants.  
17 We are going to be having a discussion on four  
18 chapters today. We will probably have a subcommittee  
19 meeting in January for additional chapters, and  
20 consider this with the full committee probably March,  
21 full committee meeting. So, in preparation for that,  
22 please keep in mind the things that you are most  
23 wanting to discuss at full committee and let us know  
24 by the end of the day when we get to the end of the  
25 discussion, or by your report, consultant reports, so

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 that when we get together and prepare for the full  
2 committee, and we'll have a number of chapters, we  
3 want to be relatively organized as to what we focus on  
4 in the full committee and not go through all of the  
5 chapters, because it's just not going to be possible.

6 MEMBER APOSTOLAKIS: Are we going to write  
7 the letter in March?

8 CHAIRMAN CORRADINI: Yes, we will. We've  
9 written the interim letter on the first set of  
10 chapters, we will do the same again in March for the  
11 next set of chapters.

12 MEMBER APOSTOLAKIS: The PRA part is  
13 separate?

14 CHAIRMAN CORRADINI: Separate. We are  
15 anxiously awaiting for that.

16 Okay, so let's proceed. I'll call upon  
17 Jim Kinsey of G.E./Hitachi Nuclear Energy Americas,  
18 LLC, to begin. Jim?

19 MR. KINSEY: Good morning. My name is Jim  
20 Kinsey from G.E./Hitachi. Just a couple of brief  
21 opening remarks. We appreciate the subcommittee's  
22 attendance this morning and the opportunity to present  
23 four more chapters out of our design control document  
24 with a portion of a fifth chapter as requested.

25 I wanted to point out that in some of our

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 previous sessions you have raised some issues and  
2 questions that we promised we'd come back around to  
3 when we covered the chapters that more directly  
4 addressed those issues. Many of those are on the  
5 agenda for today, so we expect that we should be able  
6 to answer your questions in those areas today.

7 And also, as Dr. Corradini mentioned,  
8 it's, basically, our goal to answer your questions or  
9 understand whatever open items you may have at the end  
10 of the day today, with our goal being that you'll have  
11 no significant issues going forward, but if you do we  
12 just want to be sure that we clearly understand those  
13 so that we are prepared to address them when we come  
14 back around for the full committee.

15 And, I guess on that note, I'll turn  
16 things over to our chapter --

17 CHAIRMAN CORRADINI: I think there's  
18 another comment back here.

19 MR. KINSEY: Oh, I'm sorry.

20 MEMBER MAYNARD: Before you start, I hope  
21 you got the message I'd sent through the staff. I  
22 reviewed Chapter 9, Chapter 9 has a lot of systems in  
23 it, and a lot of interaction, and I think we could  
24 probably spend a week talking about Chapter 9.

25 I think that there's four areas that we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 need to make sure that we focus on, and then as we  
2 have time we can go into lots of others, one of those  
3 being the refueling systems, the refueling the pools,  
4 the elevation differences, the incline transfer, the  
5 fuel pool heatings and coolings, especially without  
6 AC. Another was the standby liquid control system,  
7 since that's important for shut down there. HVAC,  
8 without AC, as to how we handle the smoke and the  
9 necessary equipment, instrumentation, control room  
10 operators and stuff, and then also fire protection,  
11 how do we handle fire protection without AC and  
12 without pumps and stuff.

13 When I started to do this, I did generate  
14 a long list of questions. I think we need to make  
15 sure we stay focused on those things necessary to make  
16 the safety case, and then we can deal with other  
17 questions if we have time or submit those to you  
18 later.

19 MR. KINSEY: Appreciate that feedback. I  
20 think our presentation will generally touch on those  
21 topics and we'll try to focus our attention on those  
22 and make sure we answer any questions or clearly  
23 describe what's there.

24 CHAIRMAN CORRADINI: Thank you.

25 Go ahead.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. ALFORD: Good morning. My name is Art  
2 Alford of GEH. I am a Regulatory Affairs Chapter  
3 Engineer for D.C. Chapter 9. I'd like to introduce  
4 both Michael Arcaro and John Gels for the presentation  
5 on DCB Chapter 9, Utility Systems, and Section 6.4,  
6 Control Room Habitability.

7 Mike?

8 MR. ARCARO: Good morning. My name is  
9 Mike Arcaro, I'm the Principal Engineer for balance-  
10 of-plant auxiliary systems for ESBWR.

11 What we'd like to do today is provide a  
12 broad overview of the auxiliary systems associated  
13 with ESBWR, as described in Chapter 9, and we'll also  
14 touch on the control room habitability in Section 6.4,  
15 which follows along in the Chapter 9, 9.4-1 section  
16 for control room ventilation.

17 As was stated, there's an awful lot of  
18 scope in Chapter 9, there's 44 sections in 9, so what  
19 we wanted to do is just a broad overview, a big  
20 picture look at what the similarities and differences  
21 are from previous designs, and some of the design  
22 features that are unique for ESBWR.

23 Chapter 9 provides a description of the  
24 auxiliary and support systems required to support the  
25 operation of ESBWR under normal, transient, shutdown

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 and emergency conditions. The auxiliary systems  
2 include the standard systems, such as service water,  
3 cooling water systems, fire protection, heating and  
4 ventilation and lighting systems.

5 ESBWR auxiliary systems do have safety-  
6 related systems, safety-related functions being  
7 performed, and then RTNSS functions. Examples of  
8 safety-related systems are ultimate heat sink. In the  
9 ESBWR that's performed by the isolation condenser and  
10 passive condenser cooling. Previously plants,  
11 ultimate heat sink was safety related as a body of  
12 water, lakes, rivers, and we are performing the same  
13 function using the passive design with the pools.

14 Standby liquid control, we'll get into  
15 that later, that's a safety-related system for ESBWR.  
16 Control Room HVAC is safety related for habitability  
17 concerns.

18 Functions, safety-related functions that  
19 are being performed, fuel build in HVAC has safety-  
20 related instrumentation and functions for isolation on  
21 the high rad signal. Reactor build in HVAC, the same  
22 function, isolation on a rad signal, and then the  
23 Control Room HVAC system habitability envelope is also  
24 safety related.

25 RTNSS systems, for the first 72 hours we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 take credit for passive systems, so traditional  
2 systems that were safety related in earlier BWR  
3 designs are now RTNSS systems, so these systems are  
4 not required for the first 72 hours to obtain safe  
5 shutdown and perform safety-related functions.

6 Examples of this are fire protection  
7 system, fire protection provides support for cooling,  
8 for refilling the fuel and aux pool cooling, post 72  
9 hours. Diesel generators for ESBWR we'll talk about  
10 that in a little more detail, is also a RTNSS system  
11 post 72 hours, and that's a difference from the  
12 standard plan.

13 Service water, both plant service water  
14 and reactor closed fueling water systems, for previous  
15 plants were safety related, for ESBWR they are also  
16 RTNSS systems.

17 Typical systems, some systems that are  
18 what you are used to in earlier vintages of well and  
19 water reactor plants include service air systems and  
20 TCCW systems.

21 MR. WALLIS: Can I ask? Systems like  
22 service water are part of the ESBWR design or they are  
23 left to some architect-engineer, so they are different  
24 for every plant? Are they standard for a given -- are  
25 all plants the same?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. ARCARO: Well, we'll get -- I have a  
2 specific slide for the service water system.

3 MR. WALLIS: The architect-engineer,  
4 whoever it is, has to change the design of those  
5 things, so they are different for every plant.

6 MR. ARCARO: The standard plant has the  
7 general service water system. The site-specific part  
8 of the service water is the heat removal portion of  
9 it.

10 MR. WALLIS: But, otherwise it's a  
11 standard system?

12 MR. ARCARO: That's correct.

13 MR. WALLIS: It's part of the design.

14 MR. ARCARO: That's correct. Service  
15 water is -- the system is part of the standard design,  
16 and it has site-specific portions of it.

17 MR. WALLIS: The problem with the present  
18 designs in this country, sometimes it's difficult to  
19 find out what the design is of something like the  
20 service water system.

21 MR. ARCARO: Right. Yes, the DCD has a  
22 standard design, and there's site-specific portions of  
23 it that are called out.

24 MEMBER SIEBER: That means that the piping  
25 is part of the standard design?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. ARCARO: That's correct.

2 MEMBER SIEBER: And hangers and supports  
3 and all of that.

4 MR. ARCARO: Right, yes, there is an  
5 interface with the site-specific portions, but all the  
6 piping into the buildings, the heat exchangers, the  
7 design parameters are all standard design.

8 MEMBER SIEBER: Okay.

9 MR. ARCARO: Okay, the Section 9.1 of  
10 Chapter 9 deals with fuel storage and handling, and  
11 John Gels is going to go through and big picture some  
12 of the functions, the similarities and differences  
13 with that system.

14 MR. GELS: Thank you, Mike. Thanks, Art.

15 My name is John Gels. I work in the  
16 Mechanical Systems Group for nuclear island systems.  
17 I'm going to be discussing Section 9.1 as it relates  
18 to fuel storage, fuel handling, and fuel pool cooling.

19 In many ways, the ESBWR fuel storage  
20 handling and cooling systems are very similar to  
21 previous designs. There are some significant  
22 differences, though, so I'll try to limit my  
23 discussion to what's kind of new and unique for ESBWR,  
24 and if you have any questions along the way please  
25 feel free to ask.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           One of the unique differences between  
2       ESBWR and ABWR, our previous design, is that whereas  
3       in ABWR the spent fuel pool was contained in the  
4       reactor building at a higher elevation, it's now in a  
5       separate, adjacent building below grade level, in a  
6       more secure location.

7           One of the consequences of this is that,  
8       in the previous design when fuel was taken from the  
9       reactor it could be transferred directly to the fuel  
10      pool in the reactor building. Now it must be  
11      transferred from the reactor building to the fuel  
12      building at the lower elevation, and so to accomplish  
13      this there's also now an incline fuel transfer system  
14      included in the design that connects these upper pool  
15      volumes with the lower pool volumes in the fuel  
16      building.

17           Both buildings seismic Cat 1 structures,  
18      and I guess I'll start with a discussion of the fuel  
19      building.

20           The spent fuel pool itself is deeper than  
21      fuel pools in previous designs. That is because  
22      cooling, the safety-related cooling for the fuel pool  
23      is now passive. In the event the normal fuel pool  
24      cooling system is lost, cooling is achieved by passive  
25      boiling of the water in the spent fuel pool.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   When new fuel is delivered to the fuel  
2 building, the --

3                   MR. WALLIS:   Passive boiling   is a new  
4 technical term, is it?

5                   MR. GELS:   Well, it's an embellishment on  
6 it.

7                   MEMBER MAYNARD:   Well, how much water do  
8 you start out with above the fuel in the spent fuel  
9 pool?

10                  MR. GELS:   I believe there's slightly over  
11 14 meters of water in the fuel pool.

12                  MEMBER STETKAR:   Is that above the fuel  
13 vents or is that total depth?

14                  MR. GELS:   That's total depth.

15                  MEMBER SIEBER:   Then after you boil for 72  
16 hours how much water above the fuel vent?

17                  MR. GELS:   I believe the exact -- I don't  
18 know the exact number, but it's --

19                  MEMBER SIEBER:   Is it covered?

20                  MR. GELS:   -- approximately -- yes, it's  
21 covered.

22                  MEMBER SIEBER:   Okay.

23                  MR. GELS:   It's a meter and a half or so,  
24 I think.

25                  MR. TUCKER:   This is Larry Tucker.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Since we are talking about levels, how  
2 much water above the top of the fuel if the level is  
3 at the bottom of the transfer gate slots?

4                   MR. GELS: Are we talking about the spent  
5 fuel pool?

6                   MR. TUCKER: Spent fuel pool.

7                   MR. GELS: Okay, well there's a transfer  
8 gate between the spent fuel pool and the lower fuel  
9 transfer pool. I was going to get into that design.

10                  MR. TUCKER: Oh, okay.

11                  MR. TUCKER: If we continue these  
12 questions maybe we should just go to the next slide,  
13 as the --

14                  MR. GELS: Yes, we can do that, that might  
15 be an easier way. It's just a schematic, but it kind  
16 of gives you the general idea.

17                  You can see on the left-hand side of the  
18 drawing we have the reactor building, the vessel, the  
19 reactor cavity above it.

20                  (Whereupon, off-the-record comments.)

21                  MR. GELS: So, the idea here is, we have  
22 the reactor building here on the left side of the  
23 drawing, the vessel, the reactor cavity above it. As  
24 fuel is taken out of the reactor, like in previous  
25 designs, it can be transferred from the reactor cavity

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 to an adjacent pool.

2 We call the adjacent pool the buffer pool.  
3 Here is just, named generically, the auxiliary pools,  
4 but since we are getting into this area I'll just give  
5 a quick description of the buffer pool.

6 Whereas previous designs the spent fuel  
7 pool is at the upper elevation of the reactor  
8 building, we've now transferred it to the fuel  
9 building to facilitate refueling. We now have this  
10 buffer pool adjacent to the reactor cavity. We can  
11 now use this pool to briefly temporarily store spent  
12 fuel and store new fuel, for fuel shuffling, because  
13 you are going to have the incline fuel transfer system  
14 from one of these upper pools connecting it to the  
15 lower pools in the fuel building.

16 So, while we are transferring fuel down,  
17 we can still be taking fuel out of the reactor and  
18 storing it temporarily in this buffer pool.

19 CHAIRMAN CORRADINI: Is the -- from your  
20 current design, is that, essentially, a couple reloads  
21 size?

22 MR. GELS: The buffer pool I believe is  
23 sized to accommodate an entire refueling load of new  
24 fuel, and it's designed to contain up to 154 bundles  
25 of spent fuel.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 CHAIRMAN CORRADINI: Okay, thank you.

2 MR. GELS: The spent fuel is only allowed  
3 to be stored temporarily during an outage, and then it  
4 will be cleared before restart.

5 CHAIRMAN CORRADINI: Thank you.

6 MR. WALLIS: What is the grade level here,  
7 or is this --

8 MR. GELS: This is swelled up grade level.  
9 The spent fuel pool is located at grade level.

10 MR. WALLIS: What is above them?

11 MR. GELS: I'm sorry?

12 MR. WALLIS: Just above the pools  
13 somewhere there?

14 MEMBER MAYNARD: There's quite a bit of  
15 elevation.

16 MR. WALLIS: What's the elevation  
17 difference?

18 MR. TUCKER: This drawing is not to scale.

19 MEMBER SIEBER: Is the whole fuel pool  
20 below grade or just the active part of the fuel pool?

21 MR. GELS: It's, I believe, entirely below  
22 grade.

23 So, this gives you a general idea, even  
24 though it's just a schematic.

25 So, the incline fuel transfer system is an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1       incline tube that two bundles can be delivered into at  
2       a time, and transferred from the upper pools down to  
3       the lower pools, and then placed in the spent fuel  
4       pool.

5               There are interlocks that prevent any kind  
6       of drain down from the upper pools to the lower pools.

7               MEMBER MAYNARD:   Well, are these manual  
8       valves, or is this an automatic system that isolates  
9       that?

10              MR. GELS:   The interlocks that prevent  
11       drainage would be automatic, couldn't override those.

12              MEMBER MAYNARD:   Okay, but are the valves  
13       like motor-operated valves, or are they manual?

14              MR. GELS:   I believe they are motor  
15       operated.

16  
17              MR. ANTHONY:   How much experience does  
18       GE/Hitachi have with incline fuel transfer systems?

19              MR. TUCKER:   Maybe Hugh could speak to  
20       that.

21              MR. UPTON:   This is Hugh Upton with GEH.

22               GE has a significant amount of experience  
23       with incline fuel transfer. The incline fuel transfer  
24       system was first introduced in the BWR-6 product line.  
25       This tube is exactly identical to the BWR-6 product

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 line.

2 It's in operation at Grand Gulf. It's in  
3 operation at Clinton, and we've had a lot of success  
4 with the incline fuel transfer tube.

5 The difference here between the BWR-6 and  
6 the ESBWR incline fuel transfer tube, we do not have  
7 to open containment in order to transfer fuel. This  
8 tube is outside of containment.

9 CHAIRMAN CORRADINI: For those that are  
10 interested, it's on page 9.1-50 of their DCD.

11 Go ahead.

12 MR. GELS: That's just, basically, a view  
13 of the fueling operations. By the end of the  
14 refueling outage, all spent fuel that's stored in the  
15 buffer pool would either have to be transferred to the  
16 spent fuel pool or returned to the reactor.

17 The spent fuel pool is designed to store  
18 up to ten years' worth of spent fuel.

19 MEMBER APOSTOLAKIS: Ten years or 20?

20 MR. GELS: It's designed to store ten  
21 years of spent fuel. The systems are designed to cool  
22 20 years, that's a conservative design.

23 Normal cooling of the spent fuel is  
24 accomplished by the fuel and auxiliary pool cooling  
25 system, which is shown in the schematic here, and it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 also contained in this Figure 9.1-1 in the DCD. That  
2 figure is similar to this one, but it has slightly  
3 more detail.

4 The design of the fuel and auxiliary pool  
5 cooling system is the primary purpose of a fuel and  
6 auxiliary pool cooling system is to cool fuel in the  
7 spent fuel pool. It is a two-train cooling and  
8 cleaning system shown down here, it has two pumps, to  
9 heat exchangers, two filter demineralizer units. It  
10 can accomplish the cooling of the spent fuel pool  
11 during normal operation, using either train to  
12 accommodate a single failure. So, either train is  
13 redundant for cooling during normal operation.

14 In the event that there's a full core  
15 offload to the spent fuel pool, the worst case  
16 scenario, heat load, both cooling trains can be used  
17 to keep the pool below its design temperatures, and we  
18 need not assume a single failure in that event.

19 In addition to cooling the spent fuel  
20 pool, fuel and auxiliary pool's cooling system can  
21 achieve several other functions, although it's a non-  
22 safety-related system, it can provide several back-up  
23 containment cooling functions, including flow paths  
24 for suppression pool cooling, drywall spray, cooling  
25 of the GDCS pools, and low pressure cooling injection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 for the reactor vessel. It can also provide alternate  
2 shutdown cooling to the reactor water clean-up  
3 shutdown cooling system, but none of these functions  
4 are credited during a safety analysis.

5 While one train can be used at all times  
6 to cool the spent fuel pool, the other train can be  
7 placed in standby mode and will be available to  
8 achieve any of those other functions in the  
9 containment, be it suppression pool cooling, GDCS pool  
10 cooling or cleaning.

11 Periodically, we would imagine those pools  
12 would need cooling or clean up, and during that time  
13 it wouldn't be advisable to shut down the fuel pool  
14 cooling system.

15 MR. MILLER: I'm sorry, back to when you  
16 were talking about the cooling, and you say that, you  
17 know, without active cooling you are, basically,  
18 relying on the boil off there, and the core stays  
19 covered.

20 I forget what the requirements are. Is  
21 just keeping the core covered, or I thought there used  
22 to be like a 23-foot water depth you had to keep  
23 above? Maybe I can ask this to the staff.

24 MR. GELS: I believe during normal  
25 operation the system is designed to maintain a safe

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 shielding depth. I think the depth is 3.05 meters or  
2 ten feet.

3 In the event that we are talking about  
4 safety-related boiling, the idea is the pool -- the  
5 fuel building would be evacuated at the time,  
6 personnel wouldn't be allowed in the area, and safe  
7 shielding wouldn't be part of the design concern at  
8 that point.

9 MEMBER MAYNARD: Well, I'll ask the staff  
10 what the requirements are.

11 MR. GELS: During a fueling outage, the  
12 reactor cavity can be drained to the suppression pool.  
13 That's similar to other previous designs. And then,  
14 using the fuel in the auxiliary pool cooling system  
15 the reactor cavity can be then reflooded, using the  
16 flow path that returns water to the containment.

17 Fuel and auxiliary pool cooling system,  
18 while it's a non-safety-related system, it has a  
19 number of functions that have been considered RTNSS as  
20 back-ups to safety-related functions that are credited  
21 in the safety analysis. Although these back-ups to  
22 the safety functions are not credited in the safety  
23 analysis, they can be credited towards PRA analysis,  
24 to address uncertainty in the safety goals. Those  
25 functions include suppression pool cooling and low

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 pressure cooling injection to the reactor vessel.

2 So, while these are still non-safety-  
3 related functions, some credit for them is taken in  
4 the PRA analysis, and that's a topic of RTNSS, it's a  
5 unique design to ESBWR from our previous designs.

6 MR. BARSE: This might be a question to  
7 hold for some time when we are looking at the PRA, but  
8 do you know, when the crediting systems that are not  
9 safety related what treatment and maintenance  
10 requirements apply to that equipment?

11 MR. GELS: To the equipment --

12 MR. BARSE: That's not safety related that  
13 they are crediting in the PRA.

14 MR. GELS: That might be better addressed  
15 by Gary Miller.

16 MR. MILLER: Good morning, I'm Gary Miller  
17 with GEH, and Principal Engineer for PRA.

18 Could you repeat that question?

19 MR. BARSE: Yes, the question is, when you  
20 use non-safety-related equipment in the PRA, two  
21 questions, what are your assumptions about the  
22 maintenance requirements on that equipment, and will  
23 there be actual requirements built into tech specs or  
24 some other way to ensure that that equipment is  
25 maintained as you assume?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   MR. MILLER:    Okay, for the non-safety  
2                   equipment that we determine to be falling into the  
3                   category of RTNSS, that equipment in the PRA we  
4                   assume, you know, normal -- we don't change the  
5                   maintenance unavailability assumptions or anything,  
6                   what we do is, we categorize it as either a high or  
7                   low regulatory significance.

8                   If it's high regulatory significance, we  
9                   put it in as a tech spec. If it's low, we have  
10                  availability controls. That would be part of the  
11                  discussion in Chapter 19.

12                 MR. BARSE: Okay, can you briefly tell us  
13                  what availability controls mean, if it's not a tech  
14                  spec?

15                 MR. MILLER: It's not a tech spec, but if  
16                  you are familiar with the technical requirements  
17                  manuals, plants with current standard tech specs, it's  
18                  a lower level. It recognizes the function, and  
19                  without putting in limiting conditions for operation  
20                  or action statements it causes us to track the  
21                  availability of these functions.

22                 MR. BARSE: Us is GE?

23                 MR. MILLER: Us, I'm sorry, the licensee.  
24                  I've been with GE for a year and a half, I was one of  
25                  them.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 Yes, it requires the licensee to track the  
2 unavailability. And, in addition to that, because  
3 these are fairly significant, they would be covered by  
4 maintenance rule A4 as well.

5 MR. KRESS: How do you determine the high  
6 or low regulatory interest? Is that an importance  
7 factor, or is it an expert panel, or both?

8 MR. MILLER: Well, for RTNSS it's an  
9 importance factor, that's correct.

10 MR. GELS: I wanted to point out the one  
11 thing that's not shown on this schematic is the sub-  
12 system for cooling the ICPCC pools. The FAPCS has a  
13 completely independent sub-system used for cooling the  
14 isolation condenser passive containment cooling pools.  
15 It's an entirely non-safety, it consists of one train  
16 of heat exchanger and water clean-up unit. It's  
17 independent of the other fuel and auxiliary pool  
18 cooling system components, because we want to maintain  
19 a higher quality of water in these upper pools, as  
20 they are credited for boil off during the first 72  
21 hours.

22 I've kind of run through all of the basic  
23 principles behind the fuel pools and FAPCS rather  
24 quickly, and I will turn back to Mike.

25 If you have any questions I'd be happy to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 answer them.

2 CHAIRMAN CORRADINI: No, we'll hold them  
3 for now. We need to move on.

4 MR. GELS: Okay.

5 MR. ARCARO: Section 9.2 of the DCD talks  
6 about the water systems. Briefly, going through some  
7 of the systems, service water we touched on that,  
8 service water for ESBWR is also a RTNSS system, non-  
9 safety-required post 72 hours reactor component  
10 cooling water system similar to previous designs. For  
11 ESBWR, it's also non-safety, it's not required for  
12 component cooling water type loads, ECCS type loads,  
13 and it's not required for recirc pumps as in previous  
14 designs.

15 Some of the RTNSS requirements for these  
16 systems are similar to safety system requirements. We  
17 are required to have redundant trains, physical and  
18 electrical separation. There is seismic requirements  
19 and the requirements for hurricane missiles and flood  
20 protection.

21 Some of the other systems associated with  
22 the ESBWR that are on previous cooling water reactors,  
23 with some differences. Chill water system, chill  
24 water system for previous vintages of plants was  
25 safety related for certain applications, such as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 control room HVAC. For ESBWR, chill water is used for  
2 all the ventilation systems, portions of the chill  
3 water system are RTNSS that are required to support  
4 functions for the nuclear island chill water sub-  
5 section.

6 Condensate storage and transfer, very  
7 similar to what we had in the previous vintages of  
8 boiling water reactor design. Previous plants used  
9 condensate storage and transfer for HPCI and RCCI  
10 water sources, when the suppression pool was not  
11 available. For ESBWR, we don't have the safety system  
12 pumps that previous plants had, so for us condensate  
13 storage and transfer is used as an alternate means for  
14 reactor vessel fill and functions like that.

15 The next slide is a simplified slide of  
16 the service water system. Again, it's very similar to  
17 previous systems. We've got two trains, we've got  
18 redundant components, we've got pumps going to flight  
19 heat exchangers, both for reactor cooling loads and  
20 turbine building loads. The heat sink, which is the  
21 part of the design that would be site specific, is a  
22 requirement for, you know, heat removal capacity.

23 On the standard design, we have a cooling  
24 tower, as part of the standard design, as a heat sink  
25 for service water.

1           Okay, Section 9.3 is talking about the  
2 process auxiliaries, and here is the compressed gas  
3 systems, which includes instrument air, service air,  
4 containment inerting, high-pressure nitrogen.

5           Similarities, service air, we talked about  
6 that before, service air is doing the same functions  
7 that it was doing for previous vintages of boiling  
8 water reactors. Instrument air system for previous  
9 plants was safety related, had safety functions, for  
10 ESBWR the instrument air is non-safety and non-RTNSS.  
11 The instrument air fail position of components and the  
12 results of the PRA analysis showed that instrument air  
13 could be non-safety. The safety functions required  
14 for instrument air loads and nitrogen loads are  
15 performed by accumulators, with the accumulator and  
16 the isolation valve being part of the system that it  
17 is serving.

18           MEMBER STETKAR: Let ask you this quickly,  
19 because we don't have much time.

20           Isolation valves on the isolation  
21 condenser, steam supply and condensate containment  
22 isolation valves, what direction do they fail, on loss  
23 of pneumatic, no nitrogen, no accumulator pressure, do  
24 they go closed or do they go open?

25           MR. GELS: The isolation condenser system

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 isolation valves fail in the current position, they  
2 fail as is.

3 MEMBER STETKAR: So, the containment  
4 isolation valves for the isolation condenser, the  
5 steam supply and the condensate return, the series  
6 valves fail open?

7 MR. GELS: Well --

8 MEMBER STETKAR: They fail open, because  
9 they are normally open.

10 MR. GELS: -- yes, they are normally open,  
11 and if they would fail they would fail in the open  
12 state.

13 MEMBER ABDEL-KHALIK: Isn't there one  
14 valve that's normally closed?

15 MEMBER STETKAR: No, the containment  
16 isolation valves, the series valves on the steam  
17 supply, the condensate, return line.

18 MR. GELS: Correct.

19 MEMBER STETKAR: They fail as is.

20 MR. GELS: They fail as is.

21 All right, the other -- some of the other  
22 systems, process sampling, equipment and floor drain,  
23 for previous plants these systems were also safety  
24 related. For ESBWR, these are non-safety systems.

25 Standby liquid control, similar system as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 on previous plants. For ESBWR, some differences.  
2 Again, it functions to give you a reverse scram. With  
3 ESBWR, you don't have the recirc pumps, so the  
4 function is, you know, is required.

5 Some of the differences, the kind of  
6 borate that we are using, the solution that we are  
7 using is such that you don't have to worry about it  
8 falling out of solution at a low temperature, so the  
9 requirements for heat tracing of the piping and the  
10 tank aren't there for this design. We still maintain  
11 the room temperature above 60 degrees, but the borate  
12 solution is such that it's not as susceptible to low  
13 temperature.

14 The design of the system is passive, and  
15 that consists of nitrogen accumulators and squib  
16 valves, rather than positive displacement pumps like  
17 previous systems.

18 The injection of the borate solution into  
19 the vessel is enhanced to provide more mixing and  
20 distribution than earlier designs.

21 MR. WALLIS: How do you do that? Do you  
22 have a sparger or something, or what do you do?

23 CHAIRMAN CORRADINI: You have to go to a  
24 mic and identify yourself, please.

25 MR. MARTINO: Yes, can you repeat the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 question?

2 MR. WALLIS: How do you get this borate  
3 solution to mix with it, do you have a sparger or  
4 something?

5 MR. MARTINO: Yes, we do. My name is  
6 Wayne Martino at GEH. We have a sparger inside the  
7 core bypass region, it injects in the space between  
8 the outer-most channels and the core shroud.

9 We'll go into some more details of that in  
10 the ATWS material in Chapter 15.

11 MR. WALLIS: You do analyze the mixing  
12 process?

13 MR. MARTINO: Yes.

14 MEMBER MAYNARD: It's my understanding  
15 that both the staff at GE are still doing work on the  
16 mixing, we get a chance to address that I think in one  
17 of the later chapters.

18 CHAIRMAN CORRADINI: I think Chapter 15 is  
19 where we are going to see that, is that correct, Amy?

20 MS. CUBBAGE: Chapter 15 and 21.

21 MEMBER MAYNARD: Well, I asked  
22 specifically about that, and they said this probably  
23 wouldn't be the best place to do that.

24 CHAIRMAN CORRADINI: Thank you.

25 MR. ARCARO: All right, hydro-water

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 chemistry.

2 MEMBER MAYNARD: Back on the standby  
3 electric control system, it's all passive, but valves  
4 have to close to keep from injecting nitrogen into the  
5 vessel there, I mean, when the level gets so low, so  
6 isn't there an active component of shutting that off?

7 MR. GELS: Yes, but I don't believe that  
8 that's considered a safety function of the system.  
9 The safety function of the system is to inject the  
10 sodium penta borate.

11 MEMBER MAYNARD: Okay, so if it fails to  
12 shut off, and nitrogen gets injected in there, that's  
13 not a safety?

14 MR. GELS: It's very much a concern, but  
15 after the reactivity control, providing reactivity  
16 control is -- that's the purpose of the valve, it's  
17 outside the scope of that valve.

18 MEMBER MAYNARD: So, the shut off is not  
19 safety related then.

20 MR. GELS: Well, the entire system is  
21 considered safety related, but for the purpose of  
22 reactivity control that valve function is not safety  
23 related for controlling -- for scrambling the reactor.

24 MEMBER MAYNARD: Okay. But, I would think  
25 that's an active component, if it has to close.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MR. GELS: Yes, it is.

2 MEMBER MAYNARD: You are saying for 72  
3 hours, you are really not relying on any active  
4 components.

5 MR. TUCKER: This is Larry Tucker with  
6 GEH.

7 The safety function for the standby liquid  
8 control was to bring the reactor sub-critical as a  
9 back-up method.

10 By using the nitrogen accumulator to  
11 ensure that we get the sodium penta borate in the  
12 right place, we accomplish that safety function.

13 If the nitrogen does go in to the reactor,  
14 it's not a safety concern, but it is an operational  
15 trouble that has to be addressed.

16 MR. WALLIS: And, it can affect the long-  
17 term cooling, can't it?

18 MR. TUCKER: I do not believe so, because  
19 of the location of the suction for the long-term  
20 cooling.

21 CHAIRMAN CORRADINI: Is there someone that  
22 wants to make a comment back there?

23 MR. MARTINO: Yes, this is Wayne Martino.  
24 The nitrogen isolation function is redundant, and it's  
25 been designed that way to make sure that we terminate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the nitrogen injection in a LOCA scenario, where it  
2 could put a non-condensable gas in the containment.

3 So, we've considered that as part of the  
4 function of the standby liquid control system.

5 CHAIRMAN CORRADINI: So, just to clarify,  
6 I want to make sure I understand, Otto was trying to  
7 get relative to is it an active system, and that's  
8 where we started with this?

9 MEMBER MAYNARD: Yes.

10 CHAIRMAN CORRADINI: So, are you clear?

11 MEMBER MAYNARD: Well, I'm clear that it's  
12 active, I think it's an active system.

13 MR. TUCKER: But, it's non-credited, we  
14 don't take credit for it.

15 MEMBER STETKAR: In Chapter 15, in Chapter  
16 15 for long-term cooling post -- post ATWS, long-term  
17 cooling, not LOCA, shut the reactor down with standby  
18 liquid control, nitrogen keeps going in, you have the  
19 isolation condensers now cooling, which require steam  
20 and water and not nitrogen, not a LOCA. So,  
21 throughout the nitrogen is not an active safety  
22 function under those conditions?

23 MR. TUCKER: That's correct.

24 CHAIRMAN CORRADINI: So, you can postpone  
25 us, but where we are going with this is, if you inject

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 nitrogen unknowingly, how does that affect your  
2 isolation condenser performance? So, if you are going  
3 to tell us to wait til Chapter 15, we'll wait.

4 MR. TUCKER: Okay.

5 CHAIRMAN CORRADINI: But, we'll be there.

6 MR. TUCKER: That's where the group is  
7 going, Chapter 15, and also I believe there are RAIs,  
8 you know, in Chapter 21 on this subject, and there's  
9 conversations between GEH and the staff on that at  
10 this time.

11 CHAIRMAN CORRADINI: Okay, good.

12 MR. TUCKER: And, we are well aware of the  
13 requirement to make sure that the isolation condensers  
14 do not become gas bound with nitrogen.

15 MR. ARCARO: All right, the other process  
16 system in Chapter 9.3 is hydro-water chemistry, and  
17 ESBWR provides taps for that system.

18 MR. ARMIJO: I've got a problem with that.  
19 You know, I think the hydrogen water chemistry is  
20 important, whether you want to call it important to  
21 safety or not that's a debate, but that's a standard  
22 way to run a BWR to prevent IASCC in tracking of  
23 internals.

24 I'm just wondering why GEH has chosen not  
25 to make that part of the standard certified design,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and you might add that same thing for zinc injection,  
2 which is proven to control doses effectively.

3 And, you have made the oxygen injection  
4 system standard.

5 MR. ARCARO: Just those portions that are  
6 required outside of hydro-water chemistry.

7 MR. ARMIJO: Yes, the oxygen, which is  
8 just an operational benefit, there's no question about  
9 that, but hydrogen is probably much more important in  
10 the BWR than the oxygen addition.

11 And so, my question is, is why is that  
12 left as an option when you know that's what you need  
13 to keep the BWR materials protected?

14 MR. ARCARO: Well, you are correct, in  
15 ESBWR the hydro-water chemistry is an optional system.  
16 Existing plants, lots of existing plants, have either  
17 not implemented hydro-water chemistry, or implemented  
18 hydro-water chemistry late in life.

19 ESBWR, the design is such that the  
20 gradating factors that reduce the susceptibility to  
21 intergranular stress corrosion, there's history with,  
22 you know, the previous generation ABWR plants  
23 operating for over ten years without hydro-water  
24 chemistry, without indications of stress corrosion  
25 cracking. So, there's history there. We leave it to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the customer to decide, you know, the benefits of  
2 hydro-water chemistry versus the dose concerns.

3 You know, the risk of not implementing  
4 hydro-water chemistry at start up is minimal.

5 MR. ARMIJO: so, GEH's position is  
6 hydrogen-water chemistry is not really required for  
7 operating the ESBWR. It will be okay --

8 CHAIRMAN CORRADINI: Somebody over there  
9 is going to try to help.

10 MR. UPTON: This is Hugh Upton with GEH.

11 GE recommends the application of hydrogen  
12 water chemistry in start up. We recommend it. Okay.  
13 It's the best way to avoid cracking from occurring.

14 However, there are also other  
15 considerations. We leave it as an option, because of  
16 the concern we've seen in the past with additional  
17 shielding requirements, because of the additional M16  
18 from hydrogen-water chemistry. Also, it's an  
19 additional dose.

20 The plant itself has been designed from a  
21 shielding standpoint to handle the hydrogen-water  
22 chemistry, and the additional doses from it with  
23 shielding in the main steam tunnel, and also in the  
24 turbine building. But, we leave it as an option,  
25 because it's an economic consideration.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. ARMIJO: I don't take much comfort in  
2 that, but it will come up at the combined license, it  
3 will be a COL issue, is that the way you --

4 MR. UPTON: Well, Sam, maybe also, I mean,  
5 if you take a look at the -- again, this is Hugh Upton  
6 with GEH -- the incubation period on any of the  
7 corrosion cracking is a long time. We also are doing,  
8 you know, in-service inspections of the welds. If  
9 there's any indication at that time, during operation  
10 of a plant, that there is IGSCC going on, the utility  
11 can opt to back fit hydrogen-water chemistry.

12 We have allocated the taps, we've  
13 allocated the space. It's just a matter of a utility  
14 making that decision.

15 MR. ARMIJO: Yes, but the philosophy is,  
16 wait for something to crack and then put in the system  
17 that protects you from cracking. It's bazaar. I  
18 mean, you have an opportunity here with a brand new  
19 plant to start it up with the right water chemistry  
20 that mitigates against the nucleation of stress  
21 corrosion cracks, and it's hard to understand why GE,  
22 GEH I mean, doesn't simply say that's standard for a  
23 modern boiling water reactor, and we don't want to go  
24 through this series of materials failures that we have  
25 in the conventional, in the early BWRs.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   So, I'll leave that as that, but it seems  
2                   to me like that's the modern way to operate a BWR, you  
3                   provided the shielding. If you hadn't provided the  
4                   shielding it would really be a mess, but you provided  
5                   all the shielding, so I just don't understand why that  
6                   isn't just fundamentally the way the water chemistry  
7                   for a modern BWR.

8                   CHAIRMAN CORRADINI: Is there a comment?

9                   MR. UPTON: Yes, just one comment.

10                  Sam, also we have done a significant  
11                  amount of change in material on the ESBWR, that would  
12                  -- which is designed to mitigate IGSCC.

13                  MR. ARMIJO: Yes, but I think the Japanese  
14                  experience has proven that the old carbon 316 nuclear  
15                  grade will crack. Now, they did it without hydrogen,  
16                  and they ran BWRs without hydrogen, they cracked a lot  
17                  of components, and with the modern material. So, you  
18                  can't rely on the material alone, and defense in depth  
19                  thinking says you want water chemistry to protect you,  
20                  as well as improved materials and improved  
21                  fabrication.

22                  So, I think this is an area where I'm  
23                  certainly uncomfortable.

24                  MEMBER STETKAR: Sir, can you identify  
25                  yourself? The court reporter needs it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. UPTON: This is Hugh Upton with GEH.

2 MR. ARCARO: All right, moving on to  
3 Section 9.4 of the DCD, this is the heating  
4 ventilation and air conditioning systems.

5 A lot of similarities with the previous  
6 plants, control building HVAC, meets the same Reg  
7 guides and requirements as previous plants. We'll  
8 talk a little bit more about the habitability portion  
9 of the system in the 6.4 discussion. But, the  
10 enhancements in ESBWR are the control building, the  
11 habitability portion, and the electrical DCIS rooms  
12 are actually underground and use -- take credit for  
13 the passive cooling of the heat removal of the  
14 structure itself.

15 MR. WALLIS: Is there any way to monitor  
16 the leakage continuously, because, you know, they get  
17 tested, but then things get misplaced and they leak.  
18 Do you have any way to monitor the leakage of that?

19 MR. ARCARO: Well, we do. There is  
20 surveillance requirements. Upon start-up, we are  
21 going to, you know, there's an ITAAC, we are doing in-  
22 leakage. There's outage surveillance requirements for  
23 the tracer gas testing and leakage testing, and the DP  
24 testing for the control room.

25 MR. WALLIS: So, this goes on and on, on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)



1 some schedule. You don't just test it and leave it.

2 MR. ARCARO: We do it during the refueling  
3 outage, in accordance with the reg guide 197.

4 MEMBER MAYNARD: You say these are fairly  
5 common, yet I think this is the only one that, from a  
6 safety-related standpoint we are counting on heating  
7 ventilation with no AC power.

8 MR. ARCARO: That's correct.

9 MEMBER MAYNARD: Okay, so I think we  
10 really need to focus on that, as to with no AC power  
11 how are we cooling and how are we making sure that  
12 things that need to be maintained within a certain  
13 temperature are?

14 CHAIRMAN CORRADINI: Are you going to  
15 cover that now or under 6.4?

16 MR. ARCARO: I have it in 6.4.

17 CHAIRMAN CORRADINI: Okay, we can hold  
18 that question for a couple of slides.

19 MEMBER ABDEL-KHALIK: What's the design  
20 basis for the reactor building, HVAC?

21 MR. ARCARO: The design basis is to  
22 maintain the temperatures. It has temperature  
23 requirements for the safety-related components, and it  
24 maintains the requirements for dose and leakage  
25 concerns.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER ABDEL-KHALIK: So, what's the  
2 capacity of the reactor building HVAC system?

3 MR. ARCARO: Mike?

4 MR. SILVA: Good morning. I'm Mike Silva  
5 with the Ops Systems Group, HVAC.

6 The capacity in terms of air flow?

7 MEMBER ABDEL-KHALIK: In terms of heat  
8 removal capabilities.

9 MR. SILVA: The heat removal, during  
10 normal operation, the heat removal capability, I'm not  
11 totally sure, but let's just put it this way, the  
12 system is about 50 to 60,000 cfm air flow once through  
13 a ventilation system for two of the separate systems,  
14 and then there's a third system of clean air, and  
15 which maybe sends 30 or 40,000 cfm air flow, with  
16 cooling.

17 MEMBER ABDEL-KHALIK: I guess I've have to  
18 translate that somehow, but please continue.

19 MEMBER MAYNARD: Okay, but again, that  
20 would be with fans and stuff, right?

21 MR. SILVA: Right.

22 MEMBER MAYNARD: And, my primary interest  
23 is in design basis type accidents and stuff, how are  
24 we maintaining the temperature.

25 CHAIRMAN CORRADINI: We are going to need

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to catch that, but I think we are going to have to  
2 move on or we are going to run out of time.

3 MEMBER MAYNARD: Okay.

4 MR. ARCARO: All right, control building,  
5 we'll touch on that in 6.4.

6 MR. UPTON: Just one comment before we  
7 leave the reactor building HVAC.

8 The reactor building HVAC, again, this is  
9 Hugh Upton with GEH, sorry -- the reactor building  
10 HVAC flow rate and capacity has been designed to  
11 maintain the heat loads, the temperatures within the  
12 reactor building within normal bounds, including all  
13 of the heat loads from the equipment that's  
14 anticipated in there, in each one of the rooms.

15 So, even though it's 30 scfm, there is a  
16 temperature band to maintain that's part of the system  
17 requirements. We can get you that temperature band.

18 CHAIRMAN CORRADINI: Yes, okay.

19 MR. ARCARO: Let's see, the fuel building  
20 HVAC system, that's a separate building, a separate  
21 ventilation system, that's a RTNSS function, and it  
22 provides cooling and ventilation for the fuel  
23 building.

24 Radwaste HVAC, similar to previous boiler  
25 water designs. It has separate systems for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 control room and the general area.

2 Turbine building ventilation, similar to  
3 previous designs, is a once-through system, has  
4 different subsystems for different areas.

5 The reactor building HVAC, touched on  
6 that. Again, it's got separate subsystems for the  
7 contaminated area refuel pool and the clean area.

8 Electric building HVAC, this is different  
9 from previous designs, in that the electric building  
10 HVAC system was safety related on early vintages with  
11 BWRs, here it does have RTNSS functions, and it  
12 maintains habitability for the tech support center,  
13 and maintains the cooling for the diesel and the 1E  
14 electric and electronic loads.

15 Drywell cooling, similar to previous  
16 designs. In ESBWR we used chill water for the drywell  
17 cooling system rather than the reactor closed cooling  
18 water that was used for previous designs.

19 CHAIRMAN CORRADINI: If you have something  
20 you may want to skip, please feel free, because we are  
21 going to have to get to control room habitability, and  
22 I think people will want to know about fire  
23 protection.

24 MR. ARCARO: Okay, this slide here is just  
25 a general schematic on operational for a recirc

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 system. This is the general area for the control  
2 building. Outside air comes in through a damper. We  
3 have redundancy and back-up components. It's broken  
4 into different sections for the air flow, and recircs  
5 back on itself.

6 The other auxiliary systems in Chapter 9,  
7 communications, lighting, the diesel generators, and  
8 their support systems are part of 9.5, and fire  
9 protection.

10 Fire protection, standard fire protection  
11 functions for detection, notification, annunciation,  
12 suppression of fires.

13 Fire protection is also -- has two  
14 appendixes in Chapter 9. This is where we do the fire  
15 hazard analysis, and the summary of the design  
16 requirements.

17 The design features for Chapter 9, we've  
18 talked through most of these, service water, reactor  
19 component cooling water, chill water, high pressure  
20 nitrogen. We talked about the RTNSS functions for  
21 those.

22 Some of the significant design feature  
23 differences, we talked through the diesel auxiliaries  
24 not being safety related, being a RTNSS function. One  
25 of the recent changes we made is elimination of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 hot water system, hot water heating system. Now we  
2 are doing that function using electrical heaters  
3 rather than the hot water system.

4 One of the design features of ESBWR is,  
5 without AC power during the first 72 hours we take  
6 credit for passive heat removal. There's no active  
7 heating and air conditioning if you lose power, so the  
8 structures and systems are designed such that passive  
9 heat removal will maintain the equipment within the EQ  
10 envelope, the requirements for the equipment in the  
11 different buildings.

12 That gets us to the Section 6.4 for  
13 control room habitability. Section 6.4 provides a  
14 description for systems that make up the habitability  
15 envelope. They have included the area, habitability  
16 area HVAC system, radiation monitoring, lighting and  
17 fire protection system.

18 Some of the design features incorporated  
19 in the ESBWR design is, it takes credit for passive  
20 heat removal and maintaining the life support  
21 functions for the 72 hours without the power.

22 Control room habitability is required for  
23 dose and occupancy requirements for GDC-19. For the  
24 first 72 hours, the heat loads are removed passively,  
25 so once the non-safety heat loads are gone, which is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 assumed in the analysis to be within the first two  
2 hours, the heat loads that are remaining are removed  
3 through passive means to the structure, to the walls,  
4 to the ceiling of the building, and that's  
5 accomplished by the thermal mass of the structure, the  
6 fact that the control room habitability envelope is  
7 underground, and we are taking credit for the heat  
8 removal to the ground.

9           Habitability is maintained for the first  
10 72 hours via the emergency filtration unit, and if you  
11 go a couple slides down there's a schematic of that.  
12 Emergency filtration unit is run off of safety-related  
13 batteries. It provides the required flow rate and  
14 maintains a positive pressure in the control room for  
15 maintaining the life support and habitability for the  
16 control room operators.

17           CHAIRMAN CORRADINI: So, that's one of the  
18 loads on the batteries during the 72 hours.

19           MR. ARCARO: That's correct. The loads  
20 assumed are the safety-related loads, lighting, and  
21 then the people loads in the space.

22           MEMBER STETKAR: On the emergency  
23 submittal, the normal control room ventilation exhaust  
24 is isolated, correct?

25           MR. ARCARO: That's correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   MEMBER STETKAR: You say that the control,  
2                   the EFUs can supply up to 424 cubic feet per minute,  
3                   which is designed for 21 people, how does the air get  
4                   out? If I try to pump up a balloon, and it's a solid  
5                   balloon, I can try to put 424 cubic feet per minute in  
6                   there, but it's not going in. So, my people who are  
7                   now breathing the air are not exhausting any air, so  
8                   how do you ensure that you actually do get 424 cubic  
9                   feet per minute of new air flow in with the sufficient  
10                  exhaust going out, for 72 hours, if it's solid,  
11                  sealed, as it's designed to be?

12                 MR. MARTINO: This is Wayne Martino of  
13                 GEH.

14                 We are designing the exit for the room, we  
15                 haven't finalized the mechanism, maybe a relief  
16                 valve/check valve device to assure that we have a  
17                 controlled exit flow out of the room to provide the  
18                 flow that the fan can supply.

19                 CHAIRMAN CORRADINI: So, it's a separate  
20                 -- just so I understand -- so, it's a separate system  
21                 to filter it, and another system to, essentially, add  
22                 --

23                 MEMBER STETKAR: They need exhaust.

24                 CHAIRMAN CORRADINI: -- I understand that,  
25                 and then a separate system, essentially, to keep fresh

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 air -- the resurgence of the filtered air back in at  
2 this rate, and venting exhaust.

3 MEMBER STETKAR: It will all be part of  
4 the same system.

5 MR. ARCARO: The filter unit provides some  
6 pressurization and also the air flow, and then the  
7 exhaust mechanism will be a point, a control point,  
8 where we exhaust the flow to make sure we maintain  
9 circulation and have the air flow required.

10 MEMBER STETKAR: But, that's not designed  
11 yet.

12 MR. ARCARO: That's correct.

13 MR. BARSE: Is there an RAI on that issue?  
14 I don't remember,.

15 MR. ARCARO: No.

16 MEMBER STETKAR: There's an RAI on mixing  
17 in the recirc language, which is kind of semi  
18 relevant, but not on throughput.

19 MR. ARCARO: There's several RAIs that  
20 talk about stagnation of the gases, or how do you  
21 maintain flow.

22 MEMBER STETKAR: It's partially related.

23 MR. ARMIJO: What's the peak temperature  
24 at the end of that 72 hours? What's the maximum  
25 temperature that is allowed?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. ARCARO: For the control room  
2 habitability area, 93 degrees is the maximum  
3 temperature.

4 CHAIRMAN CORRADINI: Allowed or estimated  
5 to occur?

6 MR. ARMIJO: 93 degrees is too late, I  
7 just want to know what the maximum temperature is.

8 MR. MARTINO: Wayne Martino, 93 degrees is  
9 the acceptance criteria, starting from the maximum  
10 initial temperature from 78 degrees we get 93 degree  
11 heat up. That's every URD requirement that we are  
12 implementing, it protects the operator and the  
13 equipment in the room.

14 MEMBER ABDEL-KHALIK: What is the total  
15 heat load that you have to remove under these  
16 conditions?

17 MR. ARCARO: During -- for the 72 hours  
18 passive cooling, it's around 7,000, 7,000 watts. All  
19 you have is, you've got the low power lights, you've  
20 got minimal instrumentation. You've got the  
21 fractional horsepower fans for the EFU units, and  
22 you've got the people heat loads.

23 You know, it's a small fraction of the  
24 loads that are there with the non-safety equipment  
25 running.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER ABDEL-KHALIK: And, you said you  
2 relied to some extent on energy storage in the  
3 structures, and you also relied on heat transfer to  
4 the ground, during that time period?

5 MR. ARCARO: Correct.

6 MEMBER ABDEL-KHALIK: Now, what are the  
7 conditions of the soil that you assume in this heat  
8 transfer process?

9 MR. MARTINO: Let me clarify, we don't  
10 credit heat transfer to the soil, only to the building  
11 structure.

12 MEMBER ABDEL-KHALIK: So, you are only  
13 relying on heat storage in the structure, it takes  
14 that long?

15 MR. MARTINO: Yes, this is Wayne Martino.

16 MEMBER ABDEL-KHALIK: Okay.

17 MEMBER MAYNARD: On the control room  
18 habitability subject, we talked about heat loads, how  
19 does it work in the winter time?

20 MR. ARCARO: Well, we did a run for low  
21 temperature, and designed outside ambient temperature  
22 as -40 degrees, and I believe the results get it up to  
23 50 some degrees. So, it's still -- you know, it's  
24 still chilly.

25 MEMBER STETKAR: Are the control room

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 HVAC, the recirc air handling units, are they normally  
2 cooled by nuclear island chill water, or are they  
3 always cooled by just the control room chill water?

4 MR. ARCARO: The control room HVAC comes  
5 off of the nuclear island chill water loop normally.

6 MEMBER STETKAR: And then, it switches  
7 over to the internal chill water, what I call the  
8 internal chilled water.

9 MR. ARCARO: Well, there is no internal  
10 chill water, that's part of the nuclear island loop.

11 MEMBER STETKAR: Okay, perhaps, I'm being  
12 not very specific. There's a tank with two pumps that  
13 circulate water through the air handling units under  
14 emergency conditions, according to my drawing. That's  
15 what I'm calling the internal --

16 MR. ARCARO: Okay.

17 MEMBER STETKAR: -- not shown on that.

18 MR. ARCARO: Right.

19 MEMBER STETKAR: It's those two little  
20 lines going up the side. But, those air handling  
21 units are normally cooled by nuclear island chilled  
22 water, is that correct?

23 MR. UPTON: This is Hugh Upton with GEH.

24 The tank that you are referring to is used  
25 to cool the air handling units during an emergency,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and it's a gravity-drained tank.

2 MEMBER STETKAR: I understand that.

3 MR. UPTON: Okay.

4 MEMBER STETKAR: What normally cools those  
5 air handling units, during normal plant operation?

6 MR. UPTON: Well, it's part of the chill  
7 water system.

8 MEMBER STETKAR: Nuclear island chilled  
9 water?

10 MR. UPTON: Yes.

11 MEMBER STETKAR: Thank you.

12 MEMBER SIEBER: You do have an auxiliary  
13 boiler, that is not shown here.

14 MR. ARCARO: Yes, we do, and it is in  
15 Chapter 9.

16 All right, in summary, Chapter 9 and  
17 Section 6.4 provide a description for the auxiliary  
18 systems and control room habitability systems, and  
19 currently GEH is working with the NRC staff to address  
20 the remaining open items.

21 MR. BARSE: Could I slip one question in on  
22 what you talked about a long time ago, on the service  
23 air and the instrument air systems, because as I look  
24 through your documents I didn't see anything, and I  
25 know it's called non-safety related, but you have an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 interface between nitrogen systems and instrument air.  
2 I didn't see anything on the specifications for  
3 operation to preclude moisture and contaminants into  
4 the -- permeating the service air system, getting into  
5 instrument air. I did see you've got a dryer. But,  
6 if you have a failure there, does it get bypassed?  
7 What happens?

8 Are there any requirements on that yet, or  
9 is that not really in the design?

10 MR. ARCARO: I believe that in the DCD  
11 there is requirements for air quality on the  
12 instrument air, the system.

13 MR. BARSE: I'd like to see those, I didn't  
14 find them myself.

15 MEMBER MAYNARD: I saw that you stated  
16 that, you didn't have them for the service air system,  
17 didn't state anything about that, and they can't be  
18 interconnected in an emergency, as I understand it.

19 MR. BARSE: It's the same thing now, they  
20 changed the design.

21 MR. ARCARO: I think both in the body of  
22 the DCD, and there's a table which has parameters on  
23 that, the micron size requirements for instrument air,  
24 and the ISI, ISA requirement for cleanliness.

25 MR. BARSE: Okay, I'll have to look again,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 or if you could point those out later I'd appreciate  
2 it.

3 MEMBER ABDEL-KHALIK: Have you actually  
4 done the thermal response calculation for the control  
5 room, 400 cfm, 7 kilowatt of heat load?

6 MR. ARCARO: Yes.

7 MEMBER ABDEL-KHALIK: And, you have shown  
8 that you get adequate heat transfer through the walls,  
9 so that the temperature never goes above 92 degrees or  
10 93 degrees?

11 MR. ARCARO: Yes, that's correct.

12 MEMBER STETKAR: Since Said asked, have  
13 you done the calculations for the interior  
14 temperatures in the cabinets, not just the bulk room  
15 temperature, because the cabinets will have power  
16 supplies in them, and they, Experience -- Operating  
17 Plant shows that the interior temperatures inside the  
18 cabinets can be substantially higher than the bulk  
19 room temperatures.

20 MR. ARCARO: And, there is an RAI for  
21 that.

22 MEMBER STETKAR: Okay.

23 MR. MARTINO: This is Wayne Martino, GEH.  
24 That's right, but the equipment has not been procured  
25 yet, so we don't have -- that's part of the DAC

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 process for equipment qualification. So, the interior  
2 cabinet temperatures have not been calculated or  
3 determined yet.

4 MR. ARMIJO: Okay, so you're limiting  
5 temperature would be 93 degrees inside a cabinet?

6 MEMBER STETKAR: It's typically about 120  
7 degrees inside the cabinet.

8 MR. ARMIJO: Okay, so you've got some  
9 limiting degree room.

10 MEMBER STETKAR: It depends on the  
11 qualification temperature for the --

12 CHAIRMAN CORRADINI: Just to make sure I  
13 understand your answer, so you are saying that you  
14 have a design spec that you are looking towards to  
15 make sure that the equipment can maintain? I missed  
16 that part.

17 MR. ARCARO: Wayne?

18 MR. MARTINO: Yes.

19 MR. UPTON: This is Hugh Upton with GEH.

20 Yes, part of the design specification for  
21 the procurement of our electronics, the DCIS has  
22 temperature limits. The environmental qualification  
23 we'll have to undergo.

24 Also, I wanted to add that part of the  
25 detail design of both the control room HVAC system and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 the reactor building HVAC system will be to complete  
2 a detailed gothic analysis room by room of the  
3 temperature heat up and how the rooms perform under  
4 passive cooling.

5 So, that has not been done yet, but we  
6 plan on doing that.

7 CHAIRMAN CORRADINI: And then, just to  
8 clarify Said's question, so in the 7 kilowatt load,  
9 with the 400 and something cfm input and exhaust, in  
10 the current analysis you did include the losses to the  
11 room walls, that was there.

12 MR. ARCARO: Yes.

13 CHAIRMAN CORRADINI: Okay.

14 MR. BARSE: One last follow-up, I did find  
15 the tables you talked about on the instrument air.  
16 The sketches are real sketches, they aren't real  
17 detailed drawings. Will there be bypasses around the  
18 dryers and the filters? And, if so, what are the  
19 operational requirements?

20 MR. ARCARO: I guess the instrument air  
21 service air in Rev 4 has been revised.

22 MR. BARSE: I think we have that.

23 MR. ARCARO: You have Rev 4? Okay, so now  
24 we have three service air compressors that are feeding  
25 the entire system, and we have dryers that separate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the instrument air from the service air, and those  
2 dryers maintain the air quality downstream for the  
3 instrument air loads.

4 MR. BARSE: The drawings don't show it, but  
5 I was asking, will there be bypass valves around the  
6 filters and the dryers? And, if so, will there be  
7 operational requirements on how people use them?

8 MR. ARCARO: To maintain -- I'm not sure  
9 what the answer to that is. Later I'll be able to  
10 answer that.

11 CHAIRMAN CORRADINI: Okay, thank you very  
12 much. I appreciate it. We are a little bit late.

13 I'll turn it over to the staff.

14 Amy, are you leading the charge?

15 All right, we have our next group.

16 MS. CUBBAGE: The group is here, and I  
17 definitely would like to thank you for your advanced  
18 comments, it really helped us frame the presentation.  
19 So, we are going to do our best to focus on the areas  
20 of interest, we'll touch on some other areas. We have  
21 a very large team with us today, hopefully, we can  
22 answer any questions you have in the areas of your  
23 interest, and any other areas that come up.

24 So, I'd like to introduce the first set of  
25 people here. I don't know if we were able to get

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 everybody at the table. We will swap out when we need  
2 to. So, we have Jorge Hernandez from -- Group, and  
3 Yamir Diaz-Castillo from our Component Integrity  
4 Branch, who specializes in the chemistry area. Ben  
5 Parks, and robert Radlinski, our Fire Protection Team  
6 Leader, and I'm Amy Cubbage, Lead Project Manager for  
7 the ESBWR design certification.

8 We provided the committee with the safety  
9 evaluations for Chapter 9 and 6.4 to support this  
10 meeting. We will be coming back in January or later  
11 in the year with the rest of Chapter 6 at that time.

12 Okay, so we are going to brief you on that  
13 evaluation, which was based on DCD Revision 3. As you  
14 know, we have DCD Revision 4 and the safety  
15 evaluations have not addressed that.

16 MR. WALLIS: Is the second item worthy of  
17 a bullet?

18 MS. CUBBAGE: We always are happy to  
19 answer your questions.

20 So, in addition to the folks sitting here  
21 with me, we have a number of reviewers here in the  
22 room. I won't run through all the names.

23 Ed Forrest will be joining us up at the  
24 table when the presentation time comes, and I think  
25 everybody else is already up here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   Okay, so outline of the presentation,  
2                   briefly going to show you the applicable regulations,  
3                   the status of the RAIs for Chapter 9 and 6.4. We'll  
4                   go through the SCR topics of interest, focusing on the  
5                   committee's areas of interest. We'll discuss some of  
6                   the open items that were more significant. There are  
7                   a number of open items, we aren't going to get into  
8                   every single one of them here today. We'll touch on  
9                   some of the action items in the DCD, and again, answer  
10                  questions.

11                 So, here's the listing of all the  
12                 regulations, guidance, documents and codes and  
13                 standards that we looked at for this chapter's review.

14                 We asked a total of 216 RAIs so far in  
15                 Chapter 9, 150 of those have been resolved. We have  
16                 66 open items.

17                 For 6.4, we asked 14 RAIs, and those are  
18                 all open at this time.

19                 A number of systems included in these  
20                 chapters, and we'll touch on some of them here today.

21                 I'll turn it over to Jorge for the first  
22                 slides.

23                 MR. HERNANDEZ: Yes, good morning. My  
24                 name is Jorge Hernandez from the NRO, from the Balance  
25                 of Plant Section -- or Branch, I'm sorry.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   So, I'm going to briefly discuss the staff  
2                   evaluation of Section 9.1 in the areas of new and  
3                   spent fuel storage, the spent fuel cooling systems,  
4                   and the light and heavy load handling systems.

5                   I'm going to briefly mention significant  
6                   technical features of the systems, clear and open  
7                   items, and COL items, if any, in each of the areas.

8                   For the new and spent fuel storage, I want  
9                   to thank GE for clarifying that the actual capacity of  
10                  the pool is for ten years. We've been going back and  
11                  forth in RIAs with them as far as, you know, them  
12                  clarifying what the capacity of the pool and the  
13                  system is, I guess. The cooling system itself is able  
14                  to handle 20 years of fuel in the pool.

15                  MR. WALLIS:     How conservative is the  
16                  packing of the elements then when it has ten years  
17                  fuel elements in there?   How conservative is the  
18                  spacing?   Is it really pushing some limit, or --

19                  MR. HERNANDEZ:   That's part of an open  
20                  item right now, and there's an open item on the  
21                  thermal hydraulic analysis for the natural convection  
22                  of the rad, so we have -- I'm not sure if you have  
23                  already gotten that or not.   I guess they were  
24                  supposed to provide that this week.

25                  MS. CUBBAGE:   Right.

1 MR. HERNANDEZ: And so, we haven't had  
2 time to look at it yet.

3 MEMBER BONACA: So, the capacity is ten  
4 years, the capacity of the --

5 MR. HERNANDEZ: They are clarifying --  
6 staff understood that both the capacity of the cooling  
7 system and the pool were for 20 years. I guess the  
8 pool itself is going to -- GE is --

9 MR. TUCKER: This is Larry Tucker with  
10 GEH. The utility requirements document for spent fuel  
11 capacity is for ten years capacity, with a full core  
12 off load. The products would go commercial around  
13 2015, ten years after that, 2025, who knows what the  
14 spent fuel world will look like in 2025.

15 So, what we've done is, we've taken the  
16 approach that we are going to provide enough room in  
17 the pools, strength in the floor of the pools, and  
18 cooling capacity in the pools, for 20 years, and  
19 provide ten years of high-density racks, ten years'  
20 worth of high-density racks, as an initial offering of  
21 the ESBWR, to meet the utility requirement document of  
22 EPRI.

23 MR. BARSE: But the volume.

24 MR. TUCKER: Yes, sir, and the cooling  
25 capacity, and the seismic analysis would support

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 expansion in the future to 20 years capacity, plus a  
2 full core off load.

3 MEMBER BONACA: What was the cycle length  
4 that you assumed?

5 MR. TUCKER: Two years.

6 MEMBER BONACA: Two years.

7 MR. HERNANDEZ: Going along, the reactor  
8 building, both the pool capacities for 60 percent of  
9 the reactor pressure vessel core, the storage racks  
10 and the liner amendments are seismically qualified to  
11 Seismic Category 1.

12 The impact to racks from dropped objects  
13 is prevented by interlocks and safe mode paths, and  
14 those are discussed in Section 9.1-5.

15 And, the liner is designed to withstand  
16 the impact of one fuel assembly.

17 The staff is currently evaluating --  
18 there's currently a few open items in this section,  
19 one, we already mentioned that the applicant has  
20 submitted dynamic impact analysis of the fuel racks.  
21 To demonstrate the structural integrity during all the  
22 expected loads, and load combinations, and those  
23 include seismic load, thermal loads, fuel drop at  
24 maximum height, and they also need to provide a  
25 thermal hydraulic analysis also to demonstrate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 adequate natural convection on the racks, and also a  
2 criticality analysis.

3 MS. CUBBAGE: On that note, I'll just  
4 mention that it's going to come in the form of two  
5 topical reports. One was received just a few days  
6 ago, and the other we do expect to see, so there's  
7 some significant information there that the staff has  
8 yet to review and will brief you on when we come with  
9 the final SCR.

10 CHAIRMAN CORRADINI: Good, thank you.

11 MR. HERNANDEZ: The staff also requested  
12 the applicant to provide a drop analysis on the liner,  
13 to demonstrate that it would retain, you know, its  
14 integrity. We feel that this is an important feature  
15 for us to look at, you know, based on the fact that  
16 the ESBWR doesn't provide a safety-related make-up and  
17 they rely on the water inventory for 72 hours. So  
18 that, GE has agreed to let us do an audit on their  
19 analysis, and so we are going to be coordinating with  
20 their staff.

21 MR. WALLIS: What is the liner made of?

22 MR. HERNANDEZ: Sir?

23 MR. WALLIS: What is the liner made of?  
24 What's the material of the liner?

25 MR. HERNANDEZ: It's stainless steel.



1 MR. WALLIS: Stainless steel.

2 MR. KRESS: This drop analysis assumes  
3 there's water in there?

4 MR. HERNANDEZ: Yes. And, we haven't seen  
5 the analysis yet, but yes.

6 MEMBER MAYNARD: And, what is the  
7 requirement for cooling, is it just keeping the core  
8 -- the fuel covered, or is there a minimum pipe above  
9 the fuel?

10 MR. HERNANDEZ: Usually for active plants,  
11 you have a ten-feet, you know, margin, you are  
12 supposed to keep at least 10 feet of water, at least  
13 that's for chilling purposes.

14 There's no -- I mean, since we used to  
15 boil the water in the pool, and there's not going to  
16 be access to the building during an accident, those  
17 are the functions that are done for the full 72-hour  
18 reactions are done outside of the fuel building. We  
19 would have to evaluate that when we see the analysis,  
20 and, you know, determine whether, you know, the  
21 minimum level of water that they have in their  
22 analysis is adequate or not.

23 MEMBER STETKAR: I'll ask you the  
24 question, and maybe we'll get it this time.

25 There's a statement in the DCD that says,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 in the spent fuel pool, the bottoms of the pool gates  
2 are higher than the minimum water level required to  
3 provide adequate shielding and cooling. Do you know,  
4 what level is the bottom of those gates above the top  
5 of the active fuel? How many feet of water do we  
6 have?

7 MR. HERNANDEZ: I don't have the answer  
8 for that right now. If GE wants to address that --

9 MEMBER STETKAR: In other words, if the  
10 water level is there, and we start heating up from  
11 there, if we can get there somehow, then what type of  
12 margin do we have?

13 MS. CUBBAGE: I expect that would come in  
14 this topical report that we are expecting, and we'll  
15 be looking at thoroughly to make sure there's water.

16 MEMBER STETKAR: I hope you do look at the  
17 level that the bottom is.

18 MEMBER MAYNARD: And then also the ability  
19 to make up water after 72 hours, if that room is  
20 uninhabitable, you know, how is the make-up water, how  
21 is it going to be handled remotely to be able to get  
22 the water level back up for shielding and stuff?

23 MR. HERNANDEZ: We'll relay that.

24 MR. ARMIJO: You have an open item on the  
25 neutron absorbing monitoring program. Those are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 pretty standard materials they are specifying. What's  
2 the concern, is there a new concern, or new  
3 phenomenon, you are addressing, or is it a  
4 completeness issue?

5 MR. HERNANDEZ: For that particular item,  
6 I want to, you know, address that to Mr. Yamir Diaz-  
7 Castillo.

8 MR. DIAZ-CASTILLO: Yes, it's the  
9 completeness issue, and they didn't provide -- program  
10 that's needed to verify the material behavior for the  
11 panels in the spent fuel pool.

12 MR. ARMIJO: Okay, but there's no unusual  
13 materials or anything like that.

14 MR. DIAZ-CASTILLO: Well, we weren't clear  
15 in the application what kind of material they were  
16 going to use, whether it was going to be metamic or  
17 borate, so this is now going open issue right now, so  
18 we are still waiting for our response from GE.

19 MR. HERNANDEZ: All right, next slide.

20 For the fuel auxiliary pool cooling  
21 system, the main functions of the FAPCS are to provide  
22 safety-related passive cooling the heat-up and boil  
23 for 72 hours without make-up. It also provides non-  
24 safety-related active cooling to the other pools and  
25 the spent fuel pool. There's also some missing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 functions, the RTNSS functions in there, to provide  
2 low pressure cooling injection and spent fuel pool  
3 cooling, and there's also some other capabilities of  
4 the system to provide ultimate shutdown cooling and  
5 drywell spray, but they are not, you know, present in  
6 the safety analysis or in the PRA.

7 MR. WALLIS: Are they required to tell you  
8 what -- analyze what happens should the pool drain?

9 MR. HERNANDEZ: Yes, those are adverse  
10 interactions between, you know, the safety systems,  
11 and they have siphoning devices from, you know --

12 MR. WALLIS: Do you worry about catching  
13 fire and things like that if the pool drains? Is that  
14 part of --

15 MR. HERNANDEZ: I'm sorry?

16 MR. WALLIS: You drain the pool, does the  
17 fuel catch fire?

18 MR. HERNANDEZ: Well, yes, there's going  
19 to be heat up of the fuel, obviously.

20 MR. WALLIS: That's part of the safety  
21 evaluation, is it, in the event of a fuel pool  
22 draining?

23 MR. HERNANDEZ: Yes, it's part of the  
24 evaluation, and like I'm saying -- we'll get to that  
25 some day.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: And, the accident  
2 analysis.

3 MR. HERNANDEZ: And, the accident  
4 analysis, we'll get to that, that's going to be in  
5 Chapter -- the accident analysis will be discussed  
6 under Chapter 15.

7 MR. WALLIS: All those interesting --

8 CHAIRMAN CORRADINI: All those fun things.

9 MS. CUBBAGE: Chapter 19. We are looking  
10 to make sure that there's water in there.

11 CHAIRMAN CORRADINI: That's my fault.

12 MR. HERNANDEZ: So, in our evaluation, we  
13 requested the applicant to provide some additional  
14 information in several areas, in order for us to make,  
15 you know, a safety determination, and, you know, the  
16 following items, and I'll briefly mention them, have  
17 not been addressed.

18 You know, we want them to provide  
19 justification for not providing a safety-related  
20 atmospheric clean-up system in their design, and we  
21 are still waiting for an answer, a response from GE  
22 for that.

23 The staff also requested the applicant to  
24 provide analysis demonstrating, you know, adequate  
25 water inventory for both the spent fuel pool and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 buffer pools, for 72 hours without make-up.

2 We also --

3 CHAIRMAN CORRADINI: Just a quick  
4 clarification there. So, the assumption by the staff  
5 is, is that there's the potentiality that you'd have  
6 spent fuel in the buffer pool existing during some  
7 sort of accident? That's what I'm trying to  
8 understand, the buffer pool.

9 MR. HERNANDEZ: Well, yes, that would be  
10 a scenario, during refueling we could have a seismic  
11 event.

12 CHAIRMAN CORRADINI: Okay, that's fine.

13 MR. HERNANDEZ: I mean, and we have in  
14 mind that also the spent fuel is going to be in the  
15 pool, so it concerns us much less, but, nevertheless,  
16 we asked the question.

17 CHAIRMAN CORRADINI: Right.

18 MR. HERNANDEZ: And, we also asked the  
19 basis for, they credit 200 gpm going as an emergency  
20 make-up flow for post-72 hour make-up to the upper  
21 pools and the spent fuel pool, so we asked them to  
22 provide, you know, an analysis demonstrating, you  
23 know, what the initial conditions are, and then what  
24 the requirements are.

25 And, we've asked them also to provide, you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 know, performance requirements for the cooling systems  
2 for the RTNSS functions for low pressure cooling  
3 injection and the suppression pool core, and, you  
4 know, we are still waiting. I believe the flow rate  
5 is 1,500 gpm for the cooling system, where we are  
6 asking, you know, how many gpm would you need for the  
7 actual functions in PRA.

8 And then, the last item that I'm going to  
9 discuss is level instrumentation elevation relative to  
10 the TAF, in other words, some, you know, where are the  
11 TAFs located relative to any of the alarms, relative  
12 to the TAF and the spent fuel.

13 With regards to Sections 9.1-4 and 9.1-5  
14 under light and heavy load handling systems, I want to  
15 mention that many features for both, you know, the  
16 reactor building and the fuel -- cranes is that they  
17 have single-failure-proof cranes, also the cranes that  
18 are filling machines, and the incline fuel transfer  
19 systems are designed to withstand an SSE, and the  
20 applicant is committing to NUREGs 0554 and 0612, and  
21 all the applicable standards in that area.

22 We also want to point out that -- and it  
23 was mentioned during GE's presentation, that the  
24 incline fuel transfer system is not new to the staff,  
25 I mean, we've seen it in BWR-6, so we didn't feel that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 it's really an area that's radical, it's not a first-  
2 of-kind design. They do have, you know, like I  
3 mentioned, seismic qualifications for those systems  
4 that are needed, those components and systems that are  
5 needed for retaining the loads, you know, they have  
6 interlocks also as well to prevent, you know, opening  
7 of the cranes, of the gates, escape valves, or the  
8 valves that would allow, you know, a drainage from the  
9 upper pool the lower pool.

10 Also, you know, the transfer of the fuel,  
11 I mean, the part on the upper pools and the lower  
12 pool, and the spent fuel pool, where the fuels are  
13 going to be transferred, are separate from the rest of  
14 the pool, so there's not a potential to drain either  
15 -- in this case it would be the upper pools that would  
16 not be able to drain.

17 MR. BARSE: Can I ask a question, because  
18 I guess I hadn't heard that phrase before, I'll admit  
19 my naivete.

20 What parts of the crane system are  
21 involved when you say single-failure-proof cranes?

22 MR. HERNANDEZ: What parts of the --

23 MR. BARSE: I mean, they don't have doubled  
24 up cables, do they have doubled up foots, is it  
25 clutches, is it the electronics, what part of it is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 single-failure-proof?

2 MR. HERNANDEZ: Yes, they need to have  
3 dual-revving systems.

4 MR. BARSE: Okay.

5 MR. HERNANDEZ: Emergency brakes,  
6 redundancy in the emergency brakes as well, also --  
7 well, those are the main things.

8 MR. BARSE: Okay, thanks.

9 MR. ARMIJO: The incline fuel transfer  
10 system is unique, in that its outside containment,  
11 compared to the BWR-6.

12 MR. HERNANDEZ: Yes, GE mentioned that.

13 MR. ARMIJO: Right. Is there any unusual  
14 issues that the staff has looked at, as a result of it  
15 being outside containment?

16 MR. HERNANDEZ: Well, that particular --  
17 there's an open item on -- right now, that we've  
18 asked, you know, GE to better explain the details of  
19 the system, and that particular, you know, item, you  
20 know, being outside the containment, that's not -- the  
21 staff was not aware of that up until today, so we  
22 would have to look at GE's response on those items,  
23 and then we'll --

24 MEMBER MAYNARD: Wasn't the radiation  
25 protection an open item, was it with the incline fuel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 transfer?

2 MS. CUBBAGE: Right. Charlie Hinson, our  
3 Radiation Protection Engineer is here, and this would  
4 be his questions, but I understand them to be the  
5 shielding and assuring the access controls in areas  
6 when fuel is moving. I don't know if Charlie would  
7 like to elaborate.

8 MEMBER MAYNARD: I think that would be  
9 another unique item, not being in containment,  
10 radiation protection.

11 MR. HINSON: Yes, hi, I'm Charlie Hinson.  
12 Yes, we had some questions that are outstanding on  
13 having the applicant give us the spent fuel dose  
14 rates, when a fuel is being transferred in the tube,  
15 and the various accessible areas.

16 There are two areas that are interlocked  
17 to access the tube itself, and those are -- they have  
18 multiple interlocks and alarms and radiation monitors,  
19 but we were also concerned about, are there access  
20 paths, and we asked the applicant to provide us the  
21 shield wall thicknesses around this fuel transfer tube  
22 during transfer of a fuel assembly.

23 And so, they gave us -- they responded to  
24 the RAI and gave us some of the dose rates, which were  
25 all very low dose rates, but we had two areas that we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 still wanted some more information about from the  
2 applicant, so we have an outstanding issue on dose  
3 rates during fuel transfer operations. That's,  
4 essentially, what that was about.

5 MR. ARMIJO: Is this system capable of  
6 transferring stale fuel or damaged fuel from that  
7 buffer down through -- has that been -- how is that  
8 treated?

9 MR. HERNANDEZ: I know that they have, I  
10 mean, they have two inserts for the system, one is for  
11 fuels and the other one is for auxiliary equipment.  
12 I'm not sure, and I would like GE to, you know, answer  
13 that part. We've not asked the question.

14 MR. TUCKER: This is Larry Tucker with  
15 GEH.

16 Our operating fleet at BWRs, and also the  
17 ESBWRs for failed fuels, there are canisters that you  
18 place the bundle in, and top it off to control the  
19 concerns that you are asking about. An incline fuel  
20 transfer tube can accommodate the canister with a  
21 bundle in it.

22 MR. ARMIJO: Okay.

23 MEMBER ABDEL-KHALIK: From a structural  
24 integrity standpoint, what is this transfer tube  
25 supposed to handle, from the maximum loading?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. HERNANDEZ: That particular part of  
2 the analysis would be done by the structural  
3 engineering part, I don't --

4 MEMBER MAYNARD: About assemblies, or are  
5 you talking about weight? There's two assemblies, I  
6 thought. I think they said two assemblies.

7 CHAIRMAN CORRADINI: Is that correct?

8 MR. TUCKER: That's correct.

9 MEMBER STETKAR: Does the inclined fuel  
10 transfer tube have its own cooling system?

11 MR. HERNANDEZ: It has a valve for  
12 filling, it has a filling valve, to make sure that --  
13 but I'm not sure, I don't think that there's a cooling  
14 system for that. There's only two fuel assemblies.

15 MR. WALLIS: Two at a time, so off loading  
16 a core takes a long time?

17 MR. HERNANDEZ: No, no, no, they have a  
18 buffer pool.

19 CHAIRMAN CORRADINI: The transfer takes a  
20 while, the off loading to the buffer pool holds --

21 MR. WALLIS: About 60 percent of the core.

22 MEMBER STETKAR: If they have to off load  
23 the whole core, they need to use this thing.

24 MEMBER MAYNARD: Well, talking about the  
25 cooling in here, though, has analysis been done, what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 if the power is lost, AC power is not safety related,  
2 so if you lose power what's the cooling capability in  
3 this tube with the fuel assembly inside, or two fuel  
4 assemblies?

5 MR. HERNANDEZ: During refueling, so you  
6 are talking about a scenario during your fueling  
7 operation.

8 MEMBER MAYNARD: During refueling  
9 operation you lose power.

10 CHAIRMAN CORRADINI: I think he's saying  
11 during transfer.

12 MR. HERNANDEZ: Right, which would be  
13 under the fueling scenario, they -- well, I don't --  
14 we have not asked for analysis on that. There is water  
15 on the upper pools and on the spent fuel pool to --

16 MEMBER MAYNARD: But, they are not open.

17 MR. HERNANDEZ: They are not open.

18 MR. WALLIS: So, it could get stuck  
19 halfway and just keep heating up?

20 MEMBER SIEBER: Yes.

21 MS. CUBBAGE: I think --

22 CHAIRMAN CORRADINI: Can I ask GE to help  
23 out and --

24 MR. HERNANDEZ: We'll take note of that.

25 MR. TUCKER: This is Larry Tucker with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 GEH.

2 Incline fuel transfer is designed for two  
3 bundles at a time, assumed to be irradiated, and to  
4 withstand a safe shutdown earthquake with those two  
5 bundles inside the transfer tube.

6 The tube itself, in terms of cooling, is  
7 a very large tube, with lots of water, and if the  
8 bundles get stuck mid transit, on a rare event that  
9 has actually happened at a BWR-6, it shows that  
10 there's more than adequate cooling capacity from the  
11 volume of water of the tube and the heat radiated  
12 through the metal tube to the environment.

13 MR. ARMIJO: So, you'd count on passive  
14 cooling then, is that --

15 MR. TUCKER: Yes, sir, there's no need for  
16 active cooling of that, because as it warms up it  
17 radiates heat through the tube.

18 MR. BARSE: That's based on experience, not  
19 analysis, right?

20 CHAIRMAN CORRADINI: I think that's what  
21 he said.

22 MR. TUCKER: Yes to the first, and  
23 confirmed by the second.

24 MR. BARSE: Thank you.

25 CHAIRMAN CORRADINI: Let's move on. You

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 have 25 minutes, so I'm counting on you to --

2 MR. HERNANDEZ: Briefly, okay, the last  
3 open item we have is we asked them to provide the  
4 seismic specification of the new fuel -- I mean,  
5 they've provide the information for all of the other  
6 -- maybe there was some oversight or something, but,  
7 you know, we asked them to, just for completeness, to  
8 know what the seismic classification is.

9 CHAIRMAN CORRADINI: Okay, thank you.

10 MR. HERNANDEZ: And then, there's also COL  
11 action items to provide the heavy load listings, the  
12 fuel handling procedures, maintenance manuals, safe  
13 load paths, QA -- and everything that's, you know,  
14 within the scope of NUREG 0612 for the applicant, and  
15 with that I'll turn it back.

16 MS. CUBBAGE: All right, we need to switch  
17 out teams here. I forgot to introduce Chang Li  
18 earlier, he's our Senior Reviewer in the Balance of  
19 Plant, and he's going to talk about the water system.

20 CHAIRMAN CORRADINI: Okay.

21 MR. LI: My name is Chang Li with Balance  
22 of Plant Branch at NRO.

23 I review area covers of the water systems.  
24 Our review is based on standard review plan section  
25 9.2.1 through 9.2.6, because ESBWR is a passive

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 design, so all the water systems and non-safety-  
2 related systems, except the containment isolation, the  
3 review is different from active design, which has  
4 portions of the water system being safety related.

5 For the passive design, the standard  
6 review criteria that apply only to safety-related  
7 portion of the system are not applicable to the ESBWR.

8 Our initial RAIs, many focus on the level  
9 of details, which is like such as drawings, applicable  
10 portions of GDC instruments, mitigation for water  
11 hammers. And, one area we'll talk in the RAIs we're  
12 asking questions about identification of which systems  
13 are RTNSS systems, which -- they've responded back,  
14 and now they have determined that service water  
15 systems, reactor component cooling water systems and  
16 portions of chill water systems being the RTNSS  
17 systems.

18 And, when they say RTNSS systems, we are  
19 asking they be included in the ITAAC.

20 The remaining open items, we have  
21 questions about the details of drawings, we are  
22 working with GE in resolution to this question.

23 And, the questions about radiation  
24 monitoring for the service water systems, we have some  
25 response in RAI response, and also we asked questions

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 about the procedures for avoiding water hammers in  
2 those RTNSS systems, and we still have --

3 MR. WALLIS: Do you worry about water  
4 hammer in the fire control system?

5 MR. LI: The water hammer systems that we  
6 are asking about are RTNSS systems for performing  
7 post-72 hours RTNSS functions.

8 MR. WALLIS: You are also looking at fire  
9 water and possible water hammer in fire water systems?

10 MS. CUBBAGE: From a fire protection  
11 standpoint, or from a RTNSS pool make-up? Which  
12 factor? Or, just in general.

13 MR. WALLIS: When you get to -- probably  
14 it's another section, is it?

15 MR. LI: Yes, yes.

16 MR. WALLIS: I just want to be sure that  
17 you also look at water hammer possibility in the fire  
18 protection system.

19 MR. LI: Yes.

20 MR. UPTON: This is Hugh Upton with GEH.

21 Let me address the fire protection system.  
22 It's kept solid, except for some of the small  
23 spargers, so there isn't -- there's really no  
24 potential for water hammer in the fire protection  
25 system, by design.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. LI: And, we have remaining RAIs not  
2 responded about the make-up water systems, whether  
3 it's a RTNSS system or not.

4 MEMBER STETKAR: Let me take -- ask it  
5 now, since this is the first place. But, how are you  
6 tracking the changes. Because, obviously, a lot of  
7 these are auxiliary systems, are evolving quite  
8 rapidly.

9 MS. CUBBAGE: Changes from our safety  
10 evaluation?

11 MEMBER STETKAR: Yes, for example, the  
12 turbine component cooling water system, in Rev 3 and  
13 Rev 4 of the DCD, is different from the description of  
14 that system in the SER.

15 MS. CUBBAGE: Well, I'll be honest with  
16 you, it's a challenge.

17 MEMBER STETKAR: Instrument air, service  
18 air, hot water, have changed completely --

19 MS. CUBBAGE: Right.

20 MEMBER STETKAR: -- between Rev 3 and Rev  
21 4, but I understand Rev 3 versus Rev 4, because this  
22 SER is based on Rev 3. But, I found some  
23 discrepancies between the SER descriptions and even  
24 Rev 3 of the DCD, meaning --

25 MS. CUBBAGE: Right, and we --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: -- indicating that you  
2 hadn't really followed up on that.

3 MS. CUBBAGE: -- we've identified in a  
4 couple of areas, as a matter of fact, when we sent the  
5 safety evaluation to GE, they have identified a couple  
6 of areas where we did have a little disconnect there.  
7 The scenario with the final SER, we are not going to  
8 do a wholesale upgrade of our SER to address Rev 4,  
9 because we know we are going to get a Rev 5, so it's  
10 a little bit of a moving target, and we're doing our  
11 best there.

12 But, on Rev 4, we have an RAI milestone  
13 coming up, where we are going to ask GE any questions  
14 related to Rev 4, and we are going to go back and  
15 verify the DCD, that it matches the SER before we  
16 issue a final SER and certify the design.

17 MEMBER STETKAR: Okay.

18 MS. CUBBAGE: And, a number of -- and the  
19 reason you are seeing these discrepancies I think, in  
20 a couple of limited areas, is many of -- we got in a  
21 situation where some of the SER inputs were done a  
22 long time ago, and then others were taking longer, and  
23 so when we tried to sync up with Rev 3 it was a case  
24 of trying to make sure everything was upgraded.

25 MEMBER STETKAR: It's just a little bit

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1       difficult for us, as you can imagine, I know it's  
2       really difficult for you, but for us, in terms of we  
3       are looking at something that is in turn looking at a  
4       moving target --

5               MS. CUBBAGE: Right, well, we feel that  
6       the early interaction is beneficial for you, and for  
7       us, and for GE.

8               MEMBER STETKAR: Oh, yes.

9               MS. CUBBAGE: So, hopefully, we can -- the  
10      inconvenience.

11              MR. BARSE: Can I follow up with one more  
12      on that, because I've been a bit worried about it,  
13      too, and I know you said you are going through it page  
14      by page, but somehow when that final design comes out,  
15      as you go through, it seems to me, and you must have  
16      thought about this, you need to go back over the RAIs  
17      that have cleared and make sure they are still  
18      relevant. Is there a process for that?

19              MS. CUBBAGE: We are actually facing that  
20      as we speak, and, you know, I think the first  
21      responsibility is with GEH, because they've responded  
22      to an RAI in a manner that now they've changed, and we  
23      said it was resolved, it's incumbent upon them to  
24      identify to us that they need to update that RAI  
25      response, that their response is no longer valid.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And also, to facilitate the staff's review  
2 of Rev 4, they did provide us an aid that is a red-  
3 line strikeout between Rev 3 and Rev 4.

4 CHAIRMAN CORRADINI: The changed list that  
5 I see.

6 MS. CUBBAGE: There's a changed list, but  
7 in addition there's a courtesy copy they gave us --

8 CHAIRMAN CORRADINI: Oh, I see.

9 MS. CUBBAGE: -- a red-line strikeout  
10 type.

11 CHAIRMAN CORRADINI: In the DCD -- I'm  
12 sorry, I didn't mean to interrupt you.

13 MS. CUBBAGE: That's okay.

14 CHAIRMAN CORRADINI: In the DCD, there are  
15 places where if you compare between 3 and 4 there's a  
16 change marked.

17 MS. CUBBAGE: The change bar, but in some  
18 cases we found that if they replaced a whole paragraph  
19 the change bar and the change list weren't really  
20 adequate.

21 CHAIRMAN CORRADINI: Okay.

22 MS. CUBBAGE: So, we've asked for Rev 4,  
23 and going forward, that we get a little more help on  
24 that.

25 CHAIRMAN CORRADINI: Okay, thanks.

1 MS. CUBBAGE: With this tool.

2 MEMBER ABDEL-KHALIK: Does GE have in  
3 place a mechanism to track how changes affect earlier  
4 responses to earlier RAIs?

5 MR. KINSEY: Yes, this is Jim Kinsey from  
6 GE Hitachi. In addition to the change list tracking  
7 system, which addresses changes between revisions for,  
8 you know, Revision 3 to 4, for instance in this case,  
9 we also have an internal configuration control  
10 mechanism that's actually an electronic annotation  
11 system. So, we put tags or flags on text within the  
12 document, so if, for instance, when we are developing  
13 Rev 5 we'll go back and touch a paragraph on a page in  
14 the DCD, we can see the annotations and see the  
15 history related to previous revisions. So, we can  
16 take a look at previous responses and identify if  
17 there were any impacts or any issues to identify or  
18 address with the NRC.

19 MEMBER ABDEL-KHALIK: But, the new changes  
20 may not have had any relation to prior responses to  
21 RAIs. So, tracking in this way may not capture that.

22 MR. KINSEY: I'm not -- and this is Jim  
23 Kinsey again -- I'm not sure if I understand the  
24 specific question or concern.

25 What we are doing is, I guess two things.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 We are evaluating changes that we make against the --  
2 I guess I'll call it the history of that portion of  
3 the DCD through our annotation process, and then in  
4 addition to that, if we find that there was no impact  
5 to anything in the past, we also clearly identify the  
6 additional change that we are making to NRC, to assess  
7 whether they have any new or different questions or  
8 concerns going forward.

9 So, we try to look both directions, or  
10 identify it in two different ways.

11 MS. CUBBAGE: I mean, I can give you a  
12 real-life example. They started off this design with  
13 a bottled air system, the EBAS, for controlling the  
14 habitability. We had a number of RAIs in that area,  
15 and so between the staff and GE we had to assess  
16 whether those RAIs were completely irrelevant with the  
17 new system, or partially relevant, we've had to do  
18 that.

19 MR. TUCKER: This is Larry Tucker with  
20 GEH.

21 Following up on Amy's example, the ESBWR  
22 design, we've implemented configuration control of  
23 that. For the EBAS change out we determined that as  
24 a design change for the ESBWR, and we filled out an  
25 engineering change authorization form, which describes

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the change, it has a checklist of, it inquires about  
2 the affected analysis, drawings, commitments to the  
3 NRC, positions on reg guides, or any other kinds of  
4 correspondence, including RAIs, as you go through that  
5 change.

6 That change is brought forward to our  
7 senior management, and either approved or rejected at  
8 that time. So, we share with Amy and you the  
9 challenge of making sure that we keep all our analysis  
10 and design in lock step with what was presented in the  
11 DCD, and that's why even at this early stage we are  
12 putting in appropriate engineering configuration  
13 management controls to the design.

14 MS. CUBBAGE: And then just one more point  
15 on that, and then we'll move on, is that where DCD is  
16 applied we do not expect the type of changes we've  
17 seen in previous DCD regs, and they are all related to  
18 resolution of open items, and working with the staff  
19 going forward on that.

20 MR. SHUABHI: Let me just add, this is  
21 Muhammed Shuabhi with the staff. It's also, when we  
22 get revisions to the DCD, we do go through the  
23 revisions of the DCD, the new revisions, and make sure  
24 that we still agree that the DCD is accurate, or we  
25 ask new questions in RAIs and things.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1                   So, while initially the responsibility is  
2                   with GE, and they've got the primary responsibility to  
3                   identify to us those changes, we also go through the  
4                   DCD to make sure that our concerns are still  
5                   addressed, and that the newest DCD rev and the final  
6                   DCD rev are consistent with what we are reviewing.

7                   MR. LI: Okay, I have the last item. COL  
8                   action items, I have two bullets. The first one, COL  
9                   applicant would develop provisions to preclude long-  
10                  term corrosions and a fire in the service water  
11                  systems, procedures for avoiding water hammer in CWS,  
12                  RCCWS corrosions.

13                 The second bullet, COL applicant will  
14                 provide the design of station water system, that's,  
15                 actually, I was going to address testing change in  
16                 Revision 4, and, actually, there are other five COL  
17                 interface items that are identified in my SER, which  
18                 was in Revision 3 in Tier 1, but now it's mostly --  
19                 and we are reviewing it, we may have new RAIs  
20                 associated with those changes.

21                 MS. CUBBAGE: Okay, I think I need to  
22                 bring up another reviewer I forgot to introduce.

23                 This is David Shum.

24                 CHAIRMAN CORRADINI: We'll do a time  
25                 check.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. CUBBAGE: Yes.

2 CHAIRMAN CORRADINI: So, what do you  
3 think? Are we close to being -- should we --

4 MS. CUBBAGE: Do you want to take a quick  
5 break?

6 CHAIRMAN CORRADINI: No, I'd rather not.  
7 What I'd like to do is see if we can get through this,  
8 can we get through this by quarter of, do you think?

9 MR. SHUM: Me?

10 MS. CUBBAGE: No, everybody. We can  
11 recognize going in with this agenda that 9 might go  
12 over, and we could make up time on other chapters, but  
13 we'll move as quickly as we can.

14 Go ahead, David.

15 MR. SHUM: Good morning, my name is David  
16 Shum. I'm from the Balance of Plant System Branch,  
17 and I'm the Reviewer for this sections, compressed  
18 air, which contains instrumentation air, service air  
19 and high-pressure nitrogen supply system. I also  
20 reviewed the auxiliary boiler system, and floor drain  
21 systems.

22 All these systems are non-safety systems,  
23 and have no safety functions, other than the  
24 penetration and isolation function for this high-  
25 pressure nitrogen supply system and floor drain

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 system.

2 Since this is non-safety and non-  
3 maintenance systems, so there's no open issues, except  
4 -- except one for -- one open issue for the auxiliary  
5 boiler systems, which GE had not addressed the fail of  
6 the systems would affect any other safety systems.

7 Any question on these systems?

8 MR. BARSE: Yes, the same one I raised with  
9 GE. Historically, even though this is --  
10 historically, contaminants in instrument air systems  
11 have led to all sorts of funny operability things,  
12 opening or closing when they are not expected, things  
13 not relieving when they are supposed to, there is an  
14 interface from the service air system over to where  
15 the nitrogen system comes in on the fuel valves we did  
16 hear about.

17 Have you looked at the possibility of  
18 dryers and filters being bypassed and getting  
19 contamination into the system, and have you worried  
20 about that at all?

21 MR. SHUM: First of all, the  
22 instrumentation air to get the supply, to get air from  
23 the service air systems, service air systems itself  
24 has three compressors, a little vent for the filters,  
25 dryers, and then supplies the air to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 instrumentation air system.

2 And, the instrumentation air itself has  
3 filters. I mean, each train has its own filters, and  
4 dryers, before it supplies air to --

5 MR. BARSE: I guess I didn't say it just  
6 right.

7 In older systems, those same kind of  
8 designs have had bypasses.

9 MR. SHUM: I heard that.

10 MR. BARSE: Okay. That's what I'm worried  
11 about.

12 MR. SHUM: By looking at that diagram, I  
13 didn't see there's any bypass at all.

14 MR. BARSE: Did you ask about it?

15 MR. SHUM: No, because it's not --

16 MR. BARSE: Well, we'll ask.

17 MR. SHUM: -- because it is not safety  
18 systems, and also, also, my main focus was on whether  
19 it failed, the system on any safety -- any other  
20 safety system or not, which I didn't see there was any  
21 problem at all.

22 MR. BARSE: Thank you.

23 MR. RADLINSKI: Can I respond to that,  
24 too?

25 Bob Radlinski, I'm in the Fire Protection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Branch, and other systems as well.

2 Generally, a bypass is only used in an  
3 emergency or a back-up situation, where filters need  
4 to be placed.

5 MR. BARSE: There's a whole history that  
6 shows that generally isn't all the time.

7 MR. RADLINSKI: Okay. That's the design  
8 intent.

9 MR. BARSE: Yes.

10 MR. RADLINSKI: Obviously, long-term  
11 effects of moisture are detrimental, but if you were  
12 to operate in a bypass situation, and you expected to  
13 get moisture in the system, you would go around and  
14 blow down the system and remove the moisture.

15 MR. BARSE: It's a hard job.

16 MR. RADLINSKI: Right.

17 MEMBER STETKAR: Let me ask a related  
18 question, and I don't know if we have the right people  
19 here.

20 Containment isolation valves,  
21 pneumatically operated containment isolation valves on  
22 the ESBWR, are they normally energized solenoids, or  
23 are they normally de-energized? Does anyone -- it  
24 might be different -- okay, if you don't have it,  
25 that's fine.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: Let's go on. John  
2 will write that one down.

3 MEMBER STETKAR: Write it down.

4 CHAIRMAN CORRADINI: He has a big list.

5 MR. SHUM: So, next slide is -- I'm also  
6 the reviewer for the system for the diesel generator  
7 systems. The systems, the diesel generator itself is  
8 not our branch, we only review the diesel generator  
9 supporting systems.

10 And, since this diesel generators are not  
11 safety systems, so the only things we are focusing on  
12 whether it fail, this system will affect any other  
13 safety system or not. And, we found that in the very  
14 beginning we find that, we find out that they need to  
15 use their system as, you know, to supply power to the  
16 monitors systems and also some of the cooling systems,  
17 problems.

18 MS. CUBBAGE: Post-72 hours.

19 MR. SHUM: Post-72 hours. So, because of  
20 that capacity to make this a RTNSS system, so they  
21 did.

22 However, they have not put this into the  
23 -- they have not had ITACs for all of the systems, so  
24 this is an open issue.

25 MS. CUBBAGE: That was an open issue in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Rev 3, I believe that's been addressed in DCD Rev 4.

2 MR. SHUM: Right. I looked --

3 CHAIRMAN CORRADINI: Yet to be looked at.

4 MS. CUBBAGE: Yet to be looked at.

5 MR. SHUM: I glanced it, I found out they  
6 only list about two of them.

7 MS. CUBBAGE: Okay, still open.

8 MR. SHUM: Still open, every one, every  
9 single one.

10 CHAIRMAN CORRADINI: Okay. Questions?

11 MEMBER STETKAR: So, on control power, DC  
12 control power for starting the diesels, closing the  
13 diesel output breaker, controlling the load  
14 sequencing, if there is load sequencing, or a  
15 automatic or manual, doesn't make any difference, is  
16 that supplied from the non-safety batteries?

17 MS. CUBBAGE: Yes, that's beyond your  
18 area, right?

19 MR. SHUM: Right, that's electrical.

20 MEMBER STETKAR: Okay. The only concern  
21 here is, let me bring it out on the table, non-safety  
22 batteries are rated for two hours. After two hours in  
23 a station blackout you don't have those batteries.  
24 It's difficult to start and load a diesel at 72 hours,  
25 if you can't start it and you can't load it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 Keep that in mind.

2 MEMBER MAYNARD: I agree with that, but  
3 there's no reason they would be waiting 72 hours to  
4 start that.

5 MEMBER STETKAR: That's okey, the design  
6 says they shall be available -- what, they should be  
7 available at 72 hours, to provide back-up.

8 We should go on.

9 MR. UPTON: Dr. Stetkar, we are checking  
10 on that right now, but I believe that there are a  
11 separate set of batteries within the diesel generators  
12 themselves.

13 MEMBER STETKAR: Not just the diesel  
14 generator, it's this closing the output breaker,  
15 closing the breakers on the PIP buses, controlling the  
16 diesel -- the diesel may start, it's getting the  
17 diesel loaded onto the bus and operating stably, and  
18 closing loads onto the bus.

19 MR. UPTON: I'll have to take that as an  
20 open item and get back to you.

21 MEMBER SIEBER: Part of the answer to that  
22 is just because it's non-safety doesn't mean it won't  
23 last more than two hours. You can buy a battery that  
24 will do anything.

25 MEMBER STETKAR: Except under a station

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 blackout, they are not guaranteed. They are designed  
2 to hold load for two hours, and that's it.

3 MR. SHUM: So, there still are some open  
4 issues. One is they don't have ITAAC for each of the  
5 supporting systems, and also there's a COL applicant  
6 to ensure the safety and reliability of these systems.

7 MS. CUBBAGE: Next.

8 MR. SHUM: Any questions?

9 CHAIRMAN CORRADINI: No, I think we can  
10 move on. Thank you.

11 MS. CUBBAGE: Thank you.

12 CHAIRMAN CORRADINI: Thank you very much.

13 MR. DIAZ-CASTILLO: My name is Yamir Diaz-  
14 Castillo, I'm with the -- Branch with NRO. I'm the  
15 Technical Reviewer for Sections 9.3.9, which is the  
16 hydrogen water chemistry system, 9.3.10, which is the  
17 oxygen injection system, and 9.3.11, which is the  
18 steam injection system.

19 Let me start by saying that none of these  
20 systems are safety related, and they have no safety  
21 functions.

22 I'll start with the hydrogen water  
23 chemistry system, which this is just hydrogen through  
24 the -- water system -- all the combination of -- This  
25 system is not part of the ESBWR design, however, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 ESBWR design includes the capability to connect this  
2 system.

3 The decision to implement the system  
4 relies on the COL applicant. If the system is  
5 implemented, it would follow the EPRI and BWR water  
6 hydrogen chemistry guidelines and also the guidelines  
7 for permanent diesel or hydrogen water installations.

8 MR. ARMIJO: For the record, I'd just like  
9 you to -- the wording on what the purpose of this  
10 system is, you have it to mitigate corrosion and  
11 recombination of dissolved oxidants. The real purpose  
12 of that system is to mitigate irradiation assisted  
13 stress corrosion cracking of core internals, many of  
14 those core internals, while not necessarily safety  
15 related, like shrouds, top guides, possibly even the  
16 steam dryers and the chimneys, all of these things,  
17 welded stainless steel components, are protected by  
18 virtue of hydrogen water chemistry, also by virtue of  
19 improved materials.

20 Improved materials by themselves will not  
21 prevent cracking, so hydrogen water chemistry is a  
22 proven effective way to prevent that cracking of  
23 components that somehow NRC gets involved with when  
24 things fail.

25 So, still I think again, I made the point

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 before to GEH, that these kinds of systems should be  
2 standard to the boiling water reactor, and they do  
3 affect components that gets the NRC torqued up every  
4 time they fail.

5 So, something is -- either I'm missing  
6 something, or the staff is missing something, on not  
7 making these kinds of systems a requirement, as it  
8 certainly is important as an oxygen injection system,  
9 which is kind of -- which is not optional, it's built  
10 into the design, and this thing isn't.

11 So, I'll leave it at that for the staff to  
12 consider.

13 MS. GRUSS: This is Kim Gruss.

14 Yes, I think we understand the concern,  
15 and we'll take it back with us.

16 MEMBER SIEBER: You actually have to have  
17 a regulation that would require that. However, I'm  
18 not aware of any.

19 MR. ARMIJO: You don't for oxygen, you  
20 just put it in.

21 MS. CUBBAGE: They put it in.

22 MEMBER SIEBER: Well, maybe I'm just in a  
23 jaw bone, or I'm promoting regulation, I hate to have  
24 this become a safety-related system, in order to get  
25 it used. I mean, I feel like we are in Alice in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Wonderland, not implementing things that we know work  
2 to protect materials that we know are susceptible to  
3 cracking. I just don't understand --

4 MR. BARSE: Then they become safety  
5 concerns.

6 MR. ARMIJO: Yes, and then they become  
7 safety concerns. So, is the strategy to wait for  
8 something to crack and then put in these systems that  
9 we know worked before?

10 MS. CUBBAGE: We certainly understand your  
11 concern and your issue. We are going to move on.

12 MR. ARMIJO: Okay.

13 MR. WALLIS: Well, what we'd like to do is  
14 make it your concern as well, not just you understand  
15 that.

16 MS. GRUSS: I think, you know, IASCC is a  
17 concern to us, and from a materials integrity and  
18 performance perspective we look at those materials,  
19 and the environment in which they are in.

20 This is not a regulatory requirement, and  
21 one thing that we would have to do to make such is go  
22 through a rulemaking to change it. So, we are  
23 counting on not only GE selecting IASCC resistant  
24 materials, we are also counting on their welding  
25 controls to minimize incidents of crack initiators.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 We are also relying on the quality of those materials  
2 and trained weld operators.

3 And so, the combination of those things  
4 alone provides us with the assurance that it will be  
5 minimized.

6 I agree with you that hydrogen water  
7 chemistry can significantly minimize the incidence of  
8 IASCC.

9 MR. ARMIJO: I think it's the most  
10 powerful tool to prevent IASCC, more powerful than the  
11 materials, more powerful than the welding, and it's  
12 strange to see that it's being treated as an option.

13 MEMBER SIEBER: Well, it's investment  
14 protection.

15 MR. ARMIJO: If it were just investment  
16 protection, when something cracks the NRC shouldn't be  
17 involved.

18 But never mind, I'll drop it at that.

19 CHAIRMAN CORRADINI: I think we need to  
20 move on, but I think you'll keep on hearing this, so  
21 we will just address it.

22 MR. WALLIS: Just one thing, the ISI  
23 program is what satisfies the safety requirement that  
24 you go out and find it. What you do about it, or how  
25 you caused it is a different question.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And, the same situation exists for PWRs  
2 too, you know, there's no regulation on water  
3 chemistry for them, and in PWRs, the older ones, went  
4 through lessons with generators over there.

5 MS. CUBBAGE: Okay, did you have any  
6 points on the last two, oxygen and zinc?

7 MR. DIAZ-CASTILLO: Well, the oxygen, you  
8 know, system, just oxygen to the condensate water  
9 system also to help with suppression of corrosion and  
10 corrosion product relief, and the COL applicant will  
11 provide a description of the oxygen for stability.

12 Next, we have the zinc injection system,  
13 which is also an optional system. It would inject  
14 into the condensate water system to help with the  
15 reduction of corrosion films and radiation fields.

16 This decision to implement these systems  
17 also relies on the COL applicant.

18 And, last but not least, currently there  
19 are no open items for any of these systems.

20 MR. PARKS: My name is Benjamin Parks.  
21 I'm with the Office of Nuclear Reactor Regulation,  
22 Reactor Systems Branch, and I'm assisting NRO with the  
23 review of the standby liquid control system.

24 The staff reviewed it using guidance in  
25 SRP Section 9.3-5, and we reviewed it against the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 requirements of 10 CFR 5062, which is the requirements  
2 for reduction of risk from anticipated transients  
3 without scram.

4 I guess most notably about the ESBWR  
5 standby liquid control system design is that it is an  
6 accumulator-driven, largely passive system, and it  
7 does have direct injection to the core bypass.

8 Particular to the standby liquid control  
9 system review, and that is not -- it's performance  
10 during an ATWS scenario, the open items include system  
11 performance related ITAAC. We observed in DCD Revision  
12 3, not Revision 4, this review is based on Revision 3,  
13 that we had open items and we are interacting with GEH  
14 on what ITAAC would establish that the boron was being  
15 injected into the vessel acceptably.

16 And, the other open item we have was for  
17 leak detection and monitoring.

18 Now, by way update in Revision 4, I'm  
19 aware of significant improvements to the ITAAC and a  
20 lot of performance-related ITAAC have been added, that  
21 I have not yet had a chance to review. And, GE has  
22 also responded to our RAI on the detection and  
23 monitoring. They responded, I believe, on November  
24 9th, and we are still responding and providing  
25 feedback to that RAI response.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 MR. WALLIS: Are you concerned about  
2 injection of nitrogen into the system?

3 MR. PARKS: I am going to work from my  
4 memory, because this issue was raised about a year ago  
5 on the staff side. We were concerned about it.

6 I believe that in terms of the system's  
7 performance it would be more appropriate to discuss it  
8 during Chapter 15.

9 MR. WALLIS: All right.

10 MR. PARKS: I'm noting your concern, I  
11 will go back and look at our internal deliberations  
12 over it, and be able to provide you more at that time.

13 MR. WALLIS: Thank you.

14 MR. PARKS: I'm the ATWS reviewer, by the  
15 way, so it will be me.

16 MR. WALLIS: Okay.

17 CHAIRMAN CORRADINI: But, we are going to  
18 see you again.

19 MR. PARKS: If I can schedule a vacation.

20 MEMBER MAYNARD: I just saw one parameter  
21 on here that kind of got my attention. It's on the  
22 injection rate, and for the standby liquid control  
23 system. It says that the approximate average velocity  
24 for the first, basically, 20 feet of the injection is  
25 100 feet per second.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MR. PARKS: That's out of Table 9.3-5.

2 MEMBER MAYNARD: And, it just seemed  
3 pretty high to me.

4 MR. PARKS: That's from the DCD or the  
5 staff's SE.

6 MEMBER MAYNARD: No, that's on the DCD,  
7 this is.

8 MR. PARKS: We are reviewing performance  
9 parameters, that is not the injection velocity we  
10 assumed in our analyses. I think it was 100 feet per  
11 second is correct, 30 meters per second. The injection  
12 nozzle is clean, and we are talking about a pretty  
13 significant pressure difference.

14 So, we believe that that, I guess, is a  
15 realistic injection rate. These are really tiny  
16 nozzles.

17 MEMBER MAYNARD: Yes, but that's a long  
18 distance, 4 meters. I'm sorry, cubic meters.

19 MR. PARKS: That's also, it assumes  
20 initial -- when it comes to the system performance, I  
21 don't think that our own analyses assume that flow  
22 rate for the entire transient. I think that when we  
23 do steady state calculations, we assume significantly  
24 less than that.

25 MR. KRESS: How big is the injection line

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       itself, from the accumulator to the --

2               MR. PARKS: From the accumulator to the  
3 nozzle, I don't -- I believe that's the injection rate  
4 into the vessel, into the bypass.

5               MR. KRESS: Yes, well, how big is that  
6 line?

7               MR. PARKS: Off the top of my head, I  
8 can't remember.

9               Wayne?

10              MR. MARTINO: Wayne Martino.

11              I'm not exactly sure, but I think it's  
12 something like 30 meters, 100 feet distance.

13              MR. KRESS: And, I am still wanting the  
14 diameter.

15              MR. MARTINO: Oh, the diameter of the  
16 line?

17              MR. KRESS: Yes.

18              MR. KINSEY: Excuse me, this is Jim Kinsey  
19 from GE Hitachi. I pulled up the DCD and it's  
20 reflected as a 3-inch line, 80 millimeters.

21              MR. KRESS: Two-inch line?

22              MR. KINSEY: Three.

23              MR. KRESS: Three inch.

24              MEMBER MAYNARD: Also note in Rev 4, I  
25 think it's to biometric flow as opposed to --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. PARKS: Right, and I believe the  
2 performance requirements give a five-minute volume  
3 injection, and so we'll be reviewing that, which won't  
4 be that approximate average initial injection  
5 philosophy. It's really hard to assess.

6 MEMBER MAYNARD: I really don't think it  
7 needs anymore discussion.

8 MS. CUBBAGE: All right, we are going to  
9 swap out for Ed Forrest to come.

10 CHAIRMAN CORRADINI: So, excuse me, can we  
11 take a five-minute break?

12 Let's take five minutes.

13 (Whereupon, at 10:45 a.m., a recess until  
14 10:54 p.m.)

1 CHAIRMAN CORRADINI: Okay. We're back in  
2 the saddle. Okay. Sir?

3 MR. FORREST: I assume I can be heard  
4 okay?

5 CHAIRMAN CORRADINI: You're doing great.

6 MR. FORREST: My name is Ed Forrest. I'm  
7 a technical reviewer in the HVAC systems. I brought up  
8 to the table with me Syed Haider. He's relatively new  
9 to the agency, but he's made some significant  
10 contributions. And I thought I might need a bodyguard.

11 In any case, I'm glad to see I'm not the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 oldest guy in the room.

2 CHAIRMAN CORRADINI: Not a chance. We  
3 don't go to that point.

4 MR. FORREST: Yes. There are really just  
5 four basic issues I want to talk about two today. Two  
6 of them effect the control room and control room  
7 habitability. One of them is your favorite topic on  
8 the reactor building. And then it's all the other  
9 systems in general information.

10 I think John's question was great: How  
11 does the air get out? We've been wondering. And its  
12 effects.

13 What we look at was the adequacy of the  
14 emergency filter unit system itself. And it turns out  
15 that they changed from an air bottle system between  
16 Rev. 2 of the DCD to the emergency filter unit system  
17 in Rev. 3. And they used to size the air flow they  
18 used ASHRI 62 standard in 1980, 9 addition. I think  
19 they've even gone up to the 2000 or so edition in the  
20 Rev. 4.

21 And the staff looked at this standard and  
22 we pretty much concurred that the level of air flow  
23 was supported by the standard. But then when we got to  
24 looking at the standard, we realized that the standard  
25 was designed on a well ventilated system in which the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 outside air entered the recirculation, the section of  
2 the recirculation air handler and was distributed  
3 throughout the volume. And that there was an exit  
4 point or an outside air out take from the standard.

5 So we begin to wonder what the impact of  
6 not having the recirculation portion of the system  
7 available, the recirculation AHU. And in fact and  
8 under emergency conditions, the recirculation AHU is  
9 shut down.

10 So we thought we started looking at it,  
11 and we realized that the 424 cfm that's coming from  
12 the outside is unconditioned air, could be 117  
13 degrees, could be 40 degree minus, negative, coming  
14 into the control room. And that this air comes into  
15 the recirculation plenum, the suction plenum for the  
16 recirculation fan. And there's no recirculation fan  
17 going. So this plenum, in effect, becomes the  
18 distribution plenum for the EFU flow throughout the  
19 control room.

20 The plenum was sized for 11,000 cfm  
21 recirculation. We're putting in 424 cfm. Maybe only  
22 the first few registers see the flow, other effects  
23 can take place. A high temperature input may stratify  
24 up in the recirculation plenum. May not get  
25 distributed very well. Cold temperatures might really

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1       come through a lot faster. There's effect we don't  
2       know.

3               The concern we have is does the fresh air  
4       get to the operator's face. Does the carbon dioxide  
5       that the operator and the bio-effluents to the  
6       operator is breathing out get cleared out, go out the  
7       room. And we've asked GE to address this. And we're  
8       hoping and anticipating that they'll also tell us how  
9       the air gets out. Because there's no defined flow  
10      path through the control room at this time. The basic  
11      perception was they counting on seals in the doors as  
12      a leak-through type thing. We think that if those  
13      seals are leaking at 424 cfm then we have another  
14      problem that would have to be pursued. I don't think  
15      they'll the tracer gas.

16             But in any case, we are interested in  
17      John's question, you know, how does the air get out  
18      and how pressure is controlled in that room also.  
19      Because we don't want to get a situation where the fan  
20      backs up because pressure is building up in the room.  
21      And then we don't get the air supply that we need. We  
22      don't want to get a situation where the pressure  
23      builds up in a room and we can't open the door. So  
24      we'd like to have more information on that.

25             Carbon dioxide levels, there is a point

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 somewhere where if carbon dioxide levels reach that  
2 point, and it's not just carbon dioxide, it's bio-  
3 effluents, operator performance can be degraded, can  
4 cause confusion, can cause other issues.

5 We want GE to address the carbon dioxide  
6 buildup issue and give us the benefit of their  
7 thoughts on this. We think if there's no distribution  
8 in mixing within the control room, the levels could be  
9 much higher and maybe approach some level where it was  
10 uncomfortable or counter-productive for the operators.

11 DR. WALLIS: At 424 cubic feet per minute  
12 this is still a problem?

13 MR. FORREST: It's 434 cubic feet per  
14 minute of air coming through the EFU unit. Is that  
15 your question?

16 DR. WALLIS: I just can't imagine that  
17 carbon dioxide buildup would be a problem.

18 MEMBER STETKAR: No. That's what the  
19 design to supply.

20 MR. FORREST: I think the question is  
21 where does the problem occur. The chances of it  
22 exceeding something like an OSHA limit, which might be  
23 up at 5,000 parts per million, that might be small.  
24 It's the chances of it exceeding what ASHRI 62 calls  
25 a comfort limit, which is down around 1,000 ppm per

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 minute. That could be much higher. It's a question  
2 of it needs to be looked at and addressed by GE.

3 DR. WALLIS: Okay.

4 MR. FORREST: The second issue is the  
5 favorite control room habitability issue, the passive  
6 heat sink. We have a number of concerns about the use  
7 of the passive heat sink. Although the control room is  
8 below grade, there are passageways all around the  
9 walls of the control room of the control room  
10 habitability area. So there's conditioned space, and  
11 I think there's also conditioned space below the  
12 control room habitability area. And that sets the  
13 outside temperature of the concrete walls of the heat  
14 sink.

15 The inside walls are taken to be at 78  
16 degree, the maximum design temperature of the control  
17 room.

18 There's a question about area of heat  
19 transfer. If you have a false ceiling plenum above,  
20 this becomes a barrier to heat transfer and prevents  
21 or retards heat flowing through the ceiling.

22 If you have a supply plenum on the floor,  
23 which is the current design, then that too is also a  
24 barrier to heat transfer leaving thing.

25 If an operator hangs a poster on the wall,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 a set of drawings or maps, these become barriers.

2 So there's a question of what really  
3 constitutes the massive concrete and what its  
4 temperatures are on both sides that would be used for  
5 the removal of heat in a heat sink.

6 There's also a question of heat loads.  
7 The 7300 watts that was mentioned earlier is taken to  
8 be the electrical equipment and lighting type loads.  
9 It does not consider the loads coming in through HVAC  
10 system, 424 cfm at 117 degrees, 80 percent relative  
11 humidity -- not relative humidity. Eighty percent wet  
12 bulb coincident, it's about 20 percent relative  
13 humidity is the design number which was currently, I  
14 believe, in DCD 4. That has a substantial heat  
15 content.

16 But if you also look at their 88 degree  
17 wet bulb temperature, which they look at, which could  
18 be 100 relative humidity, the heat content is much  
19 higher.

20 If it comes in at 88 degrees, it's going  
21 to start condensing on the concrete walls. It's going  
22 to effect the heat transfer.

23 So we're concerned about getting a clear  
24 analysis of how the heat content of the air coming  
25 into the room is being accounted for n the heat

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 removal.

2 We also have the concern about cold  
3 temperature. Because if you've got minus 40 degree  
4 air coming in to that control room at 424 cfm, the  
5 parkas will be broken out very early and people will  
6 be in gloves. And there is no real source of heat,  
7 and particularly if you're counting on 7300 watts.

8 So GE has stated to us at least in a phone  
9 call that they are going to re-evaluate both ends of  
10 the thing in terms of temperature.

11 You have personnel heat loads.

12 We believe that a comprehensive heat  
13 transfer analyses must be performed, and probably  
14 should be summarized within the DCD in a tabular type  
15 form maybe of what the assumptions were and what the  
16 conclusions reached by the analyses is. And the  
17 analyses should certainly be made available to us.

18 So we're concerned about the temperature  
19 versus time in terms of the heat up of the room. The  
20 heat of the room off of equipment and off of the HVAC  
21 might be much faster than the concrete can absorb the  
22 heat. Even though the concrete may have the capacity,  
23 it's just the rate of heat transfer is much slower in  
24 the concrete than it would be from convective into  
25 air.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1                   So we're interested in GE giving us a kind  
2 of a perception of temperature versus time for the  
3 first 72 hours.

4                   MEMBER ABDEL-KHALIK: Now we were told  
5 that a detailed analyses has already been done. So  
6 that analyses was not made available to you to review?

7                   CHAIRMAN CORRADINI: I want to turn to GE  
8 about that. I thought you said you committed to a  
9 GOTHIC analysis. But is one already done?

10                  MR. UPTON: There was at GE.

11                  MR. MARTINO: There is a detailed analysis  
12 of the control room habitability area heat up that has  
13 been completed. And when we get questions from the  
14 staff we respond based on that analysis.

15                  CHAIRMAN CORRADINI: It's part of the EQ--  
16 okay. I'm sorry.

17                  MR. MARTINO: We plan to do a more  
18 detailed analysis as part of the EQ post-certification  
19 work.

20                  MR. UPTON: One more comment. The initial  
21 analysis that we did on control room heat up, it was  
22 using a staff approved code. I think it's called the  
23 Habitability -- CONTAIN. The CONTAIN code. So it  
24 was based on those results that the DCD was written.  
25 And we have committed to do detailed analysis in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 future as we get our heat loads.

2 MR. FORREST: One of the other  
3 considerations is margins and any heat transfer  
4 assessment of this nature. There's enough uncertainty  
5 that's substantial margins should be in place to cover  
6 these uncertainties, particularly since in the real  
7 life if it happened, you just can't throw up doors.  
8 There's not much you can do. So we believe that  
9 margins should be identified.

10 GE has said they're using a 15 percent  
11 margin on heat loads. We believe that's the 7300 watt  
12 number plus maybe the personnel heat loads. But it's  
13 not really taking on what might be the major heat  
14 load, the HVAC system input into the room.

15 Surveillance requirements. If you're  
16 really concerned about the control room concrete  
17 structures being available to absorb heat, you've to  
18 assure that it falls within the temperature ranges  
19 that you used within your analysis. And this would  
20 require surveillances on both surfaces of the heat  
21 transfer, and not at 2:00 a.m. in the morning when  
22 it's nice and cool, but at reasonable representative  
23 times so that you know that you're maintaining your  
24 conditions.

25 MEMBER ABDEL-KHALIK: The entire control

1 room is below grade, is that correct?

2 MR. FORREST: The entire control is below  
3 grade. I think the ceiling of the control room is  
4 just about grade level.

5 MEMBER ABDEL-KHALIK: Now the outer  
6 surface of the walls of the control room is that in  
7 direct contact with the outside world?

8 MR. FORREST: No, no. The outer surfaces  
9 of the control room habitability area are located  
10 within the control building structure. And there's  
11 passage ways and equipment rooms, I believe, below.  
12 And these are conditioned areas of the control  
13 building which lose their conditioning upon a design  
14 bases accidents. So as these rooms heat up, you could  
15 get a situation where the temperature on the outside  
16 wall of the concrete was higher than the inside wall  
17 of the concrete. And it would be a heat source instead  
18 of a heat sink.

19 MEMBER ABDEL-KHALIK: Right.

20 MR. FORREST: And that is a concern that  
21 the staff has. And that is why surveillance needs  
22 to--

23 MEMBER ARMIJO: But were these kinds of  
24 issues addressed in your CONTAIN analyses, you know,  
25 adjacent rooms and equipment and heating up? Was it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 that level of detail?

2 MR. UPTON: It was the configuration of the  
3 control building that we currently have, yes.

4 This is Hugh Upton, by the way, with GEH.

5 I want to make one correction here. It is  
6 true that the control room envelop has corridors so it  
7 is not in direct contact with exterior building walls.  
8 However, there is one wall that is in direct contact  
9 with that within the control room habitability  
10 envelop. But the configuration that we currently have  
11 in the GAS is the one that was analyzed by the CONTAIN  
12 code.

13 CHAIRMAN CORRADINI: Let's move on.

14 MR. FORREST: Okay. I want to move on to  
15 the next one. I know we're all interested in the  
16 reactor building and the reactor building HVAC system.

17 The reactor building HVAC system isolates  
18 upon the initiation of an accident, LOCA with a loop  
19 shutdown. There is no HVAC system going at this  
20 particular down.

21 The reason they do that is stated in their  
22 DCD is they want to control the release of  
23 radioactivity to the environment. But quite frankly,  
24 there's no controls on the release of radioactivity in  
25 the environment. Unlike conventional plants, the ESBWR

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 does not treat its reactor building as a containment.  
2 There's no standby gas treatment system safety related  
3 that draws it down. There's no filtering of the air  
4 that would be released by a standby gas treatment  
5 system. There is no monitoring of any of the releases  
6 leaving the reactor building.

7 Now they do have a contaminated air  
8 ventilation system which does have filters, which  
9 could operate at around 10,000 cfm, which is a fairly  
10 substantial rate. But this system is shutdown upon  
11 accident and not credited for accident mitigation  
12 whatsoever.

13 So with air in the reactor building  
14 containing possibly some degree of primary containment  
15 leakage to  $L_A$ , this is free to leak out of the reactor  
16 building through any crack, crevice. There is no real  
17 driving force for it other than meteorological  
18 conditions on the outside which can create some  
19 differential pressures. But still, there is nothing  
20 to contain it.

21 In order to meet the requirements of a  
22 design bases analysis, some reduction in the potential  
23 source would have to be made. And GE has assumed that  
24 there would be a 40 percent mixing of the primary  
25 containment leakage  $L_A$  with the reactor building air

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 prior to its exit from the building. The basis for  
2 this mixing is not clear. We've asked some questions  
3 to get a better handle on it.

4 Typical staff perception is to credit for  
5 mixing is not granted unless there's a mechanical or  
6 physical means that promotes it or some clear  
7 analytical basis for doing it. Forty percent mixing  
8 is a fairly high degree of mixing.

9 As far as releases, the design bases  
10 release for this building is 50 percent of the air by  
11 mass per day. Around 733 cfm is my calculation. An  
12 awful lot will not leak at that rate. But with a high  
13 design bases leakage like that, it doesn't require  
14 much maintenance on seals or maintaining tightness of  
15 the building. And this is one area that we've asked  
16 them --

17 DR. WALLIS: This is a release at what  
18 wind velocity outside?

19 CHAIRMAN CORRADINI: This is not  
20 containment now. This is the building outside of  
21 containment.

22 DR. WALLIS: I know that. I heard that.  
23 But I mean if it's a leaky building and there's a wind  
24 blowing, then the end blows through the building.

25 MR. FORREST: That's correct. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1       whatever is drawn out, comes in from some other side.  
2       So there's air exchange. We don't have a number for  
3       leakage under the worst wind condition of any  
4       particular area or any assumptions from GE as to what  
5       that wind condition would be.

6               What we have is a design bases saying it  
7       will be no greater than 50 percent of the air per day  
8       on a mass basis.

9               So we've asked how they intend to  
10      demonstrate it. And they have through an RAI how they  
11      intend to test it. In a conventional system we would  
12      draw it down and hold it at a negative pressure for a  
13      period of time and show that the pressure can be  
14      maintained at some desired flow rate.

15              Here it appears they're looking at some  
16      type of pressure test from the outside. And using the  
17      parameters on the fan curve, certified fan curve to  
18      assess the pressure in the building. And we have some  
19      concerns and we will be addressing these with GE in  
20      further communications.

21              But those are the three major things. Oh,  
22      one other thing is because they do not consider the  
23      reactor building and containment, they have made the  
24      statement in the DCD that GDC-16 does not apply. GDC-  
25      16 is what gives you control over releases to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 environment.

2 We think that GE needs to provide more  
3 information on how they intend to control releases to  
4 the environment. How they intend to monitor them, you  
5 know. And we would direct them to maybe consider such  
6 things as GDC-60 or GDC-64. Sixty has something about  
7 controlling the effluents to the environment, 64 is a  
8 monitoring type thing.

9 CHAIRMAN CORRADINI: This is just a  
10 clarification to make sure I understand. But there's  
11 nothing that requires them to have the containment  
12 building be a barrier.

13 MR. FORREST: Sure.

14 CHAIRMAN CORRADINI: Why would GD -- I've  
15 got all the numbers mixed up in my head. The first  
16 GDC you mentioned, it wouldn't apply, would it, since  
17 it's not the containment boundary?

18 MR. FORREST: It's an SRP guidance to use  
19 GDC-16. If GE chooses to go against an SRP guidance,  
20 they have to provide a means that is acceptable to the  
21 staff that provides an equivalent level of assurance  
22 that they're not creating a more difficult safety  
23 issue. And we're looking at that equivalent level of  
24 assurance. And we could certainly consider the GDCs as  
25 part of that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: Okay. Thank you.

2 I just wanted to make sure that they're  
3 not being held to a different standard relevant to  
4 current operation BWRs for a containment building.  
5 That's all I guess I'm trying to ascertain.

6 MR. FORREST: No. I don't think they're  
7 being held to a different standard. I think they have  
8 to do the same thing a current vintage plant would do,  
9 is if they do not accept GDC in some fashion, they  
10 have to explain why, what they propose is adequate.

11 CHAIRMAN CORRADINI: Okay.

12 MR. FORREST: The last thing is just all  
13 the other system together, lumped together. And I  
14 believe it's Chapter 19 these are listed as RTNSS  
15 systems.

16 And we have concern about the equipment  
17 that are in these buildings that may have temperature  
18 problems with the -- during a post-accident type  
19 thing, may require cooling for both 72 hours and for  
20 post-72 hours. And we're looking for information from  
21 GE that will say here's the systems that have to work  
22 in order to maintain specific components. And that we  
23 then in turn will be in a position to review the  
24 temperature rise and adequacy of the HVAC within those  
25 systems. Right now we lack information.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Thank you very much.

2 CHAIRMAN CORRADINI: Thank you very much.

3 MS. CUBBAGE: This is the last topic, fire  
4 protection.

5 CHAIRMAN CORRADINI: Good.

6 MR. FORREST: I'm going to take my  
7 bodyguard with me.

8 MR. RADLINSKI: Good morning. My name is  
9 Bob Radlinski. I'm the fire protection team leader.  
10 And I was also the technical reviewer for the ESBWR  
11 DCD.

12 I've got five slides. The first three are  
13 just going to give a high level, a very high level  
14 summary of the ESBWR fire protection program, open  
15 items and COL action items. The last two slides are  
16 going to address Mr. Maynard's concerns that were  
17 forwarded to us.

18 Generally speaking the ESBWR design  
19 includes a deterministic fire protection program which  
20 meets the intent of the so called enhanced fire  
21 protection criteria that were put forth in several  
22 SECYs.

23 For those of you who are not familiar with  
24 the enhanced fire protection, one key feature of that  
25 is that in the analyses for post-fire safe shutdown

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 you assume that everything in a particular fire area  
2 or any fire area is destroyed by the fire and also  
3 that there's no access into that fire area to take any  
4 mitigating actions.

5 The system also provides a backup function  
6 which is seismic category 1, but not safety related,  
7 to provide a source of makeup water following a design  
8 bases accident. And those aspects of the system are  
9 treated under the RTNSS program.

10 Like all new reactors and particularly the  
11 ESBWR there are a number of plant features that  
12 reduce --

13 MEMBER BLEY: I'm sorry. Can I ask a  
14 question.

15 MR. RADLINSKI: Sure.

16 MEMBER BLEY: When you assume that  
17 everything fails in that room do you assume it all  
18 fails at the same time or do you assume fails in the  
19 worst possible sequence, or something else? Or do  
20 you think about that?

21 MR. RADLINSKI: It would be the worst  
22 possible sequence.

23 MEMBER BLEY: Would it really?

24 MR. RADLINSKI: But -- well, there's  
25 still an open item with regards to spurious actuations

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER BLEY: Okay.

2 MR. RADLINSKI: So that would probably  
3 fall out of that discussion.

4 MEMBER BLEY: Okay. Thanks.

5 MR. RADLINSKI: As I was saying, the new  
6 reactors those of you who have been in fire protection  
7 for existing reactors, you really have to change your  
8 way of thinking because it's a whole new ballgame for  
9 new reactors. The systems are designed from the ground  
10 up by committing to this enhanced fire protection  
11 criteria, for the part redundant divisions are being  
12 separated by three hour physical barriers. Not 20  
13 feet of separation, but that's physical barriers  
14 wherever that's feasible. It's not feasible in  
15 containment. It's not feasible in the control room.  
16 But everywhere else in the plant in general we have  
17 three hour barrier protection between redundant  
18 divisions. For the ESBWR in particular you have an  
19 inerted containment during operation, which would not  
20 support a fire. You no longer reactor cooling pump.  
21 lube oil systems which were a significant hazard. You  
22 have minimal equipment for the passive system.  
23 Liberal use of fiberoptic cabling as opposed to copper  
24 conductors. And also digital control system.

25 All those together significantly reduce

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the risk associated with fire in the new reactor  
2 plants.

3 A couple of exceptions that the ESBWR has  
4 taken, and this is in regards to the guidance that is  
5 provided in one Reg. Guide 1.189 have to do with the  
6 main control room complex, and also safety related  
7 computer rules where they've reduced the level of fire  
8 protection recommended in that guidance. And that's  
9 primarily based on, again, the reduced the fire  
10 hazard, reduced fire load, combustible loading in  
11 those areas.

12 And the second exception is that the  
13 diesel generators, which in this case are nonsafety  
14 related, are not designed to continue operating in the  
15 event of a suppression discharge over the diesels.

16 I'd also like to point out, too, that both  
17 the AP1000 DCD and the ABWR DCD took exactly the same  
18 exceptions to the guidance for the main control room.  
19 And they were accepted for both of those plants. So we  
20 will be accepting those for the ESBWR as well.

21 Any comments about performance based fire  
22 protection.

23 MEMBER SIEBER: A question about diesels.  
24 If the diesel is non-safety related the fire  
25 protection requirements should not be as severe as,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 for example, a diesel in a current plant. Is that  
2 correct?

3 MR. RADLINSKI: Correct. That's why we're  
4 accepting it. We have no problem accepting it.

5 MEMBER SIEBER: Okay. Thanks.

6 MR. RADLINSKI: Okay. Next slide. Just  
7 roughly going over the significant open items,  
8 significant is kind of a relative term. We don't  
9 consider them to be deal breakers. We have some  
10 differences with GEH that we're still negotiating with  
11 them with regards to certain specific COL action items  
12 that we feel should be identified.

13 With regard to the post-fire safe shutdown  
14 circuit analysis, which they have not done yet and  
15 they mentioned in the DCD that they are not able to do  
16 that analyses until they've completed the design of  
17 the DCD system.

18 And also we're not quite in agreement with  
19 what constitutes a final fire hazard analysis for the  
20 plant.

21 We've also asked for their approach for  
22 identifying and evaluating multiple spurious  
23 actuations. They've not identified any specific areas  
24 where there's a potential for that. But as many of you  
25 know who have been involved in existing plants,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 multiple spurious actuations during a fire situation  
2 isn't an open issue, ongoing issue. It's not been  
3 resolved yet for existing reactors. And we intend to  
4 follow whatever resolution they have for existing  
5 reactors for new reactors.

6 Yes.

7 MEMBER STETKAR: Did I hear you say they  
8 had not identified any locations where multiple  
9 spurious actuations are possible? Because it would  
10 seem like DCIS cabinet rooms are locations where they  
11 could be possible.

12 MR. RADLINSKI: The only mention of  
13 multiple spurious is that they said they took them  
14 into consideration in the analyses of the control room  
15 fire. Okay?

16 MEMBER STETKAR: Control room fire?

17 MR. RADLINSKI: Right. But there's no  
18 specific identification for this system in this fire  
19 area you could have these spurious actuations.

20 MEMBER STETKAR: Right.

21 MR. RADLINSKI: And this is how we address  
22 those. This is how we mitigate them. There's none of  
23 that.

24 MEMBER STETKAR: But in the RAIs did they  
25 come back and say there were no locations where

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 multiple spurious actuations were possible?

2 MR. RADLINSKI: We're still waiting. We're  
3 waiting for a response.

4 MEMBER STETKAR: Okay. I guess I  
5 misinterpreted what you said.

6 MR. RADLINSKI: Okay. And kind of going  
7 along with that with the multiple spurious because  
8 typically if you have a multiple spurious, you have  
9 operator manual actions that you would use to mitigate  
10 that. We're looking to coming to some sort of  
11 agreement on how they identify operator manual actions  
12 and how they deal with the. And again, they haven't  
13 identified any in particular, although there is one  
14 that's sort of questionable.

15 CHAIRMAN CORRADINI: If that's the one for  
16 the 100 degree cool down, it's probably a separate  
17 topic. Is that the one you mentioned?

18 MR. RADLINSKI: I believe it is, yes. If  
19 they have to go to the remote shutdown panel, they say  
20 they may have to take operator manual action. I assume  
21 it's at the panel.

22 CHAIRMAN CORRADINI: This is probably a  
23 more generic issue and you're going to probably tell  
24 me it's in Chapter 15.

25 MEMBER STETKAR: It is. Go ahead.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: With that I'll be  
2 quiet. Go ahead, John.

3 MEMBER STETKAR: The question I had is  
4 that if operator mitigation is required or there's  
5 credit taken for it to control the cool down rate, and  
6 I don't care whether it's in the remote shutdown area  
7 or the main control room after a fire, then it would  
8 seem that actuation of the isolation condensers could  
9 give you a faster than 100 degree cool down rate under  
10 any kind of transient condition.

11 MS. CUBBAGE: Right. My understanding on  
12 that is that they have the capability and would like  
13 to do that, but we would not be required to do that  
14 for safety. But we are trying to get that clarified  
15 with GE.

16 MEMBER STETKAR: Well, the question is can  
17 the isolation condensers if all four of them are --

18 MS. CUBBAGE: Yes.

19 MEMBER STETKAR: -- actuated, give you  
20 faster -- hands off, give you faster than 100 degree  
21 per hour cool down rate?

22 MS. CUBBAGE: Yes. The answer to that is  
23 yes.

24 MEMBER STETKAR: They can?

25 MS. CUBBAGE: But I believe it would not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 be an immediate safety issue. I believe the plant is  
2 designed to accommodate, I don't know how many times  
3 they can accommodate it. But GE could respond to  
4 that.

5 MEMBER STETKAR: Right.

6 MS. CUBBAGE: I think they're nodding yes.

7 MR. UPTON: This is Hugh Upton with GEH.

8 Yes, the RPV is designed for a certain  
9 number of thermal cycles in which we cool down with  
10 the ICs operating at their max capacity without  
11 operator intervention.

12 MEMBER STETKAR: But do you know what the  
13 cool down rate is for that?

14 MR. UPTON: I do not know what that is off  
15 the top of my head.

16 MEMBER STETKAR: Okay.

17 MR. RADLINSKI: And if the operator manual  
18 action is at the remote shutdown panel, then it is  
19 perfectly acceptable from a fire protection criteria  
20 standpoint. What we're concerned about is they have  
21 to go somewhere else in the plant to perform some  
22 other operation, than we want to know what the  
23 criteria will be for that.

24 The third slide, it's a list of the COL  
25 action items. I don't know if one of you --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. UPTON: Excuse me. Let me make one more  
2 comment.

3 This is Hugh Upton with GEH.

4 Your concern about the ICs, it's also  
5 bounded by the depressurization from the DPVs at ATWS,  
6 the ADS system, rather. That would bound the decrease  
7 in the RPV. Yes.

8 MS. CUBBAGE: Right. An inadvertent  
9 isolation condenser action, which is a Chapter 15  
10 event.

11 MEMBER STETKAR: It's a single one. WE've  
12 had this discussion before. But it's a single one.  
13 This is all four.

14 MS. CUBBAGE: I think we do all four as an  
15 infrequent event rather than a -- the COL items, I  
16 think.

17 MR. RADLINSKI: I would like to mention  
18 one. For the most part, the COL action items are site  
19 specific fireprotection issues.

20 If you go down to the fifth bullet,  
21 proposed license condition. Again, those of you who  
22 are familiar with existing plants, there's a standard  
23 fire protection license condition that talks about you  
24 can make changes to your plant, you can self approve  
25 as long as there is no adverse effect on safe

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 shutdown.

2 We want to go back. We want to get rid of  
3 that. We want to go back to 5059 approach to make it  
4 consistent with the rest of the plant. And that  
5 guidance was in Revision 1 of Reg. Guide 1.189. So I  
6 just wanted to bring that to the attention of GE that  
7 that's what we're looking for; we're looking for 5059-  
8 like approach.

9 MEMBER SIEBER: Now you said the analysis  
10 met the fire protection, are deterministic and not  
11 NFPA-805?

12 MR. RADLINSKI: That's correct. 805 right  
13 now, I mean it's by letter. This certainly only  
14 applies to existing plants. They could not apply it.

15 MEMBER SIEBER: Right.

16 MR. RADLINSKI: Yes. And, again, you were  
17 not here, but right now there is no guidance for a  
18 performance-based fire protection program for a new  
19 reactor. Okay. There's an inter PA standard 806 in  
20 preparation, but that's a long way off.

21 DR. WALLIS: It's a bit strange. It's been  
22 put in for existing plants because it's a good thing,  
23 presumably. And it's not going to be put in future  
24 plants? It seems a bit odd, somehow.

25 MR. RADLINSKI: Well, one of the problems

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is the enhanced fire protection criteria from these  
2 SECYs is a deterministic approach. It says you will  
3 separate all your redundant trains. And that's, you  
4 know, what percent; it's 80/90 percent of your fire  
5 protection right there. If you've got that passive  
6 protection --

7 DR. WALLIS: So you don't need the other?

8 MR. RADLINSKI: So you don't need the  
9 performance-based approach. In fact, none of the  
10 licensees, and I've questioned this with NEI and some  
11 of the licensees, they're not interested in having it  
12 at least for the original design. Okay.

13 If they were going to express an interest,  
14 it would be later on once the plant is designed or at  
15 least under construction. And it would be a mechanism  
16 for making self-approving changes. Okay. But the  
17 original change, there's really -- there hasn't been  
18 any interest that we're aware of.

19 Okay. The next two slides are going to  
20 attempt to address Mr. Maynard's questions, concerns.

21 Post-fire safe shutdown of the ESBWR does  
22 not require AC power. They've done analyses that says  
23 if you lose off-site power, we can still shut the  
24 plant down.

25 Shutdown is primarily achieved with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 isolation condenser system, which again, does not  
2 require AC power.

3 And their post-fire safe shutdown analyses  
4 assumes one train fails due to the fire. They  
5 demonstrate the system can still perform its function  
6 if one train failed in that one fire area that's  
7 completely burned up. Okay.

8 You asked questions about firefighting.  
9 Again, safe shutdown post-fire does not rely on  
10 firefighting. Okay. If for some reason the fire  
11 brigade can't respond, doesn't respond, they can't get  
12 in there and put the fire out, the analyses  
13 demonstrates that you can still safely shut the plant  
14 down without that one level of defense-in-depth.  
15 Okay. But it's not required necessarily.

16 MEMBER SIEBER: Same as for existing  
17 plants, right?

18 MR. RADLINSKI: Yes. Absolutely.

19 MEMBER SIEBER: There's no change.

20 MR. RADLINSKI: All your fire protection  
21 detection systems, suppression systems are all based  
22 on DC power, they all have battery. So they don't  
23 rely on AC.

24 Lightening, there are battery powered  
25 fixed lights for access/egress routes. They're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 portable battery powered lights for the fire brigade  
2 to use during fire fighting.

3 And finally, the fire hazard analyses  
4 evaluates access for manual firefighting for each fire  
5 area. And I was hoping that GE was going to say  
6 something about the security aspects of it. But  
7 presumably that would be a consideration in the fire  
8 hazard analysis when you look at access in responding  
9 to a fire whether or not you have to go find a key or  
10 something or a card key or whatever to get through the  
11 door.

12 So ideally the worst case fire is a  
13 control room fire. And in that situation you would  
14 have to go to remove shutdown panel, and there  
15 probably aren't any doors, security doors that you  
16 have to go through to get from the control to the  
17 remote shutdown panel.

18 MEMBER STETKAR: Let me just interject  
19 something from having done a lot of this space fire  
20 analyses.

21 Probably the worst fire location is the  
22 DCIS rooms in the rector building. Just -- I'll just  
23 throw that out.

24 MR. RADLINSKI: Okay.

25 DR. WALLIS: Is there going to be a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 discussion at some point about external fires of --

2 MR. RADLINSKI: Transportation --

3 CHAIRMAN CORRADINI: You're talking  
4 external from outside the plant, aren't you?

5 DR. WALLIS: A large fire induced by some  
6 cause outside the --

7 MR. RADLINSKI: Like a transformer fire  
8 or--

9 MEMBER SIEBER: No, bigger than that.

10 MR. RADLINSKI: External event.

11 MS. CUBBAGE: As far as the PRA, they look  
12 at external events. We may be getting into some of  
13 that with Chapter 13 discussion.

14 DR. WALLIS: What happens to the control  
15 room when there's a big external fire?

16 MS. CUBBAGE: Okay. We'll talk about that  
17 this afternoon.

18 CHAIRMAN CORRADINI: That's been brought  
19 up by Dana under Chapter 2 about control room  
20 habitability from outside events interjecting their  
21 influence on --

22 MEMBER ARMIJO: Okay. So we've already  
23 got that.

24 CHAIRMAN CORRADINI: We've already labeled  
25 it as something to worry about.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER ARMIJO: Okay.

2 MR. RADLINSKI: That's it.

3 MS. CUBBAGE: And that basically concludes  
4 our presentation.

5 CHAIRMAN CORRADINI: Done? You get the  
6 last question.

7 MEMBER STETKAR: One last one. This isn't  
8 even a question. Well, it is kind of.

9 In section 9.5.33 emergency lighting,  
10 something that nobody looks at, you had an RAI 9.5-60  
11 that asked for justification for the emergency  
12 lighting supplies in the remote shutdown areas. And  
13 apparently in the SER it's on -- if you're looking in  
14 the SER, Amy, it's--

15 MS. CUBBAGE: No. It at 9.5-61, is that  
16 where you're talking.

17 MEMBER STETKAR: Yes. It's RAI 9.5-60.  
18 Six-zero.

19 MS. CUBBAGE: Sixty.

20 MEMBER STETKAR: In the SER it says the  
21 applicant -- let me see if I can summarize this.

22 MS. CUBBAGE: I can read it here.

23 MEMBER STETKAR: The applicant basically  
24 said that in the remote shutdown area there's an eight  
25 hour battery powered emergency lighting and you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 basically accepted that. Why shouldn't we supply 72  
2 hour emergency lighting in the remote shutdown area  
3 where the operators may need to spend 72 hours?

4 MS. CUBBAGE: We're going to ask Amar Pal  
5 to come up.

6 MEMBER MAYNARD: Why would they need to  
7 spend 72 hours in remote shutdown?

8 MR. PAL: This is Amar Pal, NOR

9 I reviewed just that issue. And they said  
10 they are going to have eight hour battery pack. So if  
11 the battery pack all the time for eight hours. IF the  
12 fire doesn't occurring, whenever the fire occurs then  
13 you're going to AC power. So you going to lose all  
14 the normal lighting. So that way I think if they are  
15 okay, probably loss of off-site power or loss of AC  
16 power, then the battery pack comes in to the picture  
17 and you'll have enough lights for entire eight hour  
18 duration.

19 CHAIRMAN CORRADINI: But I think his  
20 question is why is it --

21 MEMBER STETKAR: Why is not 72 hours?  
22 They supply 72 hour emergency lighting for several  
23 DCIS cabinet areas, which aren't normally habited by  
24 human beings who have to see things. But they don't  
25 supply 72 hours for places that could be occupied by

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 human beings who have to see things.

2 MR. PAL: The 72 hour lighting is provided  
3 for in the control room.

4 MEMBER STETKAR: That's right.

5 MR. PAL: That's all. And nowhere else.

6 MEMBER STETKAR: And in some apparently  
7 some remote DCIS cabinet rooms, but not -- I'm just  
8 hung up on this because the only two places that  
9 people live in this plant are the main control room or  
10 the remote shutdown areas.

11 MR. UPTON: Let me try and address that.  
12 This is Hugh Upton with GEH.

13 The remote shutdown panel, again, is there  
14 for emergency shutdown of the plant. We're not going  
15 to be in the remote shutdown panel for 72 hours.

16 In other words, it's not going to take 72  
17 hours to place the plant in a stable condition from  
18 the remote shutdown panel.

19 MEMBER STETKAR: If the main control room  
20 is not habitable, if the main control room burns  
21 up, it's a charred mass --

22 MR. UPTON: Right. Then you go to the  
23 remote shutdown panel and you begin an orderly  
24 shutdown of the plant.

25 MEMBER STETKAR: And monitor from where?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Monitor plant conditions from where? Remote shutdown  
2 panels?

3 Where do the operators go if they must --  
4 take an extreme case where the main control room is a  
5 charred mess and the operators must now -- now the  
6 automatic shutdown system should work, the operators  
7 now relocate to the remote shutdown areas and must  
8 monitor plant status.

9 MR. TUCKER: This is Larry Tucker of GEH.  
10 We need to understand a little bit better  
11 where you're coming from.

12 When there is an event and you need to  
13 shut the plant down, the plant shuts down very  
14 quickly.

15 MEMBER STETKAR: I understand.

16 MR. TUCKER: And it goes to a stable  
17 condition.

18 MEMBER STETKAR: Understand.

19 MR. TUCKER: And in general there is no  
20 credited operator actions for the next 72 hours from  
21 the onset of the event. So the operator --

22 CHAIRMAN CORRADINI: But John's question  
23 is simply the operators will probably want to  
24 understand plants, what's going on --

25 MEMBER STETKAR: What status?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Where do they go to  
2 do that if the control room is unavailable.

3 DR. WALLIS: Can they see what's there?

4 CHAIRMAN CORRADINI: Why don't --

5 MR. TUCKER: I believe we're beyond the  
6 design requirements here.

7 MEMBER STETKAR: The main control room is  
8 a charred mass. And the plant shuts down  
9 automatically and the operators relocate to the remote  
10 shutdown areas.

11 MR. TUCKER: So we're assuming that  
12 there's a loss of off-site power and a fire in the  
13 control room and --

14 MEMBER STETKAR: No, no, no. I said the  
15 main control room is a charred mess. I didn't assume  
16 anything else.

17 MR. TUCKER: Then --

18 MR. UPTON: But the only time that you  
19 would require emergency lighting for eight hours is if  
20 you lost AC power.

21 MEMBER STETKAR: Yes.

22 MR. UPTON: So we're beyond --

23 MR. TUCKER: So we're well beyond what's  
24 required.

25 MR. UPTON: -- our design basis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Because all of the off-  
2 site power controls are in the main control room. You  
3 can loss it from a fire in the main control room?

4 MR. TUCKER: Yes. So that was why I was  
5 asking what was our entry condition into your  
6 question?

7 MEMBER STETKAR: Loss of all AC power,  
8 main control room uninhabitable; period.

9 MR. TUCKER: But you --

10 MEMBER STETKAR: My only concern is why  
11 does it not --

12 MR. TUCKER: -- the safety function is to  
13 shut -- safely shut the plant down and the plant is  
14 safely shut down and it's maintained.

15 MEMBER STETKAR: Why do you supply 72  
16 hours of emergency lighting for DCIS cabinet rooms  
17 which are not inhabited by people, but you do not  
18 supply 72 hours lighting for areas that may or will be  
19 inhabited by people? That's the basic. I don't  
20 understand the discrepancy of why we need 72 hours of  
21 lighting for a cabinet room so the cabinet can see  
22 itself and not for a control room where people should  
23 be able to monitor the status of the plant.

24 PARTICIPANT: -- of the staff.

25 Let us take us take this back as an item

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 to look into. I'm not -- I'm not sure that --

2 MEMBER STETKAR: Okay. Ask the staff to  
3 look into that.

4 PARTICIPANT: Yes. I don't think that the  
5 requirement is that you assume a fire in the control  
6 room and a loss of off-site power. But let us go back  
7 and at least get back to you with an answer. You  
8 know, get back to you with an answer on that question.  
9 We understand the concern.

10 MEMBER STETKAR: Right.

11 CHAIRMAN CORRADINI: I think they're  
12 clear.

13 Anything else, Amy?

14 MS. CUBBAGE: No. I think we're ready to  
15 go to Chapter 10.

16 CHAIRMAN CORRADINI: Yes, I would  
17 appreciate it if we can go to Chapter 10. And I think  
18 General Electric -- GEH will begin. And we'll probably  
19 hope to finish that before lunch.

20 MEMBER SIEBER: That's a big hope.

21 CHAIRMAN CORRADINI: Oh no, it's in the  
22 plan.

23 MR. JORDAN: We accept the challenge.

24 Good morning, Mr. Chairman, members of the  
25 Committee.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   My name is Peter Jordan. I am the  
2                   Regulatory Affairs engineer assigned to Chapter 10 by  
3                   GEH. And this morning this discussion about Chapter  
4                   10 will be presented by Gary Anthony, who is the lead  
5                   chapter engineer. And, hopefully picking up on your  
6                   comment because this is a chapter not nearly as  
7                   involved as many others in the DCD, that Mr. Anthony  
8                   might be able to pick up a few seconds or minutes or  
9                   whatever on the presentation.

10                  Anyway, go ahead, Gary.

11                  MR. ANTHONY: Good morning, ladies and  
12                  gentlemen. My name is Gary Anthony. I'm the  
13                  principle engineer presenting my favorite ESBWR  
14                  Chapter 10, Steam and Power Conversion Systems.

15                  I have with me today Mr. Rusk Kusic,  
16                  Senior Engineer, and also the author of Chapter 10 if  
17                  you have some particular questions.

18                  I have my Lead Engineer, Mr. Hugh Upton  
19                  also.

20                  And I'll try to spend this up so we can  
21                  get to lunch.

22                  I'd like to do a quick Chapter 10 overview  
23                  today. I'll be discussing the design parameters, do an  
24                  equipment review, review the turbine and generator,  
25                  look at the main steam system, discuss feedwater and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 mitigation of flow accelerated corrosion, what we call  
2 FAC, then do a review of the principal design  
3 features, look at the power cycle schematic, which is  
4 DCD Figure 10.1-1 and I'll try to do that fairly  
5 quickly. And discuss the scope of enhanced design  
6 features we have in the ESBWR system. And I'll finish  
7 with a summary.

8 The content and level of detail that's  
9 used in DCD Chapter 10 considers the guidance in  
10 NUREG-0800, the NRC standard review plan, sections  
11 10.2 through 10.4.7.

12 Turbine, generator and power cycle systems  
13 do not perform or support any nuclear safety-related  
14 functions.

15 The standard ESBWR parameters are  
16 summarized in:

17 DCD section 10.1 which describes the  
18 principle design features and lists the corresponding  
19 design parameter in Table 10.1-1.

20 Also in DCD section 10.4 it describes the  
21 circulating water cooling requirements, which we call  
22 the circ water system.

23 For an equipment overview, the ESBWR  
24 balance plant or BOP is based upon a conventional BWR  
25 power cycle system. It's 20 percent larger than the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 BWR-6s

2 Chapter 10 presents the equipment required  
3 to basically condense unused steam into condensate and  
4 convert that water into high quality feedwater in a  
5 purification subsystem. We use filters and  
6 demineralizers for extremely pure water in the parts  
7 per billion to parts per trillion range that we can  
8 now monitor.

9 We're using Reg. Guide 156 as our  
10 standard. And we're also taking a look at the EPRI  
11 Water Guidelines in 2004 as requested by the NRC.

12 Water is then heated with standard  
13 extraction steam through low pressure and high  
14 pressure feed water heats and is then fed to the  
15 reactor in a normal system for a BWR.

16 Steam is generated then transported to the  
17 turbine via the main steam piping and converted to  
18 electrical energy from thermal energy. Any wet or  
19 excess steam is exhausted back to the condenser in a  
20 normal BWR system.

21 To take a quick look at the turbine and  
22 generator for a few minutes. We use one double flow  
23 high pressure turbine, three double flow low pressure  
24 turbines, what we call a 6F52 or six flow 52 inch  
25 blade machine.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Turbine rotors utilize an integral  
2 forging. We call them monoblocks. They're running  
3 about 500,000 pounds or 250 tons, and they're single  
4 forgings. This is to minimize the probability of  
5 missile generation. And they pretested to 120 percent  
6 of rated speed. That's a ten percent extra margin.

7 GE has a long history with this design  
8 replacing the shrunk on wheel type that the NRC and  
9 the utilities had problems with before. We've used  
10 them since about 1992, and we've got well over 4  
11 million operational hours on these monoblock forgings.  
12 We've had no problems with them at all.

13 MEMBER SIEBER: These are GE machines?

14 MR. ANTHONY: These are GE machines, yes.

15 MEMBER SIEBER: All right.

16 MR. ANTHONY: Turned last stage blades, as  
17 I said earlier, are 52 inches long and have been fully  
18 shop tested. There are a few in service at 50 Hertz  
19 and we have a few at coal stations at this time.

20 We use a standard design synchronous  
21 generator with a water cooled stator windings, a  
22 hydrogen cooled rotor. This unit is rated at a  
23 monstrous 1933 MVA. It's about 1600 megawatts  
24 electric gross depending on vacuum conditions.

25 MEMBER APOSTOLAKIS: Do these last stage

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 blades erode with droplet impingement?

2 MR. ANTHONY: Anything will erode when you  
3 have droplets in there. We have an advanced system  
4 for extracting the moisture. We have a hydrophobic  
5 steel which allows the moisture to go down the  
6 extraction steam line. And we keep them down to an  
7 absolute minimum.

8 There's very high quality materials placed  
9 on these blades to keep down to a minimum.

10 DR. WALLIS: So they have a long life?  
11 How long was their life?

12 MR. ANTHONY: At the present time we have  
13 10 to 12 year inspections required on all major pieces  
14 of equipment. And at that point in time we will give  
15 a long term life on the equipment. We're expecting 30  
16 years.

17 MEMBER SIEBER: How much cobalt is used in  
18 valves and turbine blades and so forth?

19 MR. ANTHONY: Basically from industry  
20 experience, cobalt is still the best seat material for  
21 lightening surfaces.

22 MEMBER SIEBER: That's why I asked the  
23 question.

24 MR. ANTHONY: But in the rest of our  
25 specifications we go out with the absolute minimum

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 allowed in spurious materials that are coming into the  
2 forgings themselves. So we limit it in the base  
3 materials and we only use the cobalt where it's  
4 necessary.

5 MEMBER SIEBER: You use it on the leading  
6 edge of your longer low pressure --

7 MR. ANTHONY: No, sir. We use flame-  
8 hardening. High quality material and flame hardening.  
9 We don't use cobalt overlay strips.

10 MEMBER SIEBER: Okay.

11 MEMBER ABDEL-KHALIK: What is the maximum  
12 moisture content in the low pressure stages of the  
13 turbine?

14 MR. ANTHONY: We don't design that  
15 particular part as GEH. Those are all proprietary  
16 designs for GE Steam Turbine. And if you'd like, we  
17 could have a GE Steam Turbine representative discuss  
18 the --

19 MEMBER ABDEL-KHALIK: Oh, that's a  
20 different part of the company, so you're not allowed  
21 to know that either?

22 CHAIRMAN CORRADINI: I don't think he's  
23 allowed to share it.

24 MEMBER ABDEL-KHALIK: The way you said it,  
25 I thought I'd try.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. TUCKER: This is Larry Tucker with  
2 GEH.

3 There are other turbine vendors in the  
4 audience today.

5 CHAIRMAN CORRADINI: That's perfectly  
6 understood.

7 MR. TUCKER: And we're more than willing  
8 to get the right person to share with the ACRS in  
9 appropriate forum.

10 MEMBER SIEBER: Well, it doesn't have a  
11 safety basis anyway.

12 MEMBER ABDEL-KHALIK: I was just following  
13 up on the question, the earlier question regarding  
14 erosion.

15 MR. ANTHONY: Something you'd like me to  
16 answer?

17 MEMBER ABDEL-KHALIK: No, not at this time  
18 since you don't have the information.

19 MR. ANTHONY: Let's take a quick look at  
20 the turbine main steam systems. Basically it  
21 transports steam from the nuclear boiler to the  
22 turbine inlet. The system is nonsafety related, but  
23 it's built as a quality group B system. It's  
24 designed, procured, installed, tested, inspected and  
25 "N" stamped ASME Section III, Class 2 requirements.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1                   It is also designed to seismic category II  
2 requirements.

3                   The old BWR MSIV leakage control system  
4 has been replaced with what we call the NRC approved  
5 isolated condenser system method, which has been  
6 retrofitted into some of the operating BWR plants.

7                   DR. WALLIS: Presumably MSVs are safety  
8 related?

9                   MEMBER APOSTOLAKIS: Yes.

10                  MR. ANTHONY: Yes. MSIVs are safety  
11 related.

12                  MEMBER APOSTOLAKIS: So they're part of a  
13 different discussion?

14                  MR. ANTHONY: Yes, those are the B-21  
15 system. We start at the seismic isolation going into  
16 the turbine building.

17                  MEMBER SIEBER: Do you have any ATWS  
18 mitigation that relies on reactor trip at turbine  
19 trip?

20                  MR. ANTHONY: The turbine building is  
21 basically set aside from that. ATWS is contained in  
22 the reactor building. The only thing the MSIV  
23 isolation system, if you get an MSIV isolation, the  
24 fail-safe system for the bypass valves and drain lines  
25 work as if it were happening as a LOCA. And it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 fully automated.

2 For extraction steam and feedwater,  
3 basically the standard plant design incorporates seven  
4 feedwater heaters, 4 moisture separator reheaters and  
5 multiple extraction points.

6 We use three low pressure heaters and  
7 they're located in the condenser necks.

8 The system contains an open feedwater  
9 heater tank. We call that number 4. That provides the  
10 reserve inventory for mitigating abnormal events,  
11 which is about three minutes at full power on a loss  
12 of all condensate pumps.

13 The MSRs have a standard high efficiency  
14 chevron-type moisture separators. They're used to  
15 improve steam quality and increase the thermal  
16 efficiency of our unit.

17 We use reliable steam seal designs that  
18 are instituted to contain the radioactive gases and  
19 steam.

20 And materials are selected for a 60 year  
21 life.

22 Let's talk a bit about the feedwater some  
23 more and the mitigation of flow accelerated corrosion,  
24 FAC.

25 We use the applicable operating

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 experiences and recommendations provided in the NRC  
2 General Letter 89-09 and NUREG-1344. These are  
3 applied to the system and operation.

4 Now potentially affected by FAC are  
5 analyzed from actual plant design data. We have three  
6 models. To determine where the increased wall  
7 thickness or FAC resistant resistent materials must be  
8 used to meet the 60 year design life.

9 MEMBER APOSTOLAKIS: Do you have automatic  
10 release from the seals on the turbine or this is some  
11 system of flow that prevents that?

12 MEMBER SIEBER: There is a seal.

13 MR. ANTHONY: It provides steam to seal  
14 the turbine and we have vacuum, light duty vacuum  
15 system that keeps steam or any radioactive --

16 MEMBER APOSTOLAKIS: In in-flow instead of  
17 an out-flow?

18 MR. ANTHONY: Yes. Negative vacuum around  
19 the edges.

20 MEMBER SIEBER: The back into seal to leak  
21 in rather than leak out.

22 MR. ANTHONY: We also take a look at using  
23 the EPRI CHECKWORKS or an equal design system program.

24 MEMBER APOSTOLAKIS: Doesn't that take a  
25 long time to calibrate? Doesn't that take a long time

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 to calibrate to your system, that CHECKWORKS?

2 MR. ANTHONY: CHECKWORKS? Yes, it does.  
3 It take a lot of input.

4 MEMBER APOSTOLAKIS: It took years?

5 MR. ANTHONY: And the utility can use that  
6 as the long term program. We have several that we're  
7 using up front with our designer, AE designer to take  
8 a look at potential elbows and locations that might be  
9 tight.

10 MEMBER ARMIJO: Now you use a lot of  
11 chrome molly steel in these systems.

12 MR. ANTHONY: Yes, I'll be getting to that  
13 in just a second.

14 MEMBER ARMIJO: Okay.

15 MR. ANTHONY: Basically we start with good  
16 engineering; piping design principles to ensure flow  
17 velocities are limited. And we try to have no two  
18 phased flows, which basically is what eats up a lot of  
19 the pipes.

20 We've done an internal study that was  
21 completed on the Class I piping in the reactor  
22 building, main steam lines on feedwater and the main  
23 steam lines with regular carbon steel were much, much  
24 greater than 60 years. We do have to do some CFD  
25 analysis on some of that piping for spots that we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 potentially could need to do some redesign on just  
2 because of impact flow.

3 And feedwater came out to be greater than  
4 60 years when using P22 pipe and 02 control. And as  
5 you said earlier, the P22 pipe is what we're using the  
6 two and a quarter chrome one percent molly to make  
7 sure we have a good hemotype layer. And it's also  
8 where you guys have discussed earlier today 02  
9 control. We're requiring 50 to 100 ppb of 02 control  
10 to keep an excellent corrosion layer on the piping.  
11 That limits the loss of material and gives us our 60  
12 year life design.

13 MEMBER SIEBER: Main steam system Schedule  
14 A?

15 MR. ANTHONY: It's custom built pipe at  
16 this size. We designed it as a wall thickness.

17 MEMBER SIEBER: You say it will have a  
18 schedule?

19 MR. ANTHONY: Yes. It's really big pipe.  
20 Some of the principle design features.

21 The standard main condenser is a water-  
22 cooled surface steam type made with corrosion-  
23 resistant materials and very robust spargers.

24 We'll be doing a CFD analyses on this  
25 also.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER ARMIJO: Are there options on the  
2 condenser materials?

3 MR. ANTHONY: Yes, we have two materials.  
4 We have both a stainless steel and a titanium listed  
5 in the DCD. Typically the titanium would be for a salt  
6 water service, but could be opted for fresh water  
7 service as needed.

8 MEMBER ARMIJO: But there's no copper  
9 containing materials in the options?

10 MR. ANTHONY: No.

11 MEMBER ARMIJO: Good.

12 MR. ANTHONY: No, sir.

13 The normal BWR has a 33 percent bypass  
14 valve plant, you're probably fairly familiar with  
15 those, 25 to 40 percent, around 33. This turbine  
16 bypass system is designed with a full bypass  
17 capability --

18 MEMBER ABDEL-KHALIK: Now you've had  
19 experience with plants that have full bypass  
20 capability?

21 MR. ANTHONY: Yes, we do have some  
22 experience with them. Even some of the 1972 plants  
23 were built with it, even though they weren't designed  
24 well enough to use it. But there are plants that do  
25 have the capability.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER ABDEL-KHALIK: Have those systems  
2 been actually actuated?

3 MR. ANTHONY: Yes. And we have tests from  
4 a plant that we're using for the basis of the design  
5 for our island mode system, which I'll talk about in  
6 just a minute.

7 MEMBER SIEBER: Some of them have been  
8 inadvertently actuated.

9 MEMBER MAYNARD: Do you accomplish the  
10 increase by larger valves or more valves?

11 MR. ANTHONY: More valves. We use a dozen  
12 valves. We also have a much larger condenser than  
13 normal.

14 MEMBER SIEBER: I presume there's a lot of  
15 baffles in the condenser to keep from --

16 MR. ANTHONY: We'll have baffles and  
17 specifically designed spargers. And we'll do a full  
18 CFD analysis on each section of the condenser because  
19 we are loading it with 19 million pounds mass an hour  
20 of steam.

21 MEMBER SIEBER: That is a lot.

22 MEMBER STETKAR: I had a question once you  
23 go onto design features. On the main feedwater system  
24 there's a low load low flow control valve.

25 MR. ANTHONY: Correct. We have a startup

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 valve and a low flow.

2 MEMBER STETKAR: Yes, up to about 20  
3 percent power. There's only one of those? There's no  
4 parallel -- there's a single --

5 MR. ANTHONY: At the present time if you  
6 look at the drawing we only have one on feed pump. We  
7 call it a startup system.

8 MEMBER STETKAR: Right.

9 MR. ANTHONY: We're also taking a look at  
10 having -- since we're not looking at having any single  
11 capability of failures, we're going to have that  
12 probably on two feed pumps. Such that either one of  
13 those could be a startup system.

14 MEMBER STETKAR: Okay. That's being  
15 looked at.

16 MR. ANTHONY: We have an HFE requirement  
17 on all of our systems to look at single failure proof,  
18 and that's one of the items that we may need to spend  
19 a little more money on.

20 MEMBER SIEBER: But that's not a safety  
21 issue? It's a reliability issue?

22 MR. ANTHONY: That's correct. It's an  
23 availability/reliability issue.

24 More principle features we have is loss of  
25 grid, what we call the island mode. We have a #4

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 feedwater heater sizing. It's like a big accumulator  
2 in the middle of our balance of plant system. It's  
3 got 680 cubic meters of water in it. That's about  
4 100,000 gallons of spare water in the middle of our  
5 system.

6 We keep spare feedwater and condensate  
7 pumps as backups for increased reliability. And all  
8 of this really --

9 MEMBER ABDEL-KHALIK: I'm sorry. Can you  
10 explain that third bullet? I guess I didn't appreciate  
11 its usefulness. Could you just take one more minute,  
12 please?

13 MR. ANTHONY: Certainly.

14 What I've done is I've listed some of the  
15 things that operators of plants have always wanted or  
16 European plants have requested in the design of the  
17 system.

18 Loss of grid. What happens to the plant  
19 on a loss of grid? Basically we have this plant  
20 design such if you lose the outside grid and the  
21 reactor and turbine is still in good shape, it will  
22 power the house load. We call that island load.  
23 Everything runs down to about 4 percent steam, the  
24 generator puts out enough power back through its own  
25 transformers to supply a basic house power.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Everything that's needed on the island nuclear and  
2 nonsafety. Circ water pumps, service water pumps,  
3 everything.

4 MEMBER STETKAR: Do you have any operating  
5 experience on the turbine generator control system?

6 MR. ANTHONY: We have operating experience  
7 from a plant that has this system built into it. And  
8 from their lessons learned, we found that we needed a  
9 high flow system for standard operation and a very  
10 tight logic system for low control system.

11 MEMBER STETKAR: The logic system was what  
12 I was asking about.

13 MR. ANTHONY: Yes. And we have that built  
14 in the General Electric Turbine Control system to  
15 control in island mode.

16 MEMBER STETKAR: But you don't have any  
17 actual operating experience on that particular --

18 MR. ANTHONY: We have Leibstadt plant that  
19 does, yes.

20 MEMBER STETKAR: Okay.

21 MR. ANTHONY: We're using all of their  
22 data. They've graciously given the data --

23 MEMBER STETKAR: That's okay.

24 MR. ANTHONY: We know the logic system  
25 that's needed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER STETKAR: Okay. But you don't have  
2 one on a GE design logic system yet?

3 MR. ANTHONY: Not that I know of at this  
4 time.

5 MEMBER STETKAR: Okay. Thank you.

6 MEMBER SIEBER: This have electric heat  
7 pumps or steam driven steam pumps?

8 MR. ANTHONY: Well, actually I'll get to  
9 that in another slide. But they're electric.

10 MEMBER SIEBER: Okay. And when you get  
11 back to 4 percent, that means you're dropping a lot of  
12 pressure across the feed rate valve?

13 MR. ANTHONY: Well, we use --

14 MEMBER SIEBER: How do you control that?

15 MR. ANTHONY: We use a variable speed ASD  
16 drive feed pumps.

17 MEMBER SIEBER: Oh, okay.

18 MR. ANTHONY: And that cuts down on a lot  
19 of the valve damage.

20 MEMBER SIEBER: Right. I don't think you  
21 can control it with just valves?

22 MR. ANTHONY: No. No. We have variable  
23 speed pumps like the turbines used to be, but we don't  
24 use the steam for those reasons.

25 MEMBER SIEBER: Right. Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. ANTHONY: The second item in that  
2 third bullet which we were talking about was the #4  
3 open feedwater heating sizing. A lot of plants use  
4 this as a giant accumulator in the middle of the  
5 system such that if you get plant transients in the  
6 condensate system, it has -- this create a huge  
7 capacitor for the plant, a giant accumulator. And you  
8 get, you know, three or four minutes on the total loss  
9 of condensate. That's an infinity of time for an  
10 operator, you know, to have to get one more condensate  
11 pump going.

12 CHAIRMAN CORRADINI: Thank you. That  
13 helps.

14 MR. ANTHONY: Okay. Would you like me to  
15 continue on that bullet or --

16 CHAIRMAN CORRADINI: No.

17 MR. ANTHONY: Okay. We also have a  
18 flexible circulating water system. That's the heat  
19 sink. That's site specific outside of the buildings  
20 itself. It's very flexible. This includes a series or  
21 parallel flow condenser options, depending on where  
22 you site this plant.

23 Let's take a quick look at the power  
24 cycle.

25 As we said earlier, we got 19.3 million

1 pounds mass an hour; that's the results of 4,500  
2 megawatts approximately of output on an ESBWR.

3 The first thing that comes off is the  
4 bypass valves. So if you have isolation of anything on  
5 the turbine side, you still have bypass valves that  
6 are directly controlled to the condenser.

7 Our seals are taken off right after that  
8 so we always have steam for the seals that come off  
9 main steam.

10 We have a conventional stop valve and  
11 control valves, four of each, completely independent  
12 of each other.

13 We come to a standard high pressure  
14 turbine. It'll get a little bigger, but it's a  
15 standard one.

16 This exhausts to the MSRs. We have four  
17 MSRs because they're so large instead of the two.

18 We go two choices of CIVs, either the  
19 integral or double CIVs at this point.

20 We have three low pressure turbines. This  
21 is what gets you the six flow design; two flows, two  
22 flows and two flows that's six.

23 And the 52 inch blades would be the last  
24 ones on there.

25 Three heaters in the necks of each one of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the condenser shelves. This is depicting a series circ  
2 water flow, so these are three different vacuums that  
3 runs 671,000 gallons per minute of circ water through  
4 here to cool the system.

5 Condensate is taken from here into four  
6 condensate pumps. Only three are required to run with  
7 a 100 percent backup in one pump.

8 We use the lowest temp condensate water  
9 coming from the hot wells to purify. And that makes  
10 the resins work the best, unlike some of the older  
11 plants that had them in a slightly warmer place.

12 We go through filters down to one micron  
13 if it were -- or a 10th of a micron if we're using  
14 hallow fibers, full condensate heat beds. This bypass  
15 valve is closed at all times unless we have an upset  
16 in the system. So we have 100 percent condensate  
17 cleanup system on here.

18 We go through some auxiliary cooler loads,  
19 steam jet air ejector, off-gas in the seals.

20 This runs over to our number four tank.  
21 As I said 100,000 gallons, giant accumulator. It's  
22 basically just a tank capacitor or giant flywheel for  
23 the system.

24 PWRs have it, a lot of European plants  
25 have it. We have this in coal stations.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   This runs for four independent ASD drive  
2 booster pumps which feed feed pumps. And it's shown  
3 here we just discussed a little while, this looks like  
4 a startup control valve in case you don't have to run  
5 large flows through these feedwater pumps.

6                   It comes back into the number 5, 6 and 7  
7 high pressure feedwater heaters and then up to the  
8 reactor.

9                   MEMBER ABDEL-KHALIK: So what happens if  
10 you lose condenser vacuum on one of the LP turbines?

11                  MR. ANTHONY: You would typically close  
12 off the combined interset valve to stop steam, do a  
13 power reduction and be able to control the plant just  
14 by spinning that on the best vacuum you can. It will  
15 basically force your plant down over a short period of  
16 time.

17                  MEMBER ABDEL-KHALIK: And how long does  
18 that take before -- I mean, do the other turbines  
19 speed up?

20                  MEMBER SIEBER: No.

21                  MR. ANTHONY: No. A very dedicated control  
22 system on this side. We have a speed side control  
23 system with double backup systems on it. And when you  
24 have any type of transient on the system itself that  
25 would lose horsepower for one reason or another,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 either a generator or load reduction or a loss of  
2 steam to any system, we have a standard power control  
3 system that will basically shut the control valves  
4 down to make the turbine safe at 1800 rpms.

5 MEMBER ABDEL-KHALIK: And the time  
6 constant for that process is how long?

7 MR. ANTHONY: I don't remember. It's 4  
8 milliseconds or eight milliseconds.

9 MEMBER ABDEL-KHALIK: Oh, I see.

10 MR. ANTHONY: We're extremely fast.

11 MEMBER ABDEL-KHALIK: Thanks.

12 MEMBER BLEY: Did you say that you can  
13 continue operating that way or it will eventually  
14 drive you down to the --

15 MR. ANTHONY: It will eventually drive us  
16 down.

17 MEMBER BLEY: What takes you down?

18 MR. ANTHONY: Well, because the three  
19 condensers are connected with a single pipe over to  
20 the --

21 MEMBER BLEY: Thank you very much.

22 MEMBER STETKAR: Gary, on the feedwater  
23 tank, do you need a positive steam over pressure in  
24 the feedwater tank --

25 MR. ANTHONY: Yes, you do.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MEMBER STETKAR: -- or positive suction?

2 You do?

3 MR. ANTHONY: Yes.

4 MEMBER STETKAR: For the feedwater pumps.

5 MR. ANTHONY: Well, at the present time  
6 it's fed through this -- you see this extraction steam  
7 load?

8 MEMBER STETKAR: Yes. Yes. But that's  
9 required for net positive suction head for the --

10 MR. ANTHONY: Under full power, yes.

11 MEMBER SIEBER: Well, it'll keep oxygen  
12 out, too.

13 MR. ANTHONY: Yes. It's a deairator in the  
14 top. The water sprayed in the top is a deairator and  
15 the bottom of the tank is basically a holding tank.  
16 We have 59 pounds it runs on normally.

17 MEMBER SIEBER: A quick question on  
18 circulating water. Do you do chemical treatment? And  
19 if so, do you use chlorine? And if so, it is gas or  
20 otherwise?

21 MR. ANTHONY: Yes, chemical treatment.  
22 No, that is not a GEH responsibility. That is a site  
23 design responsibility. Each architectural engineer  
24 depending on the water supplied selects the best  
25 chemical treatment system.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER SIEBER: I bring it up because if  
2 you use gas, you use chlorine and it's close to the  
3 control room ventilation intake --

4 MR. ANTHONY: That would be done under a  
5 hazardous gas --

6 MEMBER SIEBER: Sooner or later you're  
7 going to have a problem.

8 MR. ANTHONY: Yes.

9 MEMBER SIEBER: Yes. A line break or  
10 something or you're changing tanks and this goes right  
11 into the control room.

12 MR. ANTHONY: Yes, I'm used to that. I  
13 came from the Brunswick station. We used gas and  
14 chlorine.

15 MEMBER SIEBER: Right.

16 MR. ANTHONY: It requires a lot of  
17 sensors.

18 MEMBER SIEBER: It's a real adventure.

19 MR. ANTHONY: But that's up to the  
20 architectural engineer that the utility works for to  
21 design that --

22 MEMBER SIEBER: And you give them advice,  
23 right?

24 MR. ANTHONY: We do have a lot of lessons  
25 learned and recommendations we can give them.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER SIEBER: Okay.

2 MR. ANTHONY: Okay. Let's go over some of  
3 the enhanced design features. As we talked about  
4 earlier, we have integral forging, the big monoblocks.  
5 This is to reduce missile probabilities. And the  
6 turbine is also favorably oriented to the reactor  
7 building and control building, i.e., the shaft is  
8 perpendicular to the reactor control building unlike  
9 some of the older plants. It's basically a safer  
10 design basis.

11 We have adjustable speed, motor-driven  
12 feedwater pumps using variable frequency drives. This  
13 reduces dose by elimination of the steam going to the  
14 old drives and improves maintainability because we can  
15 go into the rooms anytime we need to monitor them or  
16 repair them.

17 Gland seal steam system evaporator has  
18 been eliminated. The turbine seals are back onto  
19 normal main steam, like the old BWR-4s that worked  
20 quite well. This improves reliability and reduces  
21 maintenance does through simplification of systems on  
22 the plant.

23 The turbine utilizes a fully electronic,  
24 redundant, fail safe and testable overspeed protection  
25 system. And this is for improved reliability. This

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 has been modified on many machines.

2 MEMBER STETKAR: And you do not have a  
3 mechanical overspeed trip?

4 MR. ANTHONY: That is correct. We do not  
5 use a mechanical overspeed trip. We found them very  
6 unreliable.

7 MEMBER STETKAR: Right.

8 MR. ANTHONY: And hard to maintain.

9 MEMBER SIEBER: Well, they trip you at  
10 different speeds.

11 MR. ANTHONY: Yes.

12 MEMBER SIEBER: Do you have redundancy in  
13 your trip, overspeed trip?

14 MR. ANTHONY: Yes, we do. We've had  
15 several discussions with the NRC and we've provided  
16 them with documents and schematics showing what it  
17 looks like. We use six probes and two sets of three,  
18 only two out of the three probes ever have to work on  
19 a set.

20 MEMBER SIEBER: Do you count teeth on a  
21 gear or something?

22 MR. ANTHONY: We count teeth. We have a  
23 large toothed wheel. We can take any probe out of  
24 service to test it on line. We have three systems to  
25 do that. We have normal speed and overspeed and an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 emergency overspeed systems that all independent.

2 MEMBER SIEBER: Okay. Thanks.

3 MEMBER STETKAR: Gary, do all the turbine  
4 trip signals go through, I think you call it an  
5 emergency trip device, set of solenoids that drain the  
6 hydraulics?

7 MR. ANTHONY: Yes, we do. All two of them,  
8 and they come from either end. So either the primary  
9 system can trip the solenoid or from the opposite side  
10 coil we can cut the wires on the emergency system and  
11 take it out.

12 MEMBER STETKAR: There are emergency trip  
13 -- I'll call it block because it's --

14 MR. ANTHONY: Yes. Two blocks, three coils  
15 each.

16 MEMBER STETKAR: Okay.

17 MR. ANTHONY: Each one of them can be  
18 tripped by the system.

19 MEMBER STETKAR: Thanks.

20 MR. ANTHONY: And it's all single failure  
21 proof design.

22 In summary, the DCD Chapter 10 provides a  
23 description of the standard plant design features.

24 The ESBWR balance of plant is designed with  
25 flexibility and can be sited anywhere design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 parameters are met for the cooling water systems. We  
2 have one basic set of numbers that have to be met.

3 This is a standard heat cycle for electric  
4 power conversion, stop valves, control valves,  
5 intercept valves, nonreturn valves; all the same.  
6 Extraction steam, HP/LP, monoblock turbines, and the  
7 standard tube condenser.

8 The design incorporates the best  
9 practices, incorporates many industry lessons learned.  
10 We have spare pumps, which is very important, large #4  
11 feedwater tank, 100 percent bypass valve and as a  
12 spare on there, we don't even need -- you know, we  
13 only need 11 out of 12. We have the island mode  
14 system, the early review of materials to keep FAC down  
15 to an absolute minimum, and MSR designs for the  
16 utility to have maintainability on it.

17 All of this is to increase reliability,  
18 less balance of plant initiating transients, longer  
19 plant system life, good cycle efficiency and equipment  
20 availability through online testing and maintenance.

21 That's the end of my presentation.

22 CHAIRMAN CORRADINI: Any questions by the  
23 Committee.

24 MEMBER BLEY: Yes. Just one quick one.  
25 Until you've gained more experience with that low

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 power control system on the island mode operation, if  
2 you should lose the turbine what's the sequence of  
3 events that occurs?

4 MR. ANTHONY: If it's a turbine trip, it  
5 would be like a standard plant.

6 MEMBER BLEY: Okay.

7 MR. ANTHONY: The stop valves would close,  
8 bypass valves would open and the SRI or select rod  
9 insertion in the scurry system would bring the reactor  
10 down to about 60 percent power where operations would  
11 make a choice on whether we were going to go back up  
12 in power if the turbine could get back on line, or  
13 continue on down to a safe shutdown situation.

14 Basically we're doing --

15 MEMBER BLEY: There's actually a time for  
16 that, to make that decision?

17 MR. ANTHONY: Yes.

18 MEMBER SIEBER: Yes. Well, you end up on  
19 bypass.

20 MR. ANTHONY: You end up on bypass.

21 MEMBER BLEY: That's right.

22 MR. ANTHONY: And automatically the power  
23 goes down and the reactor down to 60 percent power,  
24 which is the standard for the condenser.

25 MEMBER BLEY: How long can they stand on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that 60 percent bypass.

2 MR. ANTHONY: Indefinitely.

3 MEMBER BLEY: Really?

4 MR. ANTHONY: That's the design for the  
5 standard --

6 MEMBER BLEY: Okay.

7 MR. ANTHONY: -- you know off steam --

8 MEMBER BLEY: Everything inside will let  
9 it run --

10 MR. ANTHONY: It's all automatic. The  
11 operators can take their time, review the plant, take  
12 a look at the alarms and annunciators and make a  
13 choice on whether they're going down the rest of the  
14 way or continue back up.

15 MEMBER STETKAR: Where does steam for the  
16 feedwater tank come, since you were talking about it?  
17 Where does steam for the feedwater tank come post  
18 turbine trip? I'm assuming it normally comes from  
19 extraction of steam.

20 MR. ANTHONY: Yes. It normally comes from  
21 extraction steam. The tank is overpressured and we  
22 have automated valves and vent system on it such that  
23 it slowly vents off to the condenser. It's in a  
24 controlled fashion.

25 MEMBER STETKAR: Yes, but to keep a main

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 feed water pump running for 60 percent reactor power,  
2 you've got to have a main feed water pumps running?

3 MR. ANTHONY: Yes, you will have -- water  
4 pumps which are a lot less needed, they will drive  
5 back and the MPSH required for those pumps is much  
6 less because we have a power booster pump feeding  
7 them.

8 MEMBER MAYNARD: The old pressure was only  
9 required for 100?

10 MR. ANTHONY: A 100 percent power, that's  
11 correct. At 60 percent power we're basically at zero  
12 pounds on that.

13 MEMBER SIEBER: Or you have condensate  
14 pumps that are usually deep draft pumps and --

15 MR. ANTHONY: Yes.

16 Anything else, gentlemen?

17 CHAIRMAN CORRADINI: Committee members?

18 No.

19 Thank you very much.

20 MR. ANTHONY: Thank you.

21 CHAIRMAN CORRADINI: So I've already  
22 talked to the staff and they are ready to start after  
23 lunch. So why don't we take a break.

24 So can I ask for 45 minutes? Is that like  
25 incredibly mean or can we do that. We'll be back here

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 at 1:00.

2 (Whereupon, at 12:14 p.m. the hearing was  
3 adjourned, to reconvene this same day at 1:00 p.m.)  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

1 A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

2 1:01 p.m.

3 CHAIRMAN CORRADINI: Okay. Let's get  
4 started on our afternoon.

5 You going to start us off?

6 MR. OESTERLE: Yes, I will.

7 Thank you all for coming back from lunch.

8 My name is Eric Oesterle, I'm the Senior  
9 Project Manager in the Office of New Reactors. And I  
10 would be managing the review for Chapter 10 "Steam and  
11 Power Conversion System."

12 The purpose of the presentation this  
13 afternoon is to brief the Subcommittee on the staff's  
14 of Revision 3 of the ESBWR design certification  
15 application, that's Chapter "Steam and Power  
16 Conversion System."

17 We're also here to answer any questions as  
18 this Subcommittee may choose to ask them.

19 I want to mention, as I have in previous  
20 presentations, that the staff's review was performed  
21 to Revision 3 of the ESBWR DCD. And we do have  
22 Revision 4 of the ESBWR in house and it is currently  
23 in review. So some of the open items that you may be  
24 discussing in this presentation are from the SER with  
25 open items that we issued to you back in September.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 Some of those open items, may in fact, be resolved  
2 based upon our review of Revision 4.

3 I also wanted to indicate that some of the  
4 challenges that Amy mentioned this morning with the  
5 SER with open items maintaining consistency with the  
6 DCD revisions, so those challenges we also faced on  
7 Chapter 10. And so we have worked out some of those  
8 challenges with GE. They have responded to us and  
9 identified some areas where there are inconsistencies.  
10 And we are continuing to work with GE to resolve those  
11 as we develop our final safety analysis report.

12 With me today at the lead Chapter 10  
13 reviewers, Jorge Hernandez, George Georgiev, Robert  
14 Davis and Yamir Dias-Castillo.

15 Let me go heads up on the slides here.

16 What we'll go through in the presentation  
17 is:

18 A review of the applicable regulations;

19 A status summary of the RAIs;

20 Some selected SER technical topics;

21 Open items;

22 COL action items; and

23 Discussion of Committee questions.

24 On this slide we're presenting a summary  
25 of the regulations and other review guidance that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 staff used in performing the review of Chapter 10. I  
2 won't go into detail into each and every one of these,  
3 but you can see what they are.

4 In terms of the summary of the RAIs, we  
5 originally started out with 50 RAIs on Chapter 10.  
6 Forty-six of those were resolved on the date that we  
7 submitted the SER with open items to the Subcommittee  
8 back in September. And that left us with four open  
9 items. Those open items will be discussed later in  
10 the presentation and some of those may be resolved yet  
11 by the Revision 4 to the ESBWR DCD.

12 At this point I'd like to turn it over to  
13 Jorge Hernandez for discussion on Section 10.2.2 on  
14 the turbine generator design.

15 MR. HERNANDEZ: Good afternoon, again. My  
16 name is Jorge Hernandez from the Advanced Plant  
17 Branch, NRO.

18 I'm going to be discussing the staff  
19 evaluation for sections 10.2 and 10.3 and 10.4. I'm  
20 going to start off with the turbine generator design.

21 I'm not going to touch a lot into design  
22 of this system. You know, GE's already addressed the  
23 description of the system. So I'm just going to touch  
24 on the topics that the staff evaluated. Mostly I'm  
25 going to mention some of the key features from the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 turbine generator or the electronic overspeed  
2 protection system, which is fully electronic and does  
3 not incorporate a mechanical trip system. And then it  
4 also provides digital instrument and controls.

5 For this particular sections we don't have  
6 any COL items. We had one open item which at this  
7 point has already been resolved. It's still open in  
8 the SER, as Eric mentioned. And it has to do with the  
9 electronic overspeed system.

10 We requested the applicant to demonstrate,  
11 you know, how the design provided diverse protection  
12 means without the mechanical trip. And as I mentioned  
13 before, the proposed system provides a primary trip  
14 with three redundant channels and two out of three or  
15 GE has already described that part.

16 And it also has an emergency trip which  
17 has the same arrangement and it's powered from  
18 different sources.

19 The applicant considers that the emergency  
20 trip system provides diverse protection means because  
21 it employs redundant channels which are powered from  
22 diverse sources and not controlled from different  
23 software codes. Each channel of the emergency trip is  
24 powered from a separate UPS. And the controls use  
25 different softwares. So they address both redundancy

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and diversity. The staff found that the system  
2 provides diverse protection means.

3 We also wanted to know that in addition to  
4 the reliability of the protection system that the  
5 impact to the nuclear safety is really minimal given  
6 the design provides favorable orientation and also it  
7 reduces the risk incidents because it includes a  
8 rotor, is monoblock design.

9 MEMBER APOSTOLAKIS: What does that mean?  
10 What is a monoblock design?

11 MR. HERNANDEZ: Well, it's a rotor, it's  
12 forged -- it's a one piece.

13 MEMBER APOSTOLAKIS: Oh, that's what it  
14 is. They called it something else.

15 MR. HERNANDEZ: Okay.

16 MEMBER MAYNARD: Quick question. The  
17 manual trip function feature from the control room,  
18 does it go through one of these systems or does it  
19 have it's own?

20 MR. HERNANDEZ: Well, there's a manual  
21 trip on the machine itself, on the turbine --

22 MEMBER MAYNARD: I understand that. But  
23 from the control room can't they push a button to trip  
24 it?

25 MR. HERNANDEZ: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: Does that go through  
2 basically the turbine digital control system or is it-  
3 -

4 MR. HERNANDEZ: Yes.

5 MEMBER MAYNARD: -- go straight to --

6 MR. HERNANDEZ: It goes to -- well, I  
7 guess we can have GE address that.

8 MR. KUSIC: Russ Kusic with GEH.

9 The manual push button, it's an electronic  
10 trip. It feeds through the trip manifold assemblies,  
11 the same trip manifold assemblies that trip the  
12 turbine on normal overspeed or any other trip. But it  
13 does not go through the controls. It's a separate set  
14 of relays that interrupts the power to the trip  
15 manifold assembly solenoids.

16 MEMBER MAYNARD: Okay.

17 MR. HERNANDEZ: And with that, I'll let  
18 George discuss section 10.2.3, which is the turbine --

19 MEMBER APOSTOLAKIS: I thought the  
20 missiles were the blades and not the shaft.

21 MEMBER SIEBER: They are.

22 MEMBER APOSTOLAKIS: And what does the  
23 monoblock design do anything about missiles?

24 MEMBER SHACK: It's anything that leaves  
25 the --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MR. GEORGIEVE: I have it. I'll be  
2 talking about this.

3 MEMBER APOSTOLAKIS: You'll be talking  
4 about this?

5 MR. GEORGIEVE: So maybe it will be more  
6 proper for me to answer it.

7 Thank you.

8 My name is George Georgieve. I am Senior  
9 Materials Engineer with Component Integrity Branch.  
10 And I was assigned here for section 10.2.3.

11 And as you can see from the first slide  
12 that being the material fellow, you know I will be  
13 talking more about material properties. And we can  
14 attach on what you ask how the new improved monoblock  
15 or rotor does to reduce stresses in susceptible  
16 locations. Basically, the way it's done you have a  
17 solid forging, then it -- and you rove in the seats  
18 for the blades. And the blades are set on top of this.  
19 So in this way you reduce the stresses at the bottom  
20 of the shaft.

21 And the former shaft is shrunk. It was a  
22 straight shaft with a key and shank. And that was the  
23 historic soft spot.

24 And in modern turbine design in our  
25 industry, at least, they all went either with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 monoblock or the welded type of design which the  
2 Europeans started, basically, the forging is welded  
3 together.

4 But starting with the materials, to begin  
5 with the materials property factor very prominently in  
6 the calculation of probability of missile generation,  
7 the P1 type of probability. And you start with a very  
8 high quality steel forging to begin with. It's done  
9 with the NiCrMoV, a lower alloy forging which if it's  
10 built here to American spec will be SA 470 04 471.  
11 And they got a chemistry requirements and other  
12 mechanical properties.

13 But in our standard review of section with  
14 place fracture toughness requirement which all been  
15 about the specs. But basically by the time you meet  
16 it you end up with a very tough material which is  
17 resistant to fracture at high speeds.

18 In addition, to that, that's a starting  
19 point. Then after you wrap machine you preservice  
20 examine using ultrasonic examine of the shaft to  
21 ascertain that there is no sound fabrication or  
22 residual flaws that you have to repair or take into to  
23 whenever you do the analysis.

24 And those two things taken together will  
25 ensure that you start with a good shaft you put in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 service.

2 Next slide, please.

3 And that lists to the area of review. And  
4 the reason we review this is not only safety aspect,  
5 is the turbine missile generation which falls back in  
6 GDC 4. And in order for us to take or for the  
7 applicant to state that they meet the GDC, they have  
8 to have this type of low probability of missile  
9 generation. In our guidance we have broken it down  
10 from favorably --

11 MEMBER APOSTOLAKIS: The GDC is it safe  
12 enough?

13 MR. GEORGIEVE: General design criteria 4,  
14 it a general criteria which specify you that you  
15 design item against missiles. And turbine missile is  
16 one of these because of high speed --

17 MEMBER APOSTOLAKIS: But the GDC itself  
18 does not have --

19 MR. GEORGIEVE: No, no. The GDC doesn't.  
20 That's embedded in our guidance. Actually it's a two  
21 standard review plan.

22 MEMBER APOSTOLAKIS: So the staff has  
23 interpreted it that if you meet this, you'll met the  
24 GDC?

25 MR. GEORGIEVE: That's right. And that is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 a --

2 MEMBER APOSTOLAKIS: No, that's fine.  
3 That's fine.

4 MR. GEORGIEVE: It's a historic. We don't  
5 do any different for operating plants replacing their  
6 turbine --

7 MEMBER APOSTOLAKIS: -- ten to the minus  
8 5 is produced?

9 MR. GEORGIEVE: Yes. That is if you --  
10 turbine, you're supposed to meet that. The higher.  
11 It is a -- this design, the ESBWR it is purported to  
12 be. Of course if some COL decide to go with  
13 unfavorable, they certainly can do so but they have to  
14 meet these guidelines.

15 CHAIRMAN CORRADINI: Just so I'm clear.  
16 Favorable is like that, unfavorable is like that,  
17 right?

18 MR. GEORGIEVE: Well, as the applicant  
19 states they do have a -- it's --

20 CHAIRMAN CORRADINI: It's perpendicular  
21 versus parallel to the --

22 MR. GEORGIEVE: Right. Yes. It's a  
23 perpendicular to the reactor --

24 MEMBER APOSTOLAKIS: Perpendicular is  
25 what? Favorable?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN CORRADINI: Unfavorable.

2 DR. WALLIS: Why do you only talk about  
3 rotors? I thought that the blades the subject -- they  
4 come off some time.

5 MR. GEORGIEVE: But they do. They do. Yes,  
6 they do. But if we make sure we start with a good  
7 design, good material the likelihood to come off is  
8 less.

9 DR. WALLIS: It doesn't mention blades at  
10 all. You just talk about rotors.

11 MR. GEORGIEVE: The rotor's heavy. Yes.  
12 The blades are attached to the -- and basically you  
13 have the shaft --

14 DR. WALLIS: Well, a 40 foot long blade is  
15 a pretty good missile, isn't it?

16 MR. GEORGIEVE: It is.

17 MEMBER APOSTOLAKIS: But can you tell us  
18 plain English how one goes about to calculate the  
19 probability -- to evaluate the probability like this?  
20 What does it involve?

21 MR. GEORGIEVE: What is involved is type  
22 of material properties. You have a certain fracture  
23 toughness numbers there that you could use in the  
24 design when you analyze the shaft. And then you have  
25 partialized tangential and other stresses that you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 have to take in your design.

2 And then when you get the materials  
3 properties and the size of that oscillating -- you can  
4 calculate in terms of time, then you end up with a  
5 number. Then you do have another conforming, which is  
6 the turbine valve testing that you factor in.

7 So all these enclosed in the turbine  
8 maintenance problem, all these three elements. And  
9 actually what we do historically we have required from  
10 applicants to within three years of putting the  
11 service we give as these turbine -- which is based on  
12 three elements -- the overspeed protection and the  
13 turbine valve testing and the material properties  
14 which include fracture toughness calculation, the  
15 flaws.

16 And we do have --

17 CHAIRMAN CORRADINI: I think there's a  
18 comment over here to assist.

19 MR. GEORGIEVE: In the Reg. Guide 1.15  
20 that--

21 MR. TUCKER: This is Larry Tucker with  
22 GEH.

23 Part of what we do in doing this is  
24 assessment is exactly right. That you consider the  
25 materials, you consider the design. But I think there

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 was a slide earlier that is the most telling evidence  
2 that we meet that requirement. If you refer back that  
3 this design has over 4 million hours with zero  
4 failures. Zero rotor cracks and zero thrown blades,  
5 so you can calculate the probability from those  
6 numbers.

7 MR. GEORGIEVE: They have even Monte Carlo  
8 kind of a analysis in this. We usually discover by  
9 using the last review it --

10 MEMBER APOSTOLAKIS: Performing the  
11 probability for what?

12 MR. GEORGIEVE: Probability of missile  
13 generation. A missile detaching from the rotor and  
14 piercing through the casing.

15 MEMBER APOSTOLAKIS: Yes, but it is a  
16 condition of probabilities for something given  
17 something.

18 MR. GEORGIEVE: Per year, yes.

19 MEMBER APOSTOLAKIS: Per year.

20 MR. GEORGIEVE: Per year, yes.

21 DR. WALLIS: Well, it was claimed behind  
22 me that you could calculate this from the fact that  
23 you had 4 million hours of experience. That's only a  
24 thousand years and you're talking about 100,000 years  
25 here. I'm not quite sure how you extrapolate from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 1,000 years experience to 100,000 years.

2 MEMBER APOSTOLAKIS: Oh, hours.

3 DR. WALLIS: It's per hour

4 MEMBER APOSTOLAKIS: No, no, per year.

5 DR. WALLIS: I thought it was per year.

6 So you're talking about 100,000 years.

7 MEMBER APOSTOLAKIS: So it's the  
8 combination; statistics plus the analysis?

9 DR. WALLIS: Yes. The analysis is much  
10 more important.

11 CHAIRMAN CORRADINI: Are you saying that  
12 for George's sake?

13 MEMBER APOSTOLAKIS: This is a  
14 performance-based agency.

15 MR. GEORGIEVE: And I thought -- on the  
16 way with three slides. Okay.

17 Well, and as you can see, I'll sum it up,  
18 what we ended up was we have the -- we close all the  
19 16 because we -- provided information. But ended with  
20 ITAAC which specify, which is a P1 level of  
21 commitment, that wherever the COL holder, whoever get  
22 the license will be obligated to submit us this report  
23 to substantiate that they have this probability. P1 is  
24 like ten to the minus five.

25 And this provide the basis to conclude

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 that the turbine meets our general design criteria.

2 MR. OESTERLE: No open items in the COL  
3 items?

4 MR. GEORGIEVE: That's correct. Yes.

5 MR. HERNANDEZ: All right. So for the  
6 turbine main steam system, I'm just going to mention  
7 a few key features for the system.

8 First of all, there's no safety related  
9 components of the system. The system starts  
10 downstream of the seismic interface and up to the  
11 turbine stop valves and the turbine bypass valves.

12 So the main steam isolation valve is  
13 covered in Chapter 3 and then the main steam isolation  
14 system is covered in Chapter 5. And those are going  
15 to be discussed in a separate meeting.

16 MEMBER STETKAR: One question. Where are  
17 the main feedwater isolation discussed?

18 MR. HERNANDEZ: Main feedwater is ten  
19 percent. The main steam isolation valve --

20 MEMBER STETKAR: Nothing is discussed in  
21 either section 5 or section 10. So where are the main  
22 feedwater isolation discussed? Ten refers me to 5, 5  
23 refers me to 10 at the moment.

24 MS. GRUSS: This is Kim Gruss.

25 I think that MSIVs are discussed in 3.9.6,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 are they not?

2 MEMBER STETKAR: We haven't seen 3 yet.  
3 They may be, but we haven't seen 3 yet. I'm asking  
4 about main feedwater isolation since this says main  
5 steam isolation is in 3. Section 10 of the SER says  
6 that main feedwater and main steam isolation is  
7 reviewed in section 5. And, in fact, it says

8 MS. GRUSS: In 10.5?

9 MEMBER STETKAR: It says section 5.4 of  
10 this report discussed in detail the portions of the  
11 main steam and feedwater piping located upstream  
12 including main steam isolation. Section 10 says these  
13 systems are evaluated by the staff in Chapter 10.

14 So they refer me correctly to each other,  
15 but neither one of them says anything about feedwater  
16 or steam isolation.

17 This slide says the MSIVs are in Chapter  
18 3. So I'll accept the fact that they may be there  
19 when we see it. Where is main feedwater isolation  
20 reviewed?

21 MS. CUBBAGE: The containment isolation in  
22 general is 6.2.

23 MEMBER STETKAR: 6.2? So the main steam  
24 isolation is in 6.2 or Chapter 3?

25 MS. CUBBAGE: I'm just saying containment

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 isolation is Chapter 6. I think the valves themselves  
2 from a component perspective would be in Chapter 3,  
3 the MSIVs.

4 MEMBER STETKAR: MFIV? This says MSIVs.  
5 I'm asking about feedwater.

6 MS. CUBBAGE: Right.

7 MEMBER STETKAR: They also have check  
8 valves and isolation valves --

9 MS. GRUSS: Yes. Those should also be  
10 addressed in Chapter 3 as well.

11 MEMBER STETKAR: All right.

12 MS. GRUSS: All valves, all components.

13 MEMBER STETKAR: I hope so.

14 MS. GRUSS: MOVs.

15 MS. CUBBAGE: And I don't think you're  
16 going to see an enormous amount of detail. I don't  
17 think these are unique components for ESBWR.

18 CHAIRMAN CORRADINI: I thought we did 3.

19 MEMBER STETKAR: No, we haven't done 3.

20 MS. CUBBAGE: No, we haven't done 3 yet.

21 MEMBER STETKAR: The DCD covers them in  
22 Chapter 5. GEH is okay because they're all discussed  
23 in Chapter 5.

24 CHAIRMAN CORRADINI: So is there a  
25 particular question you have --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. CUBBAGE: Yes. I mean if our SER --

2 MEMBER STETKAR: I want to know how they  
3 work and I want -- and if the staff looked at them.

4 CHAIRMAN CORRADINI: I don't think you  
5 have the benefit of the last meeting where John was  
6 asking where it was, and so we were waiting for it  
7 here.

8 MS. CUBBAGE: Well, we certainly  
9 appreciate that if the SE is confusing is pointing and  
10 back and forth, we need to fix that. That's a given.  
11 So, thank you.

12 MR. OESTERLE: We'll take an action to  
13 look that up and get back to you.

14 MS. CUBBAGE: Well, we'll need to fix the  
15 SE to reference the right places.

16 MEMBER STETKAR: Section 10.3.2, third  
17 paragraph. But you need section 5.4 also that refers  
18 to section 10.

19 MEMBER APOSTOLAKIS: So when has this been  
20 reviewed, Chapter 3 you say we have not reviewed it.

21 CHAIRMAN CORRADINI: We'll get to it.  
22 Let's move on here. I will have an answer for you by  
23 the end of the day.

24 MR. HERNANDEZ: Well, again, on the  
25 turbine main steam system the staff focused on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 review on the ability of the system to provide path  
2 for efficient products coming from MSIV leakage to the  
3 condenser. So we verified that the system is  
4 seismically analyzed and able to provide that in fact  
5 that path to the condenser, it's classified as seismic  
6 category 2. And it has a fail safe arrangement which  
7 in loss of power the valves are required to establish  
8 a path will open.

9 We have no open items and no COL on this  
10 section. And we found it acceptable.

11 For section 10.36 I'll leave Mr. Robert  
12 Davis to discuss that.

13 MR. DAVIS: My name is Bob Davis. I'm  
14 with the Component Integrity Branch. And I review the  
15 class -- well, it would be class 2 and 3. In this  
16 case there's only class 2 because there are no class  
17 3 feedwater and main steam.

18 And the feedwater valves that somebody was  
19 just asking about, there is an RAI question that's  
20 open. I know on the material side they did not  
21 include the materials specs for the check valves and  
22 the feedwater isolation and we're still waiting to  
23 resolve that RAI.

24 The class 2 steam and feedwater systems  
25 piping is the same as it is for class 1. It's carbon

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 steel for the steam and 2 1/4 chrome for the  
2 feedwater.

3 The fracture toughness requirements of the  
4 ESBWR meet requirements of section 3 class 2  
5 components.

6 Only carbon steel and low alloy steel  
7 ferritic steel are used in class 2 systems. There's  
8 no stainless steel.

9 The DCD does not specify the use of class  
10 3 components.

11 The fabrication and welding of steam and  
12 feedwater systems meet the requirements of ASME Code  
13 Section III and they conform with the guidance of RG  
14 1.50 for preheating and post weld heat for alloy  
15 steels and RG 1.71, which pertains to qualifications  
16 of welding in restricted environments.

17 The cleaning and cleanliness controls  
18 conform with the guidance of RG 1.37, which is quality  
19 assurance requirements for cleaning of fluid systems  
20 and associated components in nuclear power plants.

21 For the ESBWR, as I'm sure everyone  
22 noticed earlier, GEH has talked about FAC. They have  
23 completed their assessment for FAC for class 1. They  
24 have not completed it for class 2. And in particular,  
25 noncode class piping which, as we all know, is usually

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 is what is the most problematic. But they did provide  
2 a description of -- they did indicate that they will  
3 perform their assessment in the same manner as they  
4 did for class 1. The materials are the same as they  
5 were for the class 1 systems as it is for class 2. And  
6 they will follow the guidance and recommendations of  
7 the generic letters and NUREGs that the NRC has  
8 published. In addition, they'll use CHECKWORKS and  
9 other codes to verify that their system design, that  
10 their corrosion rate is what they think it will be,  
11 that it will meet their 60 year life.

12 Along with mitigation for FAC, that's only  
13 part is to mitigate for FAC. And then of course the  
14 follow up on that is to have a FAC program to monitor  
15 FAC, to make sure their design was right and to follow  
16 that through throughout the life of the plant. And  
17 they have committed in the ESBWR design any applicant  
18 that comes in will have to have an FAC program.

19 The only open items that we had, and this  
20 is they failed to list the material specifications and  
21 grades earlier for the steam and feedwater materials.  
22 That has been corrected in Revision 4, so that will no  
23 longer be an open item.

24 We also had issues with their discussion  
25 on the RG for preheat/post weld heat treated low alloy

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 steels. That information has been included in  
2 Revision 4 of the ESBWR DCD and therefore is resolved.

3 They did provide a description of the  
4 steps that they would take in their design to mitigate  
5 FAC for class 2 piping. They've included that in  
6 Revision 4. But we still want them to change the DCD  
7 and provide a description for what they're doing in  
8 noncode class piping to ensure that because, as we all  
9 know, that's the piping that hurts people is the non-  
10 ASME class 1, 2 and 3 piping is what typically fails.  
11 So that will remain an open item until they provide a  
12 description.

13 And there was an issue, they were not  
14 going to code stamp or have ANI review for the class  
15 2 portion of turbine main steam system, but they have  
16 since agreed to review the DCD.

17 CHAIRMAN CORRADINI: This report  
18 information, I read that and I didn't appreciate. So  
19 that was a voluntary action. It's not required for  
20 class 2 piping?

21 MR. DAVIS: Well, they just updated a reg.  
22 guide. And I think it's RG 1.26. And it basically  
23 indicates how you classify systems 1, 2 and 3. And  
24 evidently the old reg. guide would allow them to make  
25 that portion of the system to class 2 but not to code

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 stamp them. And that's not part of -- I didn't review  
2 how they classified things or how they don't classify  
3 them. But when the new reg. guide came out I guess  
4 that is more called a loophole. But that provision  
5 that allowed them to do that was removed, basically.  
6 And therefore we asked them, it's either class 2 or it  
7 isn't. If it's not code stamped, then that brings into  
8 question what ISI has actually done. So they've agreed  
9 that it will be coded and will be N-stamped, it will  
10 be ANI reviewed. That means it'll get all the section  
11 ISI requirements.

12 CHAIRMAN CORRADINI: Okay. Thank you.

13 MR. DAVIS: And I'm finished.

14 MR. HERNANDEZ: Going to the main  
15 condenser, the review of the main condenser was mostly  
16 focused on the ability of the condenser to provide a  
17 hold-up volume for the MSIV fission product leakage  
18 from the MSIVs.

19 There's one -- the anchorage and the  
20 supports for the main condenser are seismic qualified  
21 and, you know, the staff found that it's unacceptable.  
22 There's one COL item for this section, which is the  
23 applicant choose to address DCD section 10.4.6 and  
24 it's related to providing threshold limits and  
25 procedures to address chemistry excursions on the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 condenser. And there's no open items on this section.

2 For the condenser air removal system, key  
3 features of the system. There's two mechanical vacuum  
4 pumps which are used for start up operations, two jet  
5 air ejectors which are usually during operation.

6 DR. WALLIS: No more radioactive release  
7 from the jet air ejectors?

8 MR. HERNANDEZ: Those are monitored in  
9 the--

10 DR. WALLIS: What is the normal release  
11 from them?

12 MR. HERNANDEZ: That would be covered in  
13 a different section. That would be in Chapter 12. I  
14 don't know the answer to that.

15 DR. WALLIS: I was trying to understand.  
16 What's the normal release and what's the allowable  
17 release on that system?

18 MS. CUBBAGE: Dr. Wallis, I don't think we  
19 have the people here to answer that.

20 DR. WALLIS: You don't know that. There  
21 must be some specs on that.

22 MS. CUBBAGE: So that, we could take it  
23 back.

24 DR. WALLIS: A different section.

25 MS. CUBBAGE: But I think it's a section

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that's already been covered. So if we need to, we can  
2 take that back.

3 DR. WALLIS: Oh, it's already been  
4 covered?

5 MS. CUBBAGE: Yes. Chapters 11 and 12  
6 where we look at our effluents.

7 MR. HERNANDEZ: And the exhaust of  
8 compartment systems are to the off gas system and to  
9 the turbine building component exhaust during start  
10 up.

11 There's no COL items for this section and  
12 no open items either.

13 DR. WALLIS: Well, why are you concerned  
14 about it at all?

15 MR. HERNANDEZ: For this? Well, that  
16 there is monitoring systems on the exhaust. And that  
17 they have two pumps which are capable of maintaining  
18 a vacuum under --

19 DR. WALLIS: I would think you would be  
20 concerned about the way in which they monitor the  
21 radioactive release, that's sort of the safety aspect  
22 or health aspect.

23 MR. HERNANDEZ: Right.

24 DR. WALLIS: But you don't say anything  
25 about that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. HERNANDEZ: Right, but --

2 DR. WALLIS: So otherwise why bother to  
3 mention it?

4 MR. HERNANDEZ: There's no safety impact--  
5 there's no safety design for this system.

6 MS. CUBBAGE: Radiation monitoring in  
7 effluent doses, those are covered. I should say normal  
8 operating doses were covered in Chapter 11.

9 MEMBER SIEBER: Yes, but that's on the  
10 stack. Not individual components. If you have  
11 activity in the stack, it has to come from the  
12 reactor.

13 MEMBER BLEY: It's a tech spec on it, and  
14 we'll get to that later today I think. Yes, it's right  
15 here.

16 MEMBER ARMIJO: It' a big number.

17 MEMBER BLEY: Yes. It's 2,000 --

18 MR. HERNANDEZ: We can make a note of that  
19 particular portion and request information from --  
20 here.

21 So moving along for the turbine gland seal  
22 system. The sealing system, steam is not only  
23 provided by the main steam or extraction steams, but  
24 there is also the related to the auxiliary boiler  
25 steam at all loads if it's needed.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           There's two 100 percent capacity exhaust  
2 blowers which maintain vacuum in the gland steam  
3 condenser and then they direct the noncondensable  
4 gases to the turbine building compartment exhaust.

5           And then there's monitoring for releases  
6 through the radiation monitoring system, the ERMS. And  
7 those are, again, discussed in Chapter 5, I think.

8           There's also a high radiation and flow  
9 alarms provided in the control room for this system.

10          And we don't have any open items and  
11 there's COL items.

12          The turbine bypass systems provide full  
13 load rejection or turbine trip capability without  
14 using SRV and without having a reactor trip, because  
15 that was already discussed GEH presentation. And the  
16 applicant claims that there's no single failure that  
17 can disable more than 50 percent of the installed  
18 bypass capacity.

19          And also, you know, a failure of the TBS  
20 lines does not impact essential systems.

21          We found the design acceptable and do not  
22 have any --

23          DR. WALLIS: When you have full load  
24 rejection, can the condenser handle that?

25          MR. HERNANDEZ: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: The condenser for the--

2 MR. HERNANDEZ: Right. And also there's  
3 enough flow rate from the circ water in order to  
4 handle the heat load.

5 On the circ water system, there is no  
6 safety design basis again for this system. It  
7 provides, like I mentioned, enough cooling water to  
8 commodate a full load coming from the turbine bypass  
9 system and also to remove heat during normal  
10 operations.

11 It isolates on a turbine building  
12 condenser area high water level signal.

13 The staff find the design acceptable and  
14 there's no COL items in this area. But there are  
15 portions outside of the scope of DCD in which the COL  
16 applicant needs to address. Those are the intake  
17 structure and the power heat sink and the intake  
18 pumps.

19 nd there's no open items in this section.

20 Going to the condensate purification  
21 system, that is going to be addressed by Yamir Dias-  
22 Castillo.

23 MR. DIAZ-CASTILLO: Hi. My name is Yamir  
24 Dias-Castillo with the Component Integrity Branch. I  
25 will review section 10.4.6 which is the condensate

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 purification system.

2 This is not safety related and it was  
3 performing the safety function.

4 The system purifies and treats condensate  
5 load to maintain reactor feedwater purity and it does  
6 this by passing condensate loads through a series of--  
7 demineralizers to remove those product impurities and  
8 suspended solids. This conforms with the guidance of  
9 GT 1.56.

10 There are no open items and no COL action  
11 items. However, the staff is currently in discussions  
12 with GEH regarding use of EPRI BWR water chemistry  
13 guidance, which I think they mentioned that in their  
14 presentation.

15 MR. HERNANDEZ: On the condensate and  
16 feedwater system there's four feedwater pumps and four  
17 condensate pumps, three of them are usually in service  
18 and one of them is in standby.

19 There is coincident logic and redundant  
20 controllers and input signals to reduce spurious  
21 trips.

22 And during normal operation flow control  
23 is provided by the adjustable speed controls and  
24 reactor feedwater pumps. And during low power  
25 operations there's a low flow control valve which is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 used for low power operation flow control.

2 MEMBER STETKAR: All right. How many  
3 feedwater pumps did you say there were?

4 MR. HERNANDEZ: Four. On DCD there's four  
5 in total.

6 MEMBER SIEBER: Three of them are main  
7 feedwater pumps and one is a startup pump, though,  
8 right?

9 MR. HERNANDEZ: No, no, no. They' all  
10 full--

11 MEMBER SIEBER: They're full capacity?  
12 Thanks. Sorry.

13 MR. HERNANDEZ: They have one standby.

14 MEMBER SIEBER: Thank you.

15 MR. HERNANDEZ: There's no open items on  
16 this section and no COL items.

17 MR. OESTERLE: And that concludes our  
18 presentation of Chapter 10.

19 I'd like to turn it over to the  
20 Subcommittee for additional questions or discussion.

21 CHAIRMAN CORRADINI: Additional questions?  
22 Nothing?

23 MS. CUBBAGE: I'd just like to follow up  
24 on the turbine gland seal question. I did look in DCD  
25 chapters 11 and 12. In 12 there are specs for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 amount of release and in 11 there's a subsystem for  
2 radiation monitoring. And it provides the detectors  
3 and the ranges.

4 MR. OESTERLE: We look forward to coming  
5 back to address the closure of open items on the this  
6 Chapter will the full Committee when we have our final  
7 safety evaluation prepared.

8 CHAIRMAN CORRADINI: Thank you, Eric.  
9 Thank you very much.

10 So we should move on to Chapter 13.

11 MR. BEARD: Well, good afternoon. Alan  
12 Beard with GE Hitachi. Jim Kinsey as well.

13 This should be fairly brief and to the  
14 point, but review of Chapter 13 which is Conduct of  
15 Operation.

16 Most of this Chapter is from the point of  
17 view of the responsibility of the COL applicant, but  
18 there are some elements to DCD -- part of the design  
19 certification.

20 Go to the next slide, please.

21 So we will provide a quick overview of  
22 Chapter 13 and the items that relate to the  
23 organization structure and how they will be operated--  
24 putting together the plans and the training programs  
25 that are necessary to ensure that the plant is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 operated in a safe manner.

2 And then the final item there physical  
3 security, we'll touch on that briefly in open session.  
4 And then depending on what the Committee's interests  
5 are on those items, it may be possible that we need to  
6 go into a close session to discuss some of those  
7 items.

8 Next slide, please.

9 In Chapter 13, like I said, primarily the  
10 responsibility of the COL applicant on the COL items  
11 listed here. The open items that you worry about when  
12 the staff goes up are primarily in the area of 13.6,  
13 which is security and we'll explain why there's so  
14 many open items in that particular area when we get to  
15 that point.

16 So we'll continue on to section 13.1.  
17 13.1 talks about the organizational structure. The  
18 main point that we want to come across here is GE has  
19 spent a lot of time and effort among the staff in  
20 identifying a very methodical method for coming up  
21 with a human factors engineering program that will  
22 support safe operation. A lot of that is in the  
23 digital performed instrument system, but there are a  
24 lot of the elements in this programs that are going to  
25 lead to provide input into our training programs and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 into the procedure that the -- the core measure  
2 developing procedures and capture that through --

3 MEMBER BLEY: I'd like to ask you a  
4 question now. I don't know the most appropriate  
5 place, but this is a good intro for it.

6 You're doing a new design. We've got the  
7 operating procedures since TMI essentially done by  
8 owners groups and you guys were certainly a part of  
9 that.

10 I don't quite understand. Maybe you could  
11 explain the philosophy to me of why when we're  
12 building trying to integrate the I&C into the design  
13 and human into the design, why you're not doing the  
14 emergency procedures at this stage instead of them  
15 having them added on at the end by the applicant?

16 MR. BEARD: Okay. We're allow Wayne  
17 Martino to address that question.

18 MR. MARTINO: The emergency procedures  
19 will be part of the integrated plant, the reference  
20 plant.

21 Wayne Martino, GEH.

22 They are not part of the DCD  
23 certification. There's an ITAAC item that covers the  
24 procedure development.

25 This is appropriate because the detailed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 design of the plant is not at the point that we can  
2 develop the emergency procedures at this time.

3 MEMBER APOSTOLAKIS: But that doesn't  
4 answer the question.

5 MEMBER BLEY: You're designing the whole  
6 island and that's where most of these are aimed at.

7 MR. MARTINO: And we are ramping up in  
8 this effort. And we're leveraging the work that's  
9 already been done by owners' group. We've had drafts  
10 prepared of emergency procedure guidelines.

11 What part of your question did I not  
12 answer, please?

13 MEMBER BLEY: It seems a real opportunity  
14 to me to match up the developing I&C with the  
15 developing design with the operations as you put it  
16 all together. And I know there's no regulatory  
17 requirement to do this, but I just wonder why -- and  
18 maybe you are. Maybe that's kind of what you just  
19 said. That you're actually writing them as you go  
20 because you're not submitting because it's not  
21 required at this point in time.

22 MR. MARTINO: That's right.

23 MEMBER BLEY: Is that what you're saying?

24 MR. TUCKER: This is Larry Tucker with  
25 GEH.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           We are as aware of this opportunity as you  
2           are. However, up until now it's not been appropriate  
3           because the design has not been advanced far enough to  
4           avail ourselves of that. However, in 2008 that  
5           changes. And as such, we've brought on board several  
6           SROs in our human factors organization, previous SROs.  
7           And we've also just had an individual start who was  
8           the emergency prepared procedure writer at an  
9           operating plant, BWR, and he has joined our staff in  
10          the last month. So it's --

11                 MEMBER BLEY: So this will kind of move  
12                 ahead with the finalization of the I&C?

13                 MR. TUCKER: All this together and 2008  
14                 and 2008 is the appropriate time to do that as more of  
15                 the detailed design is established, then we want to  
16                 bring these procedures along with it.

17                 MEMBER BLEY: We're glad to hear that.  
18                 Thank you.

19                 MR. BEARD: Any other question on 13.1.  
20                 Moving to 13.2.

21                 13.2 describes the necessary training  
22                 programs that need to be developed. The great detail  
23                 of those is actually captured in Chapter 18. 13.2  
24                 just kind of commits the COL applicant submitting the  
25                 necessary descriptions the time line and the types of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 procedures that will be developed. A lot of the types  
2 of procedures are found in the implementing details in  
3 Chapter 18 there.

4 We do factor in a lot of the operating  
5 experience, as we are constantly reviewing the OER  
6 reports out of EPRI as well as the foreign vendors  
7 that we have information available from. But, again,  
8 the bottom line is the COL applicant is responsible  
9 for the majority of this.

10 There will be a design centered working  
11 group approach, a focused approach that would go  
12 into push very hard to standardize this across the  
13 entire operating fleet of the ESBWRs.

14 Next slide. 13.3 emergency planning. And  
15 no surprise here. This is primarily responsibility of  
16 the combined operating license applicant. To the  
17 point that we can do things within the design of the  
18 plant, we're certainly incorporating those right now.  
19 An example of that is our technical support center.  
20 We have TSC that meets the requirements of NUREG 0696  
21 that's located on the ground floor of our electrical  
22 building. It has the dedicated spaces for the  
23 necessary functions that need to be carried out should  
24 you need to activate the TSC.

25 We don't have a safety parameters display

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 system in the legal sense, but it is a function that  
2 is capable from our DCIS and all the parameters from  
3 that you would get on an SPDS are available to the  
4 staff.

5 MEMBER SIEBER: Why did you put an SPDS in  
6 there?

7 MR. BEARD: Well, SPDS was a response to  
8 a TMI item where --

9 MEMBER SIEBER: And I understand that.

10 MR. BEARD: Because we believe that that  
11 information is readily extractable from the  
12 information we're processing --

13 MEMBER SIEBER: But it extracted somebody  
14 has to go take all this data and put it together as  
15 opposed to looking at a icon display and saying here's  
16 one of the --

17 MR. BEARD: In this case it's a -- well,  
18 it's a program element that will bring up an SPDS type  
19 of a display, but it's not a dedicated system is the  
20 point I was trying to make. We're taking the  
21 information from our existing DCIS and then putting it  
22 on screens that provide an SPDS type of capability.

23 MEMBER SIEBER: The question is is your  
24 tech support center picking it up?

25 MR. BEARD: Well --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Twenty-seven people?

2 MR. BEARD: Yes. We meet the requirements  
3 within 0696 and I don't know the exact number, but it  
4 was in the 20s.

5 MEMBER SIEBER: Twenty-seven.

6 MR. BEARD: Twenty-seven.

7 MEMBER SIEBER: And if you end up manning  
8 that around the clock, do you have any provisions or  
9 place for people to sleep and eat without going  
10 outside the radiologically protected area?

11 MR. BEARD: There are comfort facilities,  
12 but there no bunk rooms or anything like that.

13 MEMBER SIEBER: Yes. The comfort  
14 facilities are things you sit on? That'll last you  
15 about 12 hours.

16 MR. BEARD: Okay. It is provided with  
17 environmental control for our HEPA type of filtration  
18 units provide radiological protection for the staff  
19 who are manning that.

20 We do not have a safety related power  
21 supply to power that equipment. That is consistent  
22 with the staff interpretation that that's not  
23 necessary. It is provided electrical power from the  
24 on-site diesels but recognizing those on-site diesels  
25 are not safety related.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER SIEBER: So if they fail, you don't  
2 have a TSC?

3 MR. BEARD: Correct. We go to the  
4 emergency or the EOF to carry out that function.

5 MEMBER SIEBER: Does it have safety  
6 related diesels?

7 MR. BEARD: The EOF?

8 MEMBER SIEBER: Yes.

9 MR. BEARD: No.

10 MEMBER SIEBER: That's even close to the  
11 plant, right?

12 MR. BEARD: Well, it depends on the  
13 ability.

14 MEMBER MAYNARD: Well, the current TSCs  
15 don't have to have a safety related power supply. They  
16 have a back up diesel, typically, but that's not a  
17 safety related --

18 MR. BEARD: And that's consistent with our  
19 design.

20 MEMBER MAYNARD: Yes.

21 MR. BEARD: And then the EOF and the  
22 operational center, you know those to be site  
23 specific, utility specific elements. The COL  
24 addresses part of our application.

25 Next slide, please.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   13.4 operational program implementation.  
2           I'm getting to sound like a broken record, but  
3           primarily the responsibility of the COL applicant. We  
4           have developed a list of the various elements of that,  
5           but it will be the responsibility of the COL to  
6           provide a schedule and a list of the procedures that  
7           will be developed as part of that -- satisfying that  
8           particular element.

9                   MEMBER APOSTOLAKIS: If most of this is  
10          the responsibility of the COL applicant, why is it in  
11          the SRP at this stage?

12                  MS. CUBBAGE: Well, we have one SRP. We  
13          don't have one for design certs and for COL.

14                  MEMBER APOSTOLAKIS: That's everything. I  
15          see.

16                  MS. CUBBAGE: Right. So we have very, as  
17          you've seen in the SER, very short writeups in these  
18          areas to confirm that the appropriate COL action items  
19          are in there for those areas.

20                  MR. BEARD: Okay. 13.5, please.

21                  MEMBER STETKAR: Well, let me ask another  
22          question. Today's plants you have four distinct  
23          emergency facilities. You have the control room.

24                  MR. BEARD: Yes.

25                  MEMBER STETKAR: You have the on-site

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 support center which you don't discuss, as far as I  
2 can see. You have the technical support center and the  
3 EOF. Where is the on-site support center?

4 MR. BEARD: The OSC, the operational  
5 support center is something that the COL will address,  
6 however there is space provided within our service  
7 building to support that function.

8 MEMBER STETKAR: Is it shielded and  
9 atmospheric controlled and all that?

10 MR. BEARD: No. That's only required for  
11 the technical support center not for the operational  
12 support center.

13 MEMBER STETKAR: Oh. That's where you put  
14 your operators and maintenance people to send out to  
15 do the in plant work?

16 MR. BEARD: Right. That's where you stage  
17 the people necessary to recover from the event.

18 MEMBER STETKAR: And there's no shielding  
19 or atmosphere controlled or anything?

20 MR. BEARD: No. There are no specific  
21 requirements imposed.

22 MEMBER ARMIJO: Should there be if you  
23 want to protect them.

24 MEMBER SIEBER: No.

25 MEMBER MAYNARD: Is there extra room in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the TSC? Because some people have moved part of that  
2 into the --

3 MR. BEARD: Well the sizing of the TSC is  
4 for the necessary number of people. Whether you would  
5 argue that that's sufficient room for them to be in  
6 there, I'm not going to get into that argument.

7 MEMBER MAYNARD: Yes. I think part of the  
8 COL's the appropriate place to handle this. Because  
9 the licensee is going to have some of their own idea  
10 on it. But typically, I think, you find that you need  
11 more room than what you've built into these things,  
12 especially the TSC.

13 MEMBER SIEBER: Yes. And these are not  
14 simple structures. You know, an operation support  
15 center has to be in the plant area because that's  
16 where you're dispatching people from. So it's got to  
17 be a shielded building with a good ventilation system.  
18 And once the plant is built it's difficult to find a  
19 place to build another shielded building. You know,  
20 plus unless you think of it before you actually start  
21 shoveling dirt to build the plant.

22 MR. TUCKER: This is Larry Tucker GEH.

23 The operational support center and how the  
24 requirements of that are addressed are very site  
25 specific and it is the responsibility of the COL

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 applicant.

2 The actual implementation, the current  
3 practice for the majority of plant is that they have  
4 an operational support center prime designated for  
5 that and it doesn't have special shielding, but it is  
6 inside the owner protected area.

7 There is also identified an alternate  
8 location for the operational support center. So what  
9 happens is if doses come up, it come in the plume, and  
10 then people migrate to the other facility. That's the  
11 current practice across the industry. And, again, this  
12 is the responsibility --it's a site specific  
13 requirement of the --

14 MEMBER SIEBER: That may be the current  
15 practice of some utilities, but that's not the current  
16 practice of all licensees.

17 MR. TUCKER: You are current. However,  
18 that is the general way it's approached and that  
19 complies with the requirements.

20 MR. BEARD: Okay. Section 13.5 plant  
21 procedures. Again, primarily the COL responsibility  
22 and the types of procedures that are required to be  
23 developed here, it's just an example. So the operating  
24 maintenance procedures, those would be used by the  
25 health physics group that they use for monitoring as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 well as things like handing of heavy loads or new  
2 fueling types of procedures.

3 Finally, 13.6 physical security. I need  
4 to point out that 13.6 itself is classified -- it's  
5 withheld from public disclosure under the provisions  
6 of 10 CFR 2.390. But there is some description in  
7 there that are non-safeguards descriptions. Some of  
8 the key elements of the physical security for the  
9 power plants, things like lighting, communications,  
10 some of the physical barriers we credit in our  
11 response to security events.

12 As I indicate in that next bullet, much of  
13 the information here is safeguards information. The  
14 industry, and I'm sure you would hear this from the  
15 staff, based on Commission expectations that we be  
16 more proactive in designing physical security into  
17 these plants up front, there have been several task  
18 forces that have convened. We have done significant  
19 effort to try and look at these plants from a  
20 materials point of view and to identify potential  
21 design enhancements that we make early on to further  
22 increase our capability to resist those types of  
23 attacks. I think that's been a very worthwhile  
24 effort. I've been part of those groups, and I have to  
25 tell it, it's been an eye-opening experience. You

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 know, we get some of these special operations types of  
2 guys working on these things. And they start throwing  
3 on scenarios. And my comment many times is I'm glad  
4 you're on our side.

5 But the bottom line, I think the most  
6 positive comment I get out of some of these reviews  
7 are, you know, these guys are used to really  
8 challenging the safety design. And, you know, finding  
9 problems. And some of the guys have commented at the  
10 end of this, they go, "This is no fun. This plant is  
11 too safe from a security perspective."

12 So anyway, you will hear later, but we  
13 have three separate safeguard submittals that are  
14 going into the NRC. Two of those just were finished  
15 yesterday or last night. Actually, this morning. I'm  
16 sorry. And we'll be submitting to the NRC tomorrow  
17 when Jim gets back to the office and can put together  
18 the transmittal letter.

19 And then we have a third report, a  
20 safeguards assessment report that will be going into  
21 the staff the early part of next week. And, again, it  
22 does a very methodical look at various attach  
23 scenarios identifying target sets and looking at how  
24 this plant responds to those types of events.

25 Let's go to the next slide, please.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The actual implementation of the physical  
2 security plant is going to be the responsibility of  
3 the COL.

4           Contained in 13.6 there is description of  
5 ten, eleven, twelve elements of the physical security  
6 plan. That was necessary. The level of detail we  
7 provide in there provides the supporting information.  
8 We do have an ITAC on physical security. That was an  
9 element that has been required. And so the industry  
10 worked to come up with what we hope was a generic ITAC  
11 that should be acceptable. And we have the  
12 information 13.6 to support that.

13           It shouldn't come to a surprise to anybody  
14 in this group that the passive plants really when you  
15 start looking at the physical security offer some very  
16 unique capabilities and it really -- it's been an eye-  
17 opener to the security people because some of the  
18 things that they've done to cause core damage on the  
19 existing plants are just not mechanisms that work on  
20 a passive plant.

21           I think Al Tardiff when he gets up here  
22 will indicate that we've done that.

23           DR. WALLIS: So this is the responsibility  
24 of the COL, but you can do a lot presumably with the  
25 robustness of the plant?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MR. BEARD: And we are doing a lot within  
2 the walls of the building we are doing a lot of things  
3 to make it very difficult to get to areas that we  
4 considered to be vulnerable.

5 Final slide, just a summary.

6 As I've said, you know, the vast majority  
7 of this, and as Amy indicated, is the responsibility  
8 of the operator, the license holder. They only have  
9 one SRP so the FSAR will be, when the COLs submit that  
10 will have a lot more of this information.

11 There are a number of open items in the  
12 area, primarily with security, and we are working with  
13 the staff to resolve those. Most of those items will  
14 be resolved through the topical reports that were  
15 submitted.

16 So with that, I have completed my remarks.  
17 I'm up for any generic questions.

18 MEMBER MAYNARD: I would just to pile on  
19 a little bit with Dennis. And I know you're not  
20 required to have your emergency operating procedures  
21 in some of the things at this stage. The sooner you  
22 start that the better, though. Because it's kind of  
23 like doing the PRA in parallel with the design. Some  
24 of these other things may identify early enough to  
25 where a simple change in the design or something may

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 solve a lot of problems that otherwise you don't find  
2 until the tail end and then it becomes a lot more  
3 difficult.

4 MR. BEARD: I think one point that we may  
5 not have made is there are existing BWR emergency  
6 procedure guidelines which form the basis for the  
7 detailed emergency operating procedures. And we have  
8 undertaken an effort to take those existing EPGs,  
9 update them to reflect the design of the ESBWR,  
10 incorporate the element and in doing that identify are  
11 there instruments that we might want to make available  
12 or things like that, or provide additional means for  
13 introducing or problem with the containment, or  
14 whatever.

15 And so although we haven't done the  
16 detailed procedures and documented all that, you know  
17 in updating that EPG we certainly have done a lot of  
18 that type of stuff.

19 MEMBER SIEBER: The process, actually,  
20 goes like the past is that the vendor provides  
21 emergency guidelines and the applicant COL writes --  
22 actually writes procedures. Because you have a  
23 writers' guides with style and all that so that all  
24 procedures as consistent.

25 MR. BEARD: Well, again --

1                   MEMBER SIEBER:   And then your vendors  
2 provides EPGs, or SAMGs, excuse me. So there has to  
3 be involvement by both the vendor and the licensee.

4                   MR. BEARD:   And while I can't say here  
5 with 100 percent certainty because it's subject to  
6 contract provisions we'll have with our utilities, it  
7 is our expectation that this will be a fleet model  
8 type of deployment and that those procedures will be  
9 developed generically. And whether that's GEH or  
10 another contractor doing that, but it'll be the same  
11 procedures at North Anna 3 or Grand Gulf 3 or  
12 Riverbend.

13                  MEMBER STETKAR: Are you going to build a  
14 simulator that's GE controlled or the license going to  
15 do that? Because that's the perfect place to try out  
16 the emergency procedures, see how they work, see what  
17 the human factors are.

18                  MR. BEARD:   Larry Tucker.

19                  MR. TUCKER:   This is Larry Tucker with  
20 GEH.

21                  The multi-benefits of a simulator is  
22 obvious to us as well. There are discussions -- and  
23 it's also to our potential customers, our future  
24 customers.

25                  We're in negotiations and discussions now

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 with the various utilities on moving forward with  
2 simulators. Besides the emergency procedures, it also  
3 the simulator provides a key benefit in training the  
4 operators. And if you want to have certified  
5 operators by the time that the first plant goes in and  
6 you start backing up all the requirements, 2008/2009  
7 is about as late as you can start a simulator and  
8 still meet those requirements. So that's why those  
9 negotiations and discusses are ongoing right now.

10 MEMBER STETKAR: Well, I'm sure this isn't  
11 part of a design control document, but I do think it's  
12 a good idea.

13 MS. CUBBAGE: It's more than a good idea,  
14 it's a requirement.

15 MEMBER STETKAR: Pardon?

16 MS. CUBBAGE: It's a regulation.

17 MEMBER SIEBER: Oh, all right.

18 CHAIRMAN CORRADINI: Other comments about  
19 Chapter 13 for GEH?

20 So just to remind the Subcommittee if we  
21 have questions that require us to go into closed  
22 session, we'll do that after the open part of this  
23 with the staff. Okay? So if you have something, hold  
24 it and we can go into a closed session.

25 Go ahead. I'm sorry, Excuse me.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Thank you very much.

2 MR. FOSTER: Good afternoon. My name is  
3 Rocky Foster. I'm the Project Manager for the ESBWR  
4 Design Certification Review for Chapter 13 for  
5 "Conduct of Operations."

6 But I'd like to first remind everybody  
7 that this presentations is on a non-safeguards level  
8 because we do have a time period slotted for after  
9 this presentation if the Committee would like to  
10 discuss safeguards level material.

11 As I stated, the purpose is to brief the  
12 Subcommittee on the staff's review of Chapter 13 of  
13 the application. And to answer any questions that the  
14 Committee might have.

15 Our reviewers for the Chapter 13 is  
16 Richard Pelton and Bruce is sitting in for Dan Barse  
17 on this and Al Tardiff.

18 MS. CUBBAGE: Who is here as well.

19 MR. FOSTER: Who is here just in case.

20 And as far as what we will cover --

21 PARTICIPANTS: It has to do with the name  
22 tags.

23 MR. FOSTER: We've got our presentation on  
24 the applicable regulations that were used to review  
25 the application, on the status of the RAIs. And then

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 for each of the areas of reviews for the technical  
2 topics. Any open items we might have the COL  
3 information items.

4 And you can tell we have a long list of  
5 regulations and other view guidance that we use for  
6 our review.

7 And from the RAI status, we had an  
8 original number of 43 RAIs for this area. We've been  
9 able to resolve six of them so far. And we've got 39  
10 open items. The lion's share is in physical security,  
11 okay. But we do have a few in emergency preparedness.  
12 And that within physical security we have broken down  
13 by detection aids, unattended openings and special  
14 security areas/vital components.

15 We've grouped ours a little bit different  
16 than how GE grouped theirs. We'll basically talk  
17 about the easier ones first that we have and then get  
18 into the more difficult areas of the application.

19 For 13.1, and as GE previously stated, is  
20 the organizational structure. And as the staff  
21 reviewed it we found that it was consistent with human  
22 system interface.

23 This again, 13.1 organization structure  
24 will be addressed by the COL applicant.

25 MEMBER APOSTOLAKIS: Human system

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 interface, though, that's a NUREG 0700 or something?

2 MR. PELTON: 0711,

3 MEMBER APOSTOLAKIS: Huh?

4 MR. PELTON: 0711.

5 MEMBER APOSTOLAKIS: Okay.

6 MR. FOSTER: And operational programs 13.4  
7 is consistent with SECY-05-0197. Again, operational  
8 programs will be addressed by the COL applicant.

9 The trainings programs and the operational  
10 procedure programs was the area that we'll talk about.

11 In the training program development plans  
12 and the operational procedure development plans they  
13 all incorporate the appropriate human factor element  
14 and are consistent with the SRPs.

15 The DCD itself, actually referred us to  
16 Chapter 18. Where we went to Chapter 18 to get the  
17 information. And our tech staff reviewed those areas  
18 using the criteria in Chapter 13.

19 Again, we interfaced with Chapter 18 for  
20 the human factors engineering. And for 13.2 that  
21 actually interfaces with NEDO-33275, the --

22 MEMBER APOSTOLAKIS: Has human factor  
23 engineering benefitted from human reliability models  
24 or are they completely different fields? Does anybody  
25 know?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. CUBBAGE: I didn't hear the question,  
2 actually.

3 MEMBER APOSTOLAKIS: The human factors  
4 guidance, has that benefitted from the work that the  
5 agency has done and the industry on human reliability  
6 or are they just --

7 MS. CUBBAGE: I was going to say, I hate  
8 to push it off, but Chapter 18 and 19 might be a  
9 better place to discuss this. Because this area is  
10 really focused on training and procures. The human  
11 factors program we're going to have a long  
12 presentation on that at a future date?

13 MEMBER APOSTOLAKIS: January?

14 MS. CUBBAGE: It'll probably be February.

15 MR. TUCKER: Just an aside --

16 MS. CUBBAGE: But if GE would like to add  
17 anything at this point.

18 MR. TUCKER: This is Larry Tucker of GEH.  
19 The short answer to your question is yes.

20 MEMBER APOSTOLAKIS: It can't be shorter  
21 than that.

22 CHAIRMAN CORRADINI: Only if you write it  
23 down.

24 MEMBER ABDEL-KHALIK: Only from a  
25 regulator.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MEMBER BLEY: There is a subsection in  
2 Chapter 18 on HRA which tries to explain.

3 MS. CUBBAGE: Yes, and topical reports  
4 that were submitted.

5 MEMBER BLEY: But I don't think we have  
6 those yet.

7 MR. FOSTER: Section 13.5 interfaces with  
8 NEDO-33274 and NEDO-33276.

9 The licensed and non-license staff  
10 training programs, again, will be addressed by the COL  
11 applicant. And the operating procedures program will  
12 be addressed by the COL applicant.

13 And it will turn it over for an emergency  
14 preparedness.

15 MR. MUSICKO: Thank you. I'm Bruce  
16 Musicko, I'm a Senior Emergency Preparedness  
17 Specialist with ENSER.

18 With respect to certified designs,  
19 standard design certifications, the emergency planning  
20 or preparedness is a very minor subset of the DCD  
21 design control document in that the extent to which an  
22 applicant wishes to address emergency planning is  
23 optional, except for essentially identifying the  
24 location of the technical support, the TSC. There are  
25 additional things that they can do, but they're not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 required to do them.

2 As you see in the slide, the first bullet,  
3 emergency planning is mostly programmatic in nature,  
4 including facilities, equipment, personnel and  
5 training. But with respect to a certified design,  
6 various aspects of the facilities or even equipment  
7 could be included in the certified design if the  
8 applicant chose to address them. But they don't have  
9 to.

10 In this case the applicant did provide  
11 some information pertaining to the technical support  
12 center specifically dealing with size, location, data  
13 displays, power. And these are some of the general  
14 requirements that are required or actually provided  
15 for in the applicable guidance document, which is  
16 NUREG 0696, which is available on our public website,  
17 which gives a lot of the details associated with what  
18 our review would entail looking at the specifics for  
19 these facilities.

20 For example, the operational support  
21 center that you brought up, there's no habitability  
22 requirement for operational support center. It's  
23 primarily a staging area in order to support emergency  
24 operations. And so there's some flexibility with  
25 respect to where that will be located.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. WALLIS: I would think some of  
2 emergency preparedness would be in the design. If you  
3 have a really serious event, knowing what's going is  
4 very important.

5 MR. MUSICKO: That's true.

6 DR. WALLIS: And having the right kind of  
7 indications there, which are robust, is part of the  
8 design. And that's emergency preparedness.

9 MR. MUSICKO: Yes. Yes, you're exactly  
10 right.

11 DR. WALLIS: Do they do that, a good job  
12 of that?

13 MR. MUSICKO: Well, we'd have to look at--

14 DR. WALLIS: That sort of be on design  
15 basis, and so they don't do it?

16 MR. MUSICKO: We have to look at the  
17 specifics which hasn't been provided yet. The COL  
18 applicant would likely provide that.

19 But you're absolutely correct that various  
20 data displays must be available in these emergency  
21 operation facilities. And they are called out in our  
22 review as required.

23 DR. WALLIS: Okay.

24 MR. MUSICKO: And so we would review it at  
25 a later stage. However, the extent to which a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 standard design certification applicant would choose  
2 to address that in a certified design where it would  
3 be identical for all plants wherever they locate the  
4 reactor, they may not want to tie themselves down.

5 In general for a certified design what  
6 we've seen in the past and here is that there's just  
7 a limited amount of information that's provided. But  
8 basically emergency planning or preparedness is  
9 identified as a COL action item or COL information  
10 item where the programmatic aspects which would  
11 include the actual physical facilities would be  
12 addressed by the COL applicant.

13 So as far as a standard design  
14 certification review is concerned for EP, emergency  
15 planning, it's basically what they care to include in  
16 the certified design we would look at. And, again,  
17 the first bullet, if it's -- the second bullet. It  
18 would be limited to non-site-specific features that  
19 are technically relevant to the design useable for  
20 multiple sites, multiple units at multiple sites.

21 And we've specifically written this  
22 criteria into the standard review plan, SRP Section  
23 13.3 as the scope of review that would be applicable  
24 to a standard design certification. We would not  
25 review programmatic aspects, because those are not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 related to a standard design. And those would vary  
2 from COL applicant to COL applicant.

3 With respect to the OSC again, if it would  
4 be advisable, I would assume, that a COL applicant  
5 would choose to have some sort of habitability  
6 protection to the staging teams that go there, I mean  
7 like a roof in case it rains, things like that. But as  
8 far as radiological habitability is concerned there is  
9 no requirement, nor is there guidance that says you  
10 must have it.

11 MEMBER SIEBER: Part 20 give you  
12 requirements.

13 MR. MUSICKO: Part 20 deals with radiation  
14 exposure, which would be for emergency responders, not  
15 necessarily those in the OSC. OSC would be part of the  
16 emergency response teams and they would be subject to  
17 those limits, yes.

18 Now, in comparison to that we have the  
19 technical support center, the TSC. There is some  
20 guidance that pertains to habitability, specifically  
21 the habitability, radiological habitability.  
22 Specifically with respect to the TSC is that it must  
23 be comparable to the control room.

24 So we might see a common ventilation  
25 system. We might see something separate. But they're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 both required to meet general design criteria GDC 19  
2 with respect to doses, which includes getting into the  
3 Part 20.

4 Now, as far as the TSC is concerned, if  
5 the doses were to be exceeded or the habitability  
6 could not be maintained, whether it's radiological  
7 habitability or it's just the ventilation system went  
8 down and it got hot, they are allowed in NUREG 0696 to  
9 evacuate the technical support center where the  
10 management contingent in the TSC would relocate to the  
11 control room. That's the only group of people that  
12 would go there, not the entire TSC group.

13 So there is some habitability requirements  
14 pertaining to the TSC, in essence comparable with the  
15 control room.

16 I'm looking at the fourth bullet now. The  
17 DCD satisfied the TSC size/location/display/power. We  
18 had a number of RAIs that were responded to. We  
19 currently have two open items.

20 MR. FOSTER: Do you want to go on to the  
21 next slide for the RAIs?

22 MR. MUSICKO: Sure.

23 MR. FOSTER: Okay.

24 MR. MUSICKO: One specifically, and we're  
25 still reviewing the response, deals with -- this may

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 get into the number of people with the TSC. NUREG  
2 0696 addresses the number of people in the TSC,  
3 specifically the TSC working space shall be sized for  
4 a minimum of 25 persons including 20 persons dedicated  
5 by the licensee and five NRC personnel. This minimum  
6 size shall be increased if the maximum staffing level  
7 specified by the licensee's emergency plan exceeds 20  
8 persons.

9 And they have a criteria up above. This is  
10 section 2.4 dealing with the technical support center  
11 of NUREG 0696 that says that the working space without  
12 crowding for the personnel assigned to the TSC as a  
13 maximum level of occupancy, minimum size of working  
14 space provided shall be approximately 75 square feet  
15 per person.

16 I've had a chance to look at some TSCs  
17 over the years. And the amount of space that they  
18 afford for the five NRC personnel could be  
19 questionable with respect to 75 square feet. However,  
20 it's pretty easy to check it and, in fact, it's  
21 usually captured as an ITAC -- would be captured as an  
22 ITAC in a COL application safety evaluation report.  
23 And you can physically go out there with a tape  
24 measure if you want to, or just look at diagrams to  
25 verify. There's enough working space.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           The intent is that the working space is  
2           adequate to accommodate the tasks that are performed  
3           within the technical support center.

4           Moving right along. I think I've covered  
5           most of that.

6           In essence, there's usually a COL  
7           information action or COL action item that would  
8           identify the COL applicant as being responsible for  
9           providing the emergency plan.

10          Now there was a little bit of discussion  
11          earlier about the emergency procedures. You need to  
12          distinguish between emergency operations procedures  
13          and emergency implementing procedures, emergency plan  
14          implement procedures, which are in essence the  
15          procedures the emergency response personnel would use  
16          to carry out the responsibilities to initiate certain  
17          actions, notify state agencies in that site. In  
18          contrast, the emergency operation procedures, those  
19          are procedures that pertain to the operation of the  
20          plant itself. That does not fall within the scope of  
21          our section, emergency planning or emergency  
22          preparedness except to the extent that items such as  
23          the emergency action levels, EALs, which would be part  
24          of their emergency plan implementing procedures would  
25          initiate an action in an emergency operation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 procedure.

2 So there's basically two sets of  
3 procedures.

4 In addition to the possible on-site  
5 facilities that may be addressed in a certified  
6 design, again you have the operational support center,  
7 OSC, technical support center, TSC. The EOF,  
8 emergency operation facilities would not be addressed  
9 because that's an off-site facility and would be  
10 applicant specific, licensee specific. And could be  
11 located near a site, it could be located farther away.  
12 It could be a common EOF associated with one licensee  
13 or one utility that has a number of plants. There's  
14 a tendency now to combine that effort into one EOF and  
15 vary the location from the plants. So we would not  
16 expect the EOF to be part of the design certification.

17 And in some cases you might for a  
18 certified design identify a specific location for  
19 decontamination facility, maybe an HP area, health  
20 physics area.

21 So there's some flexibility with respect  
22 to the extent to which an applicant for a certified  
23 design may address certain EP related facilities or  
24 equipment. But in general we tend to see just the TSC  
25 location and size. There may be a little additional

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 information such as capabilities to receive certain  
2 information associated with the plant.

3 MEMBER STETKAR: Bruce?bm

4 Yes.

5 MEMBER STETKAR: You may have gone through  
6 this, but I'm not as familiar with the regulations and  
7 requirements as most people are.

8 Is there a requirement to maintain the  
9 information displays and habitability of the TSC for  
10 longer than 2 hours in station blackout?

11 MR. MUSICKO: Yes. Yes. It's for the  
12 duration of the accident.

13 MEMBER STETKAR: Will the GEH design  
14 satisfy those?

15 MR. MUSICKO: Well, what I can say, I'm  
16 not sure of the exact details and feel free to jump in  
17 if you can add to it, what we're seeing is that there  
18 is a 72 hour power capability which they get off  
19 batteries that support the habitability of the TSC  
20 assuming you can have -- or you have backup power. I  
21 think there's backup power for GE, but you can address  
22 that if you'd like.

23 MEMBER STETKAR: Yes.

24 MR. BEARD: Okay. Alan Beard, GEH.

25 I need to take exception to what Bruce

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 said. We're not providing a 72 hour safety related  
2 capability of electrical power to the TSC. It's not  
3 required.

4 We do have the capability from either one  
5 of our on-site nonsafety diesels to power the  
6 necessary loads within the technical support center.  
7 Either one of those diesels operating gives us the  
8 necessary power. We've got enough fuel oil on site to  
9 run those diesels for at least 72 hours.

10 MEMBER STETKAR: I asked about a station  
11 blackout, though?

12 MR. BEARD: Well the technical -- we  
13 haven't gone into the definition of station blackout  
14 because station blackout assumes you have safety  
15 related diesels.

16 MEMBER STETKAR: Let me succinct then. In  
17 the event that there is no AC power available on site  
18 from any supply whatsoever is there a requirement that  
19 the technical support center, a requirement that the  
20 technical support center be operable for longer than  
21 two hours?

22 MR. BARSE: This is Dan Barse, Team Leader  
23 for Emergency Preparedness.

24 I believe the answer to that is no. And  
25 that they would evacuate the TSC and go to the control

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 room, this is what would happen.

2 MEMBER STETKAR: I was asking about the  
3 requirement. I knew I'd get you to say something.

4 MR. MUSICKO: Well, there is some  
5 flexibility with respect to the TSC. After the Three  
6 Mile Island accident the TSC concept was brought up in  
7 regard to how close it was to the control room.  
8 Because the TSC basically relieved the control room of  
9 certain communication responsibilities so the  
10 operators could concentrate on fixing the plant,  
11 operating the plant not having to notify off-site  
12 agencies. And we came up with a guidance with respect  
13 to the TSC's location where it would be approximately  
14 two minutes walking distance from the control room so  
15 you could have runners basically -- or walkers in case  
16 going back and forth.

17 Now if you remember those times, and I do,  
18 at those times the technology wasn't quite that  
19 advanced. And one of the most sophisticated pieces of  
20 equipment that I recall was a fax machine that had  
21 just come into being. But none of the engineers,  
22 including myself, knew how to operate a fax machine.  
23 And so we had to get a specialist or a secretary to  
24 come in and tell us how the paper went in and how to  
25 operate it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           We're seeing a change in that recently in  
2           regard to the advanced communication capabilities that  
3           now exist. So there is some flexibility within the  
4           place of the location of the TSC.

5           If you look at section 13.3 of the  
6           standard review plan you'll see that we've addressed  
7           that that there is some flexibility if they can make  
8           the case that there is advanced communication  
9           capabilities that would provide for the intended  
10          purpose of having a quick back-and-forth discussion  
11          between the control room, the TSC, if their  
12          communications broke down.

13          So it was a backup to the control room  
14          where if your communications went down, you could run  
15          to the control run and get information.

16          So the location is fluid right now.

17          Now in addition to that we're seeing a  
18          future trend coming in that where you have an existing  
19          plant which may have a two unit plant which may have  
20          one TSC, if they're going to add two additional units  
21          where the certified design may certify a specific  
22          location for a TSC, if you were to add two additional  
23          reactors to an existing site, then would you have  
24          three TSCs? And then you get into trouble or a  
25          concern with respect to okay if you're going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 activate a TSC, which one do you activate? If you  
2 have an accident effecting more than one unit, are you  
3 can activate two TSCs?

4 So we're seeing a trend coming where there  
5 may be a common TSC for the entire site, which makes  
6 it a lot simpler.

7 Also a TSC that may be located outside of  
8 the annex building or near the reactor building from  
9 a security standpoint in case there was a threat, a  
10 security threat, would it could not be possibly taken  
11 out at the same time the control. Maybe have a back  
12 facility located separately. Maybe a plane hitting  
13 the site, for example. So there's a benefit to that.

14 MR. FOSTER: Thank you, Bruce.

15 Any more questions on emergency  
16 preparedness.

17 MEMBER SIEBER: Yes. Just so everybody  
18 understands, as you move from unusual event to where  
19 the site area to general, the emergency 4  
20 classification, the organization changes. And the  
21 person who is charge of the emergency changes as you  
22 step up through those things. And that is, besides  
23 the fact that everybody would rush to the control room  
24 when something bad is going on in the plant, that's  
25 one of the reasons why locations and facilities were

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 chosen the way they were.

2 MR. MUSICKO: That's the specific reason  
3 why the TSC was required about Three Mile Island.  
4 Because the control room --

5 MEMBER SIEBER: Because of the control  
6 room.

7 MR. MUSICKO: Right, wasn't big enough.

8 MEMBER SIEBER: Even Carter was there.

9 MR. FOSTER: All right. Next section is  
10 13.6 physical security.

11 MR. TARDIFF: Hi. My name is Al Tardiff.  
12 I work in the Reactor Security Branch in the Office of  
13 Nuclear Security and Incident Response. I'm going to  
14 present the physical security review on the ESBWR  
15 today.

16 Topics of interest include many security  
17 features are being identified through voluntary  
18 security assessments. The applicants on a voluntary  
19 basis are applying design basis threat scenarios and  
20 identify features associated with detection, delay and  
21 response to bolster the physical security posture of  
22 the facility.

23 Many of the issues still remaining within  
24 the review are focused towards taking credit for  
25 design features. Actually designing design features

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that they want to take for. Examples are delay  
2 features of door systems for adequate delay, cabinets  
3 that house the critical components, power supplies for  
4 communication systems and exclusion detection system  
5 and maintenance of those features identified.

6 Some of the issues to be resolved also  
7 include correction of previously made assumptions  
8 within the ESBWR analyses.

9 There are other open items, but they  
10 generally can be binned within a few categories.

11 The first bullet, accommodation of  
12 detection aids in the design. This looks at primarily  
13 with the vital area entrances.

14 Identification and design of unattended  
15 openings. Unattended openings are those unattended  
16 passages or openings through which -- at security  
17 barriers, such as culverts or HVAC ductwork.

18 Identification of special security areas  
19 and location and the design of unique physical  
20 protection measures for vital components. And that  
21 has to do -- that gets into the safeguards information  
22 or official use only information that has to do with  
23 unique features identified during security  
24 assessments.

25 All the outstanding issues are planned to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 be resolved through submission of technical reports.

2 COL information items. The COL information  
3 items include final design considerations for access  
4 controls, power supplies, unattended openings and the  
5 alarms for the unique features identified during the  
6 security assessments.

7 Also the administrative controls for  
8 unique features identified during the security  
9 assessments.

10 Capturing the COL information items and  
11 specifically attached to the unique features  
12 identified ensure a smooth transition of these unique  
13 features from the design into the COL.

14 MR. FOSTER: That is it.

15 MEMBER MAYNARD: I don't want to get into  
16 any of the details, I just want to -- on the security.  
17 Has a review encompassed taking a look at security  
18 versus what impact that may have on operations and  
19 responding to an emergency? You know, some of the  
20 things may be great for security but it may inhibit  
21 the operator from doing what's needed. I was just  
22 curious if that's part of the review in what you're  
23 looking at?

24 MR. TARDIFF: As part of the voluntary  
25 review we asked them to look at those types of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 effects. It is not a requirement today.

2 The proposed 7358 does have a safety  
3 security interface requirement. So we are asking the  
4 question while they're not required to put in  
5 provisions for that at this time.

6 CHAIRMAN CORRADINI: Any other questions  
7 from the Committee?

8 MEMBER BLEY: Just to follow up what Otta  
9 said. When the staff looks, you raise those questions  
10 yourselves and is that a source of generating RAIs  
11 back to these folks?

12 MR. TARDIFF: Yes.

13 MR. BARSE: This is Dan Barse.

14 And I would in the emergency preparedness  
15 area also we look at that or we have that consciously  
16 in mind when we do review as to what impact, you know,  
17 would a security barrier or a security event have on  
18 responders either getting to the site or being in a  
19 safe place during the event if it's a terrorist-type  
20 attack. Those are the considerations that we look at.  
21 And we would be asking in the RAI. So we didn't seek  
22 discussions of that.

23 MEMBER BLEY: Thank you.

24 CHAIRMAN CORRADINI: Other questions.

25 So I guess this is a point that if we have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 questions that need to go into closed session, I  
2 wanted to see if the Committee members have anything.

3 Jack? Graham?

4 MEMBER ARMIJO: No. I just didn't  
5 understand the agenda. I thought there was something  
6 that was -- we can go into it fine.

7 CHAIRMAN CORRADINI: There was no plan. We  
8 can go into it if we need to, but only if we need to.

9 MEMBER MAYNARD: Will we have an  
10 opportunity at some point to review security in more  
11 depth for this design?

12 DR. WALLIS: I think there's a better time  
13 and place, isn't there?

14 MEMBER SIEBER: It depends on how old you  
15 are.

16 MS. CUBBAGE: If you're talking about the  
17 integration of security into the standard design,  
18 I mean this is the time to ask those type of  
19 questions. You were provided, I believe, through Gary  
20 the safeguards reports and these additional topical  
21 reports that GE referred to haven't even been  
22 submitted yet. We'll be expecting those any day. We  
23 can get those to you as well.

24 This is the time if you want to --

25 MEMBER MAYNARD: I think the majority of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 mine would probably come more at the COL stage than  
2 looking at the --

3 MS. CUBBAGE: Right. At the COL stage.  
4 Yes, that would be the more programmatic aspects of  
5 physical security. And anything that's outside of the  
6 nuclear island.

7 DR. WALLIS: Well, there are some things,  
8 though, which can be done at the design stage which  
9 could make a significant difference. And we have  
10 actually emphasized that in our letter. And hope at  
11 sometimes, and probably not here, we want a chance to  
12 look at those.

13 MEMBER BONOCA: But this is tied to the  
14 conduct of operation, this portions, I would suspect.

15 DR. WALLIS: Right.

16 MEMBER BONOCA: It's more like force-on-  
17 force and issues that --

18 MS. CUBBAGE: The force-on-force aspects  
19 are the COL stage. Integrating security into the  
20 design is at this stage. At this point a lot of that  
21 is voluntary, as Al as alluded to in his presentation.  
22 If you want to get into that in more detail, this is  
23 the venue.

24 CHAIRMAN CORRADINI: I don't sense a great  
25 urgency by the group to jump into closed session and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 talk about it at this point. So I think we'll pass at  
2 this point.

3 MS. CUBBAGE: Right. And then there is a  
4 rule out for public comment right now on aircraft  
5 assessment. That is something that we have not gotten  
6 into detail yet on this review. But should that rule  
7 become effective, then we need to address that as a  
8 requirement in this design.

9 MEMBER BONOCA: We will be reviewing that  
10 rule, and we will comment on that probably in the  
11 March time frame. But I would expect that that has  
12 nothing to do with what you would presenting today  
13 here.

14 CHAIRMAN CORRADINI: No.

15 MS. CUBBAGE: No.

16 MEMBER STETKAR:

17 MEMBER STETKAR: Does the fire hazards  
18 analysis evaluate impacts on the portion of the  
19 security systems that are included in the design. I'm  
20 thinking about power supplies, signals, things like  
21 that.

22 MS. CUBBAGE: Al, I don't if you have  
23 anything to add on that? I know fire protection --

24 MEMBER STETKAR: I am looking at a yes or  
25 no.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. UPTON: This is Huge Upton with GEH.

2 The actual fire hazard analysis just takes  
3 a look at the combustible loads in each one of the  
4 rooms and then determines what fire protection  
5 mechanisms are necessary to fight those fires,  
6 sprinklers and that sort of thing. So it doesn't-- the  
7 question is I don't think it addresses what you're  
8 after.

9 DR. WALLIS: Go back to something we had  
10 earlier about the control room. In the control room  
11 they've apparently gone away from bottled air to  
12 external air. Now if there's an all encompassing  
13 fire, it doesn't do much good to bring in external  
14 air. But that there are some considerations here  
15 which could be important at this stage, not at some  
16 later stage. But I'm not sure we want to go into that  
17 today.

18 CHAIRMAN CORRADINI: Well I think if we  
19 do, we'll have to do it in a different venue.

20 DR. WALLIS: Yes.

21 MS. CUBBAGE: I mean we're prepared to go  
22 into the closed session if you want to do that. And it  
23 may be short, but --

24 DR. WALLIS: No. I think there's another  
25 place and another time, isn't there, for this sort of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 thing?

2 MS. CUBBAGE: No. Not really.

3 MEMBER SIEBER: Well, apparently not.

4 MS. CUBBAGE: That's what I'm trying to  
5 tell you. We want to hear --

6 CHAIRMAN CORRADINI: It could be in the  
7 COL stage for a specific application. But at the DCD  
8 stage, this is it.

9 MEMBER STETKAR: I think if it has  
10 anything to do with physical location of the security  
11 center or its environmental controls or power  
12 supplies, this is the time.

13 MS. CUBBAGE: Or any voluntary actions.

14 DR. WALLIS: But the concern I would have  
15 would be with actual features of the design itself,  
16 which design to resist certain events. Is that  
17 something--

18 MS. CUBBAGE: There's here.

19 CHAIRMAN CORRADINI: That's here and now.  
20 Granted, at --

21 DR. WALLIS: But that could go on for a  
22 long time. Do you have a big presentation or  
23 something?

24 MS. CUBBAGE: We don't have a  
25 presentation, but we --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. WALLIS: Well in that case, if you're  
2 not prepared, I'm not sure I want to ask any  
3 questions.

4 MEMBER APOSTOLAKIS: Right.

5 MR. TARDIFF: We could probably answer the  
6 questions that you ask, though.

7 MS. CUBBAGE: Right. We didn't bring  
8 paper that would have to be protected and taken back.

9 DR. WALLIS: Well, personally I think that  
10 this is an important enough subject that it may be --  
11 should be subject that you actually have a closed  
12 section devoted to it. Not something you just slip in  
13 like this when someone wants to do it. But you  
14 actually prepare something.

15 CHAIRMAN CORRADINI: Why don't I take that  
16 back and talk with Amy about it. Because I don't  
17 think they're prepared for it now and I don't think  
18 that we're generate questions --

19 MS. CUBBAGE: Well, I think Al would be  
20 happy to answer. I mean, it's not that he's not  
21 prepared. We just don't have handouts.

22 MR. FOSTER: Yes, we take you -- the slides  
23 that we have the physical security to elaborate in  
24 these areas.

25 MEMBER ARMIJO: So you're prepared to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 describe it?

2 MR. FOSTER: Yes.

3 MEMBER ABDEL-KHALIK: Without us having to  
4 ask a question and extract something?

5 MEMBER SIEBER: It's important when you  
6 think about standardizing all of this stuff in the  
7 area of security I think that it lessens security to  
8 have everything standardized so that no matter what  
9 plant you go to, you know what door to go in.

10 MS. CUBBAGE: The other thing I'll offer  
11 is -- go ahead. The other thing I'll offer is that  
12 the closed session was intended for an opportunity for  
13 GE if they chose to, they could describe some of the  
14 features that they have voluntarily incorporated into  
15 the design.

16 MR. TARDIFF: Are the unique features that  
17 I keep alluding to.

18 MEMBER ARMIJO: Right. And I'm just  
19 getting very curious and we're not going to talk about  
20 it.

21 CHAIRMAN CORRADINI: Did you have  
22 something you wanted to add?

23 MR. KINSEY: This is Jim Kinsey from GE.

24 I guess we're in the same situation as the  
25 NRC staff. We're prepared to answer questions and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 discuss the features that we've built into the plant  
2 if you're interested in talking through that today.  
3 This is probably the --

4 MEMBER MAYNARD: I would recommend we go  
5 ahead and go into close session for maybe 15 minutes  
6 and at least identify whether we need another session  
7 or answered their questions or whatever.

8 MEMBER SIEBER: Maybe we have to ask the  
9 Designated Federal Official if this room is good  
10 enough.

11 MR. HAMMER: If it's on the agenda, we can  
12 do it.

13 MEMBER MAYNARD: Well, is it just close  
14 session because it's safeguards?

15 MS. CUBBAGE: Not safeguards.

16 MR. TARDIFF: It's not safeguards.

17 MS. CUBBAGE: Not safeguards. Right, All.  
18 You would be able to keep it at a nonsafeguards but  
19 security related level?

20 MR. TARDIFF: No.

21 MS. CUBBAGE: You have to go safeguards?

22 MR. TARDIFF: Yes.

23 MS. CUBBAGE: Okay. And is this room  
24 appropriate if you shut the door?

25 MEMBER SIEBER: Well, you said it's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 safeguards?

2 MS. CUBBAGE: And we just have to shut  
3 that door.

4 CHAIRMAN CORRADINI: Two of our members  
5 will have to --

6 MEMBER APOSTOLAKIS: When we go to the  
7 room upstairs, they can't come here --

8 (All talk at once).

9 CHAIRMAN CORRADINI: So I don't think with  
10 a red badge they're allowed to stay and discuss it  
11 based on what I understand.

12 MEMBER BLEY: We couldn't get the  
13 documents.

14 CHAIRMAN CORRADINI: So I don't think if  
15 they can't get the documents, they can't have the  
16 discussion.

17 MR. TARDIFF: You could have a red badge  
18 and still be safeguards cleared in matters if you are  
19 red badged and are safeguards cleared.

20 CHAIRMAN CORRADINI: I'm not going to take  
21 the chance.

22 MEMBER STETKAR: Well, we haven't been  
23 informed that we've been cleared.

24 MEMBER BLEY: And we asked to get the  
25 documents and they said we have to wait until the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 process goes further.

2 CHAIRMAN CORRADINI: So should we go into  
3 a short closed sessions on it.

4 MEMBER APOSTOLAKIS: Let's do that.

5 CHAIRMAN CORRADINI: Okay.

6 (Whereupon, off the record at 2:45 p.m.  
7 until 3:20 p.m.)

8 CHAIRMAN CORRADINI: Jim, do you want to  
9 lead us off here?

10 MR. KINSEY: This Jim Kinsey GE Hitachi  
11 of. We're going to present an overview of the Chapter  
12 16 if the draft control document Technical  
13 Specifications.

14 And I'd like to ask Dan Williamson who  
15 give an overview of the tech specs.

16 MR. WILLIAMSON: Good afternoon.

17 Going to cover today, as the agenda shows,  
18 with some help here, really briefly cover the  
19 philosophy we used and the methods we used to develop  
20 the ESBWR generic tech specs that are in Chapter 16  
21 and 16B of the DCD, 16B being the bases.

22 We'll also discuss some differences that  
23 exist in the specs, differences from existing fleet  
24 tech specs, which you're familiar with. And then  
25 we'll discuss some of the COL applicant items that are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 there, like the applications we'll deal with when they  
2 may come in.

3 And I understand, I've been told that I  
4 don't have to encourage you to ask questions. Please  
5 feel free at any point in time.

6 In the development of the ESBWR tech specs  
7 we started with the latest BWR standard tech specs in  
8 the existing fleet, the BWR-6 NUREG 1434. And we also  
9 utilized the latest generic changes to those specs and  
10 have been keeping up with generic changes even over  
11 the last couple of years.

12 MEMBER ARMIJO: I got to ask.

13 MR. WILLIAMSON: Yes, sir.

14 MEMBER ARMIJO: Why did you start with the  
15 BWR-6 tech specs as opposed to the ABWR tech specs?  
16 I mean ESBWR is pretty different from all the others.

17 MR. WILLIAMSON: Good question. Good  
18 question.

19 MEMBER ARMIJO: But why not the ABWR?

20 MR. WILLIAMSON: Good question. The ABWR  
21 tech specs when they were developed, they were  
22 developed at a time when the BWR standard, the BWR-4  
23 and 6 standards were being finalized. So the ABWR  
24 tech specs actually started with a pre-REV 0 look at  
25 NUREG 1433, in that case. So in fact the more later

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and greater tech specs are reflected in the BWR-6  
2 standard.

3 MEMBER ARMIJO: Okay.

4 MR. WILLIAMSON: And the ABWR specs were  
5 basically frozen at that time and haven't kept up with  
6 the generic change process and all. But certainly  
7 they were a desk reference as were the SBWR tech  
8 specs. So we weren't exclusive to the BWR-6 standard,  
9 but that did form the basis. It gave us our standard  
10 content, numbering, form and format for consistency in  
11 the presentation, which facilitates the NRC review in  
12 reviewing the prior reviews they had done on passive  
13 plant certification. They tended to follow a  
14 comparison to the existing standard.

15 MEMBER ARMIJO: Okay.

16 MR. WILLIAMSON: This also provides SRO  
17 familiarity. When we go into training SROs that are  
18 coming from the existing fleet, they're going to have  
19 tech specs that they're used to seeing, they're very  
20 comfortable with.

21 MEMBER APOSTOLAKIS: I have a question.  
22 You know that it's a lot of work to risk-inform these  
23 tech specs. Do you remember this end stop business  
24 has been approved? But my question is does all these  
25 work of the lats few years on risk-informing this kind

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of stuff, does it play any role in here, or is going  
2 again the future licensees would have to request to go  
3 to a risk-informed regime?

4 MR. WILLIAMSON: The standard tech specs,  
5 the NUREG 1434 there are efforts underway and have  
6 been for a few years to do risk-informed generic  
7 changes. There's a separate little subcommittee that  
8 has many tasks that look at risk-informed  
9 improvements. Those improvements that have been  
10 approved and adopted, staff has written SERs on. To  
11 the extent they're applicable to the ESBWR design,  
12 they show up as part of the ESBWR tech specs.

13 It is not a complete risk-informed rewrite  
14 of the tech specs. I know there are future plans for  
15 some of that.

16 So there are pieces that have these risk-  
17 informed improvements on a case-by-case basis. And,  
18 again, our focus point was to provide -- to start with  
19 something that was easy for the -- something that was  
20 firm and known. Not to create something brand new for  
21 the staff to review and approve. So we started with  
22 the standard as it exists today, the applications, the  
23 risk-informed pieces that are approved today. And  
24 that positions the ESBWR also to continue to follow  
25 the rest of the fleet as they move forward with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 additional improvements and additional changes.

2 MEMBER SIEBER: If the opportunity arises  
3 during your presentation, would you point out an  
4 example of a risk-informed tech spec?

5 MR. WILLIAMSON: Sure. I will do that.  
6 Remind me because it isn't something I would have  
7 gotten into. But there probably will be a more  
8 appropriate time to do that.

9 MEMBER SIEBER: Just a simple one.

10 MR. WILLIAMSON: Okay. Well, we're  
11 talking about it now, might as well. Some of what's  
12 called the motherhood, the 3.0s, the how you use tech  
13 specs.

14 MEMBER SIEBER: 3.0.4?

15 MR. WILLIAMSON: 3.0.3, 3.0.4. In fact  
16 there was missed surveillance, SR 3.0.4 --

17 MEMBER SIEBER: Right.

18 MR. WILLIAMSON: -- that had some risk-  
19 informed looks. And what was done, essentially the  
20 risk-informed pieces show up in the bases. That if  
21 you miss a surveillance, you're allowed a time to--

22 MEMBER SIEBER: Point five percent?

23 MR. WILLIAMSON: Well, in fact the risk-  
24 informed pieces said you essentially have another  
25 frequency interval to go complete that surveillance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 provided you look at your maintenance rule. You put  
2 this issue into your maintenance rule evaluation. And  
3 so there's some references in the bases that  
4 essentially commit you to a maintenance rule look for  
5 that particular writing. And so the ESBWR bases have  
6 that same commitment to do that kind of maintenance  
7 rule activity on a missed surveillance.

8 MEMBER SIEBER: Yes. But the LCOs remains  
9 the way it was?

10 MR. WILLIAMSON: Right. The LCOs and the  
11 surveillance actions --

12 MEMBER SIEBER: Remains the way it was?

13 MR. WILLIAMSON: Exactly.

14 MEMBER SIEBER: And so when you got to the  
15 bases, you're actually outside of what the DCD would  
16 have as an approved occupant, right?

17 MR. WILLIAMSON: Well, the bases are part  
18 of what the staff required in approving this change  
19 for the fleet. And this is a fleet change that all  
20 the PWRs and BWRs have today.

21 MR. KINSEY: And the bases with that  
22 discussion are a part of the DCD, or a part of the  
23 document that's certified by the staff.

24 MEMBER SIEBER: Yes, but the staff doesn't  
25 approve it, do you or do you?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. CUBBAGE: We do. It doesn't have the  
2 same degree of finality as the rest of the  
3 certification. And when we issue a combined license,  
4 they will have tech specs that are based on the  
5 standard and become part of that license.

6 MEMBER SIEBER: Okay.

7 MEMBER APOSTOLAKIS: Now let me understand  
8 this in simple terms. Are we certifying designs and  
9 eventually the COLs, approve the COL and we are  
10 perpetuating the dual system that we have for existing  
11 LWRs?

12 MR. WILLIAMSON: Yes.

13 MEMBER APOSTOLAKIS: That's what we're  
14 doing at a higher level? We take deterministic stuff  
15 and improvise and still later wants to be published in  
16 form, they have to come here and use the appropriate--  
17 but they are not using risk-informed measures--

18 MEMBER SIEBER: One change at a time.

19 MEMBER APOSTOLAKIS: One change at a time.

20 MEMBER SIEBER: One change at a time. Yes.  
21 Or you can group them together. But it's not going to  
22 be a new standard tech spec document, as far as I can  
23 see.

24 MS. CUBBAGE: I don't think anything would  
25 have precluded GE from proposing a risk-informed tech

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 spec approach. It would have been a much more complex  
2 review, and this is what they opted to do was to base  
3 it on the standard.

4 MR. WILLIAMSON: It facilitated the  
5 schedule that was laid out for both us and the staff  
6 to reach certification, but not try to introduce  
7 something that was nonstandard.

8 MEMBER APOSTOLAKIS: Well, maybe it's  
9 fundamentally that we have really risk-informed the  
10 GPCs or rules. We have issued regulatory guides but  
11 basically the fundamental regulations would not be  
12 risk-informed.

13 MS. CUBBAGE: That's right.

14 MEMBER APOSTOLAKIS: And the ECCS rule  
15 that is in the works would be the first major, if it  
16 ever passes.

17 MS. CUBBAGE: Right. And then --

18 MEMBER APOSTOLAKIS: Right? The same with  
19 the licensees or the vendors the same way. We have to  
20 go back to the books.

21 MS. CUBBAGE: Right. The technology-  
22 neutral licensing framework, that's down the road that  
23 if whenever --

24 MEMBER APOSTOLAKIS: Or for next month --

25 MS. CUBBAGE: Yes. Yes. That's what I'm

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 saying. I mean, there's been potential for some  
2 radical licensing approaches, but not in the time  
3 frame that they're looking for a certification.

4 MEMBER APOSTOLAKIS: Yes, and I think  
5 that's a problem. Not problem. I mean this is the  
6 root cause is that the regulations themselves have not  
7 been risk-informed.

8 MEMBER SIEBER: Right.

9 MEMBER APOSTOLAKIS: And everything else  
10 is on the side.

11 MR. WILLIAMSON: Yes. Speaking of  
12 regulations --

13 MEMBER APOSTOLAKIS: It's about time we  
14 speak about regulations.

15 MR. WILLIAMSON: Starting with the  
16 standard BWR-6 standard is really just a starting  
17 point. That just kind of gives us a basket to work in  
18 and creates the standard look and feel. And it gives  
19 us a good scope of are we including enough of the  
20 right stuff. But the reality is 10 CFR 5036 will  
21 dictate the actual content of tech specs.

22 Having gone through back in the day when  
23 Grand Gulf was licensed when the first BWR-6 came  
24 along and used the BWR-5 standards, there are lessons  
25 learned in making this kind of transitions. And we're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 not ignorant of those lessons that were learned. It  
2 is a key and it is a route of 5036 that you may take  
3 your design specific safety analysis and the design  
4 specific systems that you have and evaluate them  
5 against the criterion in 5036, four criterion.

6 And so that's where the real rubber begins  
7 to meet the road. And in ESBWR we did do that,  
8 provided a detailed -- in one of our RAI responses in  
9 fact we documented a very detailed look at the safety  
10 analysis and the specific systems that ESBWR had  
11 against the criterion of 5036.

12 So it's very much a key that the design  
13 drives what the tech specs are. They're simply a  
14 reflection, operating reflection of what the design  
15 is.

16 We also took advantage of the fact that we  
17 have perspective clients. We have real SROs that have  
18 been involved in the review of the development of the  
19 tech specs. And we've factored in their comments,  
20 both in a useability review and in making sure tests  
21 can be performed and the light.

22 I also wrote myself a note. There was a  
23 question earlier about we'll defer that to Chapter 16.  
24 I believe it was a question about off-gas or --

25 MEMBER ARMIJO: Yes. Steam jet air

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ejector.

2 MS. CUBBAGE: For the gland seal.

3 MR. WILLIAMSON: Yes. We did have a tech  
4 spec 373 if you have your specs memorized on off-gas  
5 system. Yes, it might have been renumbered at one  
6 time. Yes, there is a tech specs on off-gas activity.

7 And I wasn't sure exactly what the  
8 question was. 10 CFR 5036(a) also mandates tech specs  
9 on effluent controls. A lot of the admin control  
10 section of tech specs is what meets that regulation  
11 and provides for procedures and controls on effluent  
12 releases and reporting and the things that come under  
13 5036. But in addition to that, there is the one spec  
14 on the steam jet air ejector off-gas activity.

15 MR. KINSEY: So does that answer the  
16 question from earlier, or series of questions? You  
17 think so?

18 MR. WILLIAMSON: Differences; that's how  
19 we're the same as the current fleet. Now some of the  
20 differences, obviously the ESBWR is a passive design.  
21 And as you've been hearing, the passive design results  
22 in a reduction in number of systems. Certainly results  
23 in a number of active systems. Diesel generators are  
24 not credited in the event so we don't have tech specs  
25 on diesel generators.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   There's no safety pumps or MOVs. So these  
2                   are some differences, obvious differences that you're  
3                   going to run into.

4                   The ECCS system is different for the ESBWR  
5                   relying on passive gravity drain systems, squib  
6                   valves. So we have developed ECCS inoperability  
7                   actions and we're still working on those. Those are  
8                   things that are still part of the open items that  
9                   we're working with the NRC on. But the new ECCS  
10                  design will dictate new ECCS actions.

11                  In general, I think it was a bullet on a  
12                  previous slide. We tried to maintain -- when the  
13                  systems were the same, we tried to maintain the same  
14                  actions and surveillances that the existing fleet has.  
15                  But, obviously, ECCS would be a case outside of that  
16                  box.

17                  MEMBER APOSTOLAKIS: So, I need to be  
18                  educated here. I understand how in an active system  
19                  situation you have months tests of pumps and so on.  
20                  How do you test the passive system?

21                  MR. WILLIAMSON: The tests in large part--  
22                  well, the squib valves are -- you got mini checks on  
23                  the squib valves.

24                  MEMBER SIEBER: To test the active part.

25                  MR. WILLIAMSON: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: You also change or do  
2 so some sort -- I think it was some sort of random  
3 checking of the charge, right?

4 MR. WILLIAMSON: Exactly. The squib  
5 valves set of things that are done. And then the  
6 other side of the system is the pool. And so there are  
7 surveillances on pool level temperature. So a lot  
8 less surveillance is on a passive system then you  
9 would find on a HPCI/RCCI

10 MEMBER APOSTOLAKIS: That's it. You make  
11 sure you have enough water.

12 MR. WILLIAMSON: Make sure you have  
13 enough--

14 MEMBER APOSTOLAKIS: And at the right  
15 temperature?

16 MR. WILLIAMSON: Enough water at the right  
17 temperature. And you got a squib valve that's going  
18 to fire. And there's the instrumentation side of the  
19 world which is the specs are divided in  
20 instrumentation and systems and so --

21 MEMBER ABDEL-KHALIK: How do you do  
22 periodic checks to make sure that there is no trap  
23 noncondensable gas?

24 MR. WILLIAMSON: A design question like  
25 that I would normally defer to design engineering.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 The system is open at the pool end, so I'm not sure  
2 gases would be trapped --

3 MR. UPTON: This is Hugh Upton with GEH.  
4 I'll take that question. But you have ask  
5 specifically what are you talking about. If you're  
6 talking about the ICs, the ICs have a noncondensable  
7 vent to the suppression pool.

8 MEMBER ABDEL-KHALIK: No. There are some  
9 parts in the piping where you have a check valve and  
10 then you have one of those squib valves. So it is  
11 possible for a noncondensable gas to be trapped  
12 between those two valves, unless you have some startup  
13 procedure that prevents that from happening.

14 MEMBER APOSTOLAKIS: Is not water there  
15 for a long time, for years, does it ever circulate at  
16 all?

17 CHAIRMAN CORRADINI: May I ask a question  
18 just to interject just to help the question with  
19 George?

20 So maybe I'm missing something. So with  
21 the isolation condenser you could, if you so chose as  
22 you're coming down for maintenance or refueling, to  
23 essentially exercise the isolation condenser, open the  
24 valves and essentially reject heat that way just to  
25 verify operation, close up and let it refill, right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Nothing stops you from doing that?

2 MEMBER APOSTOLAKIS: That is --

3 CHAIRMAN CORRADINI: Well, that was my  
4 next question. First, am I right that you can do that  
5 because it nitrogen operated with an accumulator  
6 backup? So do you? Is it part of the ongoing at a  
7 refueling or ever so many times to actually say, okay,  
8 let's just put it on the isolation condenser make sure  
9 everything is hunky dory and then come back off, or is  
10 that not part of the plan is the question?

11 MR. UPTON: This is Hugh Upton with GEH.

12 Typically what's done is during  
13 construction there is going to be pre-opt testing and  
14 startup testing on the ICs. That's when the capacity  
15 will be demonstrated.

16 I don't believe that there's periodic  
17 surveillance to demonstrate the heat transfer  
18 characteristics of the IC or --

19 MR. WILLIAMSON: Or any sort of  
20 degradation because of --

21 MR. UPTON: But again, let me say that the  
22 design assumes a very conservative fouling factor on  
23 both the ICs and the PCCS.

24 CHAIRMAN CORRADINI: But let me just  
25 finish on this one and then I'll turn it back to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 George. But just to use any analogy, what is the  
2 current regulation for containment leak rate testing  
3 and wouldn't it be logical that a containment, which  
4 is the best example in a current plant of that passive  
5 system, that has to be at some periodic thing go  
6 through a containment leak rate test. You would do  
7 some sort on a passive basis a test such as an  
8 insolation condenser? It seems that's the logical  
9 analogy for a current operating plant.

10 MR. UPTON: For the PCCS is part of the  
11 containment. So the containment leak rate test will  
12 demonstrate leak type integrity for the PCCS.

13 MS. CUBBAGE: There's a surveillance  
14 requirement in the tech specs to verify each ICs train  
15 is capable of removing the required heat load every 24  
16 months. I don't know how that's done, but it's in  
17 there.

18 MEMBER ARMIJO: It is a requirement. They  
19 have to figure out.

20 MEMBER APOSTOLAKIS: Say it again, what?

21 CHAIRMAN CORRADINI: No. She's repeating  
22 what is a requirement for maintenance.

23 MS. CUBBAGE: Surveillance requirement for  
24 isolation condenser is every 24 months verify each IC  
25 train is capable of removing the required heat load.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER APOSTOLAKIS: Right. So the  
2 question was how do you do that?

3 MS. CUBBAGE: I have no idea. That would  
4 be a question for GE.

5 MR. UPTON: I'm being advised that we can  
6 do that in-service testing an IC at a time.

7 MEMBER APOSTOLAKIS: So it's part of in-  
8 service testing.

9 MR. UPTON: That's what I understand.  
10 That's correct.

11 MEMBER APOSTOLAKIS: Okay. And so this  
12 would be every 24 months?

13 MS. CUBBAGE: On a staggered basis. Do  
14 one.

15 MEMBER APOSTOLAKIS: Yes, do one and then  
16 you do the other. Okay. And that's covered by tech  
17 specs?

18 MS. CUBBAGE: That is a tech specs  
19 surveillance requirement.

20 MEMBER APOSTOLAKIS: Yes.

21 CHAIRMAN CORRADINI: Thank you.

22 Does that help you with your class of  
23 questions?

24 MEMBER APOSTOLAKIS: Yes. Yes, absolutely.  
25 I thought that we were standing there.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. CUBBAGE: Well, that's the isolation  
2 condenser. I think --

3 MEMBER APOSTOLAKIS: I suspect that you  
4 would not be allowed --

5 MR. WILLIAMSON: And to tell you, ICS is  
6 one ECCS system, GDCS is another. There is a  
7 surveillance in GDCS to verify --

8 MEMBER APOSTOLAKIS: So all of these  
9 systems are subject to what Amy just read.

10 MR. WILLIAMSON: Well, GDCS will not  
11 inject. We won't do an injection test with GDCS. But  
12 we have a surveillance that was added in Rev. 4. It's  
13 not part of the Rev. 3 review. But in Rev. 4 we did  
14 add a surveillance based on an RAI that requires for  
15 GDCS to verify the flow path of each GDCS injection  
16 branch line and equalizing line is not obstructed.  
17 This would be kind of visual, likely borescope, kind  
18 of check on the GDCS line.

19 CHAIRMAN CORRADINI: And to remind me of  
20 the functioning of the system, would the GDCS that's  
21 a -- I'm going to get this wrong so I'll just say, is  
22 that some sort of squib valve, is that not correct.

23 MR. WILLIAMSON: True.

24 CHAIRMAN CORRADINI: Okay. So that's the  
25 way you do it by an unimpeded path from the once and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1       only once opening valve up through the line?  
2       Similarly, I would assume through your other pathways  
3       up to your squib valves. And then for the PCCS, how is  
4       that done? Because I have to go get a drawing to  
5       remind myself. I'm sorry.

6               MS. CUBBAGE: It's not filled with water.

7               CHAIRMAN CORRADINI: That's totally an  
8       open an line, is that not correct?

9               MR. WILLIAMSON: Yes, that's correct.

10              CHAIRMAN CORRADINI: Okay.

11              MR. UPTON: Now this is Huge Upton with  
12       GEH.

13              The PCCS is a totally passive, there are  
14       no valves in the system to operate.

15              CHAIRMAN CORRADINI: Okay.

16              MS. CUBBAGE: And it's not water filled.

17              MR. UPTON: And it's not water filled,  
18       exactly. It's open to the containment.

19              MEMBER ABDEL-KHALIK: How would you see in  
20       that last part, the part between the squib valve and  
21       the check valve?

22              MR. WILLIAMSON: Well, I don't have the  
23       procedures drafted, but in our discussions when we  
24       adopted this -- in the response to the RAI the  
25       discussion was it could be done with borescope. There

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 are test connections that are available that one could  
2 do a visual look into the piping.

3 So we verified that the surveillance was  
4 doable before we added to the tech specs.

5 MEMBER ABDEL-KHALIK: I think we sometime  
6 we ought to look at that. Because it just seems like  
7 there is a possibility that you can have one big glob  
8 of gas between these two valves, you open the squib  
9 valve and nothing happens.

10 MR. WILLIAMSON: Well, Hugh or Larry, I  
11 would defer to design engineering to answer this. But  
12 essentially if I've got a gravity fed -- I'm not sure  
13 that air would bind me if I'm gravity feeding the  
14 vessel.

15 MR. UPTON: Yes. Let me try and address the  
16 question.

17 This is Hugh Upton with GEH.

18 There's a couple of things that we need to  
19 know about the design of the GDCS system. First of  
20 all, the piping is going to be slopped back to the  
21 GDCS pool.

22 Secondly, the check valve itself is  
23 normally in the open position. It is not closed. So  
24 you're not going to be able to build up gas between  
25 the squib valve and the check valve. It will be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 drained back to the pool, which will then end up back  
2 in the containment if it's noncondensable.

3 MEMBER ABDEL-KHALIK: I guess this is  
4 going to be a detailed piping design problem. And  
5 perhaps, you know, you can design the pipe to  
6 eliminate the possibility altogether.

7 MS. CUBBAGE: I mean, do we need to take  
8 that one back or is GE taking that one back, or can  
9 they speak to would not the gravity head of water  
10 overcome this small amount of air in the line.

11 MR. TUCKER: This is Larry Tucker with  
12 GEH.

13 The check valve is to prevent flow coming  
14 from the reactor back to the pool. So in normal  
15 operation the pool is a higher level and the plant is  
16 slopped from the pool down towards the reactor with  
17 the check valve open. Okay. So there's no --

18 MS. CUBBAGE: And water against the squib.

19 MR. TUCKER: And water against up against  
20 the squib.

21 MR. UPTON: And water against the squib.  
22 That's correct.

23 MS. CUBBAGE: And then reactor water  
24 against the other side of the squib.

25 MR. TUCKER: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. UPTON: That's correct. That's correct.

2 MR. TUCKER: So there's no way that gas  
3 could build up in that line because it would bubble  
4 back up to the pool.

5 MR. UPTON: Right.

6 MS. CUBBAGE: Does that resolve the  
7 question?

8 MR. TUCKER: And then if the squib opens,  
9 if the reactor is at a higher pressure, the check  
10 valve goes closed to prevent backflow to the pool.

11 CHAIRMAN CORRADINI: Do you have more  
12 question, Said?

13 MEMBER ABDEL-KHALIK: No, I don't.

14 CHAIRMAN CORRADINI: Well, thank you.

15 MR. WILLIAMSON: Role of RTNSS, regulatory  
16 treatment of nonsafety systems. The subject came up  
17 earlier. It does show up in a few cases in the draft  
18 Chapter 16 SER. RTNSS is not really a tech spec issue  
19 or Chapter 16 issue, but I'm going to discuss it  
20 briefly simply because there is a little bit of  
21 overlap and it's probably useful to at least  
22 understand that overlap.

23 And the detail, the RTNSS evaluation and  
24 the RTNSS detail comes at Chapter 19, which will be a  
25 later meeting, so I'm not going to spend a lot of time

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 on it, nor did we bring anybody to really discuss in  
2 detail the RTNSS evaluation itself.

3 But in general, the RTNSS requirements  
4 look for an appropriate level regulatory oversight for  
5 these nonsafety systems that would be credited 0.72  
6 hours. And it looks to impose for certain systems  
7 that meet threshold, an appropriate availability  
8 control mechanism. And these are words are phrases  
9 from SECY-94-084, the Commission's policy on  
10 establishing this framework.

11 When this evaluation is done if there's an  
12 identification of a need for high regulatory  
13 oversight, that equates to us as meeting a risk  
14 criteria, one of the 5036 criterion for tech specs.  
15 And in the RTNSS evaluation that was done there has  
16 been one system identified that met that criterion,  
17 that would be the diverse protection system, the  
18 instrumentation associated with the diverse protection  
19 system.

20 Do that is a tech spec that is not yet  
21 drafted, but it's committed to be drafted as a result  
22 of the RTNSS evaluation.

23 There is another tier of items that can be  
24 identified from the RTNSS evaluation that would  
25 require a lesser level of regulatory oversight. And

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 these are the things that show up in the availability  
2 control manual. I believe Gary Miller mentioned about  
3 this availability control manual.

4 So many of the RAIs from the staff dealt  
5 with why isn't this system in tech spec or, you know,  
6 where is it. And so many of the responses and back and  
7 forth, and some of that's reflected in the SER, deal  
8 with this topic of the availability control manual.  
9 That no, it didn't meet tech spec threshold, but yes  
10 it is covered in the availability control manual.

11 So I did want to point that out it is a  
12 unique to passive plants issue, this RTNSS process.  
13 And that it does have potential impact specs, and in  
14 our case it did create one tech spec.

15 Another difference, assuming there are no  
16 questions, is that in the ESBWR design was actually  
17 implemented design change such that three of the four  
18 electrical divisions that are designed are all that's  
19 needed to satisfy safety. And two divisions actually  
20 that are needed, and it's all that's needed to satisfy  
21 all safety functions, and then the third division  
22 affords the single failure protection.

23 So the tech specs following the design and  
24 the safety analysis as they're dictated to do, have  
25 spec-ed three divisions that are required to be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 operable in the applicable nodes.

2 The tech specs also ensure by the  
3 construction, we made sure that they assure that all  
4 the circuits and logic and sensors and the power  
5 supplies are all on the same three divisions. There's  
6 no case that anybody can get confused and have three  
7 of these divisions of this kind of thing and three  
8 different divisions of power or whatever. So the specs  
9 are very detailed in prescribing that those three  
10 divisions are all the same three divisions.

11 And, again, focusing on the fact that any  
12 two divisions will accurate all safety systems is  
13 another unique design feature. That we don't really  
14 have a single division that actuates a single division  
15 of GECS, for instance.

16 So question?

17 MEMBER STETKAR: Yes. How do you account  
18 for the fact that, the way you presented it it sounds  
19 like all four divisions are equal and any three of the  
20 four are okay. In fact, any two of the four. That  
21 seems, from what I understand, to be mostly correctly  
22 but in some cases not correct. Because in a few cases  
23 there are a particular two divisions that provide  
24 safety functions, like divisions 1 and division 2  
25 only. Not divisions 1, 2, 3 or 4. So how to ensure,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 for example one of my favorite things, a remote  
2 shutdown facility panels that I was talking about  
3 earlier, one is supplied from division 1, one is  
4 supplied from division 2 period? So either that or  
5 the DCD is wrong.

6 CHAIRMAN CORRADINI: Can you repeat that  
7 so I understand it?

8 MEMBER STETKAR: According to the DCD the  
9 instrumentation systems in section 7 -- I've read  
10 ahead a little bit. The remote shutdown panels are  
11 powered from-- are division 1 and division 2. They're  
12 not four-fold-redundant. So that means that somehow  
13 division 1 and division 2 are somewhat different than  
14 division 3 and division 4 in my treatment. I would  
15 think that they should be different in my treatment of  
16 the tech specs. How do you account for that, or am I  
17 misinterpreting something on the DCD?

18 MR. UPTON: You may be misinterpreting.

19 This is Hugh Upton with GEH.

20 That was not our intent. The intent was  
21 that, for instance, one shutdown panel could be  
22 powered from divisions 1 and 3, while the other one  
23 would be powered from 2 and 4. Okay. So we have to  
24 take back under consideration.

25 CHAIRMAN CORRADINI: He specifically says

1 1 and 2.

2 MR. UPTON: We have to take that back.  
3 Well have to look into it. I'm not sure. We don't have  
4 the right people here to answer that question.

5 MS. CUBBAGE: It speaks to division 1 and  
6 2 safety related parameters being displayed.

7 MEMBER STETKAR: Right.

8 MS. CUBBAGE: So if you lose division 1  
9 and 2, I'm not sure what you're displaying the way  
10 it's written here.

11 MEMBER STETKAR: I am aiming at --

12 MS. CUBBAGE: I was looking at  
13 7.1.3.2.3.2.

14 MEMBER STETKAR: Right. Yes. I mean  
15 that's the first place I came across.

16 CHAIRMAN CORRADINI: I think you've piqued  
17 their interest and they're going to come and answer  
18 you.

19 MEMBER STETKAR: Yes.

20 MR. BEARD: Alan Beard with GEH.

21 Division 1 and 2, the existence of the  
22 remote shutdown panels are there to address the  
23 evaluation of the main control, either due to fire or  
24 toxic gas. That is their only regulatory basis.

25 They interface with division 1 or division

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 2. They are basically a computer node on the network  
2 that allows a person or an operator at that station to  
3 work with that division's worth of equipment. It was  
4 never intended that we would have N+2 type of  
5 capability for the remote shutdown station.

6 MEMBER STETKAR: I guess I was confused.  
7 Because they are in the DCD, they are summarized under  
8 things that are called safe shutdown systems which  
9 include things like standby liquid control and safety  
10 related information, post-accident monitoring.

11 MR. BEARD: But the purpose of remote  
12 shutdown stations is to allow the operator to  
13 interface with the equipment. The automatic capability  
14 is not to grade it by what happens with the remote  
15 shutdown station. So the automated capability that  
16 we talk about, the safest shutdown capability, is  
17 carried out automatically by the safety system watcher  
18 control.

19 MEMBER STETKAR: But it is true if I have  
20 divisions 1 and 2 down, the remote shutdown capability  
21 is disabled, is that correct?

22 MR. BEARD: The operator would not have  
23 the ability to interface with those divisions. That's  
24 correct.

25 MEMBER MAYNARD: But if you have both

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 those down, you're going to be down?

2 MEMBER STETKAR: No. no. No, you can  
3 have two down for eight hours or something.

4 MS. CUBBAGE: Well, one -- you can one out  
5 of service and then the second one is the signal  
6 failure, right?

7 MEMBER STETKAR: Right.

8 MR. TUCKER: This is Larry Tucker with  
9 GEH.

10 The design is somewhat similar, very  
11 similar to some of the European designs. And most of  
12 the plants, the electrical system is designed to be  
13 single failure proof, but maintenance is in fact a  
14 single failure if you take a train down from  
15 maintenance.

16 The most closely that I would describe it  
17 is single failure with maintenance, and that's why you  
18 have the four trains. And that's more like the  
19 European design of some of the later plants.  
20 Leibstadt--

21 MEMBER STETKAR: Yes, but the Leibstadt  
22 has two separate, completely separate --

23 MR. TUCKER: That's why I said it's  
24 somewhat similar.

25 MEMBER STETKAR: Their remote shutdown is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 completely different from what we're talking about  
2 here, though.

3 MR. TUCKER: Well, I'm focusing on the  
4 safety functions of safe shutdown of the reactor.

5 MEMBER STETKAR: Yes.

6 MR. TUCKER: The remote shutdown panel is  
7 more for operator interface monitoring. But the safe  
8 shutdown functions happen whether the operator can see  
9 anything at the remote shutdown panel or not. There's  
10 no operator action credited at the remote shutdown  
11 panel to assure safe shutdown, is I guess one way to  
12 say it.

13 MR. WILLIAMSON: Actually, Larry was  
14 segueing into about the only other thing I was going  
15 to mention is that it is there, it does facilitate  
16 maintenance, online maintenance of a division. It is,  
17 again, one of those things the utilities were  
18 interested, particularly interested in their  
19 capability of doing.

20 I also wanted to highlight the fact that  
21 each division has two sets of batteries, two  
22 batteries. And the testing that will be done every 24  
23 months these batteries must undergo a service  
24 discharge test and be restored back to service. But  
25 while that's being done, the Division still remains in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 service. From a tech spec perspective, from a fully  
2 operable perspective we won't consider it operable. It  
3 will be one of those divisions that's not required.  
4 But in fact it will remain in service and it will  
5 remain capable of doing what it needs to do. The  
6 duration, the 72 hour durations won't be there because  
7 you only have one of the two batteries, but  
8 functionally when the maintenance is being done the  
9 plant's not going to see this division as an out-of-  
10 service division. So I wanted to highlight that  
11 point.

12 And, these divisions will be tested.  
13 There's periodic testing that must be done. And  
14 they're going to run these divisions throughout the  
15 course of the cycle so that they're not impacting  
16 outage critical path with these tests. So there  
17 actually will be a rotation of times when different  
18 divisions would be in test or not in test.

19 And this being a safety related division,  
20 all four divisions are a part of the design, they're  
21 all safety related, they all fall under Appendix B and  
22 they all fall under the maintenance rule. Any  
23 degradation in any of the systems would be covered by  
24 the Appendix B corrective action process. And any  
25 planned maintenance would be governed by maintenance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 rule evaluations.

2           Going on to the next slide, the last item  
3 we wanted to talk about was the fact that there are  
4 COL applicant items in Chapter 16 and 16B. And these  
5 are very similar to standard tech specs. Optional  
6 features or provisions, site specific details. You can  
7 see example list on the slide. Obviously, the site  
8 description needs to be unique to each site so there  
9 are some bracketed material that the COL applicant  
10 will have to fill in.

11           Effluent reporting, where you're multiple  
12 site, single site there's some different provisions  
13 allowing you to make one report instead of multiple.  
14 So there were different wording options that are  
15 provided in the tech specs.

16           And if you happen to have a unique site-  
17 specific chemical hazard, there are different actions  
18 that might apply in the control room ventilation, in  
19 particular if that's applicable to your suite.

20           So these items will be completed with the  
21 COL applications. And they're indicated in the DCD  
22 with the brackets. And these brackets have reviewer's  
23 notes to facilitate both the staff review and the  
24 licensee when they go to fill in the brackets to clue  
25 them in about any unique features that must be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 included when they fill in those brackets.

2 So in summary we have prepared the ESBWR  
3 tech specs to be standardized and to be focused on the  
4 ESBWR design. And they're geared to support the COL  
5 applications need for completeness and technical  
6 sufficiency. And we continue to work with the NRC to  
7 close out open items.

8 MEMBER APOSTOLAKIS: Coming back to your  
9 have your discussion, there's something I don't  
10 understand. It was said that each train or each train  
11 of the isolation condenser would be tested once every  
12 two years. It will be truly tested in the sense that  
13 it will remove heat. Where does that heat come from?

14 MS. WASTLER: The timing of --reactor  
15 steam.

16 MEMBER APOSTOLAKIS: Oh, from the reactor.

17 MR. WILLIAMSON: An in-service test. The  
18 in-service wasn't mit to be --

19 MEMBER APOSTOLAKIS: The reactor itself?

20 MEMBER ABDEL-KHALIK: So you would do the  
21 test while the reactor is actually operational?

22 MR. WILLIAMSON: While shutdown.

23 MEMBER SHACK: While shutdown.

24 MR. WILLIAMSON: Yes. It would not be a  
25 test you would do while critical without a special

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 test provision.

2 MEMBER ABDEL-KHALIK: But what is the  
3 capacity of the signal --

4 MEMBER APOSTOLAKIS: So that's why am I  
5 asking, the cycle is two years, right? So one will be  
6 tested in the middle of the cycle?

7 MR. WILLIAMSON: No. Every two year cycle  
8 one of the four will be tested. Over the course of  
9 eight years it will be tested.

10 MEMBER APOSTOLAKIS: Oh. So the interim  
11 is four years?

12 MR. WILLIAMSON: Is eight.

13 MEMBER APOSTOLAKIS: Eight.

14 MR. WILLIAMSON: A particular one gets  
15 tested every eight years.

16 MEMBER APOSTOLAKIS: I see. Okay. Okay.  
17 Okay.

18 MEMBER ABDEL-KHALIK: But what's the  
19 capacity of a single ICS?

20 MR. WILLIAMSON: I defer to my design  
21 brethren.

22 MR. TUCKER: It's about 35 megawatts.

23 MEMBER ABDEL-KHALIK: Thirty-five  
24 megawatts. So that corresponds to?

25 MR. TUCKER: About two-thirds of a percent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of thermal power.

2 MR. MARTINO: This is Wayne Martino of GE.  
3 We consider that we can test the ICs during operation.

4 MEMBER APOSTOLAKIS: Really?

5 MR. MARTINO: Yes.

6 MEMBER BLEY: I asked that at the last  
7 one, they said no big deal.

8 MEMBER APOSTOLAKIS: What's not big deal--

9 MEMBER BLEY: It's not a big power load if  
10 you were to open it during operation.

11 MEMBER ABDEL-KHALIK: It is 35 megawatts--

12 MR. TUCKER: This is Larry Tucker of GEH.

13 The isolation condensers are open to the  
14 reactor in terms of the steam being able to go to the  
15 isolation condensers while we're in power operations.  
16 There is condensation that fills the return line, and  
17 there is a valve that keeps the flow from happening.  
18 It would be perfectly possible to open that valve and  
19 start the cooling of the isolation condenser and  
20 demonstrate that you can transfer heat to the pool--

21 CHAIRMAN CORRADINI: Just warn the people  
22 near the exit of the steam.

23 MEMBER APOSTOLAKIS: Whether this will be  
24 done will be determined by the utility?

25 MR. TUCKER: Yes. Whether they choose to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 do that on line or they choose they do it just after  
2 we shutdown while there is still decay heat available,  
3 that's really up to the COL applicant in how they  
4 approach their operating strategy.

5 MEMBER ABDEL-KHALIK: But if you open that  
6 valve, that's normally closed?

7 MR. TUCKER: Right.

8 MEMBER ABDEL-KHALIK: How would you  
9 actually verify that you were moving 35 megawatts?

10 MR. TUCKER: You measure the heat of both  
11 -- then you would start seeing a steam flow through  
12 the isolation condenser, which there would be --

13 MEMBER ABDEL-KHALIK: Are there flow  
14 indications on those -- not that I remember.

15 MR. TUCKER: I think you would observe it  
16 by temperature.

17 MEMBER MAYNARD: Well, I think we need to  
18 be careful, though, we don't create a bigger problem  
19 by testing --

20 MR. TUCKER: Larry Tucker with GEH.

21 MEMBER APOSTOLAKIS: Well, Otta, are you  
22 saying that this -- you ought to do during power  
23 pressure?

24 MEMBER MAYNARD: Well, I think you need to  
25 have a lot more thought put into it than us sitting

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 here -- I think the main thing is that there is test  
2 interval. I think the staff and the applicant need to  
3 decide what constitutes an appropriate test.

4 MEMBER APOSTOLAKIS: So every --

5 MEMBER MAYNARD: Well, the frequency could  
6 be determined by a number of different things. First  
7 of all, you can test certain components. You may want  
8 to cycle the valve a lot more often than once every  
9 eight years. As far as demonstrating the performance  
10 of the IC, I don't know. That may be appropriate, may  
11 not.

12 MR. UPTON: We test a lot of circuit quite  
13 frequently.

14 MEMBER MAYNARD: Yes. The parts of it you  
15 that you can test frequently. To do the full  
16 integrated test on it, I'm not sure that it's needed  
17 to be done that often.

18 Also, the frequency can be set after a  
19 while based on operating experience and what other  
20 issues may or may not come up. I mean, if you test  
21 these things frequently for five or ten years and you  
22 never run into a problem, then you may very well want  
23 to extend the frequency. If you want to run into  
24 problem, you may want to shorten the frequency.

25 MR. TUCKER: This is Larry Tucker with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 GEH.

2 Our system engineer has informed us that  
3 there are flow indication indicators on the return  
4 line from the IC condenser to the reactor. It's just  
5 a design detail below the summary level sketch of the  
6 DCD.

7 MR. WILLIAMSON: And I didn't get into it,  
8 but there are tech spec surveillances that do require  
9 this. In an overlapping fashion you could confirm each  
10 cycle for each four trains that the systems is capable  
11 of automatic actuation, which typically involves that  
12 these valves would be cycled and ASME would require  
13 them to be cycled also, strobe tested. So there are  
14 requirements for each train to go through the testing,  
15 at least a series of overlapping tests, that shows  
16 that it would function and actuate. The actual  
17 confirmation of heat removal is the one piece that  
18 would be on a different frequency.

19 MEMBER STETKAR: Let me make sure I  
20 understand. I think I do. The kind of stepping way  
21 back from this thing, the big picture philosophy of  
22 the four divisions.

23 As I understand it, the tech specs allow  
24 one of those divisions, a division, pick a division to  
25 be inoperable indefinitely?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. WILLIAMSON: Yes.

2 MEMBER STETKAR: And then if the second  
3 division becomes inoperable, you start a time clock.

4 MR. WILLIAMSON: Twenty-four hours.

5 MEMBER STETKAR: Twenty-four hours? Okay.  
6 Okay. I just want to make sure that I --

7 MR. KINSEY: Because at that point you're  
8 not singly using all your tolerance --

9 MEMBER STETKAR: That's right. Because  
10 then you're down to two.

11 Thanks.

12 CHAIRMAN CORRADINI: Other questions?  
13 Okay. Thank you very much.

14 MR. WILLIAMSON: We yield our extra time  
15 to --

16 MR. COMAR: Good afternoon. I'm Manny  
17 Comer, Project Manager Chapter 16 Technical  
18 Specifications for the ESBWR.

19 To my right is Craig, he is the Chief  
20 Reviewer for the Technical Specification Branch. We  
21 went through and coordinated the review.

22 We have provided a copy of SER to you with  
23 the open items. And with that, I'm going to start the  
24 briefing.

25 And the purpose is to brief the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Subcommittee on the Chapter 16 of the ESBWR  
2 application is based on Rev. 3 and the RAI responses  
3 that we have received so far. And then answer if the  
4 Committee has any other questions on it.

5 You already talked about the Project  
6 Manager for Chapter 16, and there are other reviewers  
7 who will present here if there are some detailed  
8 questions that the Committee might have. And they'll  
9 be happy to answer those.

10 The outline of this presentation is we're  
11 talk about the applicable regulations that we've used,  
12 the RAI status summary and then Craig will get into  
13 the review criteria and the open issues and the COL  
14 action items.

15 These are some of the overarching  
16 regulations that we used for the review of Chapter 16  
17 tech specs.

18 We originally requested 162 RAIs, of them  
19 112 have been resolved as of DCD Rev. 3. And six more  
20 resolved as a consequence of the review of DCD Rev.4  
21 It means that review is still ongoing and we're not  
22 complete with it. And that is what alludes to. So the  
23 balance left is 44 of the open items that the staff is  
24 discussing with NRC.

25 I am going to hand over to Craig to talk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 about the criteria and the other details.

2 MR. HARBUCK: Okay. My name is Craig  
3 Harbuck. And I'm Senior Reactor Engineer in the  
4 Technical Specifications Branch, NRO.

5 Typically when we look at tech specs for  
6 design cert there's three big things we keep in mind  
7 while we're looking to make sure, and these are listed  
8 on this slide. It's what I call review criteria.

9 First off, 5036 outlines what has to be in  
10 the tech specs, safety limits, setpoints, SEOs, SRs,  
11 design features and administrative controls. And so  
12 we make sure that we're meeting those requirements.

13 It's not a requirement, but we also are  
14 interested in seeing that the proposed specifications  
15 match the format and content and usage rules of the  
16 tech specs, which by doing so solve a lot of problems  
17 that were resolved by going through the improve  
18 standard tech specs.

19 And then lastly we need to make sure that  
20 the tech specs are consistent with the design as  
21 approved. And also the accident analyses. Especially  
22 the accident analyses because 5036 and its four  
23 criteria, a big emphasis there is on preserving the  
24 validity of the accident analyses.

25 As Manny mentioned, we have over 162 or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 around 162 questions. And we reduced that number down,  
2 but I'm going to mention the main categories. Some of  
3 these items in this list cover multiple issues, but  
4 this is the main points I'd like to present in the  
5 open issues.

6 But I also before you start, and I'll just  
7 mention our very first question was one asking GE to  
8 do a little more -- provide a little more detail on  
9 they derived the DLCOs by comparing to all their  
10 systems in the design against the accident analyses  
11 and 5036 criteria. And part of that we consider still  
12 be open in the sense that there's changes to the  
13 design since that was responded to. And so once we're  
14 far enough along, that will probably need to be  
15 updated, or perhaps need to be updated. We'll be  
16 checking up on that.

17 On bracketed information, we were  
18 presented with two kinds of information in the initial  
19 version of the tech specs. And it was unclear what  
20 the brackets meant. So initially that question was  
21 related to that. And Revision 3 the brackets took on  
22 two distinct meanings and we're wanting to -- and a  
23 set of those would be resolved in time for the design  
24 certification. So we're going to want to make sure  
25 that all those are resolved.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   And then as Dan mentioned earlier, the  
2                   brackets that would be with the COL action item of  
3                   bracket information, in tech specs the goal is to have  
4                   all those associated with reviewer's notes so that it  
5                   would be clear what the applicant, the COL applicant  
6                   would need to do in order to resolve or close or get  
7                   rid of those brackets.

8                   Another big issue in instrumentation  
9                   setpoint methodology. The ESBWR uses the digital  
10                  instrumentation interface for processing the signals  
11                  from the sensors. And this presents a bit of a  
12                  challenge on how you write tech specs. It was -- and  
13                  the staff has had a lot of detailed questions about  
14                  that and we're -- so a good fraction of our open  
15                  issues are specific requests for additional  
16                  information now termed open items, and the SER with  
17                  open items are pending our review.

18                  Also related to instrumentation is the  
19                  questions dealt with surveillance requirements. And  
20                  there's six main kinds of surveillance requirements.  
21                  The channel check, channel functional test, logic  
22                  system functional test, response times test, the  
23                  staggered -- the response time testing; those things  
24                  all need to be understood in how they're going to be  
25                  done in the context of additional instrumentation and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 control.

2 And you have a question?

3 MEMBER STETKAR: Yes. I noticed that most  
4 -- I'll say most because I don't remember all, is a  
5 big word. Most of the logic channel functional tests  
6 are 24 months on a staggered test basis. And since  
7 I'm not familiar with NUREGs and what's gone on in the  
8 past, is that consistent with -- what's the basis for  
9 that testing interval? Because that means each  
10 channel is functionally tested once every eight years?

11 MR. HARBUCK: The staggered testing, and  
12 I might ask GE to also respond to this if they can.  
13 But the idea is that you don't want to test something  
14 and you make an error because you tested the next one  
15 and --

16 MEMBER STETKAR: I understand the concept  
17 of staggered testing.

18 MR. HARBUCK: All right.

19 MEMBER STETKAR: I'm asking about what's  
20 the basis for once every eight years testing each  
21 channel every two years.

22 MR. HARBUCK: Well, in the standard test  
23 specs, typically such tests are done on a refueling  
24 cycle interval.

25 MEMBER STETKAR: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. HARBUCK: And so that would be 18  
2 months or 24 months, and that's where that comes from.

3 The staggered testing, I believe, I'd have  
4 to check, but I believe is in the standards.

5 MEMBER STETKAR: Okay.

6 MR. HARBUCK: So it probably comes out of  
7 maintaining consistency with the standard tech techs.

8 DR. WALLIS: Is there any technical basis?  
9 I mean shouldn't it be related to the expectation for  
10 the time by which it will be nonfunctional or  
11 something? I mean, it's got to be related to  
12 something meaningful?

13 MR. HARBUCK: When you look at the basis--

14 MEMBER APOSTOLAKIS: This is the existing  
15 tech specs for safety systems, is that monthly tests  
16 or out of the blue?

17 DR. WALLIS: You just guess something.

18 MEMBER APOSTOLAKIS: That's what the risk-  
19 informed initiatives are trying to do.

20 DR. WALLIS: Was it related to the outages  
21 or something?

22 MEMBER APOSTOLAKIS: Isn't every month is  
23 reasonable --

24 DR. WALLIS: The outages, is that where  
25 you start? Is it convenience you're doing it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 MR. HARBUCK: It's basically taking, I  
2 think, a conclusion from past precedents and applying  
3 it to these specs.

4 DR. WALLIS: There's no rationale?

5 MR. HARBUCK: No, that's not entirely  
6 true. When you look at the basis for the  
7 instrumentation and the references that are listed in  
8 support of what the frequency of a surveillance is,  
9 there's a reference to -- I believe it's a PRA  
10 analyses.

11 MEMBER APOSTOLAKIS: Ah. It was a  
12 prudent, conservative thing to do.

13 MEMBER STETKAR: Every two hears?

14 MEMBER APOSTOLAKIS: No, not this.

15 MEMBER STETKAR: What he's saying is that  
16 the evidence -- has the same base.

17 MEMBER APOSTOLAKIS: There is no base --

18 MR. WILLIAMSON: Dan Williamson GE  
19 Hitachi.

20 MEMBER STETKAR: Here we go.

21 MR. WILLIAMSON: Craig is right, there is  
22 a bracket. It's one of these things that's bracketed  
23 because it's not yet resolved. There is a reference to  
24 the PRA topical. But it's one of those things that as  
25 we resolve it, it's probably not the right answer.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   And to answer the question, let me back up  
2                   a little bit and step into what I think were several  
3                   of the questions I heard.

4                   The logic system functional test that  
5                   would be done each outage is essentially taking one  
6                   division, putting a division A trip into it. Now the  
7                   logic is any two to trip. And so the test would be now  
8                   I run it through on B trip and see if I get an output  
9                   trip. Throwing a C trip, see if I get an output trip.  
10                  Throwing a D trip, see if I get an output trip.

11                  So I'm testing this one entire division of  
12                  does it see all the other divisions' communication  
13                  paths appropriately.

14                  Now, what's the right frequency? Yes, it  
15                  should be based on a lot of stuff. And we talked to  
16                  the digital I&C folks and the vendors that are  
17                  supplying this stuff, they're saying it's software, it  
18                  doesn't change. You know, it works or it doesn't work.  
19                  And the software is self-tested. And if anything  
20                  happens to it, you know it. You probably could  
21                  justify pick a very long time.

22                  MEMBER BLEY: This test is only on the  
23                  software portion of the --

24                  MR. WILLIAMSON: The logic system  
25                  functional test is specifically looking at the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 combination of divisions.

2 MEMBER BLEY: Which is all done in  
3 software?

4 MR. WILLIAMSON: There are output load  
5 drivers also.

6 MEMBER APOSTOLAKIS: Or a loop provided?

7 MR. WILLIAMSON: Right. The focus of that  
8 test is mainly software.

9 MR. TUCKER: This is Larry Tucker with  
10 GEH.

11 One of the things about going to the  
12 digital control information system is that if there is  
13 indeed a problem itself revealing at the time it  
14 occurs, so while we do these surveillance tests many  
15 of the problems that people postulate would be self-  
16 revealed in the course of the digital system doing its  
17 own diagnostics periodically.

18 MEMBER BLEY: And have you reached the  
19 point where you folks are confident that that is  
20 really happening with the things you might be  
21 concerned it? Or you're still examining it I think is  
22 what I heard..

23 MR. WILLIAMSON: No. We're examining the  
24 words to put in the bases for why we picked 24 months.

25 MEMBER BLEY: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. WILLIAMSON: And the reality is that  
2 we review the design and the prior 24 months was  
3 somewhat picked out of the air but its been proven  
4 over time to be a very good time as finding the  
5 failures that need to be found in appropriate  
6 interval.

7 We look at those old relay designs and the  
8 types of failures mechanisms that might occur that  
9 needed to be found and we look at the software and we  
10 say, yes, we are very comfortable that 24 months is  
11 much better, at least as good as what was being done  
12 in the past for the reasons it was done.

13 We left it at 24 months to facilitate the  
14 review. Essentially for someone to be able to say, you  
15 know, yes the design is so much better. This 24 month  
16 frequency remains okay.

17 Now what might be a better, the right  
18 frequency down the road.

19 MEMBER BLEY: Let me put it another way.  
20 I'm assuming there will be a document at sometime that  
21 lays out the complete rationale on this sort of thing.  
22 Is that true or is that a pipe dream of mine?

23 MS. CUBBAGE: Craig, this is an open right  
24 now?

25 MR. HARBUCK: Yes.

1 MS. CUBBAGE: So it's an open item, so  
2 you'll get an opportunity to hear the resolution of  
3 this open item when we come with the final SE.

4 MEMBER BLEY: Let me just throw something  
5 in. I've been hearing over my shoulders, watchdog  
6 circuits and the like, and watchdog circuits test  
7 certain things but they don't test everything.

8 MS. CUBBAGE: Well, I mean if you want to  
9 get into the details of the digital I&C and how it  
10 does self-diagnostics and all that stuff, that's  
11 Chapter 7.

12 MEMBER BLEY: Okay.

13 MS. CUBBAGE: And we've got a lot of work  
14 to do yet on Chapter 7.

15 MEMBER BLEY: Chapter 7.

16 Well, I guess what I'm trying to ask is  
17 given whatever's in Chapter 7 once you're finished  
18 with that, it seems to me it would be important to  
19 have a rationale that links to what you eventually  
20 understand in Chapter 7 that explains where these  
21 intervals come from?

22 MS. CUBBAGE: Right. Our Chapter 7 and 16  
23 team are joined at the hip in this area as far as  
24 looking at what are appropriate tech specs for a  
25 digital system and surveillance frequencies, et

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 cetera.

2 MEMBER APOSTOLAKIS: You've me a little  
3 bit confused here. Forgive me. I thought I heard  
4 earlier that pieces of the system, like the squid  
5 valves, would be tested more frequently than we  
6 already use, is that correct?

7 MR. UPTON: Twenty percent of the squid  
8 valve -- this is Hugh Upton, GEH.

9 Twenty percent of the squid valve charges  
10 are removed and actually exploded or initiated and  
11 replaced every shutdown, every outage. Every  
12 refueling outage. Every refueling outage.

13 MEMBER APOSTOLAKIS: The software is  
14 tested--

15 MEMBER MAYNARD: Ten years.

16 MEMBER APOSTOLAKIS: -- more frequently  
17 than every two years? No? Everything is tested every  
18 two years for each loop?

19 MR. UPTON: What we're looking at is the  
20 chemical composition of the squib charges to confirm  
21 that they're still good. That's what's tested every  
22 refueling outage, 20 percent.

23 MEMBER MAYNARD: Well, I think it could be  
24 very difficult to go through surveillance frequency in  
25 this type of meeting. The surveillance frequencies are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 very complex. Some of the things that we're talking  
2 about are more of the full channel checks, the  
3 integrated test type things; those are usually the  
4 longer term. Each one of those components will  
5 typically have a different surveillance frequency  
6 associated with a part of that channel or certain  
7 components. And the surveillance sections of the tech  
8 specs are really quite involved as far as frequency on  
9 individual components versus bigger parts of it,  
10 verses the entire channel.

11 MEMBER APOSTOLAKIS: So individual  
12 components will be tested more frequently in general?

13 MEMBER MAYNARD: Typically.

14 MEMBER APOSTOLAKIS: Yes, that's what I  
15 understood. So it's more of an integral test every  
16 two years?

17 MEMBER MAYNARD: Well--

18 MEMBER APOSTOLAKIS: No, that's what they  
19 said earlier. That they will remove 35 megawatt or 45  
20 megawatt, do you confirm that? That's the biannual  
21 test?

22 MR. UPTON: Yes, that's correct.

23 MR. WILLIAMSON: Make sure one valve  
24 opens.

25 MEMBER APOSTOLAKIS: Confirm the right --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and the right heat removal. I mean, come on --

2 MEMBER MAYNARD: But it would be good to  
3 discuss the basic when we get a chance. But I think  
4 that current set of tech specs, most of those  
5 frequencies and stuff were not really established with  
6 a basis. It was engineering judgment I think on the  
7 part of the regulator and the applicant.

8 MEMBER STETKAR: Let me read something  
9 here, because I'm reading from the SER. This is  
10 channel calibration surveillance frequency, but it's  
11 a channel calibration.

12 Twenty-four month channel calibration  
13 surveillance frequency has been shown to be acceptable  
14 by NEDO-33-201 ESBWR design certification  
15 probabilistic risk assessment.

16 So theoretically the 24 month surveillance  
17 interval, at least for some instrumentation channel  
18 calibration is tied to the PRA according to this

19 MR. WILLIAMSON: Dan Williamson, GEH.

20 Let me clarify, and I believe even in the  
21 SER that the reference that you read to the topical is  
22 in brackets.

23 MEMBER STETKAR: It's in brackets.

24 MR. WILLIAMSON: That in particular for  
25 the channel calibration also gives me the opportunity

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 to point out that the setpoint methodology was  
2 recently submitted by GEH and is under -- the open  
3 item is it's under staff review. But the calibration  
4 and the calibration frequency is linked to the  
5 setpoint methodology and it's not linked to PRA.

6 So in the case of the channel calibration,  
7 that is one of the references, one of the bracketed  
8 items that will change to reference the appropriate  
9 document, not the PRA.

10 MEMBER APOSTOLAKIS: Typically if you try  
11 to tie frequency of a test to come probabilistic  
12 inactive systems, you usually assume some distribution  
13 of failure. So you're saying might do it X months or  
14 hours then I can do the calculations and find some  
15 unavailability. For a passive system, I don't know  
16 that you can do that. Or the software. Software. I  
17 mean what -- if you start giving me failure rates,  
18 that will be on opposite sides. I don't think you can  
19 do that.

20 Another way of looking at it is these we  
21 have very high confidence that these systems will  
22 function and this two year thing is an excellent  
23 defense-in-depth measure.

24 MS. CUBBAGE: All right.

25 MR. TUCKER: To see if there's any --

1 MEMBER APOSTOLAKIS: Huh? To see if  
2 there's anything that I have not thought of in  
3 advance--

4 MR. TUCKER: To answer the software is not  
5 degrading, is it something else.

6 MEMBER APOSTOLAKIS: Yes. So as a matter  
7 of defense-in-depth I want to look at every two years.

8 MR. TUCKER: Correct.

9 MEMBER APOSTOLAKIS: And that takes care  
10 of it because the defense-in-depth really is one of  
11 those great principles that does not need  
12 justification.

13 MEMBER BLEY: Can I ask something? This  
14 is kind of -- almost --

15 MEMBER APOSTOLAKIS: Yes, thank you very  
16 much.

17 MEMBER BLEY: -- but George's comment got  
18 me interested. There will be over time, no doubt,  
19 software upgrades to all the instrumentation. And  
20 don't recall seeing anything. Is there anything in the  
21 tech specs that deals with somehow confirmatory  
22 testing after every software upgrade?

23 MS. CUBBAGE: I think you're getting into  
24 Chapter 7.

25 MEMBER BLEY: In Chapter 7?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: Yes.

2 MEMBER BLEY: It's not a tech spec matter?

3 MR. HARBUCK: Yes. In terms of tech specs,  
4 I think that general principles that post modification  
5 or post maintenance testing is not something that we  
6 kept in the tech specs as an explicit requirement.  
7 It's sort of understood as, you know, you do what's  
8 necessary to make that equipment operable whatever  
9 you've done it so you meet the LOC. The details of  
10 that are not retained in the spec.

11 DR. WALLIS: And let me suggest that  
12 there's a human aspect to this, too. That the  
13 management likes to have some assurance every so often  
14 that things are working.

15 MEMBER APOSTOLAKIS: Well, that's defense-  
16 in-depth is.

17 MS. CUBBAGE: Right. And I think GE  
18 alluded to the online monitoring capabilities and  
19 self-diagnostics that we're still looking at in the  
20 Chapter 7 arena that I think are providing some  
21 constant assurance that the digital system is  
22 performing as expected.

23 MEMBER ABDEL-KHALIK: Are there  
24 surveillance tests for these digital instrumentation  
25 and control any different than the startup testing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that we have to do for them?

2 MR. WILLIAMSON: Dan Williamson, GEH.

3 We have a hand full of RAIs that GEH has  
4 not responded to yet that are the topic of what we've  
5 been talking about and your specific questions.

6 These surveillances that are listed on  
7 Craig's sheet and how they interface with digital and  
8 it'll actually wrap up the question on will something  
9 document how all this stuff comes together? And it'll  
10 be the responses to these handful of RAIs.

11 MS. CUBBAGE: Right. GE's RAI responses,  
12 DCD revs as necessary and the staff's final safety  
13 evaluation. So we're certainly not looking for the  
14 Committee to give us any finality on this, but we'd be  
15 interested in hearing any of your concerns to make  
16 sure that we do address them when we resolve this  
17 issue.

18 MEMBER MAYNARD: Some of the surveillance  
19 tests will be very similar to the startup tests. Some  
20 won't be.

21 MEMBER ABDEL-KHALIK: Well, but the issue  
22 of frequency, at least you have a starting point for  
23 all four of them that are pretty much the same and  
24 then you can just go from there.

25 MS. CUBBAGE: And there may be the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 capability during pre-op tests to do some more  
2 extensive testing than you would do with fuel in the  
3 reactor and water in the systems. You might be able to  
4 do some more thorough pre-op testing than you would be  
5 able to do later.

6 MR. HARBUCK: Okay. Just to continue.

7 This last note, staggered test basis.  
8 I'll briefly explain, for those who may not be  
9 familiar, prior to improve standard tech specs  
10 staggered test basis was defined as an interval and  
11 you took the number of components and divided by that  
12 number into the interval to determine how often you  
13 did the test.

14 For some reason the standard tech specs  
15 they figured it was easier to multiple than divide, so  
16 they specified the interval for each component and  
17 then you multiplied times the number of the components  
18 to get the actual interval for each separate division  
19 or channel.

20 And up until now we usually if you had X  
21 components of the design, that's how many the LCO  
22 required. Well, now we've got a more robust design  
23 the desire from electrical down to instrument is to  
24 require three of four channels that are in the design.  
25 And so there's some question about how we determine

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 what the overall interval for each division is.

2 Do we determine it using the number that's  
3 in the design or the number that's the LCO requires it  
4 to be operated? And we haven't resolved that one yet.  
5 That's what that's there for.

6 Continuing on to the reactor coolant  
7 system

8 MEMBER APOSTOLAKIS: I hope we're going to  
9 have another result. Because I'm really perplexed by  
10 all this.

11 We are assuming that we know what the  
12 testing frequency does to the reliability of the  
13 thing. And I'm not convinced we know. I don't even  
14 know that we can calculate it.

15 CHAIRMAN CORRADINI: In some sense you  
16 don't know.

17 MEMBER APOSTOLAKIS: So it's all a matter  
18 of --

19 CHAIRMAN CORRADINI: In some sense they're  
20 using past experience as their starting point.

21 MEMBER APOSTOLAKIS: Past experience with  
22 what? The passive systems.

23 CHAIRMAN CORRADINI: Well, the passive  
24 systems instruments --I guess.

25 MEMBER APOSTOLAKIS: I don't know. I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 mean, I'd like to see that. I'd like to see that past  
2 experience.

3 MS. CUBBAGE: Right. I mean I think we  
4 tailored a short presentation because we weren't sure  
5 if the Committee would be interested in tech specs in  
6 general. So if we need to come back, we can come back  
7 or we can cover it at the final SER.

8 MEMBER APOSTOLAKIS: Well, I'd like to see  
9 more.

10 MS. CUBBAGE: Or maybe as part of the PRA  
11 discussions we could tie in some of this. But I don't  
12 think we were prepared --

13 MEMBER APOSTOLAKIS: PRA usually starts  
14 with what you plan to do and evaluates the  
15 probabilities and so on. And then you got another  
16 part of that says I will use PRA arguments to  
17 determine the frequency, which we don't do typically  
18 in the view of the PRA.

19 MEMBER MAYNARD: I think it depends on  
20 what the review of the design certification really  
21 mean.

22 When we come to the COL stage we're going  
23 to be reviewing tech specs. To me it depends on are  
24 we locked in to whatever comes up here? I mean, is  
25 this going to be the final set of tech specs with a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 few specific numbers put in by the licensee?

2 MS. CUBBAGE: Yes, in essence yes.

3 MEMBER MAYNARD: Okay. So this--

4 MS. CUBBAGE: I mean from a regulatory  
5 perspective there is a little less finality on tech  
6 specs than there are on the rest of the certification.  
7 But all intents and purposes, this is the time --

8 MEMBER MAYNARD: So this would be the  
9 time?

10 MS. CUBBAGE: But if something was left in  
11 brackets, as you said, there would be an opportunity  
12 later.

13 MEMBER APOSTOLAKIS: This is not the last  
14 time we are addressing this issue.

15 MS. CUBBAGE: No. We'll come back.

16 MEMBER APOSTOLAKIS: That was good.

17 CHAIRMAN CORRADINI: They surrender,  
18 George.

19 CHAIRMAN CORRADINI: I have three parts to  
20 the answer. One is this is the first time we have to  
21 look at it. There are a number of brackets to be  
22 filled in. And we're going to have to look at all of  
23 it totality in some sense at the end. If we as a  
24 Subcommittee or the Committee as a whole wants to look  
25 at these tech specs as a whole as we come to the end,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 we're going to look at it.

2 MEMBER APOSTOLAKIS: Well, this specific  
3 thing that was just mentioned about which way to go  
4 and all that, I would be very curious to look at them.

5 MS. CUBBAGE: And to the extent that some  
6 of these are open items already, we're already  
7 thinking about these and would be coming back at the  
8 final SER.

9 MEMBER APOSTOLAKIS: You would probably be  
10 coming back.

11 MS. CUBBAGE: But we are interested to  
12 hear. It's good to know that you're interested so  
13 that we can prepare for it.

14 MEMBER MAYNARD: I think we do need  
15 another discussion.

16 MS. CUBBAGE: Yes.

17 MEMBER MAYNARD: You know, in my opinion  
18 Chapter 15 and 16 really establishes safety limits for  
19 the plant. I mean is 16 is where you really draw the  
20 line and the license of this is exactly your limits of  
21 how you operate. And you get that out of Chapter 15.  
22 And so I think this is a real key area for us.

23 CHAIRMAN CORRADINI: So we will come back.

24 MEMBER APOSTOLAKIS: The Chairman knows  
25 it.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: Well, I had a sense  
2 that you didn't want to --

3 MS. CUBBAGE: And it may be that we don't  
4 want to wait until the final.

5 CHAIRMAN CORRADINI: If we have more  
6 information, though, relative to this I think we can  
7 bring it up earlier. We don't have to wait until the  
8 very final instant.

9 MEMBER APOSTOLAKIS: No.

10 MEMBER BONOCA: That makes sense, let's  
11 move on. Let's move on.

12 CHAIRMAN CORRADINI: But I do think,  
13 though, that more will come out. We will have much  
14 more information as the months progress and we can  
15 bring it up.

16 MS. CUBBAGE: Absolutely.

17 MEMBER BLEY: Mr. Chairman, it seems to me  
18 it would make sense. As we go through the rest of the  
19 Chapters whenever we do a new chapter, we might want  
20 to come back and look at the relevant tech specs on  
21 that chapter as we go. Because looking at them all at  
22 once --

23 MS. CUBBAGE: And actually what we could  
24 do is that after we go through all the chapters cycle  
25 back for one sessions on tech specs since you will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 have had the benefit of all the others.

2 CHAIRMAN CORRADINI: Your thought, though  
3 just to make sure I understand, is as we go through  
4 the chapters looking at those particular tech specs.  
5 I think the only problem with that is we've gone  
6 through a number of them and they're still incomplete.  
7 So --

8 MEMBER BLEY: And that will keep happening  
9 and they get more complete.

10 CHAIRMAN CORRADINI: Yes.

11 MEMBER BLEY: Or completely changed.

12 CHAIRMAN CORRADINI: So let me figure out  
13 how to do that next, But I think we're still in an  
14 incomplete stage on it.

15 MS. CUBBAGE: I think so. Because when we  
16 come back in two months with ECCS, we're not likely  
17 going to be any further along on this. So it really  
18 wouldn't be worth cycling back that soon.

19 CHAIRMAN CORRADINI: At least allayed your  
20 current concerns.

21 MEMBER APOSTOLAKIS: I never had any  
22 doubt.

23 MR. HARBUCK: And moving on to reactor --

24 MEMBER APOSTOLAKIS: You seemed to be  
25 surprised that I have no doubts.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: Let's go on.

2 MR. HARBUCK: The design has 18 safety  
3 relief valves, but except for I think ATWS mitigation,  
4 we're told that only one valve is needed for the  
5 postulated events-- for over pressure reactor for the  
6 reactor ventilation system. And so the associated  
7 tech spec requires two SRVs to be operable. We've  
8 asked for analyses that explicitly accounts for only  
9 one valve. Right now they have an analyses, as I  
10 understand it, that recognizes all the valves are  
11 there and they all open a little bit, but we wanted to  
12 have it so it's explicitly there's one value. That  
13 came from the tech staff. So we're looking for that  
14 to backup that LCO one.

15 We also recognize that if you have a loss  
16 of shutdown cooling or a leak in modes in 5 and 6  
17 under certain conditions that the GDCSs is consistent  
18 that we're relying on -- safety related system we're  
19 relying to respond to that. And so we want to make  
20 sure that to the vent path there's requirement tech  
21 specs that the vent path for the RCS is available so  
22 that GDCS can perform that function. Exactly how we do  
23 that, that's what we're discussing.

24 And as Dan mentioned earlier, they're  
25 working on the action requirements for the ECCS

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 systems, the automatic depressurization system and the  
2 GDCS and the ICS. And so all the action requirements  
3 in the tech specs now are indicated as tented or  
4 bracketed. And there's analysis that they're working  
5 that we'll review when we receive it, and make our  
6 judgment about the perceived reactions.

7 Okay. Moving on to containment --

8 CHAIRMAN CORRADINI: Can I ask a timing  
9 question about that --

10 MR. HARBUCK: Yes.

11 CHAIRMAN CORRADINI: -- since you've been  
12 around timing. When do we expect to see that so just  
13 from the standpoint of for us to review it and know  
14 where to expect it. Are we talking abouts?

15 MR. HARBUCK: I'm not sure. I could  
16 probably figure it out.

17 MS. CUBBAGE: What are we looking for?

18 MR. HARBUCK: We just want to know when we  
19 expect response on that particular question.

20 MS. CUBBAGE: Oh. I think we'd have to ask  
21 GEH for that.

22 MR. HARBUCK: That's what I suggested.

23 MS. CUBBAGE: I don't think you're going  
24 to find it in your book.

25 MR. HARBUCK: I was looking for somebody

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to jump up and volunteer that.

2 MR. WILLIAMSON: Yes. Without making a  
3 regulatory commitment, we would anticipate --

4 CHAIRMAN CORRADINI: This is only a --

5 MR. HARBUCK: Count your fingers.

6 MR. WILLIAMSON: It would be in Rev. 5 and  
7 if it's prepared before then, we will likely try to  
8 make it available to the staff because we know the  
9 timeliness of their review shouldn't wait on Rev. 5.

10 MS. CUBBAGE: For the Committee benefits,,  
11 that's March 2008. And if it is available, GEH will  
12 submit it.

13 MEMBER APOSTOLAKIS: What is the best  
14 estimate of how many revisions there are going to be?  
15 You mentioned Rev. 5.

16 CHAIRMAN CORRADINI: She said that would  
17 be the target is March -- spring of '08.

18 MEMBER MAYNARD: The next one? He's  
19 wanting to know how many revs after that.

20 CHAIRMAN CORRADINI: And your question is  
21 what?

22 MEMBER APOSTOLAKIS: How many revisions.

23 MEMBER MAYNARD: Well, we're on four now.

24 MEMBER APOSTOLAKIS: Even among friends,  
25 right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. CUBBAGE: Our current schedule is  
2 based on DCD Rev. 5 being the rev that is certified.  
3 It's possible there could be additional revs required  
4 for some cleanup or to address any outstanding issues.  
5 But our current schedule is based on Rev. 5. And as  
6 you know, the AP1000 was up to 15/16. But they rev'ed  
7 more frequently. They rev'ed much more frequently and  
8 they didn't do a complete rev. There were only  
9 certain pages that rev'ed. So you recall at Rev. 16  
10 maybe 20 pages got rev'ed. It's a different --

11 MEMBER APOSTOLAKIS: So you can revise  
12 even after you have certified --

13 MS. CUBBAGE: No. Well, only if you go  
14 through the amendment process allowed by the new Part  
15 52 Rule, which is what AP1000 is proposing.

16 MEMBER APOSTOLAKIS: Okay.

17 CHAIRMAN CORRADINI: Is rev like  
18 iteration, it shows the -- Okay. Go ahead. I'm  
19 sorry.

20 MEMBER ABDEL-KHALIK: Well, we won't have  
21 this before we review Chapter 15?

22 CHAIRMAN CORRADINI: No, we will not.  
23 That's part of what I was getting to when Danny was  
24 asking about can we look at them in coincidence with  
25 them.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   Okay. I'm sorry.

2                   MR. HARBUCK:    Okay.    As proposed in  
3                   Revision 3, we're going to the GDCS pool temperature  
4                   by making the assumption of equilibrium with the  
5                   average blowout temperature of the air in the drywall.  
6                   And we had a number of questions about that.

7                   The reactor water cleanup shutdown cooling  
8                   system is a high pressure system but it's not safety  
9                   related and it has isolation valves in case there is  
10                  a leak of some sort. And we were wanting to know how  
11                  they planned to test those valves explicitly. I think  
12                  there's some experimentation that's involved with the  
13                  actuation of those isolations, but the valves  
14                  themselves didn't seem to be covered.

15                  We recognize that monitoring oxygen  
16                  concentration in a small containment, relatively small  
17                  drywell is important so we asked that there be an LCO  
18                  limited added for that.

19                  There's a surveillance requirement that  
20                  requires determining the leakage capacity, the  
21                  drywell, the wetwell vacuum breaker lines. And we  
22                  would like to expand that. And I understand that's  
23                  an issue in another section. That there's more to it  
24                  than just that simple statement. But we have an issue  
25                  on that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 DR. WALLIS: Do they test the vacuum  
2 breakers themselves?

3 MR. HARBUCK: Yes.

4 DR. WALLIS: They are an important part of  
5 the function. And vacuum breakers historically have  
6 not worked very well.

7 MR. HARBUCK: There is a surveillance  
8 requirement on it, a specific spec in 3.6, I believe.

9 MR. UPTON: If I might, this is Huge Upton  
10 with GEH.

11 The vacuum breaker for the ESBWR is a  
12 completely redesigned unique feature, okay? And it's  
13 been tested and demonstrated to be quite leak tight.  
14 So it does not -- your database on vacuum breakers  
15 needs to be adjusted, I guess on the SBWR test  
16 program.

17 CHAIRMAN CORRADINI: So I probably already  
18 have supposed to have read that. So where the vacuum  
19 breakers?

20 MR. UPTON: The vacuum breakers are  
21 discussed in Chapter 5.

22 CHAIRMAN CORRADINI: Okay. Thank you.

23 DR. WALLIS: I thought you meant where are  
24 they physically in the plant.

25 CHAIRMAN CORRADINI: I was trying to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 remember what chapter they were in that I should have  
2 caught.

3 MS. CUBBAGE: And did you find the  
4 surveillance? I found it here. There's surveillance  
5 requirements for leakage to the verify they are  
6 closed, that they can open.

7 MR. HARBUCK: And it's more than one  
8 place.

9 MS. CUBBAGE: 3.6.1.6. Anyway.

10 MR. HARBUCK: Okay. Moving on, control  
11 room habitability area temperature post accident. The  
12 current plan is for those 72 hours the temperature  
13 rise in the control room is going to be limited by two  
14 things. They are coming through the filter ventilation  
15 system from the outside and losses to ambient --  
16 walls, the concrete.

17 And so there's a limit on tech spec of  
18 controlling the temperature and then there's an  
19 assumed temperature rise, and that peak temperature is  
20 deemed to be acceptable. And we'd like to see  
21 analysis on that to support that. So we're waiting for  
22 that.

23 DR. WALLIS: Is there a limit on the  
24 temperature of the walls? Is it supposed to  
25 control--

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. HARBUCK: The trips are here for the  
2 control room habitability area. I think it's like 78  
3 degree or something.

4 DR. WALLIS: Yes, but the outside  
5 temperature of the walls. I mean the walls are part  
6 of the analysis, aren't they, and if they get too hot  
7 or too cold from the outside, that would change their  
8 behavior.

9 MR. HARBUCK: Well, presumably the air  
10 conditioning functions will establish what the initial  
11 temperature is. When the temperature if it gets too  
12 high -- or this is part of the issue, I guess --

13 DR. WALLIS: They assume the walls are in  
14 equilibrium with everything else?

15 MR. HARBUCK: There is an assumption  
16 there. And that's part of the resolution figuring out  
17 the details of that.

18 All right. We've mentioned the  
19 availability controls. And after 72 hours for the  
20 safety related systems to continue to cool the  
21 containment and the vessel and reactor, you need to  
22 put more water into the pool because the inventory is  
23 almost used up since they're evaporating away. So we  
24 want to have availability of controls to provide that  
25 level of assurance that those pools could be

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 replenished at that point in the event that, say, AC  
2 power didn't get restored.

3           There's also a concern that since it's a  
4 passive plant, 72 hours there's no active system soon  
5 to be available to, say, replenish the spent fuel pool  
6 if it was at the appropriate time, do you have  
7 analyses that shows that the amount of water or  
8 inventory you have is sufficient to mitigate or take  
9 care of that heat. And so and then that would then  
10 determine what level do we require in the availability  
11 controls for, like, spent fuel pool.

12           And getting on to electrical, you may have  
13 heard that there's plans to utilize the value  
14 regulated lead acid batteries and since these are  
15 different from the usual vended lead acid batteries  
16 that are normally in existing plants, we have some  
17 questions about temperature control and measurement  
18 and how we determine the stated charge of the battery.

19           These things are sealed so, you know,  
20 measuring specific gravity is not necessary the best  
21 way to -- I mean you can't do that. So flow current  
22 is the option. And we need to verify just how reliable  
23 that is and determine if the sizing of the battery  
24 needs to be adjusted to take any uncertainty into  
25 account.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: Not that I don't  
2 believe you, so I tried to find vacuum breakers in 5.

3 MR. UPTON: I was mistaken. They're  
4 actually in 6.

5 CHAIRMAN CORRADINI: I'll look again.

6 MR. UPTON: That was my error.

7 CHAIRMAN CORRADINI: It's not that I don't  
8 trust you, but I need verification and validation.

9 MR. HARBUCK: Because COL action items are  
10 typically proposed by the applicant and then reiterate  
11 then if we accept them in the SE. And so what I've  
12 got here on the slide it's our understanding of what  
13 we think it means. And that would be replace the  
14 brackets with plant specific information. And that  
15 information should be good enough to operate maybe not  
16 the most -- it may be too conservative, but we think  
17 it should be able to operate once the COL license is  
18 issued. So that would be our understanding of that  
19 action.

20 I'm not sure that is 100 percent  
21 consistent with what is being proposed.

22 And part of this, I've termed it adoption  
23 of topical reports. Typically there's conditions and  
24 things that you have to meet. Often times, and I think  
25 in this case in most cases this is reflected as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 reviewers' notes in the tech specs. So it's just  
2 simply saying, you know, make sure you comply with  
3 what the reviewer note says. And it may be redundant.

4 I'm not sure if this second one is  
5 explicitly called out, say, Revision 4 of the DCD, but  
6 that thought is there and it's understood.

7 MEMBER MAYNARD: I need to make sure I  
8 understand what you're saying on this first bullet.  
9 Are you saying that they need to provide plant  
10 specific, the information in the DCD?

11 MR. HARBUCK: No, no. I'm saying that the  
12 DCD needs to highlight or indicate information that  
13 needs to be provided by a COL applicant.

14 MEMBER MAYNARD: Okay. All right.

15 MS. CUBBAGE: And there is a COL applicant  
16 item in DCD Rev. 4 saying that the COLs would fill in  
17 the bracketed information.

18 MEMBER MAYNARD: That's right.

19 MR. HARBUCK: And the idea is just how  
20 complete should that be.

21 MEMBER MAYNARD: Okay.

22 MEMBER SIEBER: But there's other items in  
23 there that the vendors should know now there is a  
24 responsibility, but they aren't in the tech specs.

25 MS. CUBBAGE: That's right. And the curly

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 brackets are the things that we anticipated that GE  
2 would fill in as part of the certification.

3 MEMBER SIEBER: That's the other set?

4 MS. CUBBAGE: And so we're waiting for  
5 those to be filled in and we're not sure if all of  
6 them ultimately will get filled in, as I understand at  
7 the moment. But trying to minimize what's left.

8 MEMBER SIEBER: For failure they will.

9 MS. CUBBAGE: Well, we're trying to  
10 minimize what's left in brackets for the COL. And  
11 some of those may not be filled in by the COL  
12 applicant. It may be something that's closer to  
13 startup. I'm not sure if any of them will fall in  
14 that category. But there would be a licensed  
15 condition such that they would be filled in before  
16 startup.

17 MR. HARBUCK: To conclude, because of the  
18 issues and analyses that remain to be settled, we  
19 can't conclude yet that we meet the applicable  
20 regulations, but we're making progress. And I'd like  
21 to just emphasize that the review of tech specs is a  
22 bit unique among all the chapters because we rely so  
23 much on the technical validation from other branches  
24 and other groups. And sometimes the line is fuzzy  
25 between tech specs and the technical stuff. And you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 have to have the technical stuff there, but the  
2 purpose of our review is not so much to make those  
3 judgments ourselves, but to make someone who has got  
4 the authority and qualification to do so has made  
5 those judgment.

6 Now, any additional.

7 CHAIRMAN CORRADINI: Does the Committee  
8 have any other questions?

9 MR. HARBUCK: Okay. Well, thank you.

10 CHAIRMAN CORRADINI: Well, thank you so  
11 much. We really appreciate it.

12 So let me end off today by going around to  
13 all the members and trying to get any last point that  
14 I can capture. And also advice relative to what  
15 issues, whether we take this up at a full Committee  
16 and we're going to write another interim letter. What  
17 issues do you think are key that the staff is going to  
18 need to present there? Because we're going to  
19 probably have a half dozen at least chapters that  
20 we're going to have to go through or more.

21 MS. CUBBAGE: Eight.

22 CHAIRMAN CORRADINI: Six plus two, eight  
23 chapters that we're going to go through. And it won't  
24 be possible to go through all of them in total. It's  
25 we're going to have to pick the key things we want to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 have them discuss, and then also to get GEH's folks  
2 over here so they have the proper technical backup in  
3 case we have questions in depth.

4 MS. CUBBAGE: Right. Because if we need  
5 to be prepared on every topic, we'd have to bring a  
6 100 reviewers in here.

7 CHAIRMAN CORRADINI: So can I start with  
8 Jack and just kind of go around. And I'll try to take  
9 notes as to things. If you have written comments, you  
10 can send them to Gary and to I.

11 Jack, I'm sorry.

12 MEMBER STETKAR: Okay. We had four  
13 chapters to go through, auxiliary systems. And I  
14 basically have no comments on auxiliary systems.

15 Steam and power conversation system, you  
16 know that one is a little bit more complex, it's  
17 mostly not safety related. Or almost, I guess, all of  
18 it's not related except just for a few minor items.  
19 And I had no comments on that.

20 Conduct of operations. There were only a  
21 few staff comments and this pretty much reads the way  
22 they've read for the last 20 years, And so there's no  
23 earth shaking change there.

24 On the technical specifications, this is  
25 very complex because starting with the BWR-6 tech

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 specs the differences between BWR-6 and the ESBWR are  
2 pretty significant, mostly resulting in dropping out  
3 of various parts of the tech spec. So you have a  
4 couple of questions there.

5 Of those that you don't drop out because  
6 of the system, do they actually physically match the  
7 plant system; that's the first question. And until we  
8 go through all the plant systems, I don't think we can  
9 answer that. And that's why I sort of like the idea  
10 that someone mentioned during this discussion that  
11 when you go through plant systems, you bring in the  
12 tech specs right at that time so that we have the  
13 design in front of us, including the intent of the  
14 design and the tech specs that are related to it.

15 The other thing that I need to do more  
16 thoroughly is -- and I don't think that looking at the  
17 BWR-6 when I'm looking at the ESBWR tech specs is  
18 going to do it. But to look at the plant with a fresh  
19 eye to decide is anything being missed that didn't  
20 show up in the BWR-6 because it wasn't there, but it's  
21 important with respect to the ESBWR. I've done that  
22 as my homework assignment for coming here. And I  
23 didn't find any. I think I have to continue to --

24 MS. CUBBAGE: I think what might be  
25 helpful for you is to see GE's response to RAI 16.0-1.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 And I can take an action to get that to you through  
2 Gary. It's a very comprehensive evaluation. It was the  
3 first RAI we asked for that very same reason; we  
4 wanted to make sure nothing had been missed.

5 MEMBER STETKAR: Okay. And I guess I have  
6 a comment about surveillance frequencies.

7 I had the pleasure of working at the first  
8 commercial station and our first refueling took us a  
9 year because we recalibrated and tested every  
10 instrument and every logic circuit in the plant. And  
11 I had the opportunity to watch over 45 years how the  
12 surveillance requirements became less and less  
13 stringent as we gained more knowledge on how much  
14 specific instruments drift over time, what are their  
15 failure modes and so forth.

16 Now we have a sort of a new horse coming  
17 along which is digital instrumentation with digital  
18 logic. I don't have any reason to believe that this  
19 is going to be less foolproof than the wired logic  
20 that we had four years go. And on the other hand, I  
21 think that this was an area that we need to pay  
22 attention to.

23 I'm satisfied with this surveillance  
24 frequencies and the outage times because I've watched  
25 these things through the years, and they're strictly

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 engineering judgment. There is no risk calculation or  
2 anything like that. And it's based on failure rates;  
3 instruments where you saw, you know, significant  
4 number of failures had an increased frequency of  
5 surveillance. Or perhaps in detectors you might have  
6 to change the error band, the sensitivity it and  
7 adjust setpoints down.

8           So I'm not particularly worried about  
9 that. But you want to establish for the first customer  
10 or so a few extra things that allow us to become a  
11 little more familiar over the first cycle or two with  
12 the logic, the operation of logic systems, the  
13 operation of detectors to the extent that there's new  
14 detectors that haven't been used in nuclear power  
15 before.

16           On the other hand, I would think that the  
17 surveillance requirements and full instrumentation  
18 would be simpler in a passive plant. You just don't  
19 have that much equipment and the tech specs are  
20 obviously shorter because there's whole sections of  
21 them missing for equipment that doesn't exist in this  
22 plant that did exist in previous plants.

23           Overall, I think the tech specs chapter  
24 was difficult to review because it had a lot of little  
25 pieces, a lot of detail in it. And it was sort of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 harder for me to keep track without running several  
2 lists of things. And also because we didn't have full  
3 information on the plant design by virtue of the other  
4 chapters.

5 So I would say that that's, in my  
6 judgment, certainly an interim judgment and we can't  
7 make a final decision until we are pretty close to a  
8 final document.

9 MS. CUBBAGE: Thank you.

10 MEMBER ABDEL-KHALIK: I agree with what  
11 Jack said. I still think that would be a good idea to  
12 provide some logic for the surveillance frequency.

13 I was pleased to hear that there's going  
14 to be a surveillance for the gravity for the cooling  
15 system, even if is just checking whether or not its  
16 obstructed. I'd like that surveillance to be confirmed  
17 that the system is actually full of water, even  
18 though.

19 MEMBER APOSTOLAKIS: Surveillance the same  
20 as -- we using the terms interchangeable?

21 MEMBER ABDEL-KHALIK: No. In this case the  
22 system is not operable. You just put a borescope and  
23 make sure it's not obstructed; that's the  
24 surveillance. But if you're going to do that you  
25 might as well confirm that it is full of water. That

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 would be my only comment on that case. Even though  
2 the system is designed with inclination --

3 MS. CUBBAGE: Could I just ask for  
4 clarification on both of those?

5 MEMBER ABDEL-KHALIK: Yes.

6 MS. CUBBAGE: Would the concerns with  
7 surveillance frequency is the focus on the I&C or is  
8 it in general surveillance frequencies?

9 CHAIRMAN CORRADINI: I guess I heard from  
10 Said one, and from others, that it's somewhat digital  
11 I&C.

12 MEMBER ABDEL-KHALIK: Right.

13 CHAIRMAN CORRADINI: In some sense is for  
14 one characterization. And then your concern, or your  
15 thing is passive systems?

16 MEMBER ABDEL-KHALIK: Right. Right.

17 MS. CUBBAGE: Okay. Because I think what  
18 I had proposed on the -- when we come back for Chapter  
19 7, I think we need to integrate some tech spec  
20 discussion. Because it seems like the most  
21 challenging part of the tech spec review is really to  
22 the I&C.

23 MEMBER ABDEL-KHALIK: That's all.

24 MEMBER SIEBER: I presume you used the  
25 term surveillance, that has a specific meaning in tech

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 spec space? And I presume that when you use that  
2 term, it's a little broader.

3 CHAIRMAN CORRADINI: Did you have anything  
4 on the other chapters?

5 MEMBER ABDEL-KHALIK: No.

6 CHAIRMAN CORRADINI: Okay. Graham?

7 DR. WALLIS: Well, I think we had sort of  
8 easy chapters today, apart perhaps from the tech  
9 specs. But I'm not an expert on tech specs. I view  
10 the discussion today with a kind of sense of wonder  
11 than feeling like a contributor.

12 MEMBER APOSTOLAKIS: That'll be the last  
13 one.

14 DR. WALLIS: I'm looking forward to  
15 Chapter 15.

16 CHAIRMAN CORRADINI: Okay.

17 MS. CUBBAGE: And Craig just reminded me  
18 that the terms surveillance requirement is actually  
19 defined in the regulations.

20 MEMBER SIEBER: Yes, it is.

21 MEMBER BLEY: I had a few things, Mike.

22 The rehashing a little bit what we talked  
23 about. We had a discussion early on today about the  
24 idea that some nonsafety equipment -- well, that the  
25 nonsafety equipment is being categorized as high or

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 low regulatory interest with the high interest ones  
2 ending up with tech specs and the low interest ones  
3 ending with some kind of availability requirements, no  
4 LCO --

5 MS. CUBBAGE: Yes.

6 MEMBER BLEY: -- but tracking  
7 availability. And I think --

8 CHAIRMAN CORRADINI: Are these the RTNSS?

9 MS. CUBBAGE: Yes. Yes, and the ones that  
10 end up with the tech specs is because they meet the  
11 criteria 5036.

12 MEMBER BLEY: I think I need to understand  
13 that better.

14 MS. CUBBAGE: We'll be coming back and  
15 discussing the whole RTNSS program, what was scoped  
16 in, why, what the treatment is.

17 MEMBER BLEY: Oh, good. Good.

18 MS. CUBBAGE: And why. And that's a  
19 little ways off yet That's going to come with 19 --

20 MR. MARSHALL: This is Michael Marshall,  
21 Tech Spec Branch Chief.

22 And there's a whole separate chapter of  
23 RTNSS. RTNSS we characterize it as we have lower  
24 priority or lower regulatory priority, is just an  
25 ultimate treatment from a regulatory point of view for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 a systems past 72 hours in the passive plants.

2 MS. CUBBAGE: Right. And if you're  
3 interested in looking, for those who don't know what  
4 availability control is because it's very unique to  
5 the passive plants, Appendix 19(a) in the DCD Rev. 4  
6 you can see them. And they look like tech specs. You  
7 just won't find an action statement that says shut the  
8 plant down. You're going to have action statements  
9 that say, all right, notify the plant manager. They  
10 have to take corrective actions.

11 MEMBER BLEY: That's Appendix 19(a)?

12 MS. CUBBAGE: Yes

13 MEMBER BLEY: Which I've got.

14 MS. CUBBAGE: Yes.

15 MEMBER BLEY: Okay. The only other thing  
16 I want to bring then is aux systems was that  
17 discussion we had about instrument error and the  
18 interface with nitrogen systems. Folks from GEH gave  
19 me a little more information at one of the breaks  
20 following up what I was asking about. And no  
21 surprise, there are bypasses, of course, on the  
22 filters and on the dryers. But there's a whole system  
23 of operational tracking that's associated with it  
24 that, I don't know, at least the presentation we had  
25 on it staff said they assumed there were no bypasses

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 because there weren't any on the little cartoons. But  
2 there are.

3 MS. CUBBAGE: Well, I think --

4 MEMBER BLEY: And you folks might want to  
5 look at that and see that you're comfortable with it.

6 MS. CUBBAGE: Right. I mean I think what  
7 the review was saying that he looked to make sure that  
8 failure of instrument error would not be a safety  
9 significant issue.

10 MEMBER BLEY: I'm sorry. I also heard him  
11 say that that there were no bypasses?

12 MS. CUBBAGE: I think he did. He did. But  
13 he also said that he didn't ask and he didn't delve  
14 into it because he wasn't concerned about the  
15 consequence.

16 MEMBER BLEY: I would suggest, and I  
17 haven't looked further, that if you can get  
18 contamination or moisture that somehow ends up going  
19 through those little lines, you know, there might be  
20 a safety issue associated with it. IF you think  
21 that's a possibility. And I think that's a  
22 possibility.

23 On the chapter -- on the conduct of ops,  
24 I was real happy with what I heard toward the end of  
25 that. It's encouraging.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 I guess on the tech specs it's really  
2 there's a lot more to look at, so I won't say anything  
3 specifically on that subject..

4 CHAIRMAN CORRADINI: Okay.

5 MEMBER ABDEL-KHALIK: Mike one issue I  
6 forgot to bring up is the thermoresponse of the  
7 control room.

8 CHAIRMAN CORRADINI: And just to remind,  
9 so yours is a modeling of the --

10 MEMBER ABDEL-KHALIK: The control room  
11 response to ensure habitability, what is the peak  
12 temperature going to be, were the boundary conditions  
13 used in the calculations are, et cetera, to ensure  
14 what the temperature history will be.

15 MS. CUBBAGE: I think I'd like to defer  
16 that one to GEH if they're going to be able to handle  
17 that at the full Committee. The staff would be  
18 planning to present at the final SER stage the  
19 resolution of that issue. But unless we receive  
20 additional information from GEH, we wouldn't be in a  
21 position of providing you any more at time. So I  
22 don't know if they heard what you were saying, okay?

23 CHAIRMAN CORRADINI: If I could just split  
24 it. There were two issues. One was with operator  
25 habitability, It was to the temperatures, whether it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 be the cold or the hot swing and how they can inhabit.  
2 But the second was, if I understood it, was also  
3 components and cabinets. And there was a second  
4 different analyses that eventually was to be  
5 performed, if I remember correctly.

6 MEMBER BLEY: And there was a third one.  
7 I believe it was air mixing and delivery to the --

8 CHAIRMAN CORRADINI: Right.

9 MEMBER MAYNARD: Well, I was going to  
10 bring this up when you got to me, too. I think  
11 there's so many open items on the HVAC that we need to  
12 at some point bring that back. I'm not that the full  
13 Committee, I'm not sure are quite ready for the full  
14 Committee. But if it is, I think it might still come  
15 out as an open item because there were a --

16 MEMBER BLEY: True.

17 MEMBER MAYNARD: -- lot of still open  
18 issues for that.

19 MEMBER STETKAR: I'd expand that, Mike,  
20 also. I held back this morning just because of time.  
21 I did -- believe me.

22 We talked a lot about the control room,  
23 which obviously is important. But the same types of  
24 HVAC room heat up equipment survivability issues apply  
25 for the general areas of the control building that do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 include safety related DCIS cabinets. They apply for  
2 the nonradiological areas of the reactor building that  
3 include the safety related batteries, the safety  
4 related uninterruptible power supplies and other  
5 safety related DCIS. And maybe, and I'm not sure,  
6 parts of the electrical and control building that  
7 include nonsafety, I think, DCIS but potentially  
8 important. That's kind of it.

9 MS. CUBBAGE: I think that's an EQ issue.  
10 Yes.

11 MEMBER STETKAR: And it's not just general  
12 area. The main concern is demonstrating that the  
13 temperatures inside the cabinets will remain lower  
14 than the qualification temperatures for all the  
15 digital equipment.

16 CHAIRMAN CORRADINI: Let me turn for a  
17 moment, because personally I guess I would favor  
18 Otto's approach, which is I don't think we can bring  
19 it up to the full Committee when we don't have the  
20 full picture yet.

21 MEMBER STETKAR: Right. Right.

22 CHAIRMAN CORRADINI: So maybe the question  
23 is when will we get a picture that we want to revisit?

24 MS. CUBBAGE: Well, I think what I'd like  
25 to emphasize is that I'm hearing a lot of concerns

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that echo what the staff has been asking. And I don't  
2 think I heard -- perhaps this last item --

3 CHAIRMAN CORRADINI: I haven't heard  
4 anything else --

5 MS. CUBBAGE: -- but if I haven't heard  
6 anything -- well, except for this last issue here, I  
7 think all the other concerns are captured by the  
8 staff's open items. So what we're looking for the  
9 Committee is to agree that our open items are  
10 sufficient. And if you have additional open items,  
11 then we need to tack those on. But as far as coming  
12 back at the full Committee if GE wants to come in and  
13 try to address some of your issues, that -- you know,  
14 they can try to do that. But at this point I don't  
15 think the staff will be able to provide more than what  
16 you've already heard.

17 CHAIRMAN CORRADINI: So what you're really  
18 saying is that if from just a timing standpoint, GEH  
19 is still in the middle of doing what they need to do  
20 to address your requests for information.

21 MS. CUBBAGE: Right.

22 CHAIRMAN CORRADINI: The most that  
23 probably could be done at the full Committee is to  
24 acknowledge what the open items are, add what  
25 additional concerns we might have it and leave it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 until you can address it.

2 MS. CUBBAGE: Now I say that, but the full  
3 Committee is a ways off.

4 CHAIRMAN CORRADINI: Right.

5 MS. CUBBAGE: If GE were to respond to all  
6 these RAIs near term and we said they're all good, you  
7 know, we may be able to tell you some more. But I  
8 don't think we're going to have time to get into the  
9 resolution of all these open items at a short full  
10 Committee setting.

11 MR. KINSEY: And this Jim Kinsey from GEH.

12 I guess along the lines of Amy's  
13 discussion, it would be helpful to us, though, to  
14 understand whether the Subcommittee has any  
15 significant or additional concerns beyond those  
16 already described as open items. It would be --

17 MS. CUBBAGE: Right. That's a very  
18 important emphasis of this meeting.

19 MR. KINSEY: Even if they aren't  
20 documented as such, yes. That would help to move  
21 toward resolution.

22 CHAIRMAN CORRADINI: We will take that as  
23 our action item to get through Gary and Amy, you have  
24 something to make sure we're clear as to what we're  
25 looking for.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Dennis?

2 MEMBER BLEY: Yes. One last thing.  
3 Reading the RAIs I wasn't clear how far you were going  
4 on, say, this habitability issue in the control room  
5 hearing Mr. Forrest's presentation goes a lot further.  
6 I guess I'm just sitting here thinking if he's going  
7 to review this stuff, I have no doubt he's going to  
8 get at all these issues. Is that documented  
9 somewhere?

10 MS. CUBBAGE: It will be in the final --  
11 well, first of all, you're going to have GE's going to  
12 have to respond to the RAIs. So that will be in  
13 writing on the docket. And if you're interested we  
14 can get you those responses when they come in. And  
15 then as necessary, they'll have to update the DCD if  
16 there was an impact. And then our final SER will  
17 explain why these issues have been resolved.

18 CHAIRMAN CORRADINI: Good.

19 Sam, I'm sorry. I jumped a bit. Go  
20 ahead.

21 MEMBER ARMIJO: Are you finished?

22 I only had comments on parts of Chapter 10  
23 and Chapter 9.

24 First of all, Chapter 10 I'd like to  
25 compliment GEH on the excellent treatment of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 materials issues of the turbine and the condensers.  
2 I mean, they picked from -- taking lessons learned  
3 from prior operation on choice of titanium and  
4 stainless steel for the condenser.

5 They used words they're picking materials  
6 for greater than 60 years life. That's nice to see  
7 because I think that should be the philosophy for the  
8 entire NSSS system.

9 They use a 2 1/2 one chrome molly in their  
10 feedwater lines, although they probably could have  
11 gotten away with lesser chrome content, they choose to  
12 go to something they know would work.

13 And they've protected these materials and  
14 the system with a feedwater oxygen control to make  
15 sure everything works as they want it to work. And  
16 that's not an optional system.

17 And where my problems are, and I'll repeat  
18 it and try to be brief.

19 In Chapter 9 hydrogen water chemistry,  
20 really the most powerful proven tool available to  
21 prevent irradiation assisted stress corrosion cracking  
22 of internals and also prevent cracking of any  
23 noninternals like welded stainless steels, that's an  
24 optional system. So there's a lack of consistency in  
25 the DCD that I see that I think should be corrected,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 certainly with respect to hydrogen water chemistry  
2 system not being optional. And zinc possibly, but I  
3 don't know about that. But also is a very effective  
4 way of reducing dose.

5 And it just seems strange to me that those  
6 things are left for later.

7 CHAIRMAN CORRADINI: Okay. That's it.

8 MEMBER ARMIJO: That's it.

9 CHAIRMAN CORRADINI: Mario?

10 MEMBER BONOCA: Yes, specifically  
11 regarding new issues, if any, I don't think I have any  
12 issues that the staff has not identified as an open  
13 item or an RAI. I think that there's more a place to  
14 have additional information areas of particular  
15 interest are HVAC systems. There's a lot of  
16 information there we will get, the control room  
17 particularly.

18 You know, all the issues raised regarding  
19 temperatures. I mean, those are clearly areas where  
20 we need to have information.

21 I am not uncomfortable that GE doesn't  
22 have the proper design. It's simply we don't have  
23 information about it to give us confidence. And  
24 probably in some cases they'd like to do some  
25 analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1                   The     other     area     is     technical  
2 specifications. It seems much more complicated than I  
3 expected when I came, more open still to some  
4 definitions and I said we need to understand the basis  
5 for those various frequencies. After all the debate  
6 we had, I did not come with a clear idea of how  
7 they're going to address them. But I understand that  
8 those are open items and the fact that -- staff and we  
9 will get information for that.

10                   One area that may of interest to the rest  
11 of the Committee is the closed session on the  
12 safeguards issue. I mean there was some information  
13 there which I thought was validated about what GE has  
14 done. And I think what they have done is quite  
15 significant. And, you know, I don't know how to  
16 monitor that into a full Committee meeting.

17                   MS. CUBBAGE: Well, maybe in light of the  
18 fact that we're about to receive some additional  
19 deliverables from GE in this are, that maybe at a  
20 future date we could schedule another closed session  
21 and then, you know, maybe not in the full Committee  
22 forum, but any member who wanted to come could --

23                   MEMBER BONOCA: Yes. Well, I think that  
24 it would be an area of interest to them. So whatever  
25 it is, if the information is available --

1 CHAIRMAN CORRADINI: Okay. Thank you.

2 MEMBER MAYNARD: Covered most of the  
3 things on the HVAC system. I felt very comfortable  
4 after hearing the staff reviewer talk about -- and in  
5 fact, if anything, I got the impression we may have to  
6 ask are you going too far. That's good it's going to  
7 that depth there. So I think that will address most of  
8 those issues.

9 Standby liquid control system, ejection of  
10 nitrogen. I think we said we were going to look at  
11 that in Chapter 15 as to why that's not a problem or  
12 whatever. So I think we want to make sure we don't  
13 lose track of that in case the nitrogen does get  
14 injected after the boron gets injected.

15 I didn't have any comments on 10 or 13,  
16 Chapter 16. I think we need to keep in mind that  
17 testing is very good and it's useful. Too much testing  
18 can be a bad thing, though. I think we need to make  
19 sure we don't overboard in some of these areas.

20 I think use of the BWR-6 tech specs I  
21 think is a good start. And I agree with Jack, you  
22 know there's a lot of things really not applicable  
23 here. But I think it's important to keep the same  
24 language and to keep the same philosophy and the  
25 formatting so that it's an easy transition for the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 operator, especially going into a new design. As much  
2 familiar as possible with the existing tech specs and  
3 stuff I think will be beneficial.

4 I think it would be worthwhile to have  
5 some more discussion on some of the allowed outage  
6 times and the surveillance frequency. I don't think  
7 we have to go through everyone of them. I think it  
8 would be nice to understand some of the basis. But  
9 also I don't want to go overboard on this. I don't  
10 believe there has to be an analyses and a basis for  
11 every frequency. I have no problem with engineering  
12 judgment. I think it's important to understand when  
13 you're using engineering judgment to set that basis  
14 versus when you really have another basis behind. So  
15 I think some discussion on that in the future.

16 MEMBER BONOCA: And I agree with you,  
17 Otto. In most case, I mean whatever wasn't the basis  
18 to the PRA, typically they are conservative estimates  
19 and I think we over test. So that's true.

20 But I was left at the end of it with a  
21 sense that there is some piecemeal approach, there was  
22 information from PRAs is being used for some  
23 surveillances and other areas and -- so I understand  
24 where it comes from. And there is an approach to it.

25 MEMBER MAYNARD: Yes. That's why I think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it would be good to understand.

2 MEMBER BONOCA: And the other thing is,  
3 you know, at some point I would like to have an answer  
4 to is why not PRA basis. I mean clearly the PRA  
5 provides the most significant information insofar as  
6 past history and reflected in so much information.

7 MEMBER APOSTOLAKIS: I think it's going to  
8 effect -- would be defense-in-depth. But it would be  
9 nice to have a discussion of it.

10 MEMBER BONOCA: Yes, I mean that's the  
11 point, you know, why not the best information you do  
12 have, which is the story that better to use as a basis  
13 for determining frequency or components in the PRAs.

14 MEMBER MAYNARD: That's all I've got.

15 MEMBER STETKAR: I don't have anything.

16 CHAIRMAN CORRADINI: I have them all? All  
17 right.

18 MEMBER STETKAR: Yes.

19 CHAIRMAN CORRADINI: I'll get them. Thank  
20 you.

21 Tom?

22 MR. KRESS: And I'm going to make it  
23 unanimous on the question of the control room  
24 ventilation. I think especially Said's problem with  
25 the temperature. I think that needs a final looking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 at.

2 In general, I would like to congratulate  
3 both the staff and GE on a very compete job from what  
4 I've seen. Very complete.

5 When it comes to the high importance or  
6 low importance to determine RTNSS, this may not be  
7 appropriate at this time, but I have a problem with  
8 using importance measures the way we do to determine  
9 that. I'll tell you why.

10 If I have something like ESBWR which has  
11 a very low CDF, it's going to put importance -- it's  
12 going to use importance measures that will put things  
13 in RTNSS that probably shouldn't be there. I would  
14 defer to George on this, but I would have had an  
15 importance measure that doesn't use the absolute CDF  
16 value, but uses some CDF acceptance value. You think  
17 about it.

18 And anyway, you've got the rules in there  
19 and the regulations you have to follow. So, you know,  
20 it's a comment that we might want to think about in  
21 the future.

22 I wasn't quite convinced yet on the  
23 analysis of the case of the isolated inclined transfer  
24 tube. I'd like to see that analyses to be sure.

25 And I'd also like to second the question

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that sooner or later we need to look at the nitrogen  
2 getting injected in the RCS and the potential effects  
3 on long term cooling.

4 With respect to surveillance frequencies,  
5 I agree with George. It's almost going to have to be  
6 a defense-in-depth thing. And we need to know what  
7 the basis is for those. And if it's just engineering  
8 judgment, let's say so. But I think -- I don't see  
9 that you can risk-inform that. You can risk-inform  
10 allowed outage times very nicely. But surveillance  
11 frequencies, I don't think so. So I would second  
12 George's comment. I think it's defense-in-depth.

13 And finally, like Mario, I was much  
14 impressed with attention to the security issues. I  
15 thought there was an extremely nice job, and was glad  
16 to see that.

17 CHAIRMAN CORRADINI: You have the last  
18 word, Dr. Apostolakis.

19 MEMBER APOSTOLAKIS: Yes. My issues have  
20 been mentioned already. I'd really like to hear  
21 people's views about frequency of testing.

22 The only thing I want to say is that I  
23 second Tom's commentary. I really believe both sides  
24 are doing a professional job, a very good job. This  
25 was a good meeting. And the issues, wherever there

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



1 were questions, were difficult or there is not  
2 information at this point. But I'm very pleased with  
3 the way this going.

4 And that's it, Mr. Chairman.

5 CHAIRMAN CORRADINI: Okay. So first let  
6 me thank GEH and the staff. I think both have done,  
7 again, for our third meeting a really excellent job of  
8 summarizing and presenting what has been done.

9 The plan, let me go with the plan first.  
10 The plan is to in the third week in January to have a  
11 two day Subcommittee meeting where Chapter 15 --

12 MEMBER APOSTOLAKIS: Oh, you have the  
13 dates then.

14 CHAIRMAN CORRADINI: We just have a week.  
15 We've already agreed to at the last full Committee.

16 MEMBER APOSTOLAKIS: You have a week?

17 CHAIRMAN CORRADINI: We have in that week  
18 a couple of days for us relative to primarily Chapter  
19 15 and associated chapters, which I'm guessing may be  
20 Chapter 6 reengineering safety features.

21 MS. CUBBAGE: Right. It could be as many  
22 as four chapters. It would be four, six, fifteen and  
23 twenty-one. And I see -- look at his eyes light up.

24 MEMBER APOSTOLAKIS: Third week meaning--

25 MS. CUBBAGE: The week of the 14th of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 January.

2 CHAIRMAN CORRADINI: Week of the 14th.

3 MS. CUBBAGE: So it's possible that one of  
4 those may drop off, but --

5 CHAIRMAN CORRADINI: WE had agreed. I'm  
6 just reminding you.

7 MEMBER APOSTOLAKIS: No. I wasn't there,  
8 was I?

9 CHAIRMAN CORRADINI: I think we did that  
10 in your absence. You were incapacitated.

11 MEMBER APOSTOLAKIS: So which days do you  
12 have in mind?

13 CHAIRMAN CORRADINI: That's yet to be  
14 determined because Dr. Banerjee has other Thermal-  
15 Hydraulic Subcommittee he wants to install there,  
16 since we're all going to be here.

17 MEMBER BLEY: I had 15 to 18.

18 CHAIRMAN CORRADINI: Two days within those  
19 four.

20 MS. CUBBAGE: Right. And if we did all  
21 four of those --

22 MEMBER APOSTOLAKIS: I can be here on the  
23 18th only.

24 CHAIRMAN CORRADINI: So before we diverge  
25 on that, so I'm just alerting the Committee to that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 because we'll probably learn more relative to the  
2 schedulers since we're not trying to schedule on which  
3 of the days we fit in relative to that.

4 But if I could just remind everybody, if  
5 you have written comments relative to the four  
6 chapters, please feel free to send to me. What we're  
7 going to do is send it to myself and to Gary. Gary  
8 will pass them on to Amy and Jim and GEH so they get  
9 a feeling for the broader set of comments kind of  
10 behind the scenes that don't rise up.

11 Secondly, if you have other things that  
12 you want to be emphasized at the March meeting where  
13 we take up another interim letter, let me know now  
14 because we'll add to that list from the January  
15 meeting.

16 MS. CUBBAGE: Yes.

17 CHAIRMAN CORRADINI: And other than that,  
18 I can't think of anything else, other than to thank  
19 again the folks from GE. Thank you very much for your  
20 time. And the staff.

21 MS. CUBBAGE: Thank you. Yes. I'd  
22 definitely like to thank the Committee for a very  
23 productive day.

24 MEMBER APOSTOLAKIS: Gary, when is the PRA  
25 issue coming up again? I mean, eleven, too, has not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1       been reviewed by us, right?

2               MR. HARBUCK:   The ESBWR PRA?

3               CHAIRMAN CORRADINI:   Correct.

4               MR. HARBUCK:   I am not sure.

5               MS. CUBBAGE:   We need to come back at  
6       least twice.

7               MEMBER APOSTOLAKIS:   Are we done with  
8       level one then?   No?

9               MS. CUBBAGE:   You haven't seen the SER.  
10       We don't have an SER to send you yet.   Because we  
11       just--

12              MEMBER APOSTOLAKIS:   GE has actually made  
13       presentation from level one.

14              MS. CUBBAGE:   They have.   And we've  
15       received Rev. 2 of the PRA just this fall in its  
16       entirely.   We're still reviewing it.   We need to write  
17       an SE.

18              MEMBER APOSTOLAKIS:   So the two new  
19       members will have a chance to go over it?

20              MS. CUBBAGE:   Yes. Yes.

21              CHAIRMAN CORRADINI:   Yes.   Because things  
22       have been postponed.   This actually, today was  
23       supposed to have been the level two PRA day  
24       originally.

25              MEMBER APOSTOLAKIS:   Level two?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MS. CUBBAGE: Those were advance  
2 informational sessions. We always intended that we  
3 needed to come with an SER.

4 MEMBER APOSTOLAKIS: Do you have any idea  
5 when this may happen?

6 MS. CUBBAGE: Spring. I mean, for with an  
7 SER.

8 CHAIRMAN CORRADINI: Birds come and the  
9 flowers bloom. How about that?

10 MS. CUBBAGE: We just recently received  
11 Rev. 2 of the PRA, so --

12 MEMBER BLEY: Is that the same as Chapter  
13 18 or is that --

14 MS. CUBBAGE: No. Eighteen is much  
15 closer. We're hoping for a February Subcommittee  
16 meeting.

17 MEMBER BLEY: Okay.

18 MS. CUBBAGE: We have the SE input. WE're  
19 well along. Human factors, yes.

20 CHAIRMAN CORRADINI: So will all of us be  
21 here for SOARCA tomorrow? If so, I'll work with Gary.  
22 You will not? But we'll get to you. I'll work with  
23 Gary to find out what the current plan is in that week  
24 which Subcommittee is which day.

25 MEMBER APOSTOLAKIS: For January?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: For January. Okay.  
2 Meeting is over. Meeting is adjourned.  
3 (Whereupon, at 5:28 p.m. the meeting was  
4 adjourned.)  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

CERTIFICATE


This is to certify that the attached proceedings  
before the United States Nuclear Regulatory Commission  
in the matter of:

Name of Proceeding: Advisory Committee on  
Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD


were held as herein appears, and that this is the  
original transcript thereof for the file of the United  
States Nuclear Regulatory Commission taken by me and,  
thereafter reduced to typewriting by me or under the  
direction of the court reporting company, and that the  
transcript is a true and accurate record of the  
foregoing proceedings.

  
Charles Morrison  
Official Reporter  
Neal R. Gross & Co., Inc.

**NEAL R. GROSS**  
COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)



**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

## **Presentation to the ACRS Subcommittee**

**ESBWR Design Certification Review**

**Chapter 16**

**“Technical Specifications”**

**November 15, 2007**



# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Purpose**

- Brief the Subcommittee on the staff's review of Chapter 16 of the ESBWR DCD application
- Review based on applicant DCD Rev. 3 and RAI responses received from applicant
- Answer the Committee's questions

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Project and Technical Review Team**

- **Lead PM**
  - Manny Comar, Project Manager
- **Lead Tech. Reviewers**
  - Craig Harbuck, Sr. Reactor Engineer
  - Andrez Drozed, Sr. Reactor Engineer
  - Jorge Hernandez, Reactor System Engineer
  - Hulbert Li, Sr. Electronics Engineer
  - Sang Rhow, Electronics Engineer
  - George Thomas, Sr. Reactor Systems Engineer
  - Hanry Wagage, Sr. Reactor Engineer

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Outline of Presentation**

- Applicable Regulations and Review Guidance
- RAI Status Summary
- TS Review Criteria
- Open Issues
- COL Action Items
- Conclusion
- Discussion / Committee questions

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Applicable Regulations and Review Guidance**

- 10 CFR 50.34, 50.36 and 50.36a
- 10 CFR 52.47(a) and 52.79(a), 52.103
- 10 CFR Part 50, Appendix A
- Primary SRP Section: 16.0

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **RAI Status Summary**

- Original number of RAIs 162
- Number of RAIs resolved 112 (118)\*
- Number of Open Items 50 (44)\*

\*Based on rev 4

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **TS Review Criteria**

- Meet requirements of 10 CFR 50.36 regarding SLs, LSSS, LCOs, SRs, Design Features, and Administrative Controls
- Conform to STS conventions regarding format and usage rules
- Consistent with Plant design and accident analyses

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Open Issues**

- Resolution of Bracketed information
- Instrumentation Setpoint Methodology
- Surveillance Requirements for Digital Instrumentation and Control
  - Using Self Test Report for Channel Check and Channel Functional Test
  - Logic System Functional Test
  - Response Time Test
  - Staggered Test Basis

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Open Issues (continued)**

- Analysis to demonstrate one Safety Relief Valve is adequate for RPV overpressure protection
- RCS vent path to ensure GDACS operability in Modes 5 and 6
- Analyses to support ECCS TS Action requirements



# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Open Issues (continued)**

- Determination of drywell air temperature and GDCS pool temperature
- SR for RWCU/SDC system isolation valves
- Containment oxygen concentration TS limit
- SR to measure drywell-wetwell bypass leakage
- Control Room Habitability Area temperature post DBA

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Open Issues (continued)**

- Availability Controls for makeup water to IC/PCC pools and spent fuel pool
- Analyses to demonstrate water inventory above RPV during refueling and in spent fuel pool sufficient to mitigate loss of cooling for 72 hours
- VRLA battery issues
  - Temperature control and measurement
  - Using float current to indicate state of charge

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Chapter 16 COL Action Items**

- Replace information in curly and square brackets with valid plant specific information suitable for plant operation
- Confirm conditions related to adoption of topical reports are met

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 16**

## **Conclusion**

- Pending resolution of Open Items, cannot conclude the ESBWR generic TS comply with 10 CFR 50.34, 50.36 and 50.36a
- Completion of generic TS review contingent upon resolution of design and analysis issues outside of DCD Chapter 16

**ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 16**

Discussion/Committee Questions

**ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 16**

- **Acronyms:**
- DCD: Design Control Document
- RAI: Request for Additional Information
- TS: Technical Specifications
- COL: Combined License
- SRP: Standard Review Plan
- SL: Safety Limits
- LCO: Limiting Condition for Operation
- SR: Surveillance Requirement
- STS: Standard Technical Specifications
- RPV: Reactor Pressure Vessel
- RCS: Reactor Coolant System
- GDCS: Gravity Driven Cooling System
- ECCS: Emergency Core Cooling System
- RWCU: Reactor Water Cleanup
- SDC: Shutdown Cooling
- DBA: Design Basis Accident
- IC: Isolation Condenser
- PCC: Passive Containment Cooling
- VRLA: Valve Regulated Lead Acid

# ESBWR - Overview


## DCD Chapter 16

### Technical Specifications

**Advisory Committee  
on Reactor Safeguards**

Dan Williamson  
November 15, 2007

GE Hitachi Nuclear Energy



# **Chapter 16 Presentation Content**

- Overview of ESBWR Generic Technical Specifications (TS) and Bases
  - ESBWR TS Development Philosophy
  - Differences from Prior Technical Specifications
  - ESBWR TS COL Applicant Information Items
- Summary



## **ESBWR TS Development Philosophy**

- BWR/6 Standard Technical Specifications (NUREG-1434, Rev 3.1) Utilized as the Basis for Standard Content / Numbering / Form & Format
  - Standardization With Existing Technical Specifications
  - Included Latest Approved Generic Changes (TSTFs)
  - Completion Times and Surveillance Frequencies Generally Consistent with NUREG-1434
- ESBWR-Specific Safety Analyses and Systems Evaluated to Meet Criteria of 10 CFR 50.36

## **Differences from Prior Technical Specifications**


- ESBWR Passive Design
  - Reduction in Systems Credited in Event Mitigation
  - ECCS Inoperability Actions
  - Role of Regulatory Treatment of Non-Safety Systems
- Three (of Four) Electrical Divisions Required
  - Two Divisions Satisfy Safety – Third Provides Single Failure
  - ESBWR TS Assure All Required Divisions Are Associated With the Same Three Divisions
  - All Safety Functions Satisfied With Any Two Divisions

## ESBWR TS COL Applicant Information Items

- COL *Applicants* Provide Site-Specific Closure
  - Similar to Standard Technical Specifications Optional Provisions and Site-Specific Details
  - Examples:
    - Site Description
    - Staff Qualification Standards Employed
    - Effluent Reporting For Single vs Multi-Unit Site
    - Chemical Hazards Protection for Control Room
  - Completed at COL Application
  - Indicated With “[...]” in ESBWR TS

## Summary

- ESBWR TS Standardized Based on ESBWR Design
- ESBWR TS Support COL Application Completeness and Technical Sufficiency
- GEH Is Working With the NRC Staff to Address Remaining Open Items



**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

Presentation to the ACRS Subcommittee

ESBWR Design Certification Review  
**Chapter 13 “Conduct of Operations”**

November 15, 2007

ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13

Purpose

- Brief the Subcommittee on the staff's review of the ESBWR DCD application, Chapter 13
- Answer the Committee's questions

ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13

Review Team for Chapter 13

- Lead Project Manager
  - Rocky D. Foster
- Lead Technical Reviewers
  - Richard Pelton
  - Daniel Barss
  - Albert Tardiff

ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13

Outline of Presentation

- Applicable Regulations
- RAI Status Summary
- SER Technical Topics
- Open Items
- COL Information Items



# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Chapter 13

#### Summary of Regulations and other Review Guidance

- 10 CFR 50, 50.34 (f)(2)(xxv) and 50.47(b)(8)
- 10 CFR 52.47, 52.48 and 52.78
- 10 CFR 55
- 10 CFR 73.55 and 73.1
- NUREG-0654/FEMA-REP-1, NUREG-0696, 0718, 0737, and 0814
- SRPs 13.1-13.6.2 and 13.6.4-13.6.6
- Reg. Guide 1.101
- Reg. Guide 5.XX series

ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13

RAI Status Summary

- Original number of RAI's – 43
- Number of RAI's resolved – 6
- Number of Open Items – 39
  - Emergency preparedness
  - Detection aids
  - Unattended openings
  - Special security areas/vital components

ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13.1 and 13.4

SER Technical Topics & COL Information Items

- 13.1 - Organizational structure to be consistent w/ human system interface
- 13.1 Organizational structure to be addressed by COL applicant
- 13.4 - “Operational Programs” is consistent w/ SECY-05-0197
- 13.4 - Operational programs to be addressed by COL applicant

# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Chapter 13.2 and 13.5

#### SER Technical Topics & COL Information Items

- 13.2 and 13.5 - Training program development plan and operating procedures development plan incorporate the appropriate human factors elements and are consistent with the SRPs
- 13.2 and 13.5 - Interface with Chapter 18, "Human Factors Engineering"
- 13.2 - Interfaces with NEDO-33275, "ESBWR HFE Training Development Implementation Plan"
- 13.5 - Interfaces with NEDO-33274, "ESBWR HFE Procedures Development Implementation Plan" and NEDO-33276, ESBWR HFE Verification and Validation Implementation Plan"
- 13.2 Licensed and non-licensed staff training programs to be addressed by COL applicant
- 13.5 Operating procedures program to be addressed by COL applicant

# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Chapter 13.3

#### Emergency Preparedness Technical Topics of Interest

- EP is mostly programmatic – includes facilities, equipment, personnel and training
- Design certification – limited to non-site-specific features that are technically relevant to the design (usable for multiple units/sites)
- Standard design may include various design features, facilities, functions and equipment [e.g., technical support center (TSC)]
- DCD satisfies TSC size/location/displays/power
- COL applicant will address emergency action levels (EALs)

ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13.3

Open Items

- Backup power supply for communication equipment (move to 13.6)
- Address TSC (electrical building) 100-year winds/floods
- Provide EP ITAAC (RAI 14.3-150)
- Radiological protection to TSC communication staff (outside TSC)

ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13.3

COL Information Items

- Provide a emergency plan
- Identify OSC (and communications)
- Identify Emergency Operations Facility (EOF) (and communications)
- Provide onsite decontamination capabilities

ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13.6

Physical Security Technical Topics of Interest

- Many security features are being identified through voluntary security assessments
- Resolution of issues mainly focused towards credit for design features
- Examples are doors, cabinets, power supplies and testing and maintenance of features identified
- Correction of previously made assumptions



ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13.6

Open Items

- Accommodation of detection aids in the design
- Identification and design of unattended openings
- Identification of special security areas and location and design of unique physical protection measures for vital components
- Resolution planned through a new topical report to address all Open Items

# ACRS Subcommittee Presentation

## ESBWR Design Certification Review

### Chapter 13.6

#### COL Information Items

- Final design considerations for access controls, power supplies, unattended openings, alarms of unique features and administrative controls for unique features
- COL information items ensure transition of the unique security features identified in the ESBWR design

ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 13


Discussion/Committee Questions

# ESBWR DCD Chapter 13

## Conduct of Operations

Advisory Committee on  
Safeguards

J. Alan Beard  
November 15, 2007



**HITACHI**

# **Presentation Content**

- Chapter 13 – Overview Of Conduct of Operations
  - Organization Structure
  - Training
  - Emergency Planning
  - Operational Program Implementation
  - Plant Procedures
  - Physical Security
- Summary



**HITACHI**

# **Chapter 13 Overview – Conduct of Operations**

- Chapter 13 Provides Information Relating to Operational Plans for ESBWR
  - > It Provides Operational Plans Such That Combined Operating License (COL) Applicant's Organization Will Operate the Plant in a Manner That Protects Public Health and Safety
- The COL Applicant Referencing the ESBWR DCD Will Provide the Detailed Operation Plans



HITACHI

## **Section 13.1 – Organizational Structure**

- The Organizational structure will be consistent with Human System-Interface (HSI) design assumptions
  - > Discussed in Chapter 18, Human Factors Engineering
- COL Applicant to demonstrate their organizational structure is consistent with ESBWR Human Factors Engineering design requirements and 10 CFR 50.54(i)



**HITACHI**

## **Section 13.2 - Training**

- The Training Program Development for Licensed Operator Training and Non-licensed Operator Training Programs Are Addressed in Chapter 18
  - > Section 18.10, Training Program Development
  - > Section 18.12, Design Implementation
  - > Section 18.13, Human Performance Monitoring
- Results of Industry Operating Experience Are Incorporated Into Training and Retraining Programs
  - > e.g., NUREG-0737, Lessons-learned From Post TMI
- COL Applicant Will Provide A Description Of, and the Schedule for the Training Program for the Licensed Operator Training Program and Non-licensed Operator Training Program



HITACHI



## **Section 13.3 – Emergency Planning**

- Emergency Planning Is Not Within Scope of the ESBW Design
- Design Features, Facilities and Equipment Necessary for Emergency Planning Are Considered in Design Basis of the Standard Plant
- > Technical Support Center (TSC)
  - In Accordance With NUREG 0696, Functional Criteria for ERF
  - Includes Requirement for Safety Parameter Display System (SPDS)
  - Environmentally Controlled
  - Reliable Voice and Data Communication System
- > Emergency Operations Facility (EOF) and Operational Support Center (OSC) Is Not Within the Scope of ESBWR Standard Plant
  - COL Applicant is responsible for Identifying Its Details and Communication Interfaces for Inclusion in the Detailed Design



## **Section 13.4 – Operational Program Implementation**

- The COL Applicant Will Describe and Provide Implementation Milestones for Operational Programs As Defined By NRC SECY-05-0197 And Regulatory Guide 1.206



**HITACHI**

## **Section 13.5 – Plant Procedures**

- The COL Applicant Will Develop Administrative Procedures That Provide Administrative Control Over Activities That Are Important to Safety for Operation of the Facility
  - > For Example:
    - Operating and Maintenance Procedures
    - Radiation Monitoring
    - Handling of Heavy Loads



**HITACHI**

## **Section 13.6 – Physical Security**

- Section is Classified as Security Related Information - and Withheld From Public Disclosure Under 10 CFR 2.390
- Provides Description of Some of the Key Elements in the Physical Security of the Plant
  - >Lighting, Communications, Barriers
  - >Much of the Design Material Relating to Physical Security is Safeguards
  - >Industry Has Proactively Reviewed the Physical Security Design
  - >Documented in Separate Safeguards Submittals



HITACHI

## **Section 13.6 – Physical Security** (cont)

- Implementation of the Physical Security Program is the Responsibility of the COL
- Contains Sufficient Description to Support the Tier 1 Entries for Physical Security
- Passive Plants Simplify the Physical Security of the Plant



HITACHI

## Summary

- The COL Applicant Referencing the ESBWR DCD Will Develop The Detailed Operational Plans
- GEH Is Working With the NRC Staff to Address Remaining Open Items



HITACHI



# **Presentation to the ACRS Subcommittee**

## **ESBWR Design Certification Review**

### **Chapter 10 Steam and Power Conversion System**

**November 15, 2007**

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 10**

## **Purpose**

- Brief the Subcommittee on the staff's review of Revision 3 of the ESBWR design certification application, Chapter 10, Steam and Power Conversion System
- Answer the Committee's questions



# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 10**

## **Review Team for Chapter 10:**

- **Lead PM**
  - Eric Oesterle, Senior Project Manager
- **Lead Technical Reviewers**
  - George Georgiev
  - Robert Davis
  - Jorge Hernandez
  - Yamir Diaz Castillo

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 10**

- Applicable Regulations
- RAI Status Summary
- SER Technical Topics
- Open Items
- COL Action Items
- Discussion / Committee questions

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 10**

## **Summary of Regulations and other Review Guidance**

- 10 CFR 52 Subpart B – Standard Design Certifications
- 10 CFR 50 applicable sections and appendices
  - Appendix A, General Design Criteria
  - Appendix B, Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants
  - Appendix G, Fracture Toughness Requirements
- 10 CFR 100, Reactor Site Criteria
- GDCs: 2, 4, 5, 14, 34, 35, 44, 45, 46, 60, 64
- Reg. Guides: 1.26, 1.29, 1.33, 1.37, 1.50, 1.56, 1.71, 1.115, 1.123
- SRPs: 10.2, 10.2.2, 10.2.3, 10.3, 10.3.6, 10.4.1, 10.4.2, 10.4.3, 10.4.4, 10.4.5, 10.4.6, 10.4.7
- Other guidance (generic communications, NUREGs, and SECY's)

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 10**

## **RAI Status Summary**

- Original RAIs: 50
- RAI's resolved: 46
- Open Items: 4
- Open Items to be discussed later in the presentation

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.2.2**

#### Turbine Generator design

- **Key Features**
  - Electronic overspeed protection system
  - Digital I&C
  
- **COL Items**
  - None

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.2.2**

- Open Item 10.2-18: Electronic-only turbine overspeed trip system
  - Issue:
    - Staff requested applicant to address diversity and potential impact to safety-related equipment
  - Staff evaluation:
    - Proposed design is already in use in industry
    - Turbine is favorably oriented per RG 1.115
    - Missile probability is reduced with monoblock design
    - Triple and redundant system meets the intent of the turbine overspeed protection in SRP 10.2
  - Status:
    - Resolved

**ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 10 – SER Section 10.2.3**

**Turbine Rotor Integrity**

- ESBWR turbine rotor fabricated from high quality, high toughness, vacuum treated NiCrMoV low alloy integral forging
- Turbine rotor is subject to preservice and inservice nondestructive examinations which ensure an acceptable level of structural integrity

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.2.3**

#### Turbine Rotor Integrity (continued)

- ITAAC specifies that COL holder provide an evaluation concluding that probability of turbine missile generation,  $P_1$ , is less than  $1 \times 10^{-5}$
- ESBWR turbine generator is favorably oriented
- For favorably oriented turbine generators, SRP 3.5.1 specifies that probability of turbine missile generation,  $P_1$ , is less than  $1 \times 10^{-4}$



# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.2.3**

#### Turbine Rotor Integrity - Conclusion

- ESBWR turbine generator meets the requirements of GDC 4 with respect to use of rotor materials with acceptable fracture toughness, adequate design, and the requirements for preservice and inservice inspections
- Staff has reasonable assurance that the probability of rotor failure with missile generation is low
- No Open Items
- No COL Items

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.3**

#### **Turbine Main Steam System**

- **Key Features**
  - System begins at the seismic interface downstream of the MSIV up to the turbine stop valves and bypass valves
  - No safety-related functions (main steam isolation system is addressed in Chapter 5; MSIVs addressed in Chapter 3)
  - MSIV leakage path to condenser is seismically analyzed and provides reliable power sources (and/or fail safe design) to active components
- **COL Items**
  - None
- **Open Items**
  - None

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.3.6**

#### **Steam and Feedwater System Materials**

- Materials used for the Class 2 steam and feedwater systems are the same as those used for Class 1 steam and feedwater systems and meet the requirements of ASME Section III
- Fracture toughness meets the requirements of ASME Section III for Class 2 components
- Only carbon steel and low alloy steel ferritic materials are used in Class 2 steam and feedwater systems
- The DCD does not specify use of Class 3 components in the steam and feedwater systems

**ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 10 – SER Section 10.3.6**

**Steam and Feedwater System Materials**

- Fabrication and welding of steam and feedwater systems meet the requirements of ASME Code, Section III and conform with the guidance of RG 1.50 and RG 1.71
- Cleaning and cleanliness controls conform with the guidance of RG 1.37

**ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 10 – SER Section 10.3.6**

**Flow Accelerated Corrosion (FAC) of Class 2  
and non-Code Class systems**

- Turbine main steam system (TMSS), feedwater and condensate systems are potentially subject to the effects of FAC
- Operating experience and recommendations of Generic Letter 89-08 and NUREG-1344 are applied to their design and operation
- All susceptible Class 1, 2, 3 and non-Code piping will be subject to an augmented inspection program to monitor materials degradation due to FAC

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.3.6**

#### **Open Items**

- List materials specifications and grades for Class 2 Steam and Feedwater systems in DCD Tier 2, Section 10.3.6.
- Revise DCD Tier 2 Section 10.3.6 to include discussion of RG 1.50 and preheat requirements
- Include discussion, in DCD, regarding design attributes to mitigate FAC in ASME Code, Class 2 piping and non-Code Class systems
- Code Stamping and ANI review of Class 2 portion of TMSS system (RAI 3.2-1 S04)
- There are no COL Action Items

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.4.1**

#### **Main Condenser**

- Key Features
  - Condenser supports and anchors are designed to withstand SSE to provide a hold-up volume for MSIV fission product leakage
- COL Items
  - Applicant will provide threshold limits and procedures to address chemistry excursions (addressed in DCD Tier 2 Section 10.4.6)
- Open Items
  - None

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.4.2**

#### **Condenser Air Removal System**

- Key Features
  - 2 mechanical vacuum pumps (start up)
  - 2 steam jet air ejectors (operation)
  - Exhausts to
    - Off gas system (OGS) (operation)
    - Turbine building compartment exhaust (TBCE) (start up)
- COL Items
  - None
- Open Items
  - None



# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.4.3**

#### **Turbine Gland Seal System**

- **Key Features**
  - Sealing steam is normally provided by main steam or extraction (Auxiliary boiler can be used at all loads if needed)
  - Two 100% capacity exhaust blowers maintain a vacuum in the gland steam condenser and direct noncondensable gases to the TBCE
  - Releases are continuously monitored by the exhaust radiation monitoring system (ERMS)
  - High radiation and flow alarms provided in the control room
- **COL Items**
  - None
- **Open Items**
  - None

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.4.4**

#### **Turbine Bypass System**

- Key Features
  - Full load rejection or turbine trip capability with no SRV lifting and no reactor trip
  - No single failure can disable more than 50% of the installed bypass capacity
  - Failure of TBS lines does not impact essential systems
- COL Items
  - None
- Open Items
  - None

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.4.5**

#### **Circulating Water System**

- **Key Features**
  - No safety design basis
  - Provides sufficient cooling water to accommodate a full load rejection without exceeding condenser pressure turbine trip setpoint
  - Isolates on a Turbine Building condenser area high water level signal
- **COL Items**
  - None. However, there are portions outside the scope of the DCD and interface requirements which the COL applicant must address
- **Open Items**
  - None

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.4.6**

#### **Condensate Purification System**

- Purifies and treats condensate to maintain reactor feedwater cleanliness
- Conforms with the guidance of RG 1.56
- No Open Items
- Discussions are currently ongoing regarding use of EPRI BWR Water Chemistry Guidelines

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 10 – SER Section 10.4.7**

#### **Condensate and Feedwater System**

- Key Features
  - Four FW pumps and four condensate pumps (3 in service, 1 standby)
  - Coincident logic and redundant controllers and input signals reduce spurious trips
  - Flow control is via FW pump adjustable speed control (normal operation) and via low flow control valve (low power)
- COL Items
  - None
- Open Items
  - None

**ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 10**

**Discussion/Committee Questions**


# ESBWR DCD Chapter 10

## Steam and Power Conversion System

For: Advisory Committee  
on Reactor Safeguards

Gary M. Anthony

Nov. 15<sup>th</sup>, 2007



HITACHI

# Presentation Content

- Chapter 10 Overview
  - > Design Parameters
  - > Equipment Overview
  - > Turbine and Generator
  - > Turbine Main Steam System
  - > Feedwater and Mitigation of Flow Accelerated Corrosion (FAC)
  - > Principal Design Features
  - > Power Cycle Schematic (DCD Figure 10.1-1)
  - > Enhanced Design Features
- Summary



# Design Parameters

- The Content and Level of Detail used in DCD Chapter 10 Considers the Guidance in NUREG-0800, Standard Review Plan, Sections 10.2 to 10.4.7.
- The Turbine, Generator, and Power Cycle Systems Do Not Perform or Support Any Nuclear Safety-Related Functions.
- The Standard ESBWR BOP Parameters are Summarized in:
  - > DCD Section 10.1 which describes the principle design features and lists the corresponding design parameters in Table 10.1-1.
  - > DCD Section 10.4 describes the cooling water requirements.

# Equipment Overview

- The ESBWR BOP is Based Upon a Very Conventional BWR Power Plant Cycle ~20% larger than large BWR 6
- Chapter 10 Presents the Equipment Required to Condense Unused Steam into Condensate and Convert That into High Quality Feedwater in a Purification Subsystem. (Filters and Demineralizers)
- The Water is then Heated with Extraction Steam Through Low and High Pressure Feed Water Heaters and is Fed to the Reactor.
- Steam is Generated then Transported to the Turbine and Converted to Electrical Energy from Thermal Energy, Wet or Excess Steam is Exhausted Back the Condenser.

# Turbine and Generator

- One Double Flow High Pressure Turbine and Three Double Flow Low Pressure Turbines ( G.E. 6F52).
- Turbine Rotors Utilize Integral Forgings (Monoblocks) to Minimize the Probability of Missile Generation (pre-tested to 120% of rated speed).
- GE has a Long History with this Design Replacing the Old Shrunk on Wheel Style. (~1992, >4 Million Operational Hours)
- Turbine Last Stage Blades are 52" Long and have been fully Shop Tested.
- A Standard Design Synchronous Generator with Water Cooled Stator Windings and a Hydrogen Cooled Rotor Rated at 1933 MVA (~1600 MWe Gross).

# Turbine Main Steam System

- Transports Steam from the Nuclear Boiler System to the Turbine Inlet.
- System is Nonsafety-Related.
  - > Built as a Quality Group B: Designed, procured, Installed, Tested, Inspected and “N” Stamped to ASME Section III, Class 2 Requirements.
  - > Designed to Seismic Category II Requirements.
  - > The BWR MSIV Leakage Control System has been replaced with the NRC approved Isolated Condenser Method which has been retrofitted into some of the operating fleet.

# Feedwater

- The standard Plant Design Incorporates 7 Feedwater Heaters, 4 Moisture Separator Reheaters (MSRs), and Multiple Extraction Points.
  - > Three low pressure heaters are located in each condenser neck.
  - > The system contains an open feedwater heater / tank that provides reserve inventory for mitigating Abnormal Events.
  - > The MSRs have standard high efficiency chevron-type moisture separators that are used to improve steam quality and increase thermal efficiency.
  - > Reliable steam seal designs are instituted to contain radioactive gases and steam.
  - > Materials are selected for >60 year life.


# Feedwater and Mitigation of Flow Accelerated Corrosion (FAC)

- Applicable operating experience and recommendations provided in NRC Generic Letter 89-08 and NUREG-1344 are applied to the system design and operation.
- Systems potentially affected by FAC are analyzed from actual plant design data to determine where increased wall thicknesses or FAC resistant materials must be used to meet the 60-year design life. (e.g.: EPRI CHECKWORKS™ or equal)
- Basic piping design principals ensures process flow velocities are limited.
- Internal Study was completed on Class 1 MSL and FW piping. (MSL >> 60 years, FW >60 w/ P22 pipe and O<sub>2</sub> control).
- An augmented inspection plan is implemented based on EPRI recommendations (NSAC-202L).

# Principal Design Features

- The Standard Main Condenser is a Water-Cooled Surface Steam Type made with Corrosion-Resistant Materials and Robust Spargers.
- Turbine Bypass System is Designed with Full Bypass Capability (110% Design) to Mitigate Abnormal Events.
- Loss of Grid (Island Mode), #4 Open FW Heater Sizing, Spare FW and Condensate Pumps for Increased Reliability (Fewer SCRAMS).
- Flexible Circulating Water System and Heat Sink are Site Specific (Including Series or Parallel Flow Condenser Options).

# Power Cycle Schematic (DCD Figure 10.1-1),






# Enhanced Design Features

- Integral Forgings (Monoblock) to Reduce Turbine Missile Probability and are Favorably Oriented to the Reactor Building and Control Building.
- Adjustable Speed Motor-Driven Feedwater Pumps using Variable Frequency Drives Reduces Dose (by Elimination of Steam) and Improve Maintainability.
- The Gland Seal Steam Evaporator has been Eliminated (Seals are Back on Normal MS), Improving Reliability and Reduce Maintenance Dose Through Simplification.
- The Turbine Utilizes a Fully Electronic, Redundant, Fail Safe and Testable Overspeed Protection System.
- Single Failure Proof System Designs.

# Summary

- DCD Chapter 10 Provides a Description of ESBWR Standard Plant Design Features.
- The ESBWR BOP is Designed with Flexibility and can be Sited Anywhere the Design Parameters are met for the Cooling Water Systems (one basic design).
- This is a Standard Heat Cycle for Electrical Power Conversion (SV, CV, CIVs, NRVs, Extraction Steam, HP/LP Monoblock Turbines, Tube Condenser).
- The Design Incorporates Best Practices & Incorporates Many Industry Lessons Learned (Spare Pumps, Large #4 FW Tank, 110% BP, Island Mode, FAC Early Reviews of Materials, and MSR Designs)
- All of this is to Increase **RELIABILITY** (less BOP initiating transients), Longer Plant System Life, Good Cycle Efficiency, and Equipment Availability through On-Line Testing and Maintenance.



**U.S.NRC**


UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

## **Presentation to the ACRS Subcommittee**

**ESBWR Design Certification Review  
Chapter 9, "Auxiliary Systems," and  
Section 6.4, "Control Room Habitability System"**

**November 15, 2007**



**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

## **Presentation to the ACRS Subcommittee**

**ESBWR Design Certification Review  
Chapter 9, "Auxiliary Systems," and  
Section 6.4, "Control Room Habitability System"**

**November 15, 2007**

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 and Section 6.4**

## **Purpose**

- Brief the Subcommittee on the staff's review Revision 3 of the ESBWR design certification application, Chapter 9, "Auxiliary Systems," and Section 6.4, "Control Room Habitability System"
- Answer the Committee's questions

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 and Section 6.4**

## **Project and Technical Review Team**

- Lead PM
  - Dennis Galvin, Project Manager
- Lead Tech. Reviewers
  - Syed Haider (6.4)
  - Jorge Hernandez (9.1.1 - 9.1.5)
  - Chang Li (9.2.1-9.2.8)
  - David Shum (9.3-1, 9.3.3, 9.3.6 - 9.3.8, 9.3-12, 9.5.4 - 9.5.8)
  - Yamir Diaz-Castillo (9.3.9 - 9.3.11)
  - George Thomas (9.3.5)
  - Edwin Forrest (9.4.1 - 9.4.8)
  - Raj Goel (9.4.9)
  - Robert Radlinski (9.5.1)
  - Amar Pal (9.5.3)
- Secondary Reviewers
  - Benjamin Parks (9.3.5)

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 and Section 6.4**

## Outline of Presentation

- Applicable Regulations
- RAI Status Summary
- SER Technical Topics of Interest
- Open Items
- COL Action Items
- Discussion / Committee questions

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 and Section 6.4**

## **Key Regulations and Review Guidance**

- 10 CFR 52 Subpart B – Standard Design Certifications
- 10 CFR 50.34(f), 50.48(a), 50.62, Appendix A, GDC
- 10 CFR 20, 20.1101(b)
- GDCs: 1, 2, 3, 4, 5, 13, 14, 17, 19, 23, 26, 27, 34, 38, 44, 45, 46, 60, 61, 62, & 63
- Primary SRP Sections: 5.4.7, 6.2.2, 6.3, 6.4, 9.1.1- 9.1.5, 9.2.1 - 9.2.3, 9.2.5, 9.2.6, 9.3.1- 9.3.3, 9.3.5, 9.4.1- 9.4.4, 9.5.1, 9.5.3 -
- Regulatory Guides 1.13, 1.29, 1.39, 1.52, 1.78, 1.115, 1.117, 1.140, 1.189, 1.194, & 8.8
- Industry Standards: ANS, ANSI, ASHRAE, ASME, ASTM, IESNA, ISA, & NFPA
- Other guidance (generic communications, NUREGs, and SECY's)



# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 and Section 6.4**

## RAI Status Summary: Chapter 9

- Original number of RAIs = 216
- Number of RAIs resolved = 150
- Number of Open Items = 66

## RAI Status Summary: Section 6.4

- Original number of RAIs = 14
- Number of RAIs resolved = 0
- Number of Open Items = 14

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 and Section 6.4**

## **9.1 Fuel Storage and Handling**

- 9.1.1-New Fuel Storage
- 9.1.2-Spent Fuel Storage
- 9.1.3-Spent Fuel Pool Cooling and Cleanup System
- 9.1.4-Light Load Handling System (Related to Refueling)
- 9.1.5-Overhead Heavy Load Handling System

## **9.2 Water Systems**

- 9.2.1-Plant Service Water System
- 9.2.2-Reactor Component Cooling Water System
- 9.2.3-Makeup Water System
- 9.2.4-Potable and Sanitary Water Systems
- 9.2.5-Ultimate Heat Sink
- 9.2.6-Condensate Storage and Transfer System
- 9.2.7-Chilled Water System
- 9.2.8-Turbine Component Cooling Water System
- 9.2.9-Hot Water System
- 9.2.10-Station Water System

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 and Section 6.4**

## **9.3 Process Auxiliaries**

- 9.3.1-Compressed Air System
- 9.3.2-Process Sampling System
- 9.3.3-Equipment and Floor Drain System
- 9.3.4-Chemical and Volume Control System
- 9.3.5-Standby Liquid Control System
- 9.3.6-Instrument Air System
- 9.3.7-Service Air System
- 9.3.8-High Pressure Nitrogen Supply System
- 9.3.9-Hydrogen Water Chemistry System
- 9.3.10-Oxygen Injection System
- 9.3.11-Zinc Injection System
- 9.3.12-Auxiliary Boiler System

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 and Section 6.4**

## **9.4 Heating Ventilation and Air Conditioning**

- 9.4.1-Control Building HVAC System
- 9.4.2-Fuel Building HVAC System
- 9.4.3-Radwaste Building Heating, Ventilation and Air Conditioning System
- 9.4.4-Turbine Building HVAC System
- 9.4.5-Engineered Safety Feature Ventilation System
- 9.4.6-Reactor Building HVAC System
- 9.4.7-Electrical Building HVAC System
- 9.4.8-Drywell Cooling System
- 9.4.9-Containment Inerting System

## **6.4 Control Room Habitability System**

## **9.5 Other Auxiliary Systems**

- 9.5.1-Fire Protection Program
- 9.5.2-Communications System (presentation deferred to Chapter 7)
- 9.5.3-Plant Lighting System
- 9.5.4-Diesel Generator Fuel Oil Storage and Transfer System
- 9.5.5-Diesel Generator Jacket Cooling Water System
- 9.5.6-Diesel Generator Starting Air System
- 9.5.7-Diesel Generator Lubrication System
- 9.5.8-Diesel Generator Combustion Air Intake and Exhaust System

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.1.1 – 9.1.2**

#### New and Spent Fuel Storage

- SFP capacity - 20 yrs plus one full core offload
- RB buffer pool capacity – 60% RPV core
- Storage racks and liner embedments are Seismic I
- Impact to racks from dropped objects prevented by interlocks and safe load paths (9.1.5)
- Liner designed to withstand impact of one fuel assembly

#### Open Items

- Impact, thermal-hydraulic, and criticality analyses
- Liner structural analysis
- Neutron-absorbing panel monitoring program

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.1.3**

#### Fuel and Auxiliary Pool Cooling System

- Safety-related passive cooling (heatup and boil for 72 hours without makeup)
- Nonsafety-related active cooling
- Performs risk significant functions (LPCI, SPC)
- Other capabilities (alternate SDC, drywell spray)

#### Open Items

- Basis for not providing safety-related atmospheric cleanup
- 72-hour analysis for the buffer pool and SFP w/o makeup
- Basis for post 72-hour makeup rate (200 gpm)
- Performance criteria for normal operation and for functions credited in PRA
- Level instrumentation elevation relative to TAF

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.1.4 – 9.1.5**

#### Light and Heavy Load Handling Systems

- RB and FB cranes are single-failure-proof
- Cranes, refueling machines, and IFTS are designed to withstand SSE
- Applicant commits to NUREGs 0554 and 0612, and applicable ANSI standards
- IFTS is similar to the BWR-6 design

#### Open Items

- Provide details of the ability of the system to hold the load (carriage)
- Detailed description of standards applied to specific components
- Seismic classification of new fuel stand

#### COL Action Items

- COL applicant will provide heavy load listings, fuel handling procedures, maintenance manuals, safe load paths, QA program description, inspection and test plans, personnel qualification program descriptions.

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.2.1 – 9.2.10**

#### Review of the Water Systems

- Based on SRP Sections 9.2.1 – 9.2.6
- Passive Design
  - Excluding review guidance that applies only to safety-related portions of the systems
  - Level of detail
- RTNSS determination
- ITAAC inclusion



# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.2.1 – 9.2.10**

#### Open Items

- Drawing details
- Radiation monitoring for the PSWS
- Procedures for avoiding water hammer in PSWS, RCCWS, and CWS
- Classification of Makeup Water System as RTNSS

#### COL Action Items

- COL applicant will develop provisions to preclude long-term corrosion and fouling of the PSWS Procedures for avoiding water hammer in PSWS, RCCWS, and CWS
- COL applicant will provide the design of the station water system

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.3.1, 9.3.3, 9.3.6 - 9.3.8 and 9.3.12**

#### Process Auxiliary Systems

- 9.3.1 Compressed Air System
- 9.3.3 Equipment and Floor Drain System
- 9.3.6 Instrument Air System
- 9.3.7 Service Air System
- 9.3.8 High Pressure Nitrogen Supply System
- 9.3.12 Auxiliary Boiler System

#### RTNSS

- These are non-safety-related and non-RTNSS systems

#### Open Item

- GEH has not addressed that failure of the Auxiliary Boiler System as a result of a pipe break or malfunction of the system would not adversely affect safety-related systems or components.

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.5.4 - 9.5.8**

#### Diesel Generator Support Systems

- 9.5.4 Diesel Generator Fuel Oil Storage and Transfer System
- 9.5.5 Diesel Generator Jacket Cooling Water System
- 9.5.6 Diesel Generator Starting Air System
- 9.5.7 Diesel Generator Lubrication System
- 9.5.8 Diesel Generator Combustion Air Intake and Exhaust System

#### RTNSS:

- These are RTNSS systems

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.5.4 - 9.5.8**

#### Open Items

- No ITAAC for each DG supporting system
- COL applicant's responsibility to ensure availability and reliability these systems

#### COL Items

- COL applicant to establish procedural controls to ensure a minimum fuel oil capacity is maintained onsite.
- The COL applicant shall describe the material and corrosion protection for the underground piping portion of the fuel oil transfer system

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.3.9 - 9.3.11**

The following systems are non-safety related:

#### Hydrogen Water Chemistry System (optional)

- Injection through the Condensate and Feedwater System (CFWS) to help mitigate corrosion and for recombination of dissolved oxidants.
- COL Applicant will determine if HWCS is to be implemented.

#### Oxygen Injection System

- Injection through the CFWS to suppress corrosion and corrosion product release.
- COL Applicant will provide a description of the oxygen storage facility.

#### Zinc Injection System (optional)

- Injection through the CFWS system for reduction of corrosion films and radiation fields.
- COL Applicant will determine if ZIS is to be implemented.

#### Open Items

There are no open items for any of these systems.

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 – SER Section 9.3.5**

## Standby Liquid Control System

- Reviewed using SRP 9.3.5 and 10 CFR 50.62
- Accumulator-driven, passive system
- Direct injection to core bypass

## Open Items

- System performance-related ITAAC
- Leak detection and monitoring

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9.4 HVAC Systems**

Control Room HVAC (9.4.1) and Habitability Systems (6.4)

Reactor Building HVAC System (9.4.6)

## Other HVAC Systems

- Fuel Building
- Turbine Building
- Electrical Building
- Radwaste Building
- Drywell Cooling
- Containment Inerting

# **ACRS Subcommittee Presentation ESBWR Design Certification Review Control Room HVAC (9.4.1) and Habitability (6.4)**

## Technical Feature

- DCD Rev. 3 replaced air bottle system with a safety related fan and filter unit supply air system

## Open Item

- Post Accident EFU Adequacy and Operation
  - Quantity of Air Supply
  - Air distribution, mixing, flow paths, and temperature
  - Carbon Dioxide Levels
  - Power Supplies



# **ACRS Subcommittee Presentation ESBWR Design Certification Review Control Room HVAC (9.4.1) and Habitability (6.4)**

## Technical Feature

- Passive Heat Sink – The mass of concrete walls absorbs Control Room Heat to maintain acceptable temperatures post accident.

## Open Items:

- Temperature vs. Time in first 72 hours.
- Assumptions used and a formal heat transfer analysis
- Margin considerations
- Surveillance requirements.

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 - Reactor Building HVAC System**

#### Technical Features

- RBHVAC isolates on accident initiation
- CONAVS system not credited post accident
- No standby gas treatment system

#### Open Items

- Assumptions on mixing used to reduce source term of reactor building releases
- Testing of reactor building leak rates
- Monitoring, controlling, and processing releases

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – Other HVAC Systems**

#### Systems

- Fuel Building, Turbine Building, Electrical Building, Radwaste Building, Drywell Cooling, Containment Inerting

#### Technical Features

- Non Safety Related
- Isolated on accident initiation

#### Open Items

- RTNSS operation and impact of post accident temperatures on equipment

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.5.1**

#### Technical Summary

- Deterministic fire protection program meeting the intent of enhanced fire protection criteria put forth in SECYs 90-016, 93-087 and 94-084
- System also provides a Seismic I, but non-safety related backup source of makeup water following a design basis accident
- Plant features reduce fire risk – barrier separation of redundant divisions, inerted containment, no RCP lube oil systems, less active equipment, fiber optic cabling, and digital control systems

#### Exceptions to Guidance

- Protection in main control room complex and safety related computer rooms is reduced – based on reduced fire risk for new reactors
- Diesel generator (non-safety related) protection does not meet guidance

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.5.1**

#### Open Items

- Include COL Action Items for post-fire safe-shutdown circuit analysis and final fire hazards analysis
- Identification and treatment of fire-induced spurious actuations that could impact safe shutdown
- Identification and treatment of credited post-fire operator manual actions

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.5.1**

#### COL Action Items

- Provide design description of site-specific fire protection equipment
- Provide design and certification details for fire barriers
- Provide fire hazards analysis compliance review and site-specific fire hazards analysis
- Provide provisions for manual fire fighting and smoke control
- Provide proposed license condition for making changes that impact fire protection program
- Provide details of the QA program for fire protection
- Provide implementation schedule for fire protection program

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.5.1**

#### Loss of AC Power

- Post-fire safe shutdown does not require AC power – offsite or onsite
- Shutdown is primarily achieved with the isolation condenser system which does not require AC power
- Analysis assumes one train fails due to the fire – system function is still performed

# **ACRS Subcommittee Presentation**

## **ESBWR Design Certification Review**

### **Chapter 9 – SER Section 9.5.1**

#### Fire Fighting

- Safe shutdown does not depend on fire fighting
- Detection and suppression systems do not rely on AC power to perform their functions
- Battery-powered fixed and portable emergency lighting is provided
- Fire hazards analysis evaluates access for manual fire fighting for each area of the plant.



# **ACRS Subcommittee Presentation ESBWR Design Certification Review Chapter 9 COL Action Items**

## SER Chapter 9 COL Action Items

- Light and Heavy Load Handling Systems
- Water Systems
- Diesel Generator Support Systems
- Process Sampling System
- Hydrogen, Oxygen and Zinc Injection Systems
- Fire Protection System
- 37 Items in DCD Rev 3, 26 Items in DCD Rev 4
- Resolution of COL action items expected in the context of DCD Rev. 4 and 5 updates

**ACRS Subcommittee Presentation  
ESBWR Design Certification Review  
Chapter 9 COL Action Items**

Discussion/Committee Questions

# ESBWR - Overview

## DCD Chapter 9 & Section 6.4

### Auxiliary Systems and Control Room Habitability


**Advisory Committee  
on Reactor Safeguards**

Michael A. Arcaro

John Gels

November 15, 2007

GE Hitachi Nuclear Energy



# Presentation Content

- Chapter 9 – Overview of Auxiliary Systems
- Chapter 9 - Design Features
- Section 6.4 – Overview of Control Room Habitability
- Section 6.4 - Design Features
- Summary


# Overview of Chapter 9 - Auxiliary Systems

- Chapter 9 Provides Description Of:
  - > Auxiliary / Support Systems Required to Support Operation of ESBWR Under Normal, Transient, Shutdown and Emergency Conditions
    - Such As Service Water; Cooling Water Systems; Fire Protection; Heating, Ventilation, and Air Conditioning; and Lighting
  - > Systems Required to Perform and Support Nuclear Safety-Related Functions and Functions Related to Regulatory Treatment of Non-Safety Systems (RTNSS)
- The ESBWR Incorporates Design Features Similar to Those Auxiliary and Support Systems Utilized in Past BWR Designs

## Section 9.1 - Fuel Storage and Handling

- Provides Description of New and Spent Fuel Storage:
  - > Fuel Building
  - > Reactor Building
- The Reactor Building / Fuel Building is Seismic Category I and Designed for Natural Phenomena Such As Tornadoes, Tornado Missiles, Floods, and High Winds
- The Fuel Storage Racks Provided in the Spent Fuel Pool (SFP) in the Fuel Building Provide for Storage of Irradiated Fuel Assemblies Resulting From 10 Calendar Years of Plant Operation Plus One Full Core Off Load. The Fuel Storage Racks in the Reactor Building Buffer Pool Deep Pit Can Hold a Minimum of 154 Spent Fuel Assemblies
- Fuel and Auxiliary Pools Cooling System (FAPCS) Provides Spent Fuel Pool Cooling

### Section 9.1.3–Fuel & Auxiliary Pools Cooling




## Section 9.2 – Water Systems

- Provides description of:
  - > Plant Service Water System (PSWS) and Reactor Component Cooling Water System (RCCWS)
    - Performs Nonsafety-Related Functions
    - RTNSS function to provide post 72 hour cooling
      - Redundant Trains
      - Physical and Electrical Separation of Trains
      - Seismic Requirements
      - Ability to Withstand Category 5 Hurricane Missiles and Flood Protection
  - > Other Nonsafety-Related Water Systems such as:
    - Turbine Component Cooling Water System (TCCWS)
    - Chilled Water System
    - Condensate Storage and Transfer System



## Section 9.2 – Water Systems - PSWS




## Section 9.3 – Process Auxiliaries

- Provides Description of:
  - > Compressed Gas Systems
    - Instrument Air System (IAS)
    - Service Air System (SAS)
    - Containment Inerting Systems (CIS) (DCD Section 6.2)
    - High Pressure Nitrogen Supply System (HPNSS)
      - CIS and HPNSS Provides Nitrogen Gas for Instruments and Valve Operators Within Inerted Containment
      - Compressed Air Operated Components Having Safety-Related or RTNSS Required Functions, Have Safety-Related Accumulators or Are Fail-Safe
  - > Other Process Auxiliaries such as:
    - Process Sampling System, Equipment and Floor Drain System, and Standby Liquid Control System
    - Hydrogen Water Chemistry System (HWCS)

## Section 9.4 – Heating, Ventilation, and Air Conditioning (HVAC) Systems

- Provides Description of:
  - > Control Building HVAC
  - > Fuel Building HVAC
  - > Radwaste Building HVAC
  - > Turbine Building HVAC
  - > Reactor Building HVAC
  - > Electric Building HVAC
  - > Drywell Cooling System

## Section 9.4 – Heating, Ventilation, and Air Conditioning (HVAC) Systems



Control Building General Area HVAC Subsystem (CBGAVS)

## Section 9.5 – Other Auxiliary Systems

- Provides Description of:
  - > Communication System
  - > Lighting System
    - Artificial illumination for rooms, spaces, and outdoor areas of the plant
  - > Support Systems for Plant Investment Protection (PIP) Diesel Generator (RTNSS) that includes
    - Fuel Oil Storage and Transfer System
    - Jacket Cooling Water System
    - Starting Air System
    - Lubrication System
    - Air Intake and Exhaust System
  - > Fire Protection System
    - Detection, Notification, Annunciation and Suppression of Fires

## Appendix 9A – Fire Hazards Analysis

- Provides Description of:

- > Fire Hazards Analysis for distinct areas such as
  - Reactor Building
  - Fuel Building
  - Control Building
  - Turbine Building
  - Yard
- > Safe Shutdown Equipment and Evaluation to Confirm Sufficient Number of Safety-Related Safe Shutdown Systems Remain Available During and Following Design Basis Fire to Achieve Hot Shutdown and Maintain Safe Shutdown

## Appendix 9B – Summary of Analysis Supporting Fire Protection Design Requirements

- Analysis Associated With Fire Protection Design Decisions and Requirements
  - Fire Containment System
  - Fire Types
  - Fire Barriers
  - Transient Combustibles
  - Cable Trays

# Chapter 9 – Design Features

- Some Significant Auxiliary Systems Design Feature Differences From Past BWR Design:
  - > Plant Service Water System Is Nonsafety-Related (NSR) and Has RTNSS Functions to Provide Post 72 Hr Cooling for RCCWS and Cooling Support for FAPCS
  - > Reactor Component Cooling Water System Is NSR and Has RTNSS Functions to Provide Post 72 Hr Cooling to the Nuclear Island Chillers and PIP Diesel Generators
  - > Chilled Water System Is NSR and Has RTNSS Functions to Provide Post 72 Hr Cooling for HVAC and Provide Cooling Support for FAPCS
  - > High Pressure Nitrogen Supply System Does Not Perform Any Safety-Related Function Other Than Provision for Safety-Related Containment Penetrations and Isolation Valves

## Chapter 9 – Design Features (Cont'd)

- Some Significant Auxiliary Systems Design Feature Differences From Past BWR Design (Cont'd):
  - > PIP Diesel Generator Auxiliary Systems Have No Safety Design Basis and Have RTNSS Functions for Post Accident Monitoring, FAPCS and Support Systems
  - > Eliminated the Standard Hot Water Heating System Design (DCD Rev 4)
  - > Without AC Power During the First 72 Hrs Into an Event, There Is No Active Heating, Ventilation, and Air Conditioning
    - Passive Cooling Is the Primary Mode for Control Building Habitable Area
    - No Major Equipment Heat Loads
    - Isolation Dampers Fail Close for Reactor Bldg, Fuel Bldg, and Control Room



# ESBWR - Overview


## DCD Section 6.4

### Control Room Habitability

**Advisory Committee  
on Reactor Safeguards**

Michael A. Arcaro

November 15, 2007  
GE Hitachi Nuclear Energy




## Section 6.4 – Overview of CR Habitability

- Section 6.4 Provides Description of Systems Required for Control Room Habitability:
  - > Control Room Habitability Area (CRHA) HVAC Subsystem (CRHAVS)
  - > Radiation Monitoring Subsystem (RMS)
  - > Control Room Lighting System
  - > Fire Protection System (FPS)
- ESBWR Design Features Ensure Control Room Operators Can Remain in the Control Room in a Safe Condition Under Accident Conditions

## Section 6.4 – Design Features

- Some Significant Control Room Design Feature Differences From Past BWR Design:
  - > Control Room Habitability Temperature Control Is Provided by Passive Heat Sink. The Heat Sink for the CRHA Is Designed to Limit the Temperature Rise Inside the CRHA During the 72 Hr Period Following a Loss of Normal CRHA Cooling
  - > CRHA Boundary Envelope Structures Are Designed With Low Leakage Construction
  - > CRHA Is Contained Inside a Seismic Category I Structure (Control Building) and Is Protected From Wind and Tornado Effects, External Floods and Internal Flooding, From External and Internal Missiles and From Dynamic Effects Associated With Postulated Rupture of Pipe

## Section 6.4 – Overview of Control Room Habitability



## Summary

- Chapter 9 and Section 6.4 Provide Description of ESBWR Auxiliary and Control Room Habitability Systems
- GEH Is Working With the NRC Staff to Address Remaining Open Items