

Rancho Seco
Final Status Survey Summary Report
October 31, 2007
Switchyard Control Building - Exterior
Survey Unit F8510003

Prepared By: *D. Anderson* Date: 10/31/2007

FSS Engineer

Reviewed By: *[Signature]* Date: 11/2/07

Lead FSS Engineer

Approved By: *[Signature]* Date: 11-12-07

Dismantlement Superintendent, Radiological

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8510003, Switchyard Control Building - Exterior

Survey Unit Description:

Operating History: Operating History: This structure was used to house the instrumentation and equipment associated with monitoring and operating the electrical switchyard. This area was not reported to have been used for the storage of radioactive material. Operating records and the HSA document no occurrences of radioactive material with the potential for a release of radioactivity associated with this survey area.

Site Characterization: Direct measurements were made of the interior and exterior surfaces of the structure which confirmed the absence of plant-derived radionuclides. Direct measurements of the interior showed a mean gross activity level of 1,663 dpm/100 cm² and a maximum value of 2,376 dpm/100 cm². Direct measurements of the exterior showed a mean gross activity level of 1,397 dpm/100 cm² and a maximum value of 1,843 dpm/100 cm². Based on the classification procedure (DSIP-0020) and levels of activity reported, the area was determined to be a Class 3 area.

HSA Events: None. However, there was a later report of contaminated cameras being stored in the building.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were randomly determined and 45 m² were scanned for approximately 8% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Table 1. Survey Unit Design Parameters

Survey Design Parameter	Value	Comment
Survey Area:	F851	Switchyard Control Building - Exterior
Survey Unit:	0003	Structure Surface
Class:	3	LTP Table 5-4
SU Area (m ²):	542.7	
Evaluator:	D. Anderson	
DCGL (dpm/100 cm ²):	43,000	Gross Activity DCGL
Area Factor:	N/A	Class 3
Design DCGL _{mc} (dpm/100 cm ²):	N/A	Class 3
LBGR (dpm/100 cm ²):	42,412	Adjusted
Design Sigma (dpm/100 cm ²):	196	
Type I Error:	0.05	
Type II Error:	0.05	
Predominant Nuclide:	Cs-137	
Sample Area (m ²):	N/A	Class 3
Scan Area (m ²):	45	
Scan Coverage (%):	8%	Class 3
Z _{1-α} :	1.645	
Z _{1-β} :	1.645	
Sign P:	0.99865	
Calculated Relative Shift:	3	
Relative Shift Used:	3	Uses 3.0 if Relative Shift is >3
N-Value:	11	
Design N-Value + 20%:	14	NUREG-1575 Table 5-5
Design Min Samples N:	14	Class 3
Grid Spacing L:	N/A	Class 3

Survey Results:

A total of 14 direct measurements were made in F8510003. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. (Scan activity ranged from 1,892 dpm/100 cm² to 6,140 dpm/100 cm² for exterior surfaces, based on a surveyor efficiency of 0.5 with no background subtracted.) Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Table 2. Direct Measurement Results

Measurement ID	Gross Activity (dpm/100 cm ²)
F8510003-M0001BD	1,018
F8510003-M0002BD	920
F8510003-M0003BD	978
F8510003-M0004BD	981
F8510003-M0005BD	941
F8510003-M0006BD	1,178
F8510003-M0007BD	1,104
F8510003-M0008BD	907
F8510003-M0009BD	864
F8510003-M0010BD	834
F8510003-M0011BD	880
F8510003-M0012BD	760
F8510003-M0013BD	787
F8510003-M0014BD	831
Mean:	927
Median:	914
Standard Deviation:	118
Range:	760 – 1,178

Table 3. Removable Surface Activity Results

Measurement ID	Surface Beta Activity (dpm/100 cm ²)
F8510003M0001SM	3.58
F8510003M0002SM	1.01
F8510003M0003SM	6.14
F8510003M0004SM	2.29
F8510003M0005SM	1.01
F8510003M0006SM	8.7
F8510003M0007SM	4.86
F8510003M0008SM	-0.27
F8510003M0009SM	2.29
F8510003M0010SM	2.29
F8510003M0011SM	2.29
F8510003M0012SM	1.01
F8510003M0013SM	2.29
F8510003M0014SM	-2.83
Mean:	2.48
Median:	2.29
Standard Deviation:	2.79
Range:	-2.83 to 8.7

Survey Unit Data Assessment:

The survey design required 14 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

Table 4. Data Assessment Results

Survey Results Parameter	Value	Comment	
Material Background Used (dpm/100 cm ²):	N/A	Average Ambient BKG = 0	
Ambient Background Used (dpm/100 cm ²):	N/A		
Actual Direct Measurements (N):	14		
Median (dpm/100 cm ²):	914		
Mean (dpm/100 cm ²):	927		
Direct Measurement Standard Deviation (dpm/100 cm ²):	118		
Total Standard Deviation (dpm/100 cm ²):	118		Based on samples and backgrounds.
Maximum (dpm/100 cm ²):	1,178		Background Subtract Not Applied
Material Type:	N/A		
Sign Test Final N Value:	14		Class 3
S+ Value:	14		
Critical Value:	10		
Sufficient Samples Collected:	Yes		
Maximum Value < DCGL:	Yes		
Median Value < DCGL:	Yes		
Mean Value < DCGL:	Yes		
Maximum Value < DCGL_{emc}:	N/A		
Total Standard Deviation <= Sigma:	Yes		
Pass the Sign Test?	Yes		
Reject the Null Hypothesis?	Yes		
Does the Survey Unit Pass All Criteria?	Yes		

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 3 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 3 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43,000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8510003 meets the release criteria of 10CFR20.1402.

Attachment 1

Maps

October 31, 2007


Survey Unit F8510003





Location of Switchyard Control Building inside the Industrial Area





Map F8510003-1, Switchyard Control Building - Exterior
Location of Switchyard Control Building at Rancho Seco site





















Map F8510003-8, Switchyard Control Building
West Elevation Direct Beta Measurements
F8510003M0008BD to F8510003M0009BD







Map F8510003-11, Switchyard Control Building
West Elevation Beta Scan Measurements
F8510003M0017BS to F8510003M0036BS
Total Scan Area: 20 sq. meters



Attachment 2
Instrumentation
October 31, 2007
Survey Unit F8510003

Table 2-1. Survey Unit Instrumentation

Instrument Model; Serial No.	Detector Model; Serial No.	MDC Static (dpm/100 cm²)	MDC Scan (dpm/100 cm²)
M2350; 189089	43-68B; 148460 ¹	433	1,033
M2350; 189089	43-68B; 148460 ²	257	612
Tennelec; 0401171	N/A	5 dpm α , 11 dpm β	N/A

¹43-68B Concrete surfaces

²43-68B Metal surfaces

Table 2-2. Investigation Criteria and DCGL

Parameter	Value (dpm/100 cm²)
Investigation Criteria - Direct	21,500
Investigation Criteria – Scan	21,500
DCGL _w	43,000
DCGL _{EMC}	N/A

Attachment 3
Investigation
October 31, 2007
Survey Unit F8510003

(none required)

Attachment 4

Data Assessment

October 31, 2007

Survey Unit F8510003

