




Rancho Seco  
Final Status Survey Summary Report  
October 31, 2007  
NSEB Exterior  
Survey Unit F8150021

Prepared By:  Date: 10.31.2007  
FSS Engineer

Reviewed By:  Date: 10/31/07  
Lead FSS Engineer

Approved By:  Date: 11-13-07  
Dismantlement Superintendent, Radiological

## FINAL STATUS SURVEY SUMMARY REPORT

### Survey Unit:

F8150021, NSEB Exterior

### Survey Unit Description:

**Operating History:** The multi-story structure provided safety-class electrical distribution to site systems. This area was not reported to have been used for the storage of radioactive material. Operating records and the HSA document two events (both associated with the building sump) with the potential for a release of radioactivity associated with this survey area.

**Site Characterization:** Direct measurements were made of the interior and exterior surfaces of the structure, which confirmed the absence of plant-derived radionuclides. Direct measurements showed a mean gross activity level of 1,913 dpm/100 cm<sup>2</sup> and a maximum value of 2,669 dpm/100 cm<sup>2</sup>. Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the area was determined to be a Class 3 area.

HSA Events: PDQ-940025, 940083.

### Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were randomly determined and 92 m<sup>2</sup> were scanned for approximately 6% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

**Table 1. Survey Unit Design Parameters**

Survey Design Parameter	Value	Comment
Survey Area:	F815	NSEB Exterior
Survey Unit:	0021	Structure Surface
Class:	3	LTP Table 5-4
SU Area (m <sup>2</sup> ):	1609	
Evaluator:	Frank	
DCGL (dpm/100 cm <sup>2</sup> ):	43000	Gross Activity DCGL
Area Factor:	N/A	Class 3
Design DCGL <sub>emc</sub> (dpm/100 cm <sup>2</sup> ):	N/A	Class 3
LBGR (dpm/100 cm <sup>2</sup> ):	21500	Default = 50% DCGL
Design Sigma (dpm/100 cm <sup>2</sup> ):	261	
Type I Error:	0.05	
Type II Error:	0.05	
Predominant Nuclide:	Cs-137	
Sample Area (m <sup>2</sup> ):	N/A	Class 3
Scan Area (m <sup>2</sup> ):	92	
Scan Coverage (%):	6%	Class 3
Z <sub>1-α</sub> :	1.645	
Z <sub>1-β</sub> :	1.645	
Sign P:	0.99865	
Calculated Relative Shift:	82.3	
Relative Shift Used:	3	Uses 3.0 if Relative Shift is >3
N-Value:	11	
Design N-Value + 20%:	14	NUREG-1575 Table 5-5
Design Min Samples N:	14	Class 3
Grid Spacing L:	N/A	Class 3

### Survey Results:

A total of 14 direct measurements were made in F8150021. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. (Scan activity ranged from 3763 dpm/100cm<sup>2</sup> to 6390 dpm/100cm<sup>2</sup> for roof and wall surfaces, based on a surveyor efficiency of 0.5 with no background subtracted.) Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

**Table 2. Direct Measurement Results**

Measurement ID	Gross Activity (dpm/100 cm <sup>2</sup> )
F8150021-C0001BD	2194
F8150021-C0002BD	2090
F8150021-C0003BD	1707
F8150021-C0004BD	2039
F8150021-C0005BD	1701
F8150021-C0006BD	1982
F8150021-C0007BD	1748
F8150021-C0008BD	1722
F8150021-C0009BD	1795
F8150021-C0010BD	2049
F8150021-C0011BD	1795
F8150021-C0012BD	2033
F8150021-C0013BD	1899
F8150021-Q0014BD	1598
Mean:	1882
Median:	1847
Standard Deviation:	182
Range:	1598 - 2194

**Table 3. Removable Surface Activity Results**

<b>Measurement ID</b>	<b>Surface Beta Activity (dpm/100 cm<sup>2</sup>)</b>
F8150021C0001SM	4.86
F8150021C0002SM	2.29
F8150021C0003SM	2.29
F8150021C0004SM	6.14
F8150021C0005SM	3.58
F8150021C0006SM	3.58
F8150021C0007SM	2.29
F8150021C0008SM	-0.27
F8150021C0009SM	4.86
F8150021C0010SM	4.86
F8150021C0011SM	6.14
F8150021C0012SM	-0.27
F8150021C0013SM	3.58
F8150021Q0014SM	4.86
Mean:	3.48
Median:	3.58
Standard Deviation:	2.04
Range:	-0.27 to 6.14

**Survey Unit Data Assessment:**

The survey design required 14 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

**Table 4. Data Assessment Results**

<b>Survey Results Parameter</b>	<b>Value</b>	<b>Comment</b>
<b>Material Background Used</b> (dpm/100 cm <sup>2</sup> ):	N/A	
<b>Ambient Background Used</b> (dpm/100 cm <sup>2</sup> ):	N/A	Average Ambient BKG = 0
<b>Actual Direct Measurements (N):</b>	14	
<b>Median</b> (dpm/100 cm <sup>2</sup> ):	1847	
<b>Mean</b> (dpm/100 cm <sup>2</sup> ):	1882	
<b>Direct Measurement Standard Deviation</b>	182	
(dpm/100 cm <sup>2</sup> ):		
<b>Total Standard Deviation</b> (dpm/100 cm <sup>2</sup> ):	182	Based on samples and backgrounds.
<b>Maximum</b> (dpm/100 cm <sup>2</sup> ):	2194	
<b>Material Type:</b>	N/A	Background Subtract Not Applied
<b>Sign Test Final N Value:</b>	14	
<b>S+ Value:</b>	14	
<b>Critical Value:</b>	10	
<b>Sufficient Samples Collected:</b>	Yes	
<b>Maximum Value &lt; DCGL:</b>	Yes	
<b>Median Value &lt; DCGL:</b>	Yes	
<b>Mean Value &lt; DCGL:</b>	Yes	
<b>Maximum Value &lt; DCGL<sub>emc</sub>:</b>	N/A	Class 3
<b>Total Standard Deviation &lt;= Sigma:</b>	Yes	
<b>Pass the Sign Test?</b>	Yes	
<b>Reject the Null Hypothesis?</b>	Yes	
<b>Does the Survey Unit Pass All Criteria?</b>	Yes	

### **Survey Unit Investigations and Results:**

No investigations were required for either direct or scan measurements and no investigation results are reported.

### **ALARA Statement:**

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

### **Changes in Initial Survey Unit Assumptions:**

The survey unit was designed as a Class 3 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected.

### **Conclusion:**

The FSS of this survey unit was properly designed as a Class 3 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43000 dpm/100 cm<sup>2</sup> and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8150021 meets the release criteria of 10CFR20.1402.





**Attachment 1**


**Maps**


**October 31, 2007**


**Survey Unit F8150021**














NUC SERV ELEC BLDG  
BETA DIRECT-LOOSE SURFACE  
ACTIVITY MEASUREMENTS  
F8150021-M5

FILE: 815000.05


RC RAYMOND



NSEB WEST ELEVATION  
BETA DIRECT-LOOSE SURFACE  
ACTIVITY MEASUREMENT LOCATIONS  
F8150021-M6  
FILE: 815002.06 RC: RAYMOND









**SMUD**  
SACRAMENTO MUNICIPAL  
UTILITY DISTRICT


NSEB ROOF PARAPET ELEVATIONS  
BETA DIRECT-LOOSE SURFACE  
ACTIVITY MEASUREMENT LOCATIONS  
F8150021-M8


FILE: 815002.D6

RC: RAYMOND.









**Attachment 2**

**Instrumentation**

**October 31, 2007**

**Survey Unit F8150021**

**Table 2-1. Survey Unit Instrumentation**

<b>Instrument Model; Serial No.</b>	<b>Detector Model; Serial No.</b>	<b>MDC Static (dpm/100 cm<sup>2</sup>)</b>	<b>MDC Scan (dpm/100 cm<sup>2</sup>)</b>
M2350; 203484	43-68B; 161410	433	1033
M2350; 203486	43-68B; 161400	433	1033
M2350; 203465	43-68B; 148458	433	1033
M2350; 149802	43-68B; 148453	433	1033
Tennelec; 0401171	N/A	5 dpm $\alpha$ , 11 dpm $\beta$	N/A

**Table 2-2. Investigation Criteria and DCGL**

<b>Parameter</b>	<b>Value (dpm/100 cm<sup>2</sup>)</b>
Investigation Criteria - Direct	21500
Investigation Criteria - Scan	21500
DCGL <sub>w</sub>	43000
DCGL <sub>EMC</sub>	N/A

**Attachment 3**

**Investigation**

**October 31, 2007**

**Survey Unit F8150021**

**(none required)**



**Attachment 4**

**Data Assessment**

**October 31, 2007**

**Survey Unit F8150021**

