Rancho Seco

## Final Status Survey Summary Report

October 31, 2007

## Aux. Bldg (-) 20' EI, Rm 43, "B" HPI Pump Room, Floors & Walls

## Survey Unit F8130601

Prepared By:	A. Inderson	_Date:_	10/31/2007
	FSS Engineer		
Reviewed By:	Lead FSS Engineer	_ Date:_	11/5/07
Approved By:	5.2/6	_Date:_	11-14-07

**Dismantlement Superintendent, Radiological** 

#### FINAL STATUS SURVEY SUMMARY REPORT

#### Survey Unit:

F8130601, Aux. Bldg (-) 20' El, Rm 43, "B" HPI Pump Room, Floors & Walls

#### Survey Unit Description:

Operating History: The reinforced concrete structure contained the RadWaste processing and supporting systems. The building contained six main elevations. Residual radioactive material was known to be present on all levels of the interior of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure. One report documented contamination of the auxiliary building roof. The roof was later replaced.

Site Characterization: Direct measurements were made of each of the interior elevation surfaces as well as the exterior surfaces of the structure. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements on the -47' elevation showed a mean gross activity level of 320,071 dpm/100 cm<sup>2</sup> and a maximum value of  $5,720,000 \text{ dpm}/100 \text{ cm}^2$ . Direct measurements on the -29' elevation showed a mean gross activity level of 544,756 dpm/100  $\text{cm}^2$  and a maximum value of 11,370,000 dpm/100 cm<sup>2</sup>. Direct measurements on the -20' elevation showed a mean gross activity level of 247,831 dpm/100 cm<sup>2</sup> and a maximum value of 10,080,000 dpm/100 cm<sup>2</sup>. Direct measurements on the grade elevation showed a mean gross activity level of 373,758  $dpm/100 cm^2$  and a maximum value of 5,800,000 dpm/100 cm<sup>2</sup>. Direct measurements on the +20' elevation showed a mean gross activity level of  $85,408 \text{ dpm}/100 \text{ cm}^2$  and a maximum value of  $1,900,000 \text{ dpm}/100 \text{ cm}^2$ . Direct measurements on the +40' elevation showed a mean gross activity level of 3,288 dpm/100 cm<sup>2</sup> and a maximum value of  $24,781 \text{ dpm}/100 \text{ cm}^2$ . Direct measurements on the building exterior, including the mezzanine roof, showed a mean gross activity level of  $1,897 \text{ dpm}/100 \text{ cm}^2$  and a maximum value of 2,990 dpm/100  $\text{cm}^2$ . (The roof had been replaced prior to the classification survey.) Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the interior of the auxiliary building was determined to be a Class 1, 2 area and the exterior was a Class 2,3.

HSA Events: HSA Report pg. 63.

#### Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 162.25 m<sup>2</sup> were scanned for 100% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Survey Design Parameter	Value	Comment	
Survey Area:	F813	Aux. Bldg (-) 20' El, Rm	
		43, "B" HPI Pump Room,	
		Floors & Walls	
Survey Unit:	0601	Structure Surface	
Class:	1	LTP Table 5-4	
<b>SU Area</b> (m <sup>2</sup> ):	162.25	· · · · ·	
Evaluator:	D. Anderson	· · ·	
<b>DCGL</b> (dpm/100 cm <sup>2</sup> ):	43,000	Gross Activity DCGL	
Area Factor:	3.2	Class 1	
Design DCGLemc	137,600	Class 1	
(dpm/100 cm <sup>2</sup> ):			
<b>LBGR</b> (dpm/100 cm <sup>2</sup> ):	41,800	Adjusted	
Design Sigma (dpm/100 cm <sup>2</sup> ):	400	Based on post-remediation	
		data	
Type I Error:	0.05		
<b>Type II Error:</b>	0.05		
Predominant Nuclide:	Cs-137	Used Co-60 area factor as	
• ·		conservative measure	
Sample Area (m <sup>2</sup> ):	6.76	Class 1	
Scan Area (m <sup>2</sup> ):	162.25		
Scan Coverage (%):	100%	Class 1	
$Z_{1-\alpha}:$	1.645		
$Z_{1-\beta}:$	1.645		
Sign P:	0.99865		
Calculated Relative Shift:	. 3		
<b>Relative Shift Used:</b>	3	Uses 3.0 if Relative Shift is	
•		>3	
N-Value:	11		
Design N-Value + 20%:	14	NUREG-1575 Table 5-5	
Design Min Samples N:	24	Class 1	
Grid Spacing L:	2.6	Class 1	

## Table 1. Survey Unit Design Parameters

### **Survey Results:**

A total of 25 direct measurements were made in F8130601. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. Scan activity ranged from 2,340 dpm/100 cm<sup>2</sup> to 60,624 dpm/100 cm<sup>2</sup> for floor, wall, and juncture surfaces, based on a surveyor efficiency of 0.5 with no background subtracted. Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Measurement ID	Gross Activity (dpm/100 cm²)	
F8130601-C0001BD	1,743	
F8130601-C0002BD	1,743	
F8130601-C0003BD	1,691	
F8130601-C0004BD	1,691	
F8130601-C0005BD	1,598	
F8130601-C0006BD	1,489	
F8130601-C0007BD	1,727	
F8130601-C0008BD	1,800	
F8130601-C0009BD	1,800	
F8130601-C0010BD	1,468	
F8130601-C0011BD	1,707	
F8130601-C0012BD	1,774	
F8130601-C0013BD	1,961	
F8130601-C0014BD	1,961	
F8130601-C0015BD	1,318	
F8130601-C0016BD	1,255	
F8130601-C0017BD	1,219	
F8130601-C0018BD	1,515	
F8130601-C0019BD	1,634	
F8130601-C0020BD	1,592	
F8130601-C0021BD	1,126	
. F8130601-C0022BD	. 1,364	
F8130601-C0023BD	2,900	
F8130601-C0024BD	1,369	
F8130601-C0025BD	1,4 <u>9</u> 9	
Mean:	1,638	
Median:	1,634	
Standard Deviation:	344	
Range:	1,126 – 2,900	

#### Table 2. Direct Measurement Results

Measurement ID	Surface Beta Activity (dpm/100 cm <sup>2</sup> )
F8130601C0001SM	8.7
F8130601C0002SM	. 8.7
F8130601C0003SM	3.58
F8130601C0004SM	6.14
F8130601C0005SM	4.86
F8130601C0006SM	22.8
F8130601C0007SM	3.58
F8130601C0008SM	9.98
F8130601C0009SM	12.55
F8130601C0010SM	8.7
F8130601C0011SM	4 86
F8130601C0012SM	11.27
F8130601C0013SM	2.29
F8130601C0014SM	2.29
F8130601C0015SM	4.86
F8130601C0016SM	3.58
F8130601C0017SM	16.39
F8130601C0018SM	1.01
F8130601C0019SM	1.01
F8130601C0020SM	8.7
F8130601C0021SM	3.58
F8130601C0022SM	3.58
F8130601C0023SM	9.98
F8130601C0024SM	3.58
F8130601C0025SM	1.01
Mean:	6.7
Median:	4.86
Standard Deviation:	. 5.21
Range:	1.01 to 22.8

 Table 3. Removable Surface Activity Results

## Survey Unit Data Assessment:

The survey design required 25 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

Survey Results Parameter	Value	Comment
Material Background Used (dpm/100 cm <sup>2</sup> ):	N/A	
Ambient Background Used (dpm/100 cm <sup>2</sup> ):	N/A	Average Ambient BKG = 0
Actual Direct Measurements (N):	. 25	
<b>Median</b> (dpm/100 cm <sup>2</sup> ):	1,634	
<b>Mean</b> (dpm/100 cm <sup>2</sup> ):	1,638	
<b>Direct Measurement Standard Deviation</b>	344	
(dpm/100 cm <sup>2</sup> ):		
Total Standard Deviation (dpm/100 cm <sup>2</sup> ):	344	Based on samples and
		backgrounds.
<b>Maximum</b> (dpm/100 cm <sup>2</sup> ):	2,900	
Material Type:	N/A	Background Subtract Not
		Applied
Sign Test Final N Value:	25	
S+ Value:	25	
Critical Value:	17	
Sufficient Samples Collected:	Yes	
Maximum Value < DCGL:	Yes	
Median Value < DCGL:	Yes	· · ·
Mean Value < DCGL:	Yes	
Maximum Value < DCGLemc:	Yes	Class 1
Total Standard Deviation <= Sigma:	Yes	· · · · · · · · · · · · · · · · · · ·
Pass the Sign Test?	Yes	
Reject the Null Hypothesis?	Yes	
Does the Survey Unit Pass All Criteria?	Yes	·

# Table 4. Data Assessment Results

#### Survey Unit Investigations and Results:

One investigation (Grid C0001BS) was required for the scan measurements and the results are reported in Attachment 3. The EMC unity rule was not exceeded as shown in Table 3-1.

#### ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

#### **Changes in Initial Survey Unit Assumptions:**

The survey unit was designed as a Class 1 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. One potential area of elevated activity was detected and evaluated as shown in Attachment 3. Therefore the EMC criterion was met.

#### Conclusion:

The FSS of this survey unit was properly designed as a Class 1 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43,000 dpm/100 cm<sup>2</sup> and none of the removable surface activity measurements exceeded 10% of the DCGL. One investigation was required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8130601 meets the release criteria of 10CFR20.1402.

Attachment 1

Maps

October 31, 2007

Survey Unit F8130601

Page 2 of 12  $\odot$  $(\mathbf{v})$ п (9.1) - .15 SQ M STEEL AUXILIARY BLDG -60 SQ M CONCRETE KEY PLAN ဏ Att. 1 Maps -(9.7) ({N} *™\_* .5 SCALE METERS -\$0.3 .35 50 m Steel AUXILIARY BUILDING EL. -20' ROOM 43 FLOOR & WALLS SURFACE AREA ESTIMATE MAP F8130601-1 FLOOR PLAN SMUD SACRAMENTO MUNICIPAL UTILITY DISTRICT F8130601 RC RAYMOND DWG: 813000.02

Page 3 of 12

Att. 1 Maps





10.0 (1.7)  $\langle 0, \hat{0} \rangle$ CONT, ON MAP F8130611-2. 10 8 (162) (124) 3 CONT ON MAP FE130611-2 (122) EL. -13'-54 (20) (123) (130) œ . (28) 129) (131) (133) ß 8 (077) 3P 078 079 (080) **(B)** (982) (091) (85) (087) **(33**) (089) (090) 086) EL. -20'-0" (v) ELEVATION LOOKING WEST EL. -13'-0" AT COL LINE U ELEVATION LOOKING NORTH  $(\mathbf{v})$ Ū AT COL LINE 9.1 CONT ON MAP FB130511-2 EL -13"--5%" (9.t) P0058 EL -20'-0" ß (55) (158) (159) Ê (154) (156) EL. 0"-0" ആ (65) . (167) (198 (169) (171) ₿ ß (112) (13) (115) (116) (11) EL. -20'-0" <u>1</u>66 <u>(64</u>) (168) (170) (172 ELEVATION LOOKING SOUTH 195 (0.1) P0059 VIEW A-A 6 (188) (190) UNDERSIDE OF STAIRWAY á0.0 (181) B 📼 (185) (183) (184) ø CONT ON MAP FR130611-2 A 6 (178) 180 9 ക (37) (338) (39) 141 152 (135) ß (176) 6 ക്ക <u>096</u> (094) (095) 098 (109) /OPEN EL. -20\*-0" (092) £ (148)  $(\mathbf{v})$ (74) CONT ON MAP, F8130611-2 9 3 **(19**) (12) (45) (17) 150 ELEVATION LOOKING EAST ₿ B (104) (106) AT COL LINE V 699) (102) SCALE METERS ÓPEN (PEN AUXILIARY BUILDING EL. -20' (105)-ROOM 43 FLOOR & WALLS SMUD BETA SCAN MEASUREMENTS LKG SOUTH LKG NORTH LKG EAST LKG WEST SACRAMENTO MUNICIPAL MAP F8130601-4 DEVELOPED VIEW OF SHIELD WALL RC RAYMOND DWG: 813000.026

Page 5 of 12

Att. 1 Maps

Page 6 of 12

Att. 1 Maps







Page 8 of 12

Att. 1 Maps



Page 9 of 12

Att. 1 Maps



Page 10 of 12

Att. 1 Maps

Map F8130601-10, Auxiliary Building -20' El Rm 43, "B" HPI Pump Room Inside Shield Wall Beta Direct Measurements F8130601C0013BD Juncture Scan Measurements F8130601C0025JS to F8130601C0029JS Metal Bar Scan Measurements F8130601M0001BS to F8130601M0002BS

151 152 146 147 148 149 150 Shield Wall Doorway C0029J 104 105 C0056JS 108 109 103 106 107 MOOOTBS 13 BD /M0002BS C0025JS (OPEN) C0027JS West Interior Shield Wall North Interior Shield Wall East Interior Shield Wall



Page 12 of 12

Att. 1 Maps

Attachment 2 Instrumentation October 31, 2007 Survey Unit F8130601

Instrument Model; Serial No.	Detector Model; Serial No.	MDC Static (dpm/100 cm²)	MDC Scan (dpm/100 cm²)
M2350; 180733	43-98B; 148638	1,400	2,520
M2350; 149794	43-68/5B; 149103	433	1,033
M2350; 149794	43-116-1B; 216072 <sup>1</sup>	491	739
M2350; 149794	43-116-1B; 216072 <sup>2</sup>	796	5,895
M2350; 149794	43-116-1B; 216072 <sup>3</sup>	472	3,492
Tennelec; 0401171	N/A	5 dpm $\alpha$ , 11 dpm $\beta$	N/A

### Table 2-1. Survey Unit Instrumentation

<sup>1</sup>43-116-1B Concrete junctures <sup>2</sup>43-116-1B Concrete surfaces and penetrations <sup>3</sup>43-116-1B Metal surfaces and penetrations

## Table 2-2. Investigation Criteria and DCGL

Parameter	Value (dpm/100 cm <sup>2</sup> )
Investigation Criteria - Direct	34,400
Investigation Criteria – Scan	34,400
DCGL <sub>W</sub>	43,000
DCGL <sub>EMC</sub>	137,600

Attachment 3

Investigation

October 31, 2007

Survey Unit F8130601

Grid	Initial cpm	Elevated Area (m²)	Area Factor	DCGLEMC (dpm/100 cm²)	Investigation Result (dpm/100 cm²)	DCGLемс Unity
C0001GS	8,264	0.041	25.1	1.11E+06	36,710	3.30E-02
	>	$\langle$		SU Mean (dpm/100 cm²)	Unitized Mean	
				1.64E+03	3.81E-02	3.81E-02
EMC Unity Sum				7.11E-02		

Table 3-1. Survey Unit Investigation

Attachment 4

Data Assessment

October 31, 2007

Survey Unit F8130601



Page 2 of 4

Att. 4 Data Assessment

Page 3 of 4

Att. 4 Data Assessment



