Rancho Seco

Final Status Survey Summary Report

October 29, 2007

Exterior Surfaces of Warehouse "B"

Survey Unit F8330002

| Prepared By: Muhauf Stein | Date: 10/24/2007 |
|--|------------------|
| FSS Engineer | · |
| Reviewed By: Lead FSS Engineer | Date: 10/29/07 |
| Approved By: 5 7 7 8 9 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 | Date: 11-13 - 07 |

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8330002, Exterior Surfaces of Warehouse "B"

Survey Unit Description:

Operating History: This structure was used as a warehouse. This area was reported to have been used for the storage of radioactive material. Operating records and the HSA document two occurrences of radioactive material with the potential for a release of radioactivity associated with this survey area.

Site Characterization: Direct measurements were made of the interior and exterior surfaces of the structure which confirmed the absence of plant-derived radionuclides. Direct measurements interior showed a mean gross activity level of 635 dpm/100 cm² and a maximum value of 3,751 dpm/100 cm². Direct measurements exterior showed a mean gross activity level of 3,749 dpm/100 cm² and a maximum value of 34,785 dpm/100 cm². Survey results were adjusted for background levels caused by the handling and temporary storage of radioactive components nearby. Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the area was determined to be a Class 3 interior and Class 2 exterior area.

HSA Events: PDQ-840010, 980017.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 260 m² were scanned for approximately 10% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Table 1. Survey Unit Design Parameters

| Survey Design Parameter | Value | Comment |
|--|---------------|--------------------------|
| Survey Area: | F833 | Exterior Surfaces of |
| | · | Warehouse "B" |
| Survey Unit: | 0002 | Structure Surface |
| Class: | 2 | LTP Table 5-4 |
| SU Area (m ²): | 2574 | |
| Evaluator: | Michael Stein | · |
| DCGL (dpm/100 cm ²): | 43000 | Gross Activity DCGL |
| Area Factor: | N/A | Class 2 |
| Design DCGLemc | N/A | Class 2 |
| (dpm/100 cm ²): | | |
| LBGR (dpm/100 cm ²): | 21500 | Default = 50% DCGL |
| Design Sigma (dpm/100 cm ²): | 10064 | |
| Type I Error: | 0.05 | • |
| Type II Error: | 0.05 | |
| Predominant Nuclide: | Cs-137 | |
| Sample Area (m ²): | 171.6 | Class 2 |
| Scan Area (m²): | 260 | |
| Scan Coverage (%): | 10% | Class 2 |
| $Z_{1-\alpha}$: | 1.645 | |
| $Z_{1-\beta}$: | 1.645 | |
| Sign P: | 0.97725 | |
| Calculated Relative Shift: | 2.1 | |
| Relative Shift Used: | 2.1 | Rounded ↓ to 2.0, NUREG- |
| | | 1575 Table 5.5 |
| N-Value: | .12 | |
| Design N-Value + 20%: | 15 | NUREG-1575 Table 5-5 |
| Design Min Samples N: | 15 | Class 2 |
| Grid Spacing L: | 13.0 | Class 2 |

Survey Results:

A total of 19 direct measurements were made in F8330002. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. (Scan activity ranged from 2,744 dpm/100 cm² to 8,128 dpm/100 cm², based on a surveyor efficiency of 0.5 with no background subtracted.) Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Table 2. Direct Measurement Results

| | , |
|---------------------|--|
| Measurement ID | Gross Activity (dpm/100 cm ²) |
| F8330002-C0001BD | 2179 |
| F8330002-C0002BD | 1743 |
| F8330002-C0003BD | 2153 |
| F8330002-C0004BD | 2267 |
| F8330002-C0005BD | 2132 |
| F8330002-C0006BD | 1136 |
| F8330002-C0007BD | 1167 |
| F8330002-C0008BD | 1375 |
| F8330002-C0009BD | 1203 |
| F8330002-C0010BD | 1281 |
| F8330002-C0011BD | . 1805 |
| F8330002-C0012BD | 1790 |
| F8330002-C0013BD | 2070 |
| F8330002-C0014BD | 1914 |
| F8330002-C0015BD | 2054 |
| F8330002-C0016BD | 1515 |
| F8330002-C0017BD | 1504 |
| F8330002-C0018BD | · 1577 |
| F8330002-C0019BD | 1504 |
| Mean: | 1704 |
| Median: | 1743 |
| Standard Deviation: | 375 |
| Range: | 1136 - 2267 |

Table 3. Removable Surface Activity Results

| Measurement ID | Surface Beta Activity (dpm/100 cm ²) |
|---------------------|--|
| F8330002C0001SM | 3.58 |
| F8330002C0002SM | 4.86 |
| F8330002C0003SM | 2.29 |
| F8330002C0004SM | 15.11 |
| F8330002C0005SM | 6.14, |
| F8330002C0006SM | 4.86 |
| F8330002C0007SM | 6.14 |
| F8330002C0008SM | -0.27 |
| F8330002C0009SM | -0.27 |
| F8330002C0010SM | 7.42 |
| F8330002C0011SM | 3.58 |
| F8330002C0012SM | 1.01 |
| F8330002C0013SM | 1.01 |
| F8330002C0014SM | 7.42 |
| F8330002C0015SM | 2.29 |
| F8330002C0016SM | 4.86 |
| F8330002C0017SM | 4.86 |
| F8330002C0018SM | 2.29 |
| F8330002C0019SM | 3.58 |
| Mean: | 4.25 |
| Median: | 3.58 |
| Standard Deviation: | 3.51 |
| Range: | -0.27 to 15.11 |

Survey Unit Data Assessment:

The survey design required 19 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

Table 4. Data Assessment Results

| Survey Results Parameter | Value | Comment | |
|--|-------|-----------------------------------|--|
| Material Background Used (dpm/100 cm²): | N/A | | |
| Ambient Background Used (dpm/100 cm²): | . N/A | Average Ambient BKG = 0 | |
| Actual Direct Measurements (N): | 19 | | |
| Median (dpm/100 cm ²): | 1743 | | |
| Mean (dpm/100 cm ²): | 1704 | | |
| Direct Measurement Standard Deviation | 375 | | |
| (dpm/100 cm ²): | | | |
| Total Standard Deviation (dpm/100 cm ²): | 375 | Based on samples and backgrounds. | |
| Maximum (dpm/100 cm ²): | 2267 | | |
| Material Type: | N/A | Background Subtract Not | |
| | | Applied. | |
| Sign Test Final N Value: | 19 | .) | |
| S+ Value: | 19 | | |
| Critical Value: | 13 | | |
| Sufficient Samples Collected: | Yes | | |
| Maximum Value < DCGL: | Yes | | |
| Median Value < DCGL: | Yes | | |
| Mean Value < DCGL: | Yes | | |
| Maximum Value < DCGLemc: | N/A | Class 2 | |
| Total Standard Deviation <= Sigma: | Yes | • | |
| Pass the Sign Test? | Yes | | |
| Reject the Null Hypothesis? | Yes | | |
| Does the Survey Unit Pass All Criteria? | Yes | | |

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 2 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 2 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8330002 meets the release criteria of 10CFR20.1402.


Attachment 1


Maps


October 29, 2007


Survey Unit F8330002

















Attachment 2
Instrumentation
October 29, 2007
Survey Unit F8330002

Table 2-1. Survey Unit Instrumentation

| Instrument Model; Serial No. | Detector Model; Serial No. | MDC Static (dpm/100 cm²) | MDC Scan (dpm/100 cm²) |
|---------------------------------|-------------------------------|-----------------------------|---------------------------|
| M2350; 149802 | 43-68B; 148453 | 433 | 1033 |
| Tennelec; 0401171 | N/A | 5 dpm α, 11 dpm β | N/A |

Table 2-2. Investigation Criteria and DCGL

| Parameter | Value (dpm/100 cm²) |
|---------------------------------|------------------------|
| Investigation Criteria - Direct | 43000 |
| Investigation Criteria – Scan | 43000 |
| DCGL _{W.} | 43000 |
| DCGL _{EMC} | N/A |

Attachment 3
Investigation
October 29, 2007
Survey Unit F8330002

(none required)

Attachment 4

Data Assessment

October 29, 2007

Survey Unit F8330002

