

Rancho Seco

Final Status Survey Summary Report

November 7, 2007

"A" High Pressure Injection Pump Room Floor and Lower Walls
(Room 053)

Survey Unit F8130781

Prepared By: *Michael Stein* Date: 11/7/2007
FSS Engineer

Reviewed By: *[Signature]* Date: 11/7/07
Lead FSS Engineer

Approved By: *E. J. [Signature]* Date: 11-14-07
Dismantlement Superintendent, Radiological

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8130781, "A" High Pressure Injection Pump Room Floor and Lower Walls (Room 053)

Survey Unit Description:

Operating History: The "A" High Pressure Injection Pump Room is located on the -20' elevation of the Auxiliary Building. The Auxiliary Building is a reinforced concrete structure that, during power operations, contained the Radwaste processing and supporting systems. The building has six main elevations. Residual levels of surface radioactivity were detected on all interior elevations of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure.

Site Characterization: Direct measurements were taken on each interior elevation of the Auxiliary Building. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements taken on the -20' elevation, showed a mean gross activity level of 247,831 dpm/100 cm² and a maximum value of 10,080,000 dpm/100 cm². Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the interior surfaces of the Auxiliary Building were determined primarily to be a Class 1 for the floors and lower walls (bottom 2 meters of the walls), and Class 2 for the upper walls and ceiling. Inside the "A" High Pressure Injection Pump Room there were a number of areas on the floor where the gross surface activity levels were higher than the DCGL prior to remediation. Therefore, a Class 1 final status survey was performed on the floor and lower wall surfaces of the room.

HSA Events: HSA Report pg. 63.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 84 m² were scanned for approximately 100% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Table 1. Survey Unit Design Parameters

Survey Design Parameter	Value	Comment
Survey Area:	F813	"A" High Pressure Injection Pump Room (Room 053)
Survey Unit:	0781	
Class:	1	LTP Table 5-4
SU Area (m²):	84	
Evaluator:	Michael Stein	
DCGL (dpm/100 cm²):	43000	Gross Activity DCGL
Area Factor:	4	Class 1
Design DCGL_{mc} (dpm/100 cm²):	172000	Class 1
LBGR (dpm/100 cm²):	21500	Default = 50% DCGL
Design Sigma (dpm/100 cm²):	12035	
Type I Error:	0.05	
Type II Error:	0.05	
Predominant Nuclide:	Cs-137	
Sample Area (m²):	4.9	Class 1
Scan Area (m²):	84	
Scan Coverage (%):	100%	Class 1
Z_{1-α}:	1.645	
Z_{1-β}:	1.645	
Sign P:	0.96407	
Calculated Relative Shift:	1.7	
Relative Shift Used:	1.7	Uses 3.0 if Relative Shift is >3
N-Value:	14	
Design N-Value + 20%:	17	NUREG-1575 Table 5-5
Design Min Samples N:	17	Class 1
Grid Spacing L:	2.2	Class 1

Survey Results:

A total of 17 direct measurements were made in F8130781. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. Scan activity ranged from 2,974 to 17,569 dpm/100 cm², based on a surveyor efficiency of 0.5 and no background subtracted. Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Table 2. Direct Measurement Results

Measurement ID	Gross Activity (dpm/100 cm ²)
F8130781-C0001BD	2189
F8130781-C0002BD	2236
F8130781-C0003BD	1940
F8130781-C0004BD	1608
F8130781-C0005BD	1924
F8130781-C0006BD	2853
F8130781-C0007BD	4103
F8130781-C0008BD	2189
F8130781-C0009BD	3740
F8130781-C0010BD	2007
F8130781-C0011BD	1712
F8130781-C0012BD	2065
F8130781-C0013BD	1899
F8130781-C0014BD	2127
F8130781-C0015BD	3631
F8130781-C0016BD	3112
F8130781-C0017BD	1644
Mean:	2411
Median:	2127
Standard Deviation:	780
Range:	1608 - 4103

Table 3. Removable Surface Activity Results

Measurement ID	Surface Beta Activity (dpm/100 cm²)
F8130781C0001SM	8.7
F8130781C0002SM	7.42
F8130781C0003SM	2.29
F8130781C0004SM	6.14
F8130781C0005SM	8.7
F8130781C0006SM	2.29
F8130781C0007SM	7.42
F8130781C0008SM	8.7
F8130781C0009SM	9.98
F8130781C0010SM	3.58
F8130781C0011SM	7.42
F8130781C0012SM	4.86
F8130781C0013SM	8.7
F8130781C0014SM	3.58
F8130781C0015SM	7.42
F8130781C0016SM	8.7
F8130781C0017SM	4.86
Mean:	6.52
Median:	7.42
Standard Deviation:	2.47
Range:	2.29 to 9.98

Survey Unit Data Assessment:

The survey design required 17 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

Table 4. Data Assessment Results

Survey Results Parameter	Value	Comment	
Material Background Used (dpm/100 cm ²):	N/A	Average Ambient BKG = 0	
Ambient Background Used (dpm/100 cm ²):	N/A		
Actual Direct Measurements (N):	17		
Median (dpm/100 cm ²):	2127		
Mean (dpm/100 cm ²):	2411		
Direct Measurement Standard Deviation (dpm/100 cm ²):	780		
Total Standard Deviation (dpm/100 cm ²):	780		Based on samples and backgrounds.
Maximum (dpm/100 cm ²):	4103		Background Subtract Not Applied
Material Type:	N/A		
Sign Test Final N Value:	17		Class 1
S+ Value:	17		
Critical Value:	12		
Sufficient Samples Collected:	Yes		
Maximum Value < DCGL:	Yes		
Median Value < DCGL:	Yes		
Mean Value < DCGL:	Yes		
Maximum Value < DCGL_{mc}:	Yes		
Total Standard Deviation <= Sigma:	Yes		
Pass the Sign Test?	Yes		
Reject the Null Hypothesis?	Yes		
Does the Survey Unit Pass All Criteria?	Yes		

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 1 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected. Therefore, the EMC criterion was met.

Conclusion:

The FSS of this survey unit was properly designed as a Class 1 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8130781 meets the release criteria of 10CFR20.1402.








Attachment 1

Maps

November 7, 2007

Survey Unit F8130781






SMUD
SACRAMENTO MUNICIPAL
UTILITY DISTRICT







AUXILIARY BUILDING EL. -20'
ROOM 53 FLOOR & LOWER WALLS
BETA DIRECT/LOOSE SURFACE
ACTIVITY MEASUREMENTS
F8130781-M3

DWG: 813000.02c

SHT. 2 OF 2

RC RAYMOND






SMUD
SACRAMENTO MUNICIPAL
UTILITY DISTRICT

AUXILIARY BUILDING EL. -20'
ROOM 53 FLOOR & LOWER WALLS
BETA SCAN MEASUREMENT LOCATIONS
F8130781-M2

DWG: 813000.02c

SHT. 2 OF 2

RC RAYMOND



Attachment 2

Instrumentation

November 7, 2007

Survey Unit F8130781

Table 2-1. Survey Unit Instrumentation

Instrument Model; Serial No.	Detector Model; Serial No.	MDC Static (dpm/100 cm²)	MDC Scan (dpm/100 cm²)
M2350; 180733	43-98B; 148638	930	1680
M2350; 180733	43-94; 148620	350	610
M2350; 193700	43-68B; 190294	433	1033
M2350; 203486	43-68B; 161400	433	1033
M2350; 193715	43-68B; 148630	433	1033
M2350; 149794	43-116-1B; 216072	796	5895
M2350; 149794	43-116-1B; 216072	491 (β Juncture)	739 (β Juncture)
Tennelec; 0401171	N/A	5 dpm α, 11 dpm β	N/A

Table 2-2. Investigation Criteria and DCGL

Parameter	Value (dpm/100 cm²)
Investigation Criteria - Direct	172000
Investigation Criteria – Scan	172000
DCGL _w	43000
DCGL _{EMC}	172000

Attachment 3

Investigation

November 7, 2007

Survey Unit F8130781

(none required)

Attachment 4

Data Assessment

November 7, 2007

Survey Unit F8130781

