Rancho Seco

Final Status Survey Summary Report

November 1, 2007

Aux. Bldg. (-) 20' El, Rm 44, Makeup Pump Room

Survey Unit F8130621

Prepared By:	D. Andero on	Date:	11/1/2007
	FSS Engineer		
	Mool		
Reviewed By:	Jult all.	Date:	11/5/07
•	Lead FSS Enginee	ər	
Approved By:	2.7/6	Date:_	11-14-07
Dismantlement Superintendent, Radiological			

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8130621, Aux. Bldg. (-) 20' El, Rm 44, Makeup Pump Room

Survey Unit Description:

Operating History: The reinforced concrete structure contained the RadWaste processing and supporting systems. The building contained six main elevations. Residual radioactive material was known to be present on all levels of the interior of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure. One report documented contamination of the auxiliary building roof. The roof was later replaced.

Site Characterization: Direct measurements were made of each of the interior elevation surfaces as well as the exterior surfaces of the structure. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements on the -47' elevation showed a mean gross activity level of 320,071 dpm/100 cm² and a maximum value of $5,720,000 \text{ dpm}/100 \text{ cm}^2$. Direct measurements on the -29' elevation showed a mean gross activity level of 544,756 dpm/100 cm^2 and a maximum value of 11,370,000 $dpm/100 cm^2$. Direct measurements on the -20' elevation showed a mean gross activity level of 247,831 dpm/100 cm² and a maximum value of 10,080,000 dpm/100 cm². Direct measurements on the grade elevation showed a mean gross activity level of 373,758 $dpm/100 cm^2$ and a maximum value of 5,800,000 dpm/100 cm². Direct measurements on the +20' elevation showed a mean gross activity level of $85,408 \text{ dpm}/100 \text{ cm}^2$ and a maximum value of 1,900,000 dpm/100 cm². Direct measurements on the +40' elevation showed a mean gross activity level of 3.288 dpm/100 cm^2 and a maximum value of 24,781 dpm/100 cm². Direct measurements on the building exterior, including the mezzanine roof, showed a mean gross activity level of 1,897 dpm/100 cm^2 and a maximum value of 2,990 dpm/100 cm^2 . (The roof had been replaced prior to the classification survey.) Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the interior of the auxiliary building was determined to be a Class 1, 2 area and the exterior was a Class 2,3.

HSA Events: HSA Report pg. 63.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 277.8 m² were scanned for 100% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Survey Design Parameter	Value	Comment
Survey Area:	F813	Aux. Bldg. (-) 20' El, Rm
		44. Makeup Pump Room
Survey Unit:	0621	Structure Surface
Class:	. 1	LTP Table 5-4
SU Area (m^2) :	277.8	
Evaluator:	D. Anderson	-
DCGL $(dpm/100 cm^2)$:	43,000	Gross Activity DCGL
Area Factor:	3.3	Class 1
Design DCGLemc	141,900	Class 1
$(dpm/100 cm^2)$:		
LBGR (dpm/100 cm ²):	37,786	Adjusted
Design Sigma (dpm/100 cm ²):	1,738	-
Type I Error:	0.05	
Type II Error:	0.05	
Predominant Nuclide:	Cs-137	Used Co-60 area factor as
		conservative measure.
Sample Area (m ²):	6.94	Class 1
Scan Area (m ²):	277.8	
Scan Coverage (%):	100%	Class 1
$Z_{1-\alpha}$:	1.645	· · · · · · · · · · · · · · · · · · ·
$Z_{1-\beta}$:	1.645	•
Sign P:	0.99865	
Calculated Relative Shift:	3	
Relative Shift Used:	3	Uses 3.0 if Relative Shift is
		>3
N-Value:	11	
Design N-Value + 20%:	14	NUREG-1575 Table 5-5
Design Min Samples N:	40	Class 1
Grid Spacing L:	2.6	Class 1

Table 1. Survey Unit Design Parameters

Survey Results:

A total of 42 direct measurements were made in F8130621. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. Scan activity ranged from 1,502 to 35,271 dpm/100 cm² for floor, wall, ceiling and juncture surfaces, based on a surveyor efficiency of 0.5 and no background subtracted. Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Measurement ID	Gross Activity (dpm/100 cm²)
F8130621-C0001BD	1,919
F8130621-C0002BD	2,033
F8130621-C0003BD	2,179
F8130621-C0004BD	1,987
F8130621-C0005BD	. 1,821
F8130621-C0006BD	1,867
F8130621-C0007BD	2,708
F8130621-C0008BD	1,971
F8130621-C0009BD	2,246
F8130621-C0010BD	1,670.
F8130621-C0011BD	4,342
F8130621-C0012BD	2,096
F8130621-C0013BD	1,489
F8130621-C0014BD	1,701
F8130621-C0015BD	1,634
F8130621-C0016BD	` 1,841
F8130621-C0017BD	2,402
F8130621-C0018BD	1,577
F8130621-C0019BD	1,468
F8130621-C0020BD	1,582
F8130621-C0021BD	1,421
F8130621-C0022BD	1,193
F8130621-C0023BD	. 3,875
F8130621-C0024BD	2,023
F8130621-C0025BD	2,557
F8130621-C0026BD	1,307
F8130621-C0027BD	3,797
F8130621-C0028BD	2,116
F8130621-C0029BD	1,582
F8130621-C0030BD	3,548
F8130621-C0031BD	1,603
F8130621-C0032BD	1,572
F8130621-C0033BD	1,738
F8130621-C0034BD	1,515
F8130621-C0035BD	1,784
F8130621-C0036BD	1,556
F8130621-C0037BD	1,188
F8130621-C0038BD	. 1,338
F8130621-C0039BD	1,452
F8130621-C0040BD	1,712
F8130621-C0041BD	1,452
F8130621-C0042BD	2,324
Mean:	1,981
Median:	1,761
Standard Deviation:	723
Range:	1,188 – 4,342

Table 2. Direct Measurement Results

FSS Summary Report

Measurement ID	Surface Beta Activity (dpm/100 cm²)
F8130621C0001SM	4.86
F8130621C0002SM	2.29
F8130621C0003SM	9.98
F8130621C0004SM	9.98
F8130621C0005SM	4.86
F8130621C0006SM	2.29
F8130621C0007SM	13.83
F8130621C0008SM	11.27
F8130621C0009SM	4.86
F8130621C0010SM	3.58
F8130621C0011SM	39.47
F8130621C00125W	
F0130621000135W	-0.27
E8130621C00145M	5.50
E8130621C0016SM	68.95
F8130621C0017SM	13.83
F8130621C0018SM	6 14
F8130621C0019SM	8.7
F8130621C0020SM	29.21
F8130621C0021SM	21.52
F8130621C0022SM	17.68
F8130621C0023SM	16.39
F8130621C0024SM	4.86
F8130621C0025SM	8.7
F8130621C0026SM	16.39
F8130621C0027SM	677.85
F8130621C0028SM	`30.49
F8130621C0029SM	7.42
F8130621C0030SM	13.83
F8130621C0031SM	2.29
F8130621C0032SM	11.27
F8130621C0033SM	. 4.86
F8130621C0034SM	(.42
F8130621C0035SM	2.29
F8130621C00365W	4.80
F8130621C00375W	20.24
F8130621C00365W	4.00
E8130621000355M	2.29
F8130621C0040SM	21 52
F8130621C0042SM	39.47
Mean:	29.34
Median:	9.98
Standard Deviation:	103.35
Range:	-0.27 to 677.85

Table 3. Removable Surface Activity Results

FSS Summary Report

Survey Unit Data Assessment:

The survey design required 42 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

Survey Results Parameter	Value	Comment
Material Background Used (dpm/100 cm ²):	N/A	
Ambient Background Used (dpm/100 cm ²):	N/A	Average Ambient BKG = 0
Actual Direct Measurements (N):	42	
Median (dpm/100 cm ²):	1,761	
Mean (dpm/100 cm ²):	1,981	
Direct Measurement Standard Deviation	723	
(dpm/100 cm ²):		
Total Standard Deviation (dpm/100 cm ²):	723	Based on samples and
		backgrounds.
Maximum (dpm/100 cm ²):	4,342	
Material Type:	N/A	Background Subtract Not
		Applied
Sign Test Final N Value:	42	
S+ Value:	42	
Critical Value:	26	
Sufficient Samples Collected:	Yes	
Maximum Value < DCGL:	Yes	
Median Value < DCGL:	Yes	
Mean Value < DCGL:	Yes	
Maximum Value < DCGLemc:	Yes	Class 1
Total Standard Deviation <= Sigma:	Yes	· · · · ·
Pass the Sign Test?	Yes	
Reject the Null Hypothesis?	Yes	
Does the Survey Unit Pass All Criteria?	Yes	

Table 4. Data Assessment Results

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 1 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected. Therefore the EMC criterion was met.

Conclusion:

The FSS of this survey unit was properly designed as a Class 1 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43,000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8130621 meets the release criteria of 10CFR20.1402.

Attachment 1

Maps

November 1, 2007

Survey Unit F8130621









Page 7 of 19

Att. 1 Maps

P.29 090 Ы P.32 3 0000 8 ş ş 5¥2 P49 🔕 Ø 138 00 P30 P37 ß ß <u>(</u> ß ۲ 9 EL. 0'-0" ō P102 6 (167) 6 /@ 171 1 **663** 3 ß <u>163</u> (071) (151) (175) (79) (187 (83) (087) (091) (155) 148 3 8 (180) 9 (080) (84) 088 (168) 172 (188) (176)-(072) 156 (184) Ó æ 0000 00 (185) **ক**হুত (169) (169) (85) **@**• 6 (9) 63 (165) 119 (53) (189) **065** 6 (173) (157) (77)--069 (073) (89) (93) 8 18 6 248 දිදුව 8 8 603 **E**42) (196) 200 240 **(244**) 246 (256) (198) 206) (250) (208 6 O PER L 8 6 33 53 8 (241) 243 **(45**) (247) (197) (199) 201) ത 209 (25) **(253**) (52) ELEV LKG NORTH ELEV LKG WEST ELEV LKG NORTH ELEVATION LKG EAST P101 HEAD 5 1 SCALE METERS HEAD -4/065 5 (69) -(236) **(238** AUXILIARY BUILDING EL. -20' ROOM 44 WALL ELEVATIONS BETA SCAN MEASUREMENT LOCATIONS ରି ଜୁନ୍ତି P28 ଜୁନ୍ତି • P10 254 P27 🕑 • P100 SMUD (237) (239 SACRAMENTO MUNICIPAL MAP F8130621-7 E JAMB W JAMB E JAMB FILE: 813000.02b RC RAYMOND

Page 8 of 19

Att. 1 Maps

5 P87 Ø ۲ Ø õe 785 786 $(\hat{\mathbf{T}})$ (u) EL. 0'--0" (T) (T) (122) (18) (130) (12) (12) (142 (\overline{m}) 8 6 6 (099) (107) (115) (131) (135) (139) (143) P26 (140) OPEN 8]@ @ @ ത (32) (144) 1096 (128) **OPEN** (129) (137) (097) (105) (109) (141) (45) (101) Δ^{i} **133** (25) (226) (210) (212) 100 1000 (224) (228) (230) **@**32 214) (218) (220) (34) **(13)** മ 233 1 @S (227) 29 (3) (215) (17) ആ ඳුලු (235) -20'-0" ELEVATION LKG WEST ELEVATION LKG SOUTH (8.7) HATCH #4 LKG WEST SURVEY WITH FLOOR PLUG REMOVED HATCH #4 LKG NORTH SURVEY WITH FLOOR PLUG REMOVED HATCH #4 LKG SOUTH SURVEY WITH FLOOR PLUG REMOVED (9.7 ō .5 1 SCALE METERS AUXILIARY BUILDING EL. -20' ROOM 44 WALL ELEVATIONS BETA SCAN MEASUREMENT LOCATIONS MAP F8130621-8 SMUD HATCH #4 LKG EAST SURVEY WITH FLOOR PLUG REMOVED SACRAMENTO MUNICIPAL RC RAYMOND FILE: 813000.025

Page 9 of 19

Att. 1 Maps

Page 10 of 19

Ħ 1 Maps









Page 13 of 19

Att. 1 Maps





C0049J 1.508 m S 2.6 m 2.000 CO046JS 1.251 m 34BC 2.099 m 2.6 m -32BD -33BD 2.6 m 2.6 m 50044JS 29BF -30BD 31BD 1.192 m C0043JS C0042.JS East Wall Map F8130622-15, Auxiliary Building -20' El. Rm 44, Makeup Pump Room East Wall 0.5 Distance in Meters 1.0 Beta Direct Measurements F8130621C0029BD to F8130621C0034BD Juncture Scans F8130621C0043JS to F8130621C0049JS

Page 16 of 19

Att. 1 Maps



Page 17 of 19

Att. 1 Maps



Att. 1 Maps

Page 18 of 19



Attachment 2

Instrumentation

November 1, 2007

Survey Unit F8130621

Instrument Model; Serial No.	Detector Model; Serial No.	MDC Static (dpm/100 cm ²)	MDC Scan (dpm/100 cm²)
M2350; 180733	43-94; 148620	2,630	4,580
M2350; 175834	43-68B; 190482 ¹		
M2350; 180738	43-68B; 160051 ¹		1.022
M2350; 175834	43-68B; 148634 ¹	433	. 1,033
M2350; 149802	43-68B; 148453 ¹		
M2350; 149802	43-68B; 148453 ²	433	1,084
M2350; 203465	43-68/5B; 148942 ¹	433	1,033
M2350; 203465	43-116-1B; 216073 ³		-
M2350; 149794	43-116-1B; 216072 ³	401	720
M2350; 149802	43-116-1B; 190173 ³	491	/39
M2350; 180738	43-116-1B; 190643 ³		•
M2350; 203465	43-116-1B; 216073 ⁴	470	2,402
M2350; 149802	43-116-1B; 190173 ⁴	.472	3,492
M2350; 203465	43-116-1B; 216073 ⁵		
M2350; 149794	43-116-1B; 216072 ⁵	796	5,895
M2350; 149802	43-116-1B; 190173 ⁵		
Tennelec; 0401171	N/A	5 dpm α , 11 dpm β	N/A

Table 2-1. Survey Unit Instrumentation

¹43-68B Concrete surfaces ²43-68B Concrete penetrations ³43-116-1B Concrete junctures ⁴43-116-1B Metal penetrations ⁵43-116-1B Concrete penetrations

Table 2-1. Survey Unit Instrumentation

Instrument	Detector Serial No.	MDC (dpm/100 cm²)
InSpector	08051294	691 dpm/100 cm ² Cs-137 416 dpm/100 cm ² Co-60
ISOCȘ	2983947	831 dpm/100 cm ² Cs-137 1,140 dpm/100 cm ² Co-60

Page 2 of 3

Att. 2 Instrumentation

Parameter	Value (dpm/100 cm ²)
Investigation Criteria - Direct	141,900
Investigation Criteria – Scan	141,900 .
DCGL _W	43,000
DCGL _{EMC}	141,900

Table 2-2.	Investigation	Criteria	and	DCGL

Instrument	Parameter	Value (dpm/100 cm ²) To detect a 100 cm ² hot spot at the EMC Criterion within the detector field of view
ISOCS	Investigation Criteria - Scan	Concrete $- 190,000 \text{ dpm}/100 \text{ cm}^2 \text{ Cs}-137$ 64,000 dpm/100 cm ² Co-60

Attachment 3

Investigation

November 1, 2007

Survey Unit F8130621

(none required)

Attachment 4

Data Assessment

November 1, 2007

Survey Unit F8130621



Page 2 of 4

Att. 4 Data Assessment

Page 3 of 4

Att. 4 Data Assessment





Data