

Rancho Seco  
Final Status Survey Summary Report  
November 4, 2007  
Aux. Bldg (-) 20' El, Rm 45, NE Corridor  
Survey Unit F8130631

Prepared By: D. Anderson Date: 11/4/2007

FSS Engineer

Reviewed By: A. D. C. Date: 11/5/07

Lead FSS Engineer

Approved By: E. J. S. Date: 11-12-07

Dismantlement Superintendent, Radiological

## FINAL STATUS SURVEY SUMMARY REPORT

### Survey Unit:

F8130631, Aux. Bldg (-) 20' El, Rm 45, NE Corridor

### Survey Unit Description:

Operating History: The reinforced concrete structure contained the RadWaste processing and supporting systems. The building contained six main elevations. Residual radioactive material was known to be present on all levels of the interior of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure. One report documented contamination of the auxiliary building roof. The roof was later replaced.

Site Characterization: Direct measurements were made of each of the interior elevation surfaces as well as the exterior surfaces of the structure. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements on the -47' elevation showed a mean gross activity level of 320,071 dpm/100 cm<sup>2</sup> and a maximum value of 5,720,000 dpm/100 cm<sup>2</sup>. Direct measurements on the -29' elevation showed a mean gross activity level of 544,756 dpm/100 cm<sup>2</sup> and a maximum value of 11,370,000 dpm/100 cm<sup>2</sup>. Direct measurements on the -20' elevation showed a mean gross activity level of 247,831 dpm/100 cm<sup>2</sup> and a maximum value of 10,080,000 dpm/100 cm<sup>2</sup>. Direct measurements on the grade elevation showed a mean gross activity level of 373,758 dpm/100 cm<sup>2</sup> and a maximum value of 5,800,000 dpm/100 cm<sup>2</sup>. Direct measurements on the +20' elevation showed a mean gross activity level of 85,408 dpm/100 cm<sup>2</sup> and a maximum value of 1,900,000 dpm/100 cm<sup>2</sup>. Direct measurements on the +40' elevation showed a mean gross activity level of 3,288 dpm/100 cm<sup>2</sup> and a maximum value of 24,781 dpm/100 cm<sup>2</sup>. Direct measurements on the building exterior, including the mezzanine roof, showed a mean gross activity level of 1,897 dpm/100 cm<sup>2</sup> and a maximum value of 2,990 dpm/100 cm<sup>2</sup>. (The roof had been replaced prior to the classification survey.) Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the interior of the auxiliary building was determined to be a Class 1, 2 area and the exterior was a Class 2,3.

HSA Events: HSA Report pg. 63:

### Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 262.5 m<sup>2</sup> were scanned for 100% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

**Table 1. Survey Unit Design Parameters**

Survey Design Parameter	Value	Comment
<b>Survey Area:</b>	F813	
<b>Survey Unit:</b>	0631	
<b>Class:</b>	1	
<b>SU Area (m<sup>2</sup>):</b>	262.5	
<b>Evaluator:</b>	D. Anderson	
<b>DCGL (dpm/100 cm<sup>2</sup>):</b>	43,000	Gross Activity DCGL
<b>Area Factor:</b>	3.5	Class 1
<b>Design DCGLemc (dpm/100 cm<sup>2</sup>):</b>	141,900	Class 1
<b>LBGR (dpm/100 cm<sup>2</sup>):</b>	21,500	Default = 50% DCGL
<b>Design Sigma (dpm/100 cm<sup>2</sup>):</b>	12,035	
<b>Type I Error:</b>	0.05	
<b>Type II Error:</b>	0.05	
<b>Predominant Nuclide:</b>	Cs-137	Used Co-60 area factor as conservative measure
<b>Sample Area (m<sup>2</sup>):</b>	6.9	Class 1
<b>Scan Area (m<sup>2</sup>):</b>	262.5	
<b>Scan Coverage (%):</b>	100%	Class 1
<b>Z<sub>1-α</sub> :</b>	1.645	
<b>Z<sub>1-β</sub> :</b>	1.645	
<b>Sign P:</b>	0.955435	
<b>Calculated Relative Shift:</b>	1.7	
<b>Relative Shift Used:</b>	1.7	Uses 3.0 if Relative Shift is >3
<b>N-Value:</b>	14	
<b>Design N-Value + 20%:</b>	17	NUREG-1575 Table 5-5
<b>Design Min Samples N:</b>	38	Class 1
<b>Grid Spacing L:</b>	2.6	Class 1

### **Survey Results:**

A total of 43 direct measurements were made in F8130631. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. Six scan measurements indicated areas of elevated activity. Scan activity ranged from 4,434 to 129,800 dpm/100 cm<sup>2</sup> for floor, wall, ceiling and juncture surfaces, based on a surveyor efficiency of 0.5 and no background subtracted. Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

**Table 2. Direct Measurement Results**

Measurement ID	Gross Activity (dpm/100 cm <sup>2</sup> )
F8130631-C0001BD	3,216
F8130631-C0002BD	2,236
F8130631-C0003BD	2,884
F8130631-C0004BD	3,413
F8130631-C0005BD	2,173
F8130631-C0006BD	2,220
F8130631-C0007BD	3,660
F8130631-C0008BD	4,045
F8130631-C0009BD	2,345
F8130631-C0010BD	3,715
F8130631-C0011BD	2,028
F8130631-C0012BD	4,597
F8130631-C0013BD	3,230
F8130631-C0014BD	3,671
F8130631-C0015BD	3,527
F8130631-C0016BD	3,020
F8130631-C0017BD	3,935
F8130631-C0018BD	5,919
F8130631-C0019BD	1,712
F8130631-C0020BD	3,450
F8130631-C0021BD	3,560
F8130631-C0022BD	4,960
F8130631-C0023BD	2,028
F8130631-C0024BD	3,604
F8130631-C0025BD	1,758
F8130631-C0026BD	3,869
F8130631-C0027BD	1,375
F8130631-C0028BD	3,417
F8130631-C0029BD	1,561
F8130631-C0030BD	3,197
F8130631-C0031BD	3,020
F8130631-C0032BD	3,329
F8130631-C0033BD	3,604
F8130631-C0034BD	3,263
F8130631-C0035BD	3,946
F8130631-C0036BD	3,748
F8130631-C0037BD	3,527
F8130631-C0038BD	3,825
F8130631-C0039BD	3,638
F8130631-C0040BD	3,428
F8130631-C0041BD	4,112
F8130631-C0042BD	6,790
F8130631-C0043BD	4,255
Mean:	3,368
Median:	3,450
Standard Deviation:	1,066
Range:	1,375 – 6,790

**Table 3. Removable Surface Activity Results**

Measurement ID	Surface Beta Activity (dpm/100 cm <sup>2</sup> )
F8130631C0001SM	3.58
F8130631C0002SM	6.14
F8130631C0003SM	7.42
F8130631C0004SM	9.98
F8130631C0005SM	4.86
F8130631C0006SM	1.01
F8130631C0007SM	8.7
F8130631C0008SM	3.58
F8130631C0009SM	7.42
F8130631C0010SM	13.83
F8130631C0011SM	-0.27
F8130631C0012SM	20.24
F8130631C0013SM	4.86
F8130631C0014SM	7.42
F8130631C0015SM	3.58
F8130631C0016SM	15.11
F8130631C0017SM	2.29
F8130631C0018SM	103.56
F8130631C0019SM	3.58
F8130631C0020SM	1.01
F8130631C0021SM	4.86
F8130631C0022SM	2.29
F8130631C0023SM	2.29
F8130631C0024SM	6.14
F8130631C0025SM	2.29
F8130631C0026SM	11.27
F8130631C0027SM	8.7
F8130631C0028SM	2.29
F8130631C0029SM	-1.55
F8130631C0030SM	4.86
F8130631C0031SM	2.29
F8130631C0032SM	3.58
F8130631C0033SM	6.14
F8130631C0034SM	4.86
F8130631C0035SM	2.29
F8130631C0036SM	59.98
F8130631C0037SM	-1.55
F8130631C0038SM	29.21
F8130631C0039SM	1.01
F8130631C0040SM	-0.27
F8130631C0041SM	1.01
F8130631C0042SM	3.58
F8130631C0043SM	8.7
Mean:	9.12
Median:	4.86
Standard Deviation:	17.86
Range:	-1.55 to 103.56

### **Survey Unit Data Assessment:**

The survey design required 43 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

**Table 4. Data Assessment Results**

Survey Results Parameter	Value	Comment
<b>Material Background Used</b> (dpm/100 cm <sup>2</sup> ):	N/A	
<b>Ambient Background Used</b> (dpm/100 cm <sup>2</sup> ):	N/A	Average Ambient BKG = 0
<b>Actual Direct Measurements (N):</b>	43	
<b>Median</b> (dpm/100 cm <sup>2</sup> ):	3,450	
<b>Mean</b> (dpm/100 cm <sup>2</sup> ):	3,368	
<b>Direct Measurement Standard Deviation</b> (dpm/100 cm <sup>2</sup> ):	1,066	
<b>Total Standard Deviation</b> (dpm/100 cm <sup>2</sup> ):	1,066	Based on samples and backgrounds.
<b>Maximum</b> (dpm/100 cm <sup>2</sup> ):	6,790	
<b>Material Type:</b>	N/A	Background Subtract Not Applied
<b>Sign Test Final N Value:</b>	43	
<b>S+</b> Value:	43	
<b>Critical Value:</b>	27	
<b>Sufficient Samples Collected:</b>	Yes	
<b>Maximum Value &lt; DCGL:</b>	Yes	
<b>Median Value &lt; DCGL:</b>	Yes	
<b>Mean Value &lt; DCGL:</b>	Yes	
<b>Maximum Value &lt; DCGLemc:</b>	Yes	
<b>Total Standard Deviation &lt;= Sigma:</b>	Yes	
<b>Pass the Sign Test?</b>	Yes	
<b>Reject the Null Hypothesis?</b>	Yes	
<b>Does the Survey Unit Pass All Criteria?</b>	Yes	Class 1

### **Survey Unit Investigations and Results:**

Six investigations (penetrations P0061, P0062, P0063, P0064, P0076 and P0068) were required for the scan measurements and the results are reported in Attachment 3. The EMC unity rule was not exceeded as shown in Table 3-1.

### **ALARA Statement:**

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

### **Changes in Initial Survey Unit Assumptions:**

The survey unit was designed as a Class 1 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. Six potential areas of elevated activity were detected and evaluated as shown in Attachment 3. Therefore the EMC criterion was met.

### **Conclusion:**

The FSS of this survey unit was properly designed as a Class 1 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43,000 dpm/100 cm<sup>2</sup> and none of the removable surface activity measurements exceeded 10% of the DCGL. Six investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8130631 meets the release criteria of 10CFR20.1402.


**Attachment 1**


**Maps**


**November 4, 2007**


**Survey Unit F8130631**



























186BS	190BS	194BS	198BS
187BS	191BS	195BS	199BS
188BS	192BS	196BS	200BS
189BS	193BS	197BS	201BS
222BS	220BS	218BS	216BS
223BS	221BS	219BS	217BS

Map F8130630-11, Auxiliary Building -20' El.  
Rm 45, NE Corridor East Wall  
Beta Scan Measurements  
F8130631C0186BS to F8130631C0201BS and  
F8130631C0216BS to F8130631C0223BS  
Juncture Scan Measurements  
F8130631C0014JS to F8130631C0015JS



0.0 0.5 1.0 1.5 2.0  
Distance in Meters


	98BS														
946			Pipe Chase												
	99BS	103BS	102BS												
	95BS	91BS		90BS		86BS	82BS	78BS	74BS	70BS	66BS	62BS	58BS	54BS	
	100BS	96BS	92BS		88BS	84BS	80BS	76BS	72BS	68BS	64BS	60BS	56BS		
	101BS	97BS	93BS		89BS	85BS	81BS	77BS	73BS	69BS	65BS	61BS	57BS		
	246BS	244BS	242BS		240BS	238BS	236BS	234BS	232BS	230BS	228BS	226BS	224BS		
	249BS	247BS	245BS		243BS	241BS	239BS	237BS	235BS	233BS	231BS	229BS	227BS	225BS	

Map F8130630-12, Auxiliary Building -20' El.  
 Rm 45, NE Corridor South Wall 1  
 Beta Scan Measurements  
 F8130631C0054BS to F8130631C0105BS and  
 F8130631C0224BS to F8130631C0249BS

0.0    0.5    1.0    1.5    2.0  
 Distance in Meters

162BS	158BS	154BS	150BS	146BS	142BS	138BS	134BS	130BS	126BS	122BS	118BS	Pipe Chase	114BS	110BS	106BS	
163BS	159BS	155BS	151BS	147BS	143BS	139BS	135BS	131BS	127BS	123BS	119BS	115BS	111BS		107BS	
164BS	160BS	156BS	152BS	148BS	144BS	140BS	136BS	132BS	128BS	124BS	120BS	116BS	112BS		108BS	
165BS	161BS	157BS	153BS	149BS	145BS	141BS	137BS	133BS	129BS	125BS	121BS	117BS	113BS		109BS	
278BS	276BS	274BS	272BS	270BS	268BS	266BS	264BS		262BS	260BS	258BS	256BS	254BS	252BS		250BS
279BS	277BS	275BS	273BS	271BS	269BS	267BS	265BS		263BS	261BS	259BS	257BS	255BS	253BS		251BS

Map F8130630-13, Auxiliary Building -20' El.  
Rm 45, NE Corridor North Wall 1  
Beta Scan Measurements  
F8130631C0106BS to F8130631C0165BS and  
F8130631C0250BS to F8130631C0279BS






Map F8130630-14, Auxiliary Building -20' EI.  
Rm 45, NE Corridor North Wall 2  
Beta Scan Measurements  
F8130631C0166BS to F8130631C0169BS and  
F8130631C0288BS to F8130631C0289BS


166BS
167BS
168BS
169BS
288BS
289BS


182BS	178BS	174BS	170BS
183BS	179BS	175BS	171BS
184BS	180BS	176BS	172BS
185BS	181BS	177BS	173BS
289BS	284BS	282BS	280BS
287BS	285BS	283BS	281BS


Map F8130630-14, Auxiliary Building -20' EI.  
Rm 45, NE Corridor West Wall  
Beta Scan Measurements  
F8130631C0170BS to F8130631C0185BS and  
F8130631C0280BS to F8130631C0287BS  
Juncture Scan Measurements  
F8130631C0002JS to F8130631C0003JS














Map F8130630-18, Auxiliary Building -20' El.  
Rm 45, NE Corridor East Wall  
Beta Direct Measurements  
F8130631C0007BD to F8130631C0008BD



Map F8130630-18, Auxiliary Building -20' El.  
Rm 45, NE Corridor South Wall 2  
Beta Direct Measurements  
F8130631C0009BD to F8130631C0012BD

0.0 0.5 1.0 1.5 2.0  
Distance in Meters









0.0    0.5    1.0    1.5    2.0  
Distance in Meters


Map F8130630-20, Auxiliary Building -20' EI.  
Rm 45, NE Corridor North Wall 1  
Beta Direct Measurements  
F8130631C0023BD to F8130631C0032BD



Map F8130630-21, Auxiliary Building -20' El.  
Rm 45, NE Corridor North Wall 2





Map F8130630-21, Auxiliary Building -20' El.  
Rm 45, NE Corridor West Wall  
Beta Direct Measurements  
F8130631C0033BD to F8130631C0036BD









Aux. Bldg -20' El, Rm 43, NE Corridor  
Penetrations-1



Aux. Bldg -20' El, Rm 43, NE Corridor Penetrations-2



Aux. Bldg -20' El, Rm 43, NE Corridor  
Penetrations-3



Aux. Bldg -20' El, Rm 43, NE Corridor  
Penetrations-4  
Remaining penetrations surveyed under the  
following packages: F8130611, F8130621,  
and F8130641

**Attachment 2**

**Instrumentation**

**November 4, 2007**

**Survey Unit F8130631**

**Table 2-1. Survey Unit Instrumentation**

<b>Instrument Model; Serial No.</b>	<b>Detector Model; Serial No.</b>	<b>MDC Static (dpm/100 cm<sup>2</sup>)</b>	<b>MDC Scan (dpm/100 cm<sup>2</sup>)</b>
M2350; 180733	43-94; 148620	2,630	4,580
M2350; 203481	43-68B; 161405 <sup>1</sup>	909	2,169
M2350; 149802	43-68B; 148453 <sup>1</sup>		
M2350; 193715	43-68B; 148630 <sup>2</sup>	433	1,033
M2350; 149802	43-68B; 148453 <sup>2</sup>		
M2350; 142499	43-37; 148502	198	616
M2350; 203486	43-51B; 190666 <sup>3</sup>	784	2,660
M2350; 203486	43-51B; 190666 <sup>4</sup>	1,324	4,494
M2350; 203486	43-51B; 190666 <sup>5</sup>	990	2,313
M2350; 203486	43-51B; 190666 <sup>6</sup>	2,078	4,856
M2350; 203465	43-116-1B; 216073 <sup>7</sup>	472	3,492
M2350; 149794	43-116-1B; 216072 <sup>7</sup>		
M2350; 203465	43-116-1B; 216073 <sup>8</sup>	796	5,895
M2350; 149794	43-116-1B; 216072 <sup>8</sup>		
M2350; 203486	43-116-1B; 190642 <sup>9</sup>	491	739
Tennelec; 0401171	N/A	5 dpm α, 11 dpm β	N/A

<sup>1</sup>43-68B Concrete surfaces with 1 paint layer

<sup>2</sup>43-68B Concrete surfaces

<sup>3</sup>43-51B Metal surfaces

<sup>4</sup>43-51B Concrete surfaces

<sup>5</sup>43-51B Concrete junctures

<sup>6</sup>43-51B Concrete junctures with 1 paint layer

<sup>7</sup>43-116-1B Metal surfaces

<sup>8</sup>43-116-1B Concrete surfaces

<sup>9</sup>43-116-1B Concrete junctures

<b>Instrument</b>	<b>Detector Serial No.</b>	<b>MDC (dpm/100 cm<sup>2</sup>)</b>
InSpector	08051294	4,670 dpm/100 cm <sup>2</sup> Cs-137 1,340 dpm/100 cm <sup>2</sup> Co-60

**Table 2-2. Investigation Criteria and DCGL**

<b>Parameter</b>	<b>Value (dpm/100 cm<sup>2</sup>)</b>
Investigation Criteria - Direct	141,900
Investigation Criteria – Scan	141,900
DCGL <sub>W</sub>	43,000
DCGL <sub>EMC</sub>	141,900



**Attachment 3**

**Investigation**

**November 4, 2007**

**Survey Unit F8130631**

**Table 3-1. Survey Unit Investigation**

Grid	Initial cpm	Elevated Area (m <sup>2</sup> )	Area Factor	DCGLEMC (dpm/100 cm <sup>2</sup> )	Investigation Result (dpm/100 cm <sup>2</sup> )	DCGLEMC Unity
P0061	N/A	0.219	25.9	1.11E+06	90,710	8.14E-02
P0062	N/A	0.347	25.9	1.11E+06	18,172	1.63E-02
P0063	N/A	0.328	25.9	1.11E+06	9,313	8.36E-03
P0064	N/A	0.930	13.8	5.93E+05	23,372	3.94E-02
P0067	N/A	0.255	25.9	1.11E+06	129,800	1.17E-01
P0068	N/A	0.438	25.9	1.11E+06	63,690	5.72E-02
				SU Mean (dpm/100 cm <sup>2</sup> )	Unitized Mean	
				3.368E+03	7.83E-02	7.83E-02
EMC Unity Sum						3.98E-01

**Attachment 4**  
**Data Assessment**  
**November 4, 2007**  
**Survey Unit F8130631**

F8130631 Gross Activity Sample Results Quantile Plot  
DCGL = 43000 dpm/100cm<sup>2</sup>

