

December 4, 2007

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)
Tennessee Valley Authority (TVA))

Docket No. 50-328

**SEQUOYAH NUCLEAR PLANT (SQN) - UNIT 2 CYCLE 14 (U2C14) - 12-MONTH
STEAM GENERATOR (SG) INSPECTION REPORT**

In accordance with the requirements of SQN Unit 2 Technical Specification 4.4.5.5.b, TVA is submitting the 12-month report that includes the results of inservice inspections performed on Unit 2 SGs during the U2C14 refueling outage.

There are no commitments contained in this letter.

Please direct questions concerning this issue to me at (423) 843-7170 or J. W. Proffitt at (423) 843-6651.

Sincerely,

Original signed by James D. Proffitt for:

James D. Smith
Manager, Site Licensing and
Industry Affairs

Enclosure
cc: See page 2

U.S. Nuclear Regulatory Commission
Page 2
December 4, 2007

cc (Enclosure):

Mr. Brendan Moroney, Senior Project Manager
U.S. Nuclear Regulatory Commission
Mail Stop 08G-9a
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2739

Tennessee Valley Authority

Sequoyah Nuclear Plant

**Unit 2 Cycle 14
Refueling Outage
December 2006**

12 Month Steam Generator Inspection Report

Prepared by: Emmett A. Conyer 27 Nov 07

Verified by: William David James 11/28/07

Approved by: Tim E. Massey 11/28/07

Table 2 AVB Wear

In accordance with Technical Specification 4.5.5.5, this report documents the results of the Unit 2 Cycle 14 steam generator (SG) tube inservice inspection. The following list includes the examinations that were performed and the extent the tubes were tested.

- 100-percent Full-length bobbin examination in all 4 SGs.
- 100-percent hot leg top of tubesheet (HTS) RPC examination in all 4 SGs using a plus point probe +2"/-8" (Ref. WCAP-14797)
- 100-percent of low Row U-bends using a mid range magnetic biased ZETEC +Point Row 1-4 U-Bend probe
- 100-percent Row 5 through 8 U-Bend using a MHI probe (or +Point) in all SGs.
- 100-percent freespan dings greater than or equal to 2 volts (Cycle 13) from HTS to H07 using the +Pt probe
- 100-percent TSPs H01 to C07 dented greater than or equal to 2 volts (Cycle 13) using the +Pt probe
- 100-percent of AVB locations with dents with a +Pt probe (Ref. Corp PER 03-000055-000).
- 100-percent of MBM with dings with a +Pt probe (Ref. Corp PER 03-000023-000).
- 100-percent of all free-span dents or dings in the U-bend region (any voltage) using the +Pt probe (Ref. Corp. PER 03-000055-000).
- 100-percent DSIs greater than 1v and less than 2 volts with a +Pt probe during the inspection to add margin for out of ordinary DSI voltage growth. Westinghouse position supports +Point exams for 1.6 volts and greater, TVA tested 1 volt and greater during U2C12, U2C13, and U2C14.
- 100 -percent DSIs greater than or equal to 2 volts with a + Pt probe. If + Pt probe detected the indication the tube was plugged.
- All identified OXPs were plus point examined.
- All new cold leg indications at tube support plate intersections were plus point probe examined.

35,723 examinations were performed during the SQN Unit 2 Cycle 14 Steam Generator Inservice Inspection.

Attached are tables listing location and percent of wall-thickness penetration or eddy current voltage associated with each indication by mechanism and the status of the tube (plugged or in service).

Condition monitoring and operational assessments were performed for each damage mechanism. Performance criteria were met for both the last cycle and the full cycle 15 operation. No tubes exceeded in situ pressure test screening criteria.

Sludge lancing and foreign object search and retrieval was performed on all 4 SGs.

Table 2
AVB Wear

TABLE 1
Nomenclature

AVB - Anti-Vibration Bar

CA - Crack angle, the circumferential extent of a circumferential crack in degrees

CA_{TW_{SL}} - Structural limit crack angle for a 100-percent through wall circumferential crack in degrees

C01 - First cold leg tube support plate intersection

C02 - Second cold leg tube support plate intersection

C03 - Third cold leg tube support plate intersection

C04 - Fourth cold leg tube support plate intersection

C05 - Fifth cold leg tube support plate intersection

C06 - Sixth cold leg tube support plate intersection

C07 - Seventh cold tube support plate intersection

CTE - Cold leg tube end. (Primary side cold leg face of tubesheet)

CTS - Cold leg top-of-tubesheet. (Secondary side cold leg face of tubesheet)

C/L - Cold Leg

H01 - First hot leg tube support plate intersection

H02 - Second hot leg tube support plate intersection

H03 - Third hot leg tube support plate intersection

H04 - Fourth hot leg tube support plate intersection

H05 - Fifth hot leg tube support plate intersection

H06 - Sixth hot leg tube support plate intersection

H07 - Seventh hot leg tube support plate intersection

HTE - Hot leg tube end. (Primary side hot leg face of tubesheet)

HTS - Hot leg top-of-tubesheet. (Secondary side cold leg face of tubesheet)

L_{STR} - Structural length for a 100-percent through-wall axial crack in inches

MHI - Mitsubishi Heavy Industry Array probe

ODSCC - Outside Diameter Stress Corrosion Cracking

PWSCC - Primary Water Stress Corrosion Cracking

RFO - Refuel Outage

RPC - Literally 'Rotating Pancake Coil' eddy current probe. This term is also used to describe eddy current probes in which the coil face contacts the tube wall while rotating and being pulled through the tube axially such that the examination path is helical.

SAI - Single Axial Indication

SCI - Single Circumferential Indication

SG - Steam Generator

SVI - Single Volumetric Indication

SQN - Sequoyah Nuclear Plant

Stab - Tube was stabilized

TBP - "To-Be-Plugged" Analysts determined tube should be plugged (Majority of these were analysis of Axial ODSCC at TSPs bobbin vs +Pt comparison)

TSP - Tube Support Plate

TTS - Top of Tubesheet

Table 2
AVB Wear

The indications below were characterized as Anti-Vibration Bar Wear which were detected by bobbin coil. The associated maximum depth and voltage are included. These indications are plugged at 40-percent through wall (TW) or greater.

SG	ROW	COL	LOCATION	% TW	VOLTS	CHARACTERIZATION	RESOLUTION
1	19	38	AV3+.00	22	0.28	AVB WEAR	In Service <40%TW
1	19	38	AV2+.00	35	0.62	AVB WEAR	In Service <40%TW
1	27	29	AV3+.11	22	0.44	AVB WEAR	In Service <40%TW
1	27	31	AV3+.00	21	0.42	AVB WEAR	In Service <40%TW
1	27	31	AV2+.46	19	0.38	AVB WEAR	In Service <40%TW
1	32	64	AV2+.09	25	0.64	AVB WEAR	In Service <40%TW
1	32	64	AV3+.18	20	0.45	AVB WEAR	In Service <40%TW
1	32	64	AV4+.15	16	0.34	AVB WEAR	In Service <40%TW
1	36	66	AV3+.06	17	0.38	AVB WEAR	In Service <40%TW
1	37	62	AV2+.12	19	0.31	AVB WEAR	In Service <40%TW
1	37	62	AV4-.09	19	0.3	AVB WEAR	In Service <40%TW
1	37	62	AV3+.00	42	1.25	AVB WEAR	PLUGGED
1	39	45	AV2+.00	20	0.35	AVB WEAR	In Service <40%TW
2	17	28	AV1+.21	17	0.29	AVB WEAR	In Service <40%TW
2	17	28	AV3-.35	31	0.76	AVB WEAR	In Service <40%TW
2	17	28	AV2-.23	15	0.24	AVB WEAR	In Service <40%TW
2	17	64	AV1+.00	17	0.21	AVB WEAR	In Service <40%TW
2	17	64	AV2+.00	21	0.3	AVB WEAR	In Service <40%TW
2	17	64	AV3+.00	22	0.32	AVB WEAR	In Service <40%TW
2	18	42	AV2+.26	17	0.25	AVB WEAR	In Service <40%TW
2	18	72	AV3+.00	15	0.18	AVB WEAR	In Service <40%TW
2	19	28	AV1-.42	19	0.35	AVB WEAR	In Service <40%TW
2	19	74	AV2-.06	15	0.2	AVB WEAR	In Service <40%TW
2	22	41	AV2+.09	24	0.4	AVB WEAR	In Service <40%TW
2	23	69	AV3+.09	29	0.55	AVB WEAR	In Service <40%TW
2	23	69	AV2+.12	30	0.51	AVB WEAR	In Service <40%TW
2	24	61	AV4+.00	16	0.26	AVB WEAR	In Service <40%TW
2	24	61	AV2+.30	36	1.01	AVB WEAR	In Service <40%TW
2	24	63	AV2+.00	30	0.6	AVB WEAR	In Service <40%TW
2	24	64	AV3+.16	24	0.41	AVB WEAR	In Service <40%TW
2	24	64	AV1-.11	18	0.28	AVB WEAR	In Service <40%TW
2	24	64	AV4+.19	17	0.25	AVB WEAR	In Service <40%TW
2	24	64	AV2-.12	23	0.4	AVB WEAR	In Service <40%TW
2	24	71	AV3+.00	21	0.32	AVB WEAR	In Service <40%TW
2	26	70	AV3+.15	32	0.63	AVB WEAR	In Service <40%TW
2	27	43	AV3+.03	25	0.44	AVB WEAR	In Service <40%TW
2	27	65	AV1-.22	17	0.26	AVB WEAR	In Service <40%TW
2	27	65	AV2-.43	31	0.65	AVB WEAR	In Service <40%TW
2	27	65	AV3+.00	38	1.05	AVB WEAR	In Service <40%TW
2	29	39	AV2+.55	28	0.49	AVB WEAR	In Service <40%TW
2	29	39	AV3-.47	18	0.25	AVB WEAR	In Service <40%TW
2	32	46	AV2+.08	6	0.09	AVB WEAR	In Service <40%TW
2	32	56	AV3+.00	31	0.66	AVB WEAR	In Service <40%TW
2	32	56	AV1+.00	29	0.57	AVB WEAR	In Service <40%TW
2	32	56	AV2+.00	30	0.62	AVB WEAR	In Service <40%TW
2	32	62	AV3-.21	23	0.31	AVB WEAR	In Service <40%TW
2	32	62	AV2+.27	21	0.32	AVB WEAR	In Service <40%TW
2	33	62	AV3+.37	19	0.24	AVB WEAR	In Service <40%TW
2	33	77	AV3+.12	25	0.32	AVB WEAR	In Service <40%TW
2	38	43	AV3+.06	14	0.23	AVB WEAR	In Service <40%TW

Table 2
AVB Wear

SG	ROW	COL	LOCATION	% TW	VOLTS	CHARACTERIZATION	RESOLUTION
2	38	46	AV4+.16	20	0.36	AVB WEAR	In Service <40%TW
2	38	46	AV3+.11	20	0.37	AVB WEAR	In Service <40%TW
2	39	49	AV3+.00	16	0.26	AVB WEAR	In Service <40%TW
2	39	49	AV4+.00	15	0.24	AVB WEAR	In Service <40%TW
3	18	30	AV2-.20	19	0.38	AVB WEAR	In Service <40%TW
3	19	64	AV2+.00	22	0.4	AVB WEAR	In Service <40%TW
3	19	64	AV3-.06	25	0.51	AVB WEAR	In Service <40%TW
3	23	55	AV3+.18	23	0.32	AVB WEAR	In Service <40%TW
3	23	55	AV4+.00	18	0.21	AVB WEAR	In Service <40%TW
3	23	55	AV2+.24	15	0.18	AVB WEAR	In Service <40%TW
3	28	45	AV1+.00	19	0.35	AVB WEAR	In Service <40%TW
3	28	45	AV2+.00	21	0.43	AVB WEAR	In Service <40%TW
3	28	45	AV3+.00	19	0.38	AVB WEAR	In Service <40%TW
3	32	40	AV3+.00	18	0.31	AVB WEAR	In Service <40%TW
3	33	61	AV2+.09	27	0.44	AVB WEAR	In Service <40%TW
3	33	61	AV3+.10	21	0.3	AVB WEAR	In Service <40%TW
3	34	42	AV4+.00	15	0.28	AVB WEAR	In Service <40%TW
3	34	42	AV3+.00	19	0.42	AVB WEAR	In Service <40%TW
3	35	39	AV2+.00	15	0.29	AVB WEAR	In Service <40%TW
3	35	39	AV1+.00	21	0.43	AVB WEAR	In Service <40%TW
3	35	39	AV3+.00	16	0.31	AVB WEAR	In Service <40%TW
3	38	40	AV3+.00	17	0.37	AVB WEAR	In Service <40%TW
3	38	40	AV4+.00	19	0.42	AVB WEAR	In Service <40%TW
3	40	56	AV2-.03	22	0.31	AVB WEAR	In Service <40%TW
4	29	67	AV3+.00	34	0.9	AVB WEAR	In Service <40%TW
4	29	67	AV2+.00	18	0.32	AVB WEAR	In Service <40%TW
4	29	67	AV4+.00	20	0.36	AVB WEAR	In Service <40%TW
4	29	67	AV1+.00	19	0.36	AVB WEAR	In Service <40%TW
4	32	41	AV3+.20	10	0.13	AVB WEAR	In Service <40%TW
4	32	41	AV2+.22	16	0.24	AVB WEAR	In Service <40%TW
4	35	55	AV2+.00	19	0.3	AVB WEAR	In Service <40%TW
4	35	55	AV1+.41	25	0.46	AVB WEAR	In Service <40%TW
4	38	44	AV3+.00	25	0.42	AVB WEAR	In Service <40%TW
4	38	47	AV4+.00	24	0.42	AVB WEAR	In Service <40%TW
4	38	47	AV3+.00	24	0.41	AVB WEAR	In Service <40%TW
4	38	49	AV4+.00	18	0.26	AVB WEAR	In Service <40%TW
4	38	49	AV3+.00	25	0.44	AVB WEAR	In Service <40%TW
4	38	52	AV4-.12	24	0.41	AVB WEAR	In Service <40%TW
4	38	52	AV3+.00	22	0.36	AVB WEAR	In Service <40%TW
4	38	65	AV2+.00	15	0.25	AVB WEAR	In Service <40%TW
4	38	65	AV1-.03	15	0.25	AVB WEAR	In Service <40%TW

**Table 3
Cold Leg Thinning**

The indications below are Cold Leg Thinning indications. These indications are detected with bobbin coil. The associated voltage and maximum depth are listed. These indications are plugged at 40-percent through wall or greater. Plus point examinations are performed on new cold leg tube support plate intersection indications to confirm that the indication is not crack-like. In addition, old Cold Leg Thinning indications which have changed significantly are examined with a plus point probe. The plus point call "VOL" indicates a volumetric wall loss of the tube.

SG	ROW	COL	LOCATION	INDIC	VOLTAGE	CHARACTERIZATION	RESOLUTION
1	1	1	C01-.06	20	0.35	C/L THINNING	In Service <40%TW
1	5	1	C01+.15	29	0.91	C/L THINNING	In Service <40%TW
1	7	1	C01+.03	5	0.55	C/L THINNING	In Service <40%TW
1	7	1	C01+.25	VOL	0.22	C/L THINNING	+Pt Confirmation
1	10	3	C01+.11	17	0.49	C/L THINNING	In Service <40%TW
1	10	3	C01+.28	VOL	0.41	C/L THINNING	+Pt Confirmation
1	11	2	C01+.03	1	0.51	C/L THINNING	In Service <40%TW
1	11	2	C01+.29	VOL	0.31	C/L THINNING	+Pt Confirmation
1	11	4	C01-.14	11	0.53	C/L THINNING	In Service <40%TW
1	11	4	C01+.06	VOL	0.32	C/L THINNING	+Pt Confirmation
1	16	91	C01+.06	25	0.23	C/L THINNING	In Service <40%TW
1	16	91	C01+.11	VOL	0.23	C/L THINNING	+Pt Confirmation
1	17	4	C01+.00	<20	0.23	C/L THINNING	In Service <40%TW
1	17	4	C01+.15	VOL	0.19	C/L THINNING	+Pt Confirmation
1	29	84	C01+.09	1	0.67	C/L THINNING	In Service <40%TW
1	30	83	C01+.15	34	1.55	C/L THINNING	In Service <40%TW
1	31	79	C01-.17	<20	0.46	C/L THINNING	In Service <40%TW
1	31	82	C01+.12	1	1.26	C/L THINNING	In Service <40%TW
1	34	19	C01+.14	24	1.48	C/L THINNING	In Service <40%TW
1	34	79	C03-.09	16	0.66	C/L THINNING	In Service <40%TW
1	38	70	C01-.21	16	0.56	C/L THINNING	In Service <40%TW
1	42	30	C01+.20	<20	0.65	C/L THINNING	In Service <40%TW
1	42	62	C01-.21	16	0.72	C/L THINNING	In Service <40%TW
1	43	31	C01+.10	16	1.09	C/L THINNING	In Service <40%TW
1	43	32	C01-.08	14	1.19	C/L THINNING	In Service <40%TW
1	43	62	C01-.15	10	0.69	C/L THINNING	In Service <40%TW
1	44	35	C01-.18	20	0.52	C/L THINNING	In Service <40%TW
1	44	36	C01+.13	33	0.68	C/L THINNING	In Service <40%TW
1	44	36	C02-.26	35	0.36	C/L THINNING	In Service <40%TW
1	44	37	C02-.18	1	0.58	C/L THINNING	In Service <40%TW
1	44	37	C02+.01	VOL	0.16	C/L THINNING	+Pt Confirmation
1	44	39	C02-.20	20	1.42	C/L THINNING	In Service <40%TW
1	44	45	C02+.05	22	1.30	C/L THINNING	In Service <40%TW
1	44	58	C01-.18	11	1.96	C/L THINNING	In Service <40%TW
1	44	59	C01-.24	<20	0.48	C/L THINNING	In Service <40%TW
1	44	61	C01-.24	23	0.43	C/L THINNING	In Service <40%TW
1	45	39	C01+.28	<20	0.61	C/L THINNING	In Service <40%TW
1	45	41	C02-.28	18	0.55	C/L THINNING	In Service <40%TW
1	45	55	C01-.24	<20	0.28	C/L THINNING	In Service <40%TW
1	46	43	C02-.26	17	0.52	C/L THINNING	In Service <40%TW
1	46	44	C02-.23	8	0.42	C/L THINNING	In Service <40%TW
1	46	50	C01+.21	22	0.96	C/L THINNING	In Service <40%TW
1	46	51	C02+.00	1	0.83	C/L THINNING	In Service <40%TW
1	46	51	C02+.18	VOL	0.47	C/L THINNING	+Pt Confirmation
1	46	52	C02+.03	<20	0.99	C/L THINNING	In Service <40%TW
1	46	53	C01-.21	7	0.84	C/L THINNING	In Service <40%TW
2	5	3	C01-.11	1	0.60	C/L THINNING	In Service <40%TW

**Table 3
Cold Leg Thinning**

2	5	3	C01+.02	VOL	0.21	C/L THINNING	+Pt Confirmation
2	5	93	C01-.03	29	0.73	C/L THINNING	In Service <40%TW
2	6	94	C01-.28	7	0.64	C/L THINNING	In Service <40%TW
2	7	4	C01-.25	15	0.52	C/L THINNING	In Service <40%TW
2	7	92	C01-.14	13	0.75	C/L THINNING	In Service <40%TW
2	7	94	C01-.17	12	1.19	C/L THINNING	In Service <40%TW
2	9	93	C01-.17	1	0.63	C/L THINNING	In Service <40%TW
2	9	93	C01-.03	VOL	0.28	C/L THINNING	+Pt Confirmation
2	10	92	C01-.15	8	0.98	C/L THINNING	In Service <40%TW
2	11	4	C01-.27	20	0.68	C/L THINNING	In Service <40%TW
2	12	4	C01-.18	1	0.71	C/L THINNING	In Service <40%TW
2	12	4	C01-.05	VOL	0.17	C/L THINNING	+Pt Confirmation
2	19	6	C01-.03	12	1.25	C/L THINNING	In Service <40%TW
2	24	8	C01-.21	28	1.47	C/L THINNING	In Service <40%TW
2	24	9	C01+.06	24	0.82	C/L THINNING	In Service <40%TW
2	27	85	C01-.17	19	0.49	C/L THINNING	In Service <40%TW
2	28	11	C01-.22	25	1.61	C/L THINNING	In Service <40%TW
2	28	12	C02-.24	28	1.25	C/L THINNING	In Service <40%TW
2	30	16	C02+.17	31	0.45	C/L THINNING	In Service <40%TW
2	31	80	C02+.12	1	0.43	C/L THINNING	In Service <40%TW
2	32	17	C03-.20	1	0.70	C/L THINNING	In Service <40%TW
2	33	16	C02-.12	<20	0.57	C/L THINNING	In Service <40%TW
2	33	16	C02+.01	VOL	0.28	C/L THINNING	+Pt Confirmation
2	33	16	C03-.06	58	1.57	C/L THINNING	PLUGGED
2	33	16	C03+.00	VOL	0.79	C/L THINNING	+Pt Confirmation
2	33	19	C01-.23	1	1.06	C/L THINNING	In Service <40%TW
2	33	19	C01-.08	VOL	0.11	C/L THINNING	+Pt Confirmation
2	33	71	C02-.18	<20	0.32	C/L THINNING	In Service <40%TW
2	33	71	C02-.13	VOL	0.25	C/L THINNING	+Pt Confirmation
2	33	74	C02-.12	15	0.83	C/L THINNING	In Service <40%TW
2	33	78	C02-.15	34	1.48	C/L THINNING	In Service <40%TW
2	34	78	C02-.15	23	0.88	C/L THINNING	In Service <40%TW
2	36	18	C01+.14	28	1.76	C/L THINNING	In Service <40%TW
2	36	20	C01-.15	26	2.30	C/L THINNING	In Service <40%TW
2	36	22	C01-.20	<20	0.45	C/L THINNING	In Service <40%TW
2	36	76	C02-.12	38	1.64	C/L THINNING	In Service <40%TW
2	38	21	C01-.26	5	0.59	C/L THINNING	In Service <40%TW
2	38	22	C03+.00	14	0.68	C/L THINNING	In Service <40%TW
2	38	24	C01+.14	32	1.08	C/L THINNING	In Service <40%TW
2	38	73	C02-.15	26	0.61	C/L THINNING	In Service <40%TW
2	38	74	C02+.24	11	0.72	C/L THINNING	In Service <40%TW
2	39	70	C02+.00	35	0.77	C/L THINNING	In Service <40%TW
2	39	73	C02+.06	19	0.56	C/L THINNING	In Service <40%TW
2	40	24	C01-.09	36	1.45	C/L THINNING	In Service <40%TW
2	40	24	C02-.23	21	0.81	C/L THINNING	In Service <40%TW
2	40	25	C01+.12	16	0.44	C/L THINNING	In Service <40%TW
2	40	25	C01+.22	VOL	0.19	C/L THINNING	+Pt Confirmation
2	40	27	C01-.17	18	0.90	C/L THINNING	In Service <40%TW
2	40	67	C02+.18	4	0.93	C/L THINNING	In Service <40%TW
2	40	68	C02-.03	30	0.69	C/L THINNING	In Service <40%TW
2	40	71	C03-.18	17	0.42	C/L THINNING	In Service <40%TW
2	41	26	C02-.32	7	0.71	C/L THINNING	In Service <40%TW
2	41	26	C02-.15	VOL	0.29	C/L THINNING	+Pt Confirmation
2	41	29	C01-.06	30	0.64	C/L THINNING	In Service <40%TW
2	41	36	C02-.26	6	0.67	C/L THINNING	In Service <40%TW
2	41	69	C01+.24	2	0.68	C/L THINNING	In Service <40%TW
2	42	28	C01-.26	15	0.56	C/L THINNING	In Service <40%TW

**Table 3
Cold Leg Thinning**

2	42	29	C01+.14	14	0.96	C/L THINNING	In Service <40%TW
2	42	36	C01-.26	26	0.64	C/L THINNING	In Service <40%TW
2	42	64	C01+.21	19	1.89	C/L THINNING	In Service <40%TW
2	42	65	C01+.28	1	0.81	C/L THINNING	In Service <40%TW
2	42	65	C01+.31	VOL	0.27	C/L THINNING	+Pt Confirmation
2	42	66	C01+.09	18	0.63	C/L THINNING	In Service <40%TW
2	42	67	C01+.22	2	0.53	C/L THINNING	In Service <40%TW
2	43	32	C01+.18	34	2.30	C/L THINNING	In Service <40%TW
2	43	57	C02+.30	13	0.53	C/L THINNING	In Service <40%TW
2	43	58	C02+.27	<20	0.36	C/L THINNING	In Service <40%TW
2	43	62	C01+.22	<20	0.70	C/L THINNING	In Service <40%TW
2	43	63	C01+.00	37	0.54	C/L THINNING	In Service <40%TW
2	44	39	C02-.20	25	1.06	C/L THINNING	In Service <40%TW
2	45	37	C02+.23	<20	0.63	C/L THINNING	In Service <40%TW
2	45	40	C01-.09	29	0.95	C/L THINNING	In Service <40%TW
2	45	43	C01-.29	34	0.51	C/L THINNING	In Service <40%TW
2	45	46	C01-.26	6	0.48	C/L THINNING	In Service <40%TW
2	45	59	C02-.19	34	1.51	C/L THINNING	In Service <40%TW
2	45	59	C02-.05	VOL	0.40	C/L THINNING	+Pt Confirmation
2	45	59	C02+.37	VOL	0.09	C/L THINNING	+Pt Confirmation
2	46	48	C01+.06	12	0.84	C/L THINNING	In Service <40%TW
2	46	53	C01+.24	38	0.33	C/L THINNING	In Service <40%TW
3	2	1	C01-.06	31	0.36	C/L THINNING	In Service <40%TW
3	2	1	C01-.06	VOL	0.28	C/L THINNING	+Pt Confirmation
3	5	1	C01+.06	31	0.80	C/L THINNING	In Service <40%TW
3	7	1	C01+.03	31	1.26	C/L THINNING	In Service <40%TW
3	7	1	C01+.06	VOL	0.72	C/L THINNING	+Pt Confirmation
3	7	2	C02+.06	1	0.59	C/L THINNING	In Service <40%TW
3	10	2	C01+.14	10	1.11	C/L THINNING	In Service <40%TW
3	11	90	C01-.21	<20	0.36	C/L THINNING	In Service <40%TW
3	11	92	C01-.06	26	1.04	C/L THINNING	In Service <40%TW
3	12	3	C01+.06	<20	0.38	C/L THINNING	In Service <40%TW
3	17	91	C01-.06	6	0.41	C/L THINNING	In Service <40%TW
3	17	91	C01+.03	VOL	0.16	C/L THINNING	+Pt Confirmation
3	24	87	C01-.18	48	1.67	C/L THINNING	PLUGGED
3	24	87	C01-.09	VOL	0.59	C/L THINNING	+Pt Confirmation
3	25	9	C01+.03	<20	0.47	C/L THINNING	In Service <40%TW
3	27	84	C01-.18	37	1.34	C/L THINNING	In Service <40%TW
3	29	83	C01-.06	<20	0.74	C/L THINNING	In Service <40%TW
3	30	83	C01-.18	14	1.35	C/L THINNING	In Service <40%TW
3	30	83	C02+.03	<20	0.20	C/L THINNING	In Service <40%TW
3	31	82	C01+.00	43	1.98	C/L THINNING	PLUGGED
3	31	82	C01+.05	VOL	0.58	C/L THINNING	+Pt Confirmation
3	33	78	C01-.09	19	0.79	C/L THINNING	In Service <40%TW
3	33	79	C01+.00	38	2.13	C/L THINNING	In Service <40%TW
3	34	16	C01-.20	20	0.61	C/L THINNING	In Service <40%TW
3	34	16	C02-.26	14	0.49	C/L THINNING	In Service <40%TW
3	34	78	C01+.09	11	0.23	C/L THINNING	In Service <40%TW
3	35	17	C01-.03	<20	0.44	C/L THINNING	In Service <40%TW
3	35	17	C01-.06	VOL	0.38	C/L THINNING	+Pt Confirmation
3	35	17	C02-.11	22	0.48	C/L THINNING	In Service <40%TW
3	35	78	C01+.18	1	1.35	C/L THINNING	In Service <40%TW
3	36	19	C02+.15	<20	0.27	C/L THINNING	In Service <40%TW
3	36	19	C02+.08	VOL	0.18	C/L THINNING	+Pt Confirmation
3	36	74	C01-.12	19	0.62	C/L THINNING	In Service <40%TW
3	36	74	C01+.21	21	1.01	C/L THINNING	In Service <40%TW
3	36	76	C01-.09	19	0.36	C/L THINNING	In Service <40%TW

**Table 3
Cold Leg Thinning**

3	36	76	C01-.03	VOL	0.20	C/L THINNING	+Pt Confirmation
3	38	74	C01-.06	31	1.10	C/L THINNING	In Service <40%TW
3	38	74	C01+.07	VOL	0.55	C/L THINNING	+Pt Confirmation
3	39	68	C01+.09	28	0.83	C/L THINNING	In Service <40%TW
3	39	71	C01+.06	<20	0.19	C/L THINNING	In Service <40%TW
3	39	71	C01+.39	VOL	0.22	C/L THINNING	+Pt Confirmation
3	39	73	C01-.09	1	0.74	C/L THINNING	In Service <40%TW
3	39	73	C01-.02	VOL	0.27	C/L THINNING	+Pt Confirmation
3	40	26	C02-.20	25	0.91	C/L THINNING	In Service <40%TW
3	42	28	C01-.03	<20	0.27	C/L THINNING	In Service <40%TW
3	42	34	C01+.03	<20	0.27	C/L THINNING	In Service <40%TW
3	42	60	C01-.15	17	0.38	C/L THINNING	In Service <40%TW
3	43	30	C01-.08	<20	0.81	C/L THINNING	In Service <40%TW
3	43	62	C01+.12	8	0.98	C/L THINNING	In Service <40%TW
3	44	33	C01+.11	1	0.68	C/L THINNING	In Service <40%TW
3	44	34	C02-.14	40	1.87	C/L THINNING	PLUGGED
3	44	34	C02+.01	VOL	1.03	C/L THINNING	+Pt Confirmation
3	44	56	C01+.12	9	0.65	C/L THINNING	In Service <40%TW
3	44	57	C01-.18	17	0.88	C/L THINNING	In Service <40%TW
3	44	60	C01-.12	33	0.51	C/L THINNING	In Service <40%TW
3	44	60	C01+.26	VOL	0.44	C/L THINNING	+Pt Confirmation
3	45	40	C03-.26	13	0.51	C/L THINNING	In Service <40%TW
3	45	52	C01-.12	16	1.53	C/L THINNING	In Service <40%TW
3	45	53	C01+.11	1	0.72	C/L THINNING	In Service <40%TW
3	45	58	C01-.12	36	1.01	C/L THINNING	In Service <40%TW
3	46	41	C02-.35	34	0.59	C/L THINNING	In Service <40%TW
4	6	2	C01-.34	<20	0.29	C/L THINNING	In Service <40%TW
4	7	94	C01-.20	18	0.92	C/L THINNING	In Service <40%TW
4	11	3	C01-.31	10	1.02	C/L THINNING	In Service <40%TW
4	17	91	C01-.08	1	0.69	C/L THINNING	In Service <40%TW
4	18	88	C01-.03	3	0.57	C/L THINNING	In Service <40%TW
4	19	7	C01-.32	<20	0.65	C/L THINNING	In Service <40%TW
4	27	11	C01-.35	<20	0.64	C/L THINNING	In Service <40%TW
4	30	15	C01-.28	<20	0.66	C/L THINNING	In Service <40%TW
4	31	13	C01-.23	18	2.32	C/L THINNING	In Service <40%TW
4	34	76	C02+.28	18	0.69	C/L THINNING	In Service <40%TW
4	34	79	C04-.23	1	0.57	C/L THINNING	In Service <40%TW
4	37	19	C01-.11	4	0.81	C/L THINNING	In Service <40%TW
4	39	22	C02-.14	33	1.15	C/L THINNING	In Service <40%TW
4	39	31	C02-.23	14	0.40	C/L THINNING	In Service <40%TW
4	39	71	C02+.06	<20	0.42	C/L THINNING	In Service <40%TW
4	40	63	C02+.00	<20	0.61	C/L THINNING	In Service <40%TW
4	40	71	C02-.18	35	1.47	C/L THINNING	In Service <40%TW
4	41	30	C02-.28	15	0.52	C/L THINNING	In Service <40%TW
4	41	34	C02-.28	1	0.59	C/L THINNING	In Service <40%TW
4	41	58	C02-.14	39	1.33	C/L THINNING	In Service <40%TW
4	41	62	C02-.17	28	2.58	C/L THINNING	In Service <40%TW
4	41	67	C01-.26	<20	0.54	C/L THINNING	In Service <40%TW
4	42	44	C02-.26	24	0.71	C/L THINNING	In Service <40%TW
4	43	35	C02+.03	1	0.89	C/L THINNING	In Service <40%TW
4	43	47	C02-.29	26	0.32	C/L THINNING	In Service <40%TW
4	43	54	C02-.14	27	1.38	C/L THINNING	In Service <40%TW
4	44	34	C02-.25	33	2.03	C/L THINNING	In Service <40%TW
4	44	38	C02-.25	16	0.82	C/L THINNING	In Service <40%TW
4	44	39	C02-.20	1	0.74	C/L THINNING	In Service <40%TW
4	44	39	C02-.02	VOL	0.39	C/L THINNING	+Pt Confirmation
4	44	47	C02-.32	<20	0.35	C/L THINNING	In Service <40%TW

**Table 3
Cold Leg Thinning**

4	45	36	C02+.06	1	0.54	C/L THINNING	In Service <40%TW
4	45	41	C02-.34	<20	0.27	C/L THINNING	In Service <40%TW
4	45	42	C02-.14	25	0.93	C/L THINNING	In Service <40%TW
4	45	44	C02-.20	15	0.56	C/L THINNING	In Service <40%TW
4	45	45	C02-.29	26	1.50	C/L THINNING	In Service <40%TW
4	45	50	C02-.18	34	0.59	C/L THINNING	In Service <40%TW
4	45	54	C02+.08	23	0.55	C/L THINNING	In Service <40%TW
4	45	55	C01-.22	15	0.40	C/L THINNING	In Service <40%TW
4	45	57	C02-.11	39	2.02	C/L THINNING	In Service <40%TW
4	46	53	C02+.25	33	0.92	C/L THINNING	In Service <40%TW

Table 4
ODSCC Freespan Axial

The indications below are axial (SAI) outside diameter stress corrosion cracking (ODSCC). The SG2R8C2 H01 was dented and therefore detected by the plus point examination. SG3R31C61 was detected by bobbin and confirmed with plus point probe examination. These plus point indications are plugged on detection.

SG	ROW	COL	LOCATION	% TW	VOLTS	CHARACTERIZATION	RESOLUTION
2	8	2	H01+.49	SAI	0.17	ODSCC FREESPAN AXIAL	PLUGGED
3	31	61	HTS+47.63	SAI	0.32	ODSCC FREESPAN AXIAL	PLUGGED
3	31	61	HTS+47.70	DFI	0.33	ODSCC FREESPAN AXIAL	PLUGGED

Table 5
ODSCC Top of Tubesheet Axial

The indications below are axial (SAI) outside diameter stress corrosion cracking (ODSCC) detected by the plus point examinations performed at the hot leg top of the tubesheet (HTS). These indications are plugged on detection.

SG	ROW	COL	LOCATION	INDIC	VOLTAGE	CHARACTERIZATION	RESOLUTION
3	26	42	HTS-.07	SAI	0.09	ODSCC HTS AXIAL	PLUGGED
4	22	28	HTS-.08	SAI	0.37	ODSCC HTS AXIAL	PLUGGED
4	26	33	HTS-.10	SAI	0.22	ODSCC HTS AXIAL	PLUGGED

Table 6
ODSCC Top of Tubesheet Circumferential

The indications below are circumferential (SCI) outside diameter stress corrosion cracking (ODSCC) at the hot leg top of the tubesheet. These indications are detected by the plus point examination and are plugged on detection.

SG	ROW	COL	LOCATION	INDIC	VOLTAGE	CHARACTERIZATION	RESOLUTION
2	13	67	HTS-.17	SCI	0.17	ODSCC HTS CIRC	PLUGGED
2	15	38	HTS+.05	SCI	0.16	ODSCC HTS CIRC	PLUGGED
3	11	28	HTS-.01	SCI	0.2	ODSCC HTS CIRC	PLUGGED
4	8	71	HTS+.00	SCI	0.25	ODSCC HTS CIRC	PLUGGED

Table 7
ODSCC Tube Support Plate Axial

The following indications are axial outside diameter stress corrosion cracking (ODSCC) indications at the tube support plates (TSP). The eddy current call “DSI” is a bobbin coil call and the call “SAI” is a plus point probe call. If the bobbin voltage is less than 2 volts, the indication may remain in service via the ODSCC Generic Letter 95-05 Alternate Plugging Criteria (APC). Plus point exams are required for indication 2 volts and greater. At Sequoyah, plus point exams are performed on all indications greater than or equal to 1 volt and the indication is profiled for further analysis. Based on this profile, the indication may be plugged to prevent extreme voltage growth. The details of the ODSCC indications were reported in the required 90-Day Report. The tubes marked “Plugged Preventively” are the tubes with indications that were determined to have potential for extreme growth.

SG	ROW	COL	LOCATION	INDIC	VOLTAGE	CHARACTERIZATION	RESOLUTION
1	2	8	H02+.00	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
1	2	10	H01+.09	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
1	2	12	H02+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
1	2	12	H03-.09	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
1	2	13	H01+.00	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
1	2	18	H01+.06	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
1	3	1	H05+.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
1	3	15	H01+.09	DSI	1.57	ODSCC TSP AXIAL	In Service via APC
1	3	15	H01+.20	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
1	3	15	H05+.15	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
1	3	16	H01-.06	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
1	3	16	H02+.09	DSI	2.36	ODSCC TSP AXIAL	PLUGGED
1	3	16	H02+.30	SAI	0.24	ODSCC TSP AXIAL	PLUGGED
1	3	16	H02+.31	SAI	0.8	ODSCC TSP AXIAL	PLUGGED
1	3	20	H02-.12	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
1	3	25	H02+.00	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
1	3	25	H02+.19	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
1	3	26	H01+.03	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
1	3	26	H01+.17	SAI	0.08	ODSCC TSP AXIAL	In Service via APC
1	3	27	H01+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
1	3	34	H01+.00	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
1	3	42	H01+.03	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
1	3	46	H01+.03	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
1	3	46	H01+.21	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
1	3	46	H01+.28	SAI	0.37	ODSCC TSP AXIAL	In Service via APC
1	3	46	H02+.12	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
1	3	47	H01-.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
1	3	47	H01+.05	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
1	3	47	H02-.03	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
1	3	52	H01-.03	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
1	3	70	H04+.00	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
1	4	6	H02-.03	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	4	7	H01+.00	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	4	7	H02+.00	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
1	4	8	H01+.00	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
1	4	9	H03+.00	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
1	4	9	H03+.24	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
1	4	11	H01+.00	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
1	4	15	H01-.15	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
1	4	32	H01-.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
1	4	40	H02-.06	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
1	4	78	H02-.09	DSI	0.48	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

1	4	81	H02-.21	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
1	4	81	H02-.02	SAI	0.44	ODSCC TSP AXIAL	In Service via APC
1	4	81	H02+.18	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
1	5	3	H03+.00	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
1	5	7	H01+.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
1	5	7	H02-.09	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
1	5	11	H01+.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
1	5	13	H02+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
1	5	17	H02+.00	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
1	5	24	H03-.12	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
1	5	26	H01+.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
1	5	26	H02+.00	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
1	5	31	H02-.06	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
1	5	32	H01+.00	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
1	5	32	H01-.02	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
1	5	32	H02-.03	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
1	5	33	H01+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
1	5	35	H01-.03	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	5	35	H01+.13	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
1	5	35	H03+.06	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
1	5	35	H03-.06	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
1	5	36	H02+.00	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
1	5	43	H02-.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
1	5	46	H01-.03	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
1	5	50	H02+.00	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
1	5	50	H02+.11	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
1	5	51	H01+.00	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
1	5	54	H03-.06	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
1	5	72	H02-.03	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
1	5	72	H02+.27	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
1	5	72	H03-.09	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
1	5	72	H03-.11	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
1	5	80	H02-.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	5	81	H03+.00	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
1	6	2	H01+.09	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
1	6	2	H01+.27	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
1	6	2	H02-.06	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
1	6	2	H03+.03	DSI	1	ODSCC TSP AXIAL	In Service via APC
1	6	2	H03+.17	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
1	6	3	H01+.00	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
1	6	4	H01+.00	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
1	6	9	H01+.00	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
1	6	14	H01+.03	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
1	6	14	H01+.07	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
1	6	15	H01+.09	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
1	6	15	H01-.15	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
1	6	15	H02-.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
1	6	19	H03+.00	DSI	1	ODSCC TSP AXIAL	In Service via APC
1	6	19	H03-.01	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
1	6	19	H03+.05	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
1	6	21	H01-.12	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
1	6	21	H01-.07	SAI	0.53	ODSCC TSP AXIAL	In Service via APC
1	6	24	H01+.00	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
1	6	24	H03+.00	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
1	6	26	H01+.00	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
1	6	27	H02+.00	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
1	6	29	H01-.09	DSI	0.48	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

1	6	35	H01+.03	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
1	6	38	H01-.06	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
1	6	45	H01+.00	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
1	6	54	H02+.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	6	73	C04+.09	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
1	6	91	H02-.03	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	6	93	H02-.03	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
1	6	94	H03+.00	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
1	7	3	H05+.00	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
1	7	10	H02+.03	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
1	7	20	H01+.00	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
1	8	3	H01+.00	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	8	3	H01+.23	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
1	8	3	H02+.00	DSI	1.29	ODSCC TSP AXIAL	In Service via APC
1	8	3	H02+.00	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
1	8	3	H02+.23	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
1	8	3	H02+.34	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
1	8	3	H03+.00	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
1	8	4	H02-.03	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
1	8	6	H01-.03	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
1	8	6	H01-.07	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
1	8	6	H01+.03	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
1	8	6	H01+.12	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
1	8	12	H01+.00	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
1	8	21	H02-.03	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
1	8	21	H04+.00	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
1	8	33	H01+.00	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
1	8	63	H04+.00	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
1	9	19	H01-.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
1	9	25	H02+.09	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
1	9	28	H04+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
1	9	30	H02+.03	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
1	9	32	H01+.00	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
1	9	34	H04-.06	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
1	9	39	H01+.12	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
1	9	41	H02-.03	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
1	9	43	H03+.03	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
1	9	92	H01+.00	DSI	1.49	ODSCC TSP AXIAL	In Service via APC
1	9	92	H01+.26	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
1	10	3	H06+.06	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
1	10	34	H01+.14	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
1	10	37	H01+.00	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
1	10	70	H01-.03	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
1	10	70	H03-.03	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
1	10	75	H01-.03	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
1	10	75	H02+.09	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
1	10	75	H06-.15	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
1	10	77	H01-.03	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
1	10	77	H02-.06	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
1	10	77	H02+.11	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
1	10	77	H04-.09	DSI	1.38	ODSCC TSP AXIAL	In Service via APC
1	10	77	H04+.03	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
1	10	77	H04+.25	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
1	10	78	H02-.15	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
1	10	84	H02-.06	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
1	11	3	H05+.09	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
1	11	3	H06+.03	DSI	0.93	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

1	11	4	H06+.06	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
1	11	58	H02+.06	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
1	11	61	H02+.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
1	11	72	H01-.15	DSI	1.91	ODSCC TSP AXIAL	PLUGGED-Preventive
1	11	72	H01+.24	SAI	1.61	ODSCC TSP AXIAL	PLUGGED-Preventive
1	11	88	H04+.03	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
1	11	93	H02-.03	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
1	11	93	H02+.29	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
1	12	3	H01+.00	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
1	12	3	H05-.06	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
1	12	3	H06+.06	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	12	5	H06+.09	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
1	12	6	H04+.08	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
1	12	10	H01+.14	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
1	12	44	H02+.08	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
1	12	46	H02+.00	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
1	12	48	H02-.12	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
1	13	9	H01+.06	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
1	13	42	H07+.05	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
1	13	54	H03+.24	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
1	13	62	H05-.06	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
1	13	62	H06-.12	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
1	13	89	H02-.09	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
1	14	4	H01+.08	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
1	14	5	H01+.22	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
1	14	5	H02+.03	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
1	15	5	H02-.20	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
1	15	14	H03+.06	DSI	0.1	ODSCC TSP AXIAL	In Service via APC
1	15	18	H01-.06	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
1	15	18	H01-.09	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
1	15	31	H01+.06	DSI	1.71	ODSCC TSP AXIAL	In Service via APC
1	15	31	H01+.16	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
1	16	29	H02+.06	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
1	16	30	H01+.06	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
1	16	86	H04-.06	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
1	17	4	H01+.22	DSI	1.44	ODSCC TSP AXIAL	In Service via APC
1	17	4	H01+.28	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
1	17	4	H01+.31	SAI	0.42	ODSCC TSP AXIAL	In Service via APC
1	17	4	H02+.11	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
1	17	4	H03+.06	DSI	1.41	ODSCC TSP AXIAL	In Service via APC
1	17	4	H03+.24	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
1	17	4	H03+.27	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
1	17	4	H04+.20	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
1	17	4	H04+.00	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
1	17	4	H06+.11	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
1	17	16	H01+.11	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
1	17	20	H01+.00	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
1	17	21	H02+.08	DSI	0.21	ODSCC TSP AXIAL	In Service via APC
1	17	24	H01+.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
1	17	33	H02-.14	DSI	1.33	ODSCC TSP AXIAL	In Service via APC
1	17	33	H02-.08	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
1	17	33	H02-.07	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
1	17	33	H02-.05	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
1	17	33	H02+.23	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
1	17	82	H05-.09	DSI	0.18	ODSCC TSP AXIAL	In Service via APC
1	18	7	H03+.08	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
1	18	8	H02+.12	DSI	0.65	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

1	18	17	H01+.06	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
1	18	19	H02+.20	DSI	1.24	ODSCC TSP AXIAL	In Service via APC
1	18	21	H02+.06	DSI	0.15	ODSCC TSP AXIAL	In Service via APC
1	18	57	H01+.00	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
1	18	82	H02-.06	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
1	18	89	H05+.06	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
1	19	8	H02+.08	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
1	19	8	H05+.14	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
1	19	45	H01+.07	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
1	19	45	H02+.07	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
1	19	51	H01-.03	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
1	19	66	H01+.03	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
1	19	68	H02-.03	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
1	19	74	H02+.00	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
1	19	77	H02-.15	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
1	19	77	H03-.09	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
1	20	9	H02+.06	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
1	20	32	H01+.03	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
1	20	32	H02+.08	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
1	20	51	H01-.09	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
1	20	51	H01+.07	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
1	20	58	H01+.06	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
1	20	65	H02-.18	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
1	20	65	H02+.02	SAI	0.41	ODSCC TSP AXIAL	In Service via APC
1	20	65	H02+.27	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
1	20	67	H01+.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
1	21	7	H01+.03	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
1	21	7	H02+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
1	21	8	H01+.17	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
1	21	8	H02+.00	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
1	21	8	H02+.10	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
1	21	8	H02+.12	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
1	21	8	H02+.14	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
1	21	71	H02-.12	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
1	21	73	H01+.03	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
1	21	76	H03-.03	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
1	21	78	H02-.06	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
1	21	83	H02+.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
1	21	87	H02-.03	DSI	1.23	ODSCC TSP AXIAL	In Service via APC
1	21	87	H02+.17	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
1	21	87	H02+.18	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
1	21	88	H02-.06	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	22	9	H01+.06	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
1	22	10	H02+.08	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
1	22	11	H03+.08	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
1	22	19	H01+.06	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
1	22	21	H01+.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
1	22	25	H01+.06	DSI	1.2	ODSCC TSP AXIAL	In Service via APC
1	22	28	H01+.08	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
1	22	31	H01+.06	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
1	22	33	H02+.08	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
1	22	33	H02+.04	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
1	22	33	H02+.20	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
1	22	46	H04+.08	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
1	22	47	H02+.02	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
1	22	48	H01+.00	DSI	1.49	ODSCC TSP AXIAL	In Service via APC
1	22	48	H01+.14	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
1	22	48	H01+.21	SAI	0.22	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

1	22	48	H01+.23	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
1	22	50	H02-.20	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
1	22	67	H01+.18	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
1	22	68	H02+.03	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
1	22	72	H02-.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
1	23	7	H01+.00	DSI	1.47	ODSCC TSP AXIAL	In Service via APC
1	23	7	H01+.28	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
1	23	9	H01+.06	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
1	23	9	H02+.06	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
1	23	11	H02+.14	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
1	23	15	H01+.06	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
1	23	20	H02+.08	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
1	23	31	H01+.17	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
1	23	32	H04+.03	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
1	23	64	H03+.00	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
1	24	9	H01+.08	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
1	24	15	H01+.08	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
1	24	15	H01+.13	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
1	24	17	H02+.06	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
1	24	21	H01-.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
1	24	21	H02+.14	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
1	24	21	H02-.02	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
1	24	21	H03+.00	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	24	21	H04+.09	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
1	24	22	H01+.11	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
1	24	25	H01+.11	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
1	24	29	H01+.06	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
1	24	29	H02+.06	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
1	24	34	H01+.06	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
1	24	46	H01+.05	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
1	24	60	H01+.03	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
1	24	73	H03-.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
1	25	8	H01+.06	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
1	25	14	H02+.08	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
1	25	25	H01+.06	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
1	25	32	H01+.06	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
1	25	37	H01+.08	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	25	38	H02+.14	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
1	25	42	H02-.08	DSI	1.48	ODSCC TSP AXIAL	PLUGGED-Preventive
1	25	42	H02+.15	SAI	1.17	ODSCC TSP AXIAL	PLUGGED-Preventive
1	25	77	H02+.00	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
1	26	11	H01+.11	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
1	26	17	H01+.14	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
1	26	20	H02+.17	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
1	26	25	H04+.06	DSI	0.18	ODSCC TSP AXIAL	In Service via APC
1	26	30	H02+.08	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
1	26	54	H01-.03	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
1	26	54	H01+.12	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
1	26	63	C03+.12	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
1	26	64	H01+.03	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
1	26	64	H01+.19	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
1	26	64	H01+.22	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
1	26	64	H01+.23	SAI	0.08	ODSCC TSP AXIAL	In Service via APC
1	26	68	H03-.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
1	26	86	H03-.12	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
1	27	16	H02+.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

1	27	18	H01-.05	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
1	27	18	H02+.08	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
1	27	19	H03+.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
1	27	21	H02+.03	DSI	0.19	ODSCC TSP AXIAL	In Service via APC
1	27	24	H02+.08	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
1	27	31	H03+.14	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
1	27	48	H01-.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
1	27	48	H01+.14	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
1	27	48	H01+.20	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
1	27	48	H01+.24	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
1	27	48	H02-.03	DSI	1.38	ODSCC TSP AXIAL	In Service via APC
1	27	48	H02+.14	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
1	27	48	H02+.15	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
1	27	48	H02+.16	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
1	27	52	H01-.11	DSI	1.23	ODSCC TSP AXIAL	In Service via APC
1	27	52	H01+.09	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
1	27	52	H01+.12	SAI	0.42	ODSCC TSP AXIAL	In Service via APC
1	27	58	H01+.00	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
1	27	60	H01-.03	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
1	27	60	H01+.11	SAI	0.41	ODSCC TSP AXIAL	In Service via APC
1	27	82	H02+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
1	28	10	H02+.06	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
1	28	11	H01+.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	28	12	H01+.03	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
1	28	16	H01+.08	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
1	28	17	H04+.11	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
1	28	21	H03+.06	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
1	28	26	H02+.03	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
1	28	27	H02+.03	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
1	28	28	H04+.06	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
1	28	28	H06+.12	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
1	28	31	H02+.08	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
1	28	43	H02+.03	DSI	1.35	ODSCC TSP AXIAL	In Service via APC
1	28	43	H02+.08	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
1	28	43	H02+.28	SAI	0.33	ODSCC TSP AXIAL	In Service via APC
1	28	43	H02+.29	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
1	28	45	H02+.00	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
1	28	45	H02+.17	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
1	28	45	H02+.18	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
1	28	46	H02+.00	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
1	28	46	H02+.03	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
1	28	46	H06+.23	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
1	28	50	H02-.03	DSI	1.44	ODSCC TSP AXIAL	In Service via APC
1	28	50	H02+.16	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
1	28	50	H02+.17	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
1	28	56	H02-.09	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
1	28	77	H02-.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
1	28	79	H01-.06	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
1	28	79	H02+.00	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
1	29	50	H02+.00	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	29	52	H02+.05	DSI	1.36	ODSCC TSP AXIAL	In Service via APC
1	29	52	H02+.15	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
1	29	52	H02+.27	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
1	29	55	H02-.03	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
1	29	56	H03-.03	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
1	30	24	H06+.06	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
1	30	41	H02-.08	DSI	0.69	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

1	30	49	H02+.00	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
1	30	50	H01-.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
1	30	50	H03+.00	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	30	62	H02-.06	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
1	30	75	H03+.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
1	30	82	H01+.00	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
1	30	82	H02-.06	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
1	30	82	H03-.09	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
1	31	19	H02+.06	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
1	31	19	H03+.03	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
1	31	33	H02+.02	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
1	31	54	H02-.03	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
1	31	54	H02+.04	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
1	31	56	H04-.03	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
1	31	59	H04-.06	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
1	31	62	H03+.00	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
1	31	64	H03-.06	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
1	31	70	H04-.09	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
1	32	17	H02+.23	DSI	1.43	ODSCC TSP AXIAL	In Service via APC
1	32	17	H02+.16	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
1	32	40	H03+.13	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
1	32	42	H01+.07	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
1	32	42	H02+.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	32	44	H04+.08	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
1	32	48	H02+.05	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
1	32	49	H01+.03	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
1	32	52	H02+.00	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
1	32	53	H01+.13	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
1	32	53	H03-.05	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
1	32	54	H02-.03	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
1	32	54	H02+.04	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
1	32	59	H03+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
1	32	63	H03+.00	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
1	32	65	H04-.06	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
1	32	68	H01-.06	DSI	2	ODSCC TSP AXIAL	PLUGGED
1	32	68	H01+.30	SAI	1.11	ODSCC TSP AXIAL	PLUGGED
1	32	71	H03+.00	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
1	32	73	H02-.03	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
1	32	74	H03-.03	DSI	1.21	ODSCC TSP AXIAL	In Service via APC
1	32	77	H05-.09	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
1	32	79	H01-.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
1	33	17	H03+.23	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
1	33	17	H03+.00	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
1	33	17	H03+.18	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
1	33	27	H04+.09	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
1	33	42	H02+.03	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
1	33	43	H01+.08	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
1	33	50	H02+.08	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
1	33	67	H03-.15	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
1	33	67	H04-.03	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
1	33	71	H02-.06	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
1	33	72	H02-.12	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
1	33	75	H05+.06	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
1	34	22	H02-.03	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
1	34	28	H01+.03	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
1	34	30	H03+.00	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
1	34	74	H04-.03	DSI	0.35	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

1	35	17	H02+.03	DSI	1.16	ODSCC TSP AXIAL	In Service via APC
1	35	17	H02+.22	SAI	0.08	ODSCC TSP AXIAL	In Service via APC
1	35	17	H02+.30	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
1	35	17	H02+.31	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
1	35	17	H03+.28	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
1	35	17	H06+.06	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
1	35	19	H01+.06	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
1	35	19	H01-.01	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
1	35	19	H03-.06	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
1	35	19	H04+.09	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
1	35	21	H01+.11	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
1	35	21	H02+.08	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	35	21	H04+.03	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
1	35	22	H01+.08	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
1	35	22	H02+.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
1	35	22	H03+.03	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
1	35	23	H01+.17	DSI	1.28	ODSCC TSP AXIAL	In Service via APC
1	35	23	H01+.21	SAI	0.48	ODSCC TSP AXIAL	In Service via APC
1	35	23	H01+.27	SAI	0.41	ODSCC TSP AXIAL	In Service via APC
1	35	30	H01-.03	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
1	35	30	H01-.04	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
1	35	30	H01+.17	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
1	35	30	H02+.05	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
1	35	30	H03+.00	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
1	35	32	H01+.05	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
1	35	32	H03+.05	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
1	35	33	H02+.10	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
1	35	33	H03+.05	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
1	35	42	H02+.00	DSI	1.55	ODSCC TSP AXIAL	In Service via APC
1	35	42	H02+.10	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
1	35	44	H06+.08	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
1	35	47	H02+.08	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
1	36	25	H04+.06	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
1	36	35	H04+.05	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
1	36	42	H02-.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
1	36	47	H02+.13	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
1	36	54	H02+.03	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
1	36	62	H02-.03	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
1	36	62	H03-.06	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
1	36	62	H04+.12	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
1	37	32	H05+.03	DSI	0.15	ODSCC TSP AXIAL	In Service via APC
1	37	40	H01+.03	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
1	37	60	H05+.06	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
1	37	61	H02-.03	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
1	37	61	H02+.05	SAI	0.66	ODSCC TSP AXIAL	In Service via APC
1	37	61	H03-.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
1	38	24	H02-.17	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
1	38	40	H01+.10	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
1	38	46	H04+.03	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
1	38	51	H02+.10	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
1	38	63	H02-.06	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	38	64	H03+.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
1	38	65	H02-.06	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
1	38	65	H04-.09	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
1	39	27	H04+.11	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
1	39	30	H03+.00	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
1	39	30	H05+.00	DSI	0.47	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

1	39	36	H05+.08	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
1	39	40	H01+.10	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
1	39	46	H01+.05	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
1	39	55	C04+.09	DSI	0.21	ODSCC TSP AXIAL	In Service via APC
1	40	24	H01+.20	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
1	40	24	H01+.00	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
1	40	24	H01+.33	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
1	40	24	H02+.03	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
1	40	25	H01+.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
1	40	25	H02+.03	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
1	40	25	H04+.11	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
1	40	26	H01+.12	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
1	40	26	H04+.09	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
1	40	26	H05+.09	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
1	40	27	H02+.06	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
1	40	36	H03+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
1	40	51	H03-.03	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
1	40	70	H03-.09	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
1	41	37	H02+.13	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
1	42	40	H01+.05	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
1	42	40	H02+.03	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
1	42	40	H07-.13	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
1	42	49	H02+.05	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
1	42	62	H01-.03	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
1	43	38	H01+.10	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
1	43	46	H04+.11	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
1	43	59	H01-.09	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
1	43	59	H01+.16	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
1	44	37	H02-.03	DSI	1.5	ODSCC TSP AXIAL	In Service via APC
1	44	40	H02+.10	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
1	44	42	H02+.08	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
1	44	45	H02+.03	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
1	44	50	H02+.05	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
1	44	56	H03-.03	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
1	44	57	H01-.06	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
1	45	37	H02+.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	45	39	H01+.20	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
1	45	39	H06+.13	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
1	45	44	H03+.08	DSI	1.52	ODSCC TSP AXIAL	In Service via APC
1	45	47	H02+.13	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
1	45	47	H03+.13	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
1	45	47	H04+.11	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
1	45	49	H02+.10	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
1	45	51	H02+.08	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
1	45	51	H02+.21	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
1	45	51	H02+.23	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
1	45	55	H03-.12	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
1	46	41	H03+.15	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
1	46	50	H03+.05	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
2	1	76	H01-.06	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
2	2	2	H02+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
2	2	2	H02+.20	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	2	2	H05+.03	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
2	2	14	H02+.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
2	2	22	H02+.03	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
2	2	30	H02+.00	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
2	2	37	H02+.09	DSI	0.55	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	2	42	H01+.00	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
2	2	43	H02+.11	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
2	2	43	H02+.20	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
2	2	45	H02-.03	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
2	2	46	H02+.22	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
2	2	47	H05+.00	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
2	2	48	H01-.03	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
2	2	49	H01+.06	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
2	2	49	H02-.06	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	2	50	H02-.06	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
2	2	55	H01+.00	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
2	2	55	H02+.00	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
2	2	58	H01-.03	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
2	2	58	H01+.10	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	2	58	H01+.30	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
2	2	58	H02+.00	DSI	1.61	ODSCC TSP AXIAL	In Service via APC
2	2	58	H02+.08	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
2	2	58	H02+.13	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	2	58	H02+.28	SAI	0.33	ODSCC TSP AXIAL	In Service via APC
2	2	61	H02+.00	DSI	1.32	ODSCC TSP AXIAL	In Service via APC
2	2	61	H02+.02	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
2	2	61	H02+.20	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	2	61	H02+.24	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	2	62	H02+.00	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
2	2	63	H04+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
2	2	66	H02+.00	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
2	2	70	H02-.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
2	2	73	H01-.12	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
2	2	73	H02+.00	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
2	2	76	H02-.15	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
2	2	77	H01-.06	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
2	2	82	H04-.12	DSI	1.45	ODSCC TSP AXIAL	In Service via APC
2	2	82	H04+.05	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	2	82	H04+.20	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	2	83	H01-.15	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
2	2	83	H04+.06	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
2	2	84	H01+.03	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
2	2	85	H01-.09	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
2	2	85	H02+.00	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
2	2	85	H04-.03	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
2	2	87	H01+.03	DSI	1.2	ODSCC TSP AXIAL	In Service via APC
2	2	87	H01+.19	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	2	87	H01+.27	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	2	88	H01-.06	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
2	2	88	H02-.03	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
2	2	88	H02+.10	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
2	2	88	H02+.21	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
2	2	88	H03+.00	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
2	2	88	H06+.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
2	2	90	H01+.09	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
2	2	94	H01-.06	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
2	2	94	H02-.06	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
2	3	5	H02-.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
2	3	5	H03+.20	DSI	1.61	ODSCC TSP AXIAL	PLUGGED
2	3	5	H03+.30	SAI	0.19	ODSCC TSP AXIAL	PLUGGED
2	3	5	H04-.06	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
2	3	12	H04+.03	DSI	0.21	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	3	16	H02-.09	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
2	3	17	H02-.06	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
2	3	30	H02-.06	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
2	3	31	H01+.06	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
2	3	31	H02-.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	3	37	H02-.03	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
2	3	38	H05+.00	DSI	0.17	ODSCC TSP AXIAL	In Service via APC
2	3	42	H02+.00	DSI	1.73	ODSCC TSP AXIAL	In Service via APC
2	3	42	H02+.19	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
2	3	42	H02+.22	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
2	3	42	H04+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
2	3	49	H02-.12	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
2	3	51	H02-.03	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
2	3	61	H02+.00	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
2	3	61	H02+.11	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
2	3	61	H02+.34	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	3	62	H02-.03	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
2	3	72	H01+.03	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
2	3	72	H03+.00	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
2	3	76	H02+.15	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
2	3	88	H02+.09	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	3	92	H01+.09	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
2	4	1	H02-.03	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
2	4	1	H04-.06	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	4	22	H02+.09	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
2	4	26	H02+.06	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
2	4	27	H02+.03	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
2	4	29	H04+.00	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
2	4	36	H01-.03	DSI	1.13	ODSCC TSP AXIAL	In Service via APC
2	4	36	H01+.11	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
2	4	36	H01+.28	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	4	45	H02+.00	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
2	4	50	H01+.03	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
2	4	50	H02+.03	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
2	4	54	H02-.12	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
2	4	56	H02+.14	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
2	4	56	H02+.09	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	4	56	H02+.23	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	4	57	H01-.09	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
2	4	57	H04+.00	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
2	4	59	H01-.06	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
2	4	59	H01+.00	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	4	59	H01+.23	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
2	4	59	H02+.00	DSI	1.36	ODSCC TSP AXIAL	In Service via APC
2	4	59	H02-.08	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
2	4	61	H04+.00	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
2	4	64	H01+.00	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
2	4	91	H01+.00	DSI	1.3	ODSCC TSP AXIAL	In Service via APC
2	4	91	H01+.16	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
2	4	92	H03-.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
2	4	92	H04+.00	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	4	92	H05+.03	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
2	4	94	H01-.09	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
2	4	94	H02-.06	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
2	4	94	H02+.29	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
2	4	94	H02+.32	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
2	5	1	H02-.06	DSI	0.56	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	5	5	H04+.00	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	5	6	H02+.00	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
2	5	27	H01-.03	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
2	5	28	C04-.09	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
2	5	59	H02+.00	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
2	5	60	H01+.00	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
2	5	60	H04-.03	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
2	5	65	H01+.06	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	5	65	H02+.00	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
2	5	65	H02+.18	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	5	66	H02-.09	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
2	5	91	H01-.03	DSI	1.04	ODSCC TSP AXIAL	In Service via APC
2	5	91	H01+.23	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
2	5	92	H01+.06	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
2	5	93	H01+.00	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
2	5	94	C04+.00	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
2	5	94	H01-.09	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
2	6	1	H02-.03	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
2	6	3	H02+.00	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
2	6	4	H01+.00	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
2	6	13	H04+.00	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
2	6	16	H02+.00	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
2	6	24	H02+.06	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
2	6	38	H02-.09	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
2	6	39	H02-.03	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
2	6	40	H01+.03	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
2	6	43	H02-.14	DSI	1.48	ODSCC TSP AXIAL	In Service via APC
2	6	43	H02+.01	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
2	6	48	H01-.12	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
2	6	55	C02+.00	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
2	6	57	H02-.09	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
2	6	68	H06+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
2	6	70	H02-.06	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
2	6	84	H02+.00	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
2	6	90	H02-.03	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
2	6	90	H04+.00	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
2	6	94	H01+.00	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
2	7	1	H05-.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	7	2	H04-.03	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
2	7	4	H01+.03	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
2	7	4	H02+.06	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
2	7	7	H04+.03	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
2	7	9	H02-.06	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
2	7	9	H04-.06	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
2	7	10	H02+.00	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
2	7	10	H02+.34	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	7	12	H04-.03	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
2	7	13	H01-.09	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
2	7	13	H02-.03	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
2	7	17	H01+.06	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
2	7	17	H01+.00	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
2	7	17	H01+.24	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
2	7	20	H05+.14	DSI	1.59	ODSCC TSP AXIAL	PLUGGED
2	7	20	H05+.24	SAI	0.17	ODSCC TSP AXIAL	PLUGGED
2	7	21	H01-.03	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
2	7	21	H04+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
2	7	21	H04+.05	SAI	0.11	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	7	27	H01+.00	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
2	7	27	H01+.20	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
2	7	32	H03+.00	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
2	7	32	H03+.10	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
2	7	38	H02+.03	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
2	7	42	H04+.00	DSI	0.12	ODSCC TSP AXIAL	In Service via APC
2	7	43	H02-.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
2	7	44	H01+.00	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
2	7	44	H01+.16	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	7	57	H02+.00	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
2	7	58	H01-.03	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
2	7	67	H02-.03	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
2	7	68	H01-.06	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
2	7	68	H02-.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
2	7	71	H02-.03	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
2	7	72	H01-.06	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
2	7	89	H02+.00	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
2	7	89	H02+.18	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	7	91	H01+.00	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
2	8	3	H01+.17	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
2	8	3	H01+.11	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
2	8	3	H01+.20	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	8	11	H02+.00	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
2	8	13	H02+.03	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
2	8	34	H03-.03	DSI	0.21	ODSCC TSP AXIAL	In Service via APC
2	8	38	H02+.00	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
2	8	42	H02+.03	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
2	8	44	H01+.00	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
2	8	44	H01+.07	SAI	0.08	ODSCC TSP AXIAL	In Service via APC
2	8	44	H01+.12	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
2	8	45	H02-.03	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
2	8	47	H02+.00	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
2	8	51	H01+.00	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
2	8	51	H02+.03	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
2	8	60	H01-.06	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
2	8	61	H02+.00	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
2	8	62	H07+.11	DSI	0.14	ODSCC TSP AXIAL	In Service via APC
2	8	64	H02-.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
2	8	68	H02+.00	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
2	8	69	H01+.00	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
2	8	70	H03+.00	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
2	8	71	H01+.00	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
2	8	90	H01+.03	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
2	8	90	H02-.06	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
2	8	91	H01-.03	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
2	9	14	H02+.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
2	9	22	H02-.14	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
2	9	23	H02-.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
2	9	29	H04-.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
2	9	32	H01-.06	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
2	9	33	H01-.03	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
2	9	33	H01+.08	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
2	9	33	H01+.19	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
2	9	36	H02+.00	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
2	9	40	H02+.00	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
2	9	41	H02-.03	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
2	9	41	H02-.19	SAI	0.14	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	9	41	H02+.03	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	9	41	H05+.00	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
2	9	48	H02-.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
2	9	50	H04-.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
2	9	57	H02-.03	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
2	9	69	H02+.06	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
2	9	72	H01+.03	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
2	9	72	H02-.11	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	9	91	H01+.03	DSI	1.34	ODSCC TSP AXIAL	In Service via APC
2	9	91	H01+.15	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	10	4	H02+.00	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
2	10	18	C05+.14	DSI	1.3	ODSCC TSP AXIAL	In Service via APC
2	10	31	H01+.06	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
2	10	31	H02-.14	DSI	1.23	ODSCC TSP AXIAL	In Service via APC
2	10	31	H02+.01	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
2	10	31	H02+.12	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
2	10	31	H02+.15	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	10	31	H04+.09	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
2	10	32	H05+.09	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	10	89	H02+.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
2	10	89	H02+.22	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
2	11	21	H01+.09	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
2	11	25	H01+.09	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
2	11	25	H02+.12	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
2	11	57	H01-.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
2	11	63	H02-.03	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
2	11	65	H02+.09	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
2	11	67	H02-.06	DSI	1.68	ODSCC TSP AXIAL	In Service via APC
2	11	67	H02+.16	SAI	0.08	ODSCC TSP AXIAL	In Service via APC
2	11	75	H02-.03	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
2	11	88	H02+.00	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
2	11	91	C01-.12	DSI	0.2	ODSCC TSP AXIAL	In Service via APC
2	12	6	H02+.09	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
2	12	44	H02+.08	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
2	12	51	C03+.03	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
2	12	59	H01-.03	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
2	12	59	H02-.06	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
2	12	60	C02+.06	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
2	12	85	H02-.09	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
2	12	90	H02+.12	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
2	13	21	H02+.06	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
2	13	68	H01+.00	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
2	13	68	H02-.03	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
2	13	89	H01+.00	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
2	14	11	H02+.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
2	14	18	H02+.06	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
2	14	84	H01+.00	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
2	14	86	H01+.03	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
2	14	86	H01+.19	SAI	0.47	ODSCC TSP AXIAL	In Service via APC
2	14	90	H01+.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	14	90	H01+.12	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
2	14	90	H01+.16	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
2	15	5	H01-.03	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
2	15	5	H01+.23	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
2	15	5	H01+.24	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
2	15	5	H01+.28	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
2	15	32	H04+.06	DSI	0.56	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	15	36	H01+.06	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
2	15	40	H02-.14	DSI	1.16	ODSCC TSP AXIAL	In Service via APC
2	15	40	H02+.09	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
2	15	40	H02+.32	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
2	15	49	H01-.06	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
2	15	49	H02-.06	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
2	15	87	H01-.03	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
2	15	87	H02-.06	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	15	87	H02+.20	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
2	15	89	H01+.00	DSI	1.38	ODSCC TSP AXIAL	In Service via APC
2	15	89	H01+.06	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	15	89	H01+.09	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	15	89	H01+.21	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
2	15	89	H01+.23	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
2	15	89	H01+.25	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
2	15	89	H01+.36	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
2	16	11	H02+.03	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
2	16	33	H03+.06	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
2	16	41	C02+.00	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
2	16	48	H05-.21	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
2	16	48	H05-.06	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
2	16	60	H01-.03	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
2	16	80	H03+.03	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
2	17	41	H01+.08	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
2	17	49	H01-.06	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
2	17	77	C04+.18	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
2	17	86	H03+.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	18	7	H02+.18	DSI	1.61	ODSCC TSP AXIAL	In Service via APC
2	18	7	H02+.16	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
2	18	7	H02+.28	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	18	11	H01+.31	DSI	1.5	ODSCC TSP AXIAL	In Service via APC
2	18	11	H01+.16	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
2	18	11	H01+.35	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
2	18	14	H02+.12	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
2	18	22	H01-.06	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
2	18	56	H02-.06	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
2	19	15	H02+.03	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
2	19	22	H01+.06	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	19	22	H02+.03	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
2	19	61	H01+.00	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
2	19	63	H02+.00	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
2	19	68	H02-.09	DSI	0.18	ODSCC TSP AXIAL	In Service via APC
2	19	69	H01-.06	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
2	19	70	H02+.00	DSI	0.2	ODSCC TSP AXIAL	In Service via APC
2	20	10	H03-.03	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
2	20	22	H03+.06	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
2	20	33	H04+.09	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
2	20	43	H05+.03	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
2	20	44	H02+.09	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	20	49	H01-.06	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
2	20	49	H02+.00	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
2	20	52	H01+.03	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
2	20	52	H01+.31	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
2	20	56	H02-.03	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
2	20	57	H01-.03	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	20	58	H01-.09	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
2	20	62	H01-.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	20	64	H05+.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	20	65	H01-.09	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	20	89	H02+.00	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
2	21	9	H02+.03	DSI	1.04	ODSCC TSP AXIAL	In Service via APC
2	21	20	H02+.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	21	20	H02+.23	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
2	21	20	H02+.31	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
2	21	61	H01+.06	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
2	21	64	H01-.12	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
2	21	69	H01-.03	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
2	21	69	H01+.13	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
2	21	69	H01+.15	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	21	87	H01+.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
2	22	30	H02+.09	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
2	22	34	H01+.06	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
2	22	36	H04+.00	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
2	22	37	H05+.06	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	22	58	H01+.18	DSI	1.4	ODSCC TSP AXIAL	In Service via APC
2	22	58	H01+.24	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	22	58	H01+.37	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
2	22	68	H02-.03	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
2	22	69	H01-.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
2	22	73	H04-.03	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
2	23	17	H02+.06	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
2	23	22	H02+.12	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
2	23	44	H01+.17	DSI	1.32	ODSCC TSP AXIAL	In Service via APC
2	23	44	H01+.09	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
2	23	44	H05+.00	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
2	23	49	H01+.03	DSI	1.44	ODSCC TSP AXIAL	In Service via APC
2	23	49	H01+.28	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
2	23	49	H01+.35	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
2	23	55	H01+.00	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
2	23	70	H03-.09	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
2	23	72	H02-.03	DSI	0.19	ODSCC TSP AXIAL	In Service via APC
2	23	73	H02-.06	DSI	1.43	ODSCC TSP AXIAL	In Service via APC
2	23	73	H02+.11	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
2	23	73	H02+.26	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
2	23	74	H03-.06	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
2	23	85	H01-.09	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
2	23	85	H02+.00	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
2	23	86	H02+.12	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
2	24	37	H02+.09	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
2	24	37	H04+.23	DSI	1.14	ODSCC TSP AXIAL	In Service via APC
2	24	37	H04+.35	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
2	24	38	H02-.14	DSI	1.5	ODSCC TSP AXIAL	In Service via APC
2	24	38	H02+.34	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
2	24	43	H02+.23	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
2	24	43	H02+.32	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
2	24	43	H02+.35	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
2	24	50	H01-.09	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
2	24	60	H02-.03	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
2	24	60	H02+.21	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
2	24	87	H01-.03	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
2	24	87	H04+.00	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
2	25	9	H07-.06	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
2	25	22	H02+.09	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
2	25	22	H02+.00	SAI	0.1	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	25	22	H02+.14	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	25	22	H02+.26	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
2	25	43	H02+.00	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	25	56	H03+.13	DSI	1	ODSCC TSP AXIAL	In Service via APC
2	25	56	H03+.30	SAI	0.43	ODSCC TSP AXIAL	In Service via APC
2	25	66	H03+.00	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
2	25	68	H03-.09	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
2	25	72	H02+.00	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
2	25	72	H04+.06	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
2	26	11	C04-.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
2	26	17	H02+.09	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
2	26	17	H02+.09	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
2	26	18	H01+.29	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
2	26	59	H01-.03	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
2	26	59	H01+.08	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
2	26	59	H01+.29	SAI	0.41	ODSCC TSP AXIAL	In Service via APC
2	26	59	H01+.32	SAI	0.49	ODSCC TSP AXIAL	In Service via APC
2	26	59	H02+.00	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
2	26	59	H03-.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	27	53	H02+.00	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
2	27	68	H01+.00	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
2	27	68	H02+.00	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
2	27	84	H01+.00	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
2	27	84	H02-.03	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
2	28	12	H02+.09	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
2	28	17	H02+.06	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
2	28	60	H02-.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
2	28	60	H02+.33	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
2	28	66	H03+.00	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
2	28	69	H02-.03	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
2	28	73	H03-.06	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
2	28	79	H02+.00	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
2	29	16	H01+.26	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
2	29	16	H01+.20	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
2	29	16	H02+.12	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
2	29	17	H02+.03	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
2	29	20	H02+.09	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
2	29	21	H02+.06	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
2	29	45	H02+.06	DSI	0.21	ODSCC TSP AXIAL	In Service via APC
2	29	61	H02+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
2	29	61	H02+.36	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
2	29	61	H03+.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
2	29	67	H01+.03	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	29	79	H01+.03	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
2	29	79	H02-.06	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
2	30	16	H02+.09	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
2	30	17	H02+.09	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
2	30	19	H04+.00	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
2	30	20	H01+.14	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
2	30	20	H01+.23	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	30	20	H01+.24	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
2	30	21	H02+.06	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
2	30	22	H02+.09	DSI	1.18	ODSCC TSP AXIAL	In Service via APC
2	30	46	C02+.06	DSI	0.2	ODSCC TSP AXIAL	In Service via APC
2	30	54	H01+.12	DSI	1.39	ODSCC TSP AXIAL	In Service via APC
2	30	54	H01+.22	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
2	30	54	H01+.32	SAI	0.47	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	30	55	H01+.15	DSI	1.5	ODSCC TSP AXIAL	In Service via APC
2	30	55	H01+.35	SAI	0.43	ODSCC TSP AXIAL	In Service via APC
2	30	55	H05+.00	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
2	30	68	H02-.03	DSI	1.47	ODSCC TSP AXIAL	In Service via APC
2	30	68	H02+.06	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
2	30	68	H02+.30	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	30	68	H02+.36	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
2	30	70	H01-.03	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
2	30	74	H02-.03	DSI	1.52	ODSCC TSP AXIAL	In Service via APC
2	30	74	H02+.21	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
2	30	74	H02+.26	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	30	74	H02+.29	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
2	30	76	H02-.03	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
2	30	77	H02+.00	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
2	30	77	H03+.00	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
2	30	79	H02-.03	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
2	30	81	H01+.00	DSI	1.2	ODSCC TSP AXIAL	In Service via APC
2	30	81	H01+.03	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
2	30	81	H01+.22	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
2	30	81	H04-.03	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
2	30	82	H02+.03	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
2	30	83	H01-.09	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
2	30	83	H02-.03	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	31	25	H02+.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
2	31	38	H04+.00	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
2	31	39	H02+.06	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
2	31	47	H02-.03	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
2	31	48	H01-.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
2	31	66	H02+.00	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
2	31	67	H02+.03	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
2	31	67	H03+.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
2	31	70	H01+.00	DSI	1.29	ODSCC TSP AXIAL	In Service via APC
2	31	70	H01+.19	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
2	31	70	H01+.36	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
2	31	70	H02-.12	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
2	31	74	H01-.03	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
2	31	74	H02-.03	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
2	32	17	H05+.09	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
2	32	19	C01-.23	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
2	32	20	H01+.14	DSI	1.81	ODSCC TSP AXIAL	In Service via APC
2	32	20	H01+.08	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
2	32	20	H01+.25	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
2	32	20	H01+.31	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
2	32	20	H02+.00	DSI	1.35	ODSCC TSP AXIAL	In Service via APC
2	32	20	H02+.09	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	32	20	H02+.31	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	32	20	H02+.32	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	32	20	H02+.34	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
2	32	21	H02+.09	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	32	21	H02+.23	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
2	32	23	H02+.09	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
2	32	26	H01+.06	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
2	32	32	H01+.00	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	32	32	H01+.11	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
2	32	32	H01+.31	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	32	61	H02-.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
2	32	63	H01-.06	DSI	0.3	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	33	31	H02-.09	DSI	1.71	ODSCC TSP AXIAL	In Service via APC
2	33	31	H02+.13	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	33	31	H02+.14	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
2	33	31	H02+.15	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
2	33	50	H07+.09	DSI	0.2	ODSCC TSP AXIAL	In Service via APC
2	34	72	H01-.03	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
2	34	73	H01+.03	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
2	35	42	H02+.00	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
2	35	44	H02+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
2	35	45	H02+.06	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
2	35	58	H04+.06	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	35	59	H02-.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
2	35	61	H03+.00	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
2	35	72	H03-.03	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
2	35	75	H01+.06	DSI	0.18	ODSCC TSP AXIAL	In Service via APC
2	36	33	H02+.06	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
2	36	42	H01+.12	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
2	36	42	H02+.15	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
2	36	63	H02-.06	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
2	36	64	H01+.06	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
2	36	71	H01+.06	DSI	1.28	ODSCC TSP AXIAL	In Service via APC
2	36	71	H01+.23	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
2	36	71	H01+.26	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
2	36	71	H01+.27	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
2	36	71	H02+.00	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
2	36	71	H02+.28	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	36	74	H02-.03	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	36	75	H02+.00	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
2	37	20	H01+.12	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
2	37	20	H01+.06	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
2	37	20	H01+.15	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
2	37	20	H01+.29	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
2	37	23	C01-.29	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
2	37	26	H02+.11	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	37	55	H02+.00	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
2	37	66	H01-.09	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
2	38	25	H02+.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	38	26	H01+.11	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
2	38	28	H02+.06	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
2	38	32	H02+.14	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
2	38	33	H02+.23	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
2	38	33	H03+.12	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	38	33	H04+.06	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
2	38	45	H02-.13	DSI	1.41	ODSCC TSP AXIAL	In Service via APC
2	38	45	H02+.01	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	38	45	H02+.02	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
2	38	45	H02+.22	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	38	45	H03+.05	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
2	38	49	H02+.06	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
2	38	53	H02+.00	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
2	38	59	H02+.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	38	66	H01-.03	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
2	38	74	H04-.03	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
2	39	25	H01+.06	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
2	39	25	H02+.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
2	39	31	H02+.09	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
2	39	37	H02+.06	DSI	0.55	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	39	38	H02+.11	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
2	39	38	H02+.31	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
2	39	40	H02+.06	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
2	39	55	H02-.03	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
2	39	58	H04+.03	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
2	39	59	H02-.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	39	62	H02-.06	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
2	39	70	H02+.06	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
2	40	29	H02+.09	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
2	40	29	H02+.09	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	40	31	H02+.03	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
2	40	37	H02+.06	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
2	40	40	H03+.14	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
2	40	41	H03-.11	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
2	40	42	C02+.03	DSI	0.18	ODSCC TSP AXIAL	In Service via APC
2	40	48	H05+.03	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
2	40	55	C02+.06	DSI	0.17	ODSCC TSP AXIAL	In Service via APC
2	40	57	H02+.00	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	40	60	H02-.12	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
2	40	64	H01-.09	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	41	34	H02+.06	DSI	1.37	ODSCC TSP AXIAL	In Service via APC
2	41	37	H02+.11	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
2	41	37	H04+.08	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
2	41	39	H02+.09	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
2	41	41	H04+.14	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
2	41	41	H04+.31	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
2	41	43	H02+.00	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
2	41	43	H02+.21	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
2	41	43	H03+.06	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
2	41	50	H01+.22	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
2	41	50	H02+.14	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
2	41	54	H01-.03	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
2	41	54	H02+.00	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
2	41	54	H03+.03	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
2	41	55	H03+.00	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
2	41	67	H01-.03	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
2	41	69	H01+.03	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
2	42	34	H02+.09	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
2	42	37	H05+.09	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
2	42	43	H03+.11	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	42	50	H02-.06	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
2	42	51	H02+.06	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
2	42	61	H01+.18	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
2	42	66	H06-.06	DSI	1.56	ODSCC TSP AXIAL	In Service via APC
2	42	67	H06+.06	DSI	1.57	ODSCC TSP AXIAL	In Service via APC
2	43	38	H02+.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
2	43	43	H02-.06	DSI	1	ODSCC TSP AXIAL	In Service via APC
2	43	43	H02+.19	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
2	43	43	H03+.06	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
2	43	44	H03+.06	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
2	43	47	H02+.06	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
2	43	49	H02+.00	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
2	43	50	H01+.31	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
2	43	50	H02+.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	43	52	H01+.31	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
2	43	52	H01+.33	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
2	43	52	H01+.34	SAI	0.23	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

2	43	52	H02+.09	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
2	43	52	H02+.01	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
2	43	52	H03+.17	DSI	0.2	ODSCC TSP AXIAL	In Service via APC
2	43	53	H04+.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
2	43	54	H04+.00	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
2	43	65	C01-.09	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
2	44	39	H02+.06	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
2	44	40	C01+.37	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	44	44	H02+.06	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
2	44	45	H02+.09	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
2	44	52	H02+.08	DSI	1.55	ODSCC TSP AXIAL	In Service via APC
2	44	52	H02+.06	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
2	44	52	H02+.11	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
2	44	52	H02+.25	SAI	0.07	ODSCC TSP AXIAL	In Service via APC
2	45	39	H03+.09	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
2	45	39	H04+.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
2	45	42	H02+.00	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
2	45	48	H02+.09	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
2	45	49	H03+.06	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
2	45	51	H02+.03	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
2	45	52	H01-.06	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
2	45	52	H02+.00	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
2	45	54	H02+.00	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
2	45	54	H02+.18	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
2	45	54	H02+.21	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
2	45	55	C01-.22	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
2	45	56	C01-.19	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
2	46	50	H02+.00	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
3	1	74	C01-.06	DSI	2.17	ODSCC TSP AXIAL	In Service via APC
3	1	76	H03+.18	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
3	1	79	H02-.12	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
3	1	79	H03+.15	DSI	1.47	ODSCC TSP AXIAL	In Service via APC
3	1	82	C01-.03	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
3	1	84	H03-.06	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
3	2	16	H01+.00	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
3	2	25	H02-.09	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
3	2	25	H03-.02	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	2	31	H01+.12	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
3	2	31	H03+.01	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
3	2	32	H01+.00	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	2	33	H01+.12	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	2	35	H01-.06	DSI	1	ODSCC TSP AXIAL	In Service via APC
3	2	35	H01+.18	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	2	38	H02+.01	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
3	2	38	H04+.03	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
3	2	39	H02+.01	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
3	2	58	C01+.12	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
3	2	73	H02-.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	2	79	H01-.03	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
3	3	1	H01+.21	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
3	3	1	H02-.03	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
3	3	2	H01+.00	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
3	3	2	H03+.00	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
3	3	5	H01-.03	DSI	1.38	ODSCC TSP AXIAL	In Service via APC
3	3	5	H01+.06	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
3	3	5	H05+.03	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
3	3	10	H01+.09	DSI	1.65	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	3	10	H01+.29	SAI	0.53	ODSCC TSP AXIAL	In Service via APC
3	3	16	H03+.12	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
3	3	19	H01+.24	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
3	3	23	H01+.06	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
3	3	24	H02+.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
3	3	29	H01+.03	DSI	1.45	ODSCC TSP AXIAL	In Service via APC
3	3	29	H01+.26	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
3	3	34	H01+.00	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
3	3	34	H05-.06	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	3	49	H02-.03	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
3	3	51	H02+.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
3	3	94	H02+.12	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	3	94	H04-.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	4	25	H02+.00	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
3	4	25	H02+.23	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	4	26	H01-.15	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
3	4	27	H01-.05	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
3	4	34	H01-.03	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
3	4	39	H01+.15	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
3	4	46	H01-.08	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
3	4	48	H01+.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
3	4	50	H01-.09	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
3	4	50	H05-.03	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
3	4	51	H01-.03	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
3	4	55	H01+.03	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
3	4	55	H02+.00	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
3	4	55	H02+.32	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
3	4	60	H02-.03	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
3	4	60	H02+.22	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
3	4	60	H02+.23	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	5	1	H01-.03	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
3	5	1	H01+.35	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	5	1	H02-.03	DSI	1.52	ODSCC TSP AXIAL	In Service via APC
3	5	4	H01+.00	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
3	5	4	H01+.25	SAI	0.73	ODSCC TSP AXIAL	In Service via APC
3	5	4	H01+.29	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
3	5	4	H02+.06	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
3	5	4	H03+.00	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
3	5	5	H02+.03	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
3	5	5	H03+.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
3	5	10	H01+.03	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
3	5	12	H01+.00	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
3	5	17	H02+.00	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
3	5	18	H01-.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
3	5	22	H01-.03	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
3	5	22	H01+.13	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	5	22	H01+.14	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	5	85	C01-.03	DSI	0.15	ODSCC TSP AXIAL	In Service via APC
3	6	1	H01-.06	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
3	6	5	H01+.12	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
3	6	10	H01+.00	DSI	1.25	ODSCC TSP AXIAL	In Service via APC
3	6	10	H01+.20	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	6	11	H01+.03	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	6	30	H01+.06	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
3	6	30	H01+.01	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
3	6	30	H01+.22	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	6	30	H01+.31	SAI	0.12	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	6	37	H02-.03	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
3	6	38	H01+.00	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
3	6	38	H01+.26	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	6	38	H02+.06	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
3	6	38	H03+.00	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
3	6	40	H05-.06	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
3	6	50	H01+.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
3	6	77	H02-.06	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
3	6	79	H02+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
3	6	79	H03-.03	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	7	1	H02+.00	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
3	7	14	H01+.00	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
3	7	14	H01+.21	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
3	7	14	H02-.06	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
3	7	24	H02+.03	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
3	7	25	H01+.00	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
3	7	25	H02+.00	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
3	7	29	H01+.03	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
3	7	29	H01+.15	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	7	29	H01+.21	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
3	7	29	H01+.24	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	7	35	H03+.00	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
3	7	38	H02+.00	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
3	7	42	H04-.06	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
3	7	56	H01-.12	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
3	7	56	H02+.18	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
3	7	58	H02+.06	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
3	7	58	H02+.30	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
3	7	60	H01-.12	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
3	7	61	H01+.06	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	7	64	H01-.08	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	7	70	H01-.05	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
3	7	71	H01+.02	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
3	7	71	H02+.01	DSI	1.52	ODSCC TSP AXIAL	In Service via APC
3	7	71	H02+.24	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
3	7	71	H02+.28	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
3	7	71	H03+.01	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
3	7	72	H01+.02	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
3	7	72	H02+.00	DSI	1.16	ODSCC TSP AXIAL	In Service via APC
3	7	73	H02-.02	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
3	7	81	H06-.09	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
3	7	91	H02-.05	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
3	7	92	H01-.11	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	7	92	H03+.05	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
3	7	93	H01-.03	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
3	7	93	H02+.00	DSI	1.45	ODSCC TSP AXIAL	In Service via APC
3	7	93	H02+.12	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
3	7	93	H03-.08	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	7	94	H03-.06	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	8	6	H03-.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
3	8	7	H03+.03	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
3	8	7	H03+.23	SAI	0.33	ODSCC TSP AXIAL	In Service via APC
3	8	15	H02+.03	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	8	18	H03+.00	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
3	8	18	H05+.00	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
3	8	22	H03+.03	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
3	8	24	H03+.00	DSI	0.56	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	8	28	H01-.03	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
3	8	49	H01+.06	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
3	8	49	H01+.14	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	8	50	H01-.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
3	8	51	H01-.15	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
3	8	52	H01-.21	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
3	8	55	H02-.03	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
3	8	57	H04-.06	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
3	8	59	H01-.09	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
3	8	63	H01-.03	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
3	8	63	H02-.15	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
3	8	63	H02+.11	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
3	8	63	H02+.17	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
3	8	64	H01-.09	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
3	8	67	H02-.06	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
3	8	69	H01-.03	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
3	8	69	H01+.15	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	8	70	H03-.06	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
3	8	70	H05+.20	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	9	4	H01+.00	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
3	9	4	H01+.26	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	9	5	H01+.03	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
3	9	5	H01+.21	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
3	9	6	H01+.15	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
3	9	7	H01+.00	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	9	8	H01-.03	DSI	1.24	ODSCC TSP AXIAL	In Service via APC
3	9	8	H01+.30	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
3	9	10	H03+.03	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
3	9	11	H01+.00	DSI	1.21	ODSCC TSP AXIAL	In Service via APC
3	9	11	H01+.30	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
3	9	12	H01-.06	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
3	9	13	H02+.00	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
3	9	13	H05-.03	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
3	9	14	H01-.03	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
3	9	14	H01+.16	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	9	14	H01+.24	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	9	14	H01+.28	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
3	9	15	H03-.03	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
3	9	16	H01+.00	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
3	9	20	H02-.06	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	9	21	H02+.03	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
3	9	21	H02+.15	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	9	21	H02+.22	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
3	9	23	H03-.03	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
3	9	23	H03+.06	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	9	40	H02-.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	9	41	H01+.06	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
3	9	48	H01+.03	DSI	1.6	ODSCC TSP AXIAL	In Service via APC
3	9	48	H01+.13	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	9	48	H01+.25	SAI	0.49	ODSCC TSP AXIAL	In Service via APC
3	9	48	H01+.32	SAI	0.5	ODSCC TSP AXIAL	In Service via APC
3	9	48	H02-.11	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
3	9	48	H02-.06	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	9	50	H01+.06	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	9	51	H01+.11	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
3	9	51	H01+.23	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	9	52	H01-.18	DSI	0.23	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	10	5	H01+.17	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
3	10	6	H03+.28	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
3	10	14	H01-.03	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
3	10	42	C03+.06	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
3	11	5	H03+.00	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	11	6	H01+.03	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
3	11	11	H01+.14	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
3	11	11	H01-.10	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	11	11	H01+.27	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
3	11	11	H01+.32	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
3	11	16	H03+.03	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
3	11	16	H06+.06	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
3	11	17	H02+.09	DSI	1.3	ODSCC TSP AXIAL	In Service via APC
3	11	17	H02+.10	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	11	17	H02+.19	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	11	19	H02+.06	DSI	1.35	ODSCC TSP AXIAL	In Service via APC
3	11	27	H01+.03	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
3	11	36	H01+.09	DSI	1.66	ODSCC TSP AXIAL	In Service via APC
3	11	36	H01+.29	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
3	11	37	H01+.12	DSI	1.38	ODSCC TSP AXIAL	In Service via APC
3	11	37	H01-.13	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	11	37	H01+.23	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
3	11	37	H01+.24	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	11	46	H02+.03	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
3	11	46	H02+.12	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	12	22	H02+.11	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
3	12	27	H01+.00	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
3	12	35	H01+.03	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
3	12	35	H01+.28	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
3	12	35	H02+.03	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
3	12	35	H03+.12	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
3	12	38	H01+.09	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
3	12	58	H05+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
3	13	3	H01+.12	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
3	13	3	H01+.03	SAI	0.07	ODSCC TSP AXIAL	In Service via APC
3	13	3	H01+.07	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	13	3	H01+.18	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	13	3	H01+.19	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	13	3	H02+.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
3	13	5	H03+.06	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
3	13	7	H01+.06	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
3	13	9	H01+.09	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
3	13	10	H02+.11	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
3	13	17	H02+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
3	13	24	H01+.05	DSI	1.29	ODSCC TSP AXIAL	In Service via APC
3	13	24	H01-.02	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	13	24	H01+.21	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
3	13	24	H02+.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
3	13	29	H01+.00	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
3	13	29	H02-.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
3	13	29	H02+.24	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
3	13	30	H01+.06	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
3	13	36	H01+.03	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
3	13	36	H01+.14	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	13	44	H02+.00	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
3	13	53	H01-.03	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
3	13	54	H01+.06	DSI	0.61	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	14	3	H03+.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	14	4	H01+.08	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
3	14	6	H03+.06	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
3	14	11	H03+.06	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
3	14	14	H01+.14	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
3	14	16	H05+.11	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
3	14	18	H01+.03	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
3	14	18	H01+.09	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	14	18	H01+.18	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	14	18	H04+.11	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
3	14	20	H02+.03	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
3	14	21	H02+.00	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
3	14	26	H06+.06	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
3	14	39	H01-.09	DSI	1.87	ODSCC TSP AXIAL	In Service via APC
3	14	39	H01-.10	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	14	39	H01-.08	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
3	14	39	H01+.00	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	14	39	H01+.04	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	14	39	H01+.23	SAI	0.42	ODSCC TSP AXIAL	In Service via APC
3	14	39	H01+.26	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
3	14	39	H01+.29	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
3	14	39	H03+.03	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
3	14	39	H04-.03	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	14	41	H01+.11	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
3	14	41	H02+.12	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	14	52	H01+.03	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
3	14	79	H02+.00	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
3	15	3	H01+.15	DSI	1.21	ODSCC TSP AXIAL	In Service via APC
3	15	3	H01+.23	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	15	3	H01+.34	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
3	15	3	H02+.03	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
3	15	3	H02-.07	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	15	3	H03+.00	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
3	15	6	H01+.08	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
3	15	6	H02-.06	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
3	15	15	H01+.09	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
3	15	16	H01+.00	DSI	1.04	ODSCC TSP AXIAL	In Service via APC
3	15	16	H01+.24	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	15	16	H01+.27	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
3	15	18	H02+.00	DSI	1.44	ODSCC TSP AXIAL	In Service via APC
3	15	18	H02+.13	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	15	26	H01+.05	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
3	15	29	H02+.03	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
3	15	30	H01+.09	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
3	15	33	H03+.03	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
3	15	33	H04-.09	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
3	15	36	H02+.03	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
3	15	37	H01+.03	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
3	15	39	H01+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
3	15	43	H01+.00	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
3	15	43	H02+.09	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
3	15	71	H05+.06	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
3	16	4	H01+.00	DSI	1.81	ODSCC TSP AXIAL	In Service via APC
3	16	4	H01+.36	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	16	4	H02+.08	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
3	16	5	H04+.00	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
3	16	21	H01+.06	DSI	1.24	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	16	21	H01+.27	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	16	21	H02+.03	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
3	16	22	H01+.08	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
3	16	24	H01+.03	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
3	16	40	H01+.00	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
3	16	41	H01+.09	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
3	16	54	H01-.06	DSI	1	ODSCC TSP AXIAL	In Service via APC
3	16	54	H01+.10	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	17	6	H02+.00	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
3	17	11	H01+.23	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
3	17	12	H01+.22	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
3	17	13	H01+.11	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
3	17	20	H01+.16	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
3	17	22	H01+.11	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
3	17	22	H01+.21	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
3	17	37	H01+.09	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
3	17	39	H02+.06	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
3	17	40	H01+.00	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
3	17	40	H01+.13	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	17	47	H01-.03	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
3	17	50	H01-.06	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
3	17	53	H01+.03	DSI	1.24	ODSCC TSP AXIAL	In Service via APC
3	17	53	H01+.24	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	17	82	H05+.00	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
3	17	87	H01+.03	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
3	17	87	H04-.15	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
3	18	8	H01+.03	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	18	18	H01+.06	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
3	18	21	H01+.09	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
3	18	35	H01+.03	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
3	18	35	H01+.33	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
3	18	35	H01+.34	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	18	37	H01+.09	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
3	18	37	H01+.08	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	18	37	H01+.30	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
3	18	37	H02-.06	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
3	18	38	H01+.09	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
3	18	38	H01+.15	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
3	18	38	H01+.25	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
3	18	38	H01+.36	SAI	0.37	ODSCC TSP AXIAL	In Service via APC
3	18	45	H01+.09	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
3	18	45	H03+.09	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
3	18	53	H05-.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	18	81	H03+.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
3	18	89	H01+.00	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
3	19	6	H01+.06	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
3	19	10	H01+.08	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
3	19	12	H02-.20	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
3	19	13	H01+.11	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
3	19	13	H01-.10	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
3	19	13	H01+.15	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	19	13	H01+.20	SAI	0.34	ODSCC TSP AXIAL	In Service via APC
3	19	13	H01+.25	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	19	13	H01+.27	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
3	19	13	H01+.36	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
3	19	13	H03+.09	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
3	19	17	H01+.12	DSI	0.6	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	19	22	H01+.08	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
3	19	22	H02+.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
3	19	37	H01+.09	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
3	19	37	H01+.24	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	19	37	H01+.25	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	19	39	H01+.14	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
3	19	69	H07-.09	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
3	20	6	H01+.09	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
3	20	12	H01+.17	DSI	1.42	ODSCC TSP AXIAL	In Service via APC
3	20	12	H01+.30	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	20	12	H01+.31	SAI	0.4	ODSCC TSP AXIAL	In Service via APC
3	20	12	H01+.34	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
3	20	19	H01+.03	DSI	1.34	ODSCC TSP AXIAL	In Service via APC
3	20	19	H01+.23	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	20	19	H01+.25	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
3	20	19	H01+.30	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	20	19	H01+.31	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	20	26	H02+.06	DSI	1.04	ODSCC TSP AXIAL	In Service via APC
3	20	26	H02-.15	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	20	26	H02+.06	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	20	28	H01+.17	DSI	1.51	ODSCC TSP AXIAL	In Service via APC
3	20	28	H01+.21	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
3	20	28	H01+.28	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	20	29	H01+.00	DSI	1.82	ODSCC TSP AXIAL	In Service via APC
3	20	29	H01+.20	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	20	29	H01+.28	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	20	29	H01+.29	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
3	20	29	H01+.31	SAI	0.45	ODSCC TSP AXIAL	In Service via APC
3	20	30	H01+.14	DSI	1	ODSCC TSP AXIAL	In Service via APC
3	20	30	H01+.21	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
3	20	30	H01+.24	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
3	20	30	H01+.27	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
3	20	31	H01+.12	DSI	1.31	ODSCC TSP AXIAL	In Service via APC
3	20	31	H01+.22	SAI	0.37	ODSCC TSP AXIAL	In Service via APC
3	20	31	H01+.23	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
3	20	31	H01+.24	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
3	20	31	H03+.15	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
3	20	32	H01+.12	DSI	1.93	ODSCC TSP AXIAL	In Service via APC
3	20	32	H01+.20	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
3	20	32	H01+.25	SAI	0.42	ODSCC TSP AXIAL	In Service via APC
3	20	32	H01+.28	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	20	35	H01+.12	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	20	35	H02+.03	DSI	1.86	ODSCC TSP AXIAL	In Service via APC
3	20	35	H02-.11	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	20	35	H02+.24	SAI	0.54	ODSCC TSP AXIAL	In Service via APC
3	20	35	H02+.35	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
3	20	35	H03+.00	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
3	20	37	H01+.12	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
3	20	39	H01-.03	DSI	1.3	ODSCC TSP AXIAL	In Service via APC
3	20	39	H01-.04	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	20	39	H01+.07	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
3	20	39	H01+.23	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	20	47	H01+.11	DSI	1.29	ODSCC TSP AXIAL	In Service via APC
3	20	47	H01+.31	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	20	50	H02-.15	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
3	20	71	H03+.03	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
3	20	79	H02-.03	DSI	0.34	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	20	80	H03+.00	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
3	20	80	H06+.00	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
3	20	85	H03+.00	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
3	20	86	H01+.00	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
3	20	88	H01-.06	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
3	20	89	H01+.03	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	21	15	H02+.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	21	20	H02+.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
3	21	24	H01+.00	DSI	1.41	ODSCC TSP AXIAL	In Service via APC
3	21	24	H01+.25	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
3	21	24	H01+.31	SAI	0.53	ODSCC TSP AXIAL	In Service via APC
3	21	41	H01+.00	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
3	21	81	H02-.06	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
3	21	81	H03+.00	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
3	21	84	H04+.00	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
3	21	88	H01+.03	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
3	21	89	H03-.03	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
3	22	7	H01+.06	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
3	22	7	H01+.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
3	22	21	H01+.12	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
3	22	23	H01+.09	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	22	26	H02+.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
3	22	28	H02+.00	DSI	1.48	ODSCC TSP AXIAL	In Service via APC
3	22	28	H02+.13	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	22	29	H01+.09	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
3	22	38	H01+.18	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
3	22	40	H01-.09	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
3	22	52	H01+.00	DSI	1.23	ODSCC TSP AXIAL	In Service via APC
3	22	52	H01+.30	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	22	61	H03-.06	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
3	22	68	H02+.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
3	23	13	H01+.11	DSI	1.57	ODSCC TSP AXIAL	In Service via APC
3	23	13	H01+.21	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	23	13	H01+.29	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	23	13	H01+.33	SAI	0.59	ODSCC TSP AXIAL	In Service via APC
3	23	14	H03+.08	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
3	23	22	H01+.27	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
3	23	26	H02-.21	DSI	1.39	ODSCC TSP AXIAL	In Service via APC
3	23	26	H02+.20	SAI	0.07	ODSCC TSP AXIAL	In Service via APC
3	23	26	H02+.29	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	23	30	H01+.06	DSI	1.25	ODSCC TSP AXIAL	In Service via APC
3	23	30	H01+.23	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	23	30	H01+.24	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	23	30	H01+.28	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	23	30	H01+.30	SAI	0.42	ODSCC TSP AXIAL	In Service via APC
3	23	38	H01+.03	DSI	1.54	ODSCC TSP AXIAL	In Service via APC
3	23	38	H01+.31	SAI	0.57	ODSCC TSP AXIAL	In Service via APC
3	23	44	H01-.06	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
3	23	51	H04-.15	DSI	2.01	ODSCC TSP AXIAL	PLUGGED
3	23	51	H04+.30	SAI	1.01	ODSCC TSP AXIAL	PLUGGED
3	23	60	H02-.03	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
3	23	75	H03+.00	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
3	24	10	H01+.06	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
3	24	12	H01+.11	DSI	1.58	ODSCC TSP AXIAL	In Service via APC
3	24	12	H01+.22	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	24	12	H01+.23	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	24	12	H01+.28	SAI	0.31	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	24	12	H01+.29	SAI	0.37	ODSCC TSP AXIAL	In Service via APC
3	24	12	H01+.30	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	24	12	H02+.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
3	24	13	H02+.09	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
3	24	16	H01+.11	DSI	1.28	ODSCC TSP AXIAL	In Service via APC
3	24	16	H01+.32	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
3	24	16	H01+.33	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
3	24	16	H02+.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
3	24	19	H01+.06	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
3	24	21	H03+.12	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
3	24	21	H05+.00	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
3	24	23	H02+.12	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
3	24	23	H03-.03	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
3	24	25	H01+.09	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
3	24	29	H01+.00	DSI	1.64	ODSCC TSP AXIAL	In Service via APC
3	24	29	H01+.10	SAI	0.06	ODSCC TSP AXIAL	In Service via APC
3	24	29	H01+.22	SAI	0.38	ODSCC TSP AXIAL	In Service via APC
3	24	29	H01+.25	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	24	35	H01+.00	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
3	25	8	H01+.12	DSI	1.94	ODSCC TSP AXIAL	In Service via APC
3	25	8	H01+.29	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	25	8	H01+.30	SAI	0.07	ODSCC TSP AXIAL	In Service via APC
3	25	8	H01+.31	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
3	25	8	H01+.32	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	25	14	H04+.09	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
3	25	18	H01+.06	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
3	25	18	H01+.25	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
3	25	18	H01+.26	SAI	0.53	ODSCC TSP AXIAL	In Service via APC
3	25	21	H01+.14	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
3	25	24	H01+.00	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
3	25	24	H02+.08	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
3	25	26	H02+.06	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
3	25	26	H02+.29	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
3	25	35	H01+.17	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
3	25	49	H01-.06	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	25	52	H02-.06	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
3	25	72	H02+.00	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
3	25	81	H02+.03	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
3	26	9	H01+.14	DSI	1.23	ODSCC TSP AXIAL	In Service via APC
3	26	9	H01+.35	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
3	26	12	H01+.00	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
3	26	14	H01+.03	DSI	1.9	ODSCC TSP AXIAL	In Service via APC
3	26	14	H01+.26	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
3	26	14	H01+.28	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	26	14	H01+.30	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	26	14	H01+.34	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	26	16	H02+.08	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
3	26	17	H02+.03	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
3	26	17	H02+.03	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	26	17	H02+.17	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
3	26	17	H02+.26	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	26	20	H02+.11	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
3	26	22	H04+.09	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	26	22	H05+.09	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
3	26	22	H06+.06	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
3	26	23	H01+.23	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
3	26	24	H01+.06	DSI	0.42	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	26	25	H02+.06	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
3	26	25	H02+.32	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
3	26	27	H01+.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
3	26	28	H01+.03	DSI	1.81	ODSCC TSP AXIAL	In Service via APC
3	26	28	H01+.18	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	26	28	H01+.29	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	26	28	H01+.30	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
3	26	29	H01-.09	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
3	26	29	H03-.09	DSI	1.35	ODSCC TSP AXIAL	In Service via APC
3	26	29	H03-.06	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	26	29	H03-.03	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	26	29	H03+.26	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	26	30	H02+.00	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
3	26	35	H01+.03	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
3	26	35	H01+.27	SAI	0.4	ODSCC TSP AXIAL	In Service via APC
3	26	81	H02-.09	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
3	26	81	H02+.09	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	27	15	H01+.03	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
3	27	16	H01+.08	DSI	2.04	ODSCC TSP AXIAL	PLUGGED
3	27	16	H01+.24	SAI	0.14	ODSCC TSP AXIAL	PLUGGED
3	27	16	H01+.28	SAI	0.14	ODSCC TSP AXIAL	PLUGGED
3	27	16	H02+.06	DSI	1.14	ODSCC TSP AXIAL	In Service via APC
3	27	16	H02+.03	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	27	16	H02+.31	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	27	18	H01+.08	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
3	27	18	H03+.14	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	27	24	H02+.11	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
3	27	26	H01+.08	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
3	27	26	H02+.03	DSI	1.31	ODSCC TSP AXIAL	In Service via APC
3	27	26	H02+.11	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	27	26	H02+.12	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	27	26	H02+.30	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	27	26	H02+.32	SAI	0.34	ODSCC TSP AXIAL	In Service via APC
3	27	27	H01+.23	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
3	27	29	H01+.12	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
3	27	29	H02+.06	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
3	27	30	H02+.06	DSI	1.29	ODSCC TSP AXIAL	In Service via APC
3	27	30	H02+.18	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	27	30	H02+.22	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
3	27	30	H02+.35	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	27	35	H01+.03	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
3	27	35	H01+.23	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	27	35	H01+.34	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
3	27	36	H02+.00	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
3	27	60	H02+.03	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
3	27	63	H02+.00	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
3	27	63	H03-.03	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
3	27	67	H02-.03	DSI	0.2	ODSCC TSP AXIAL	In Service via APC
3	27	68	H02-.03	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
3	27	68	H05+.00	DSI	0.18	ODSCC TSP AXIAL	In Service via APC
3	27	69	H04-.09	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
3	27	79	H02+.00	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
3	27	79	H06+.00	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
3	27	85	H02+.00	DSI	0.14	ODSCC TSP AXIAL	In Service via APC
3	28	14	H01+.08	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
3	28	14	H01+.13	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	28	26	H01+.00	DSI	1.64	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	28	26	H01+.13	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
3	28	26	H01+.17	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
3	28	27	H03+.09	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	28	84	H01+.00	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
3	29	14	H01+.03	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
3	29	14	H01-.06	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	29	14	H01+.05	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	29	14	H01+.16	SAI	0.08	ODSCC TSP AXIAL	In Service via APC
3	29	14	H01+.20	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	29	14	H01+.24	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	29	23	H05+.06	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
3	29	35	H01+.09	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
3	29	50	H03-.03	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
3	29	79	C03+.15	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
3	30	18	H01+.28	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
3	30	21	H01+.03	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
3	30	23	H01+.23	DSI	1.56	ODSCC TSP AXIAL	In Service via APC
3	30	23	H01+.21	SAI	0.49	ODSCC TSP AXIAL	In Service via APC
3	30	23	H01+.22	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	30	23	H01+.27	SAI	0.63	ODSCC TSP AXIAL	In Service via APC
3	30	42	H02+.06	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
3	30	42	H03+.00	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
3	30	46	H02+.00	DSI	1.3	ODSCC TSP AXIAL	In Service via APC
3	30	46	H02+.20	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
3	30	46	H03+.09	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
3	30	50	H01-.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
3	30	50	H01+.31	SAI	0.34	ODSCC TSP AXIAL	In Service via APC
3	30	50	H03-.03	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
3	30	59	H06+.00	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	31	14	H03+.03	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
3	31	20	H01-.03	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	31	25	H02+.09	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
3	31	26	H02+.06	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
3	31	26	H03+.06	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
3	31	28	H01+.00	DSI	1.85	ODSCC TSP AXIAL	In Service via APC
3	31	28	H01+.05	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	31	28	H01+.24	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
3	31	28	H01+.26	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	31	28	H04-.22	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
3	31	30	H01+.00	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
3	31	32	H02+.09	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
3	31	32	H02+.22	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	31	42	H02+.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	31	65	H02+.00	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
3	31	76	H01+.00	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
3	31	76	H02+.00	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
3	32	20	H01+.00	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
3	32	21	H01+.09	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
3	32	23	H01+.00	DSI	1.99	ODSCC TSP AXIAL	In Service via APC
3	32	23	H01+.28	SAI	0.37	ODSCC TSP AXIAL	In Service via APC
3	32	25	H02+.14	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
3	32	29	H01+.09	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
3	32	33	H02+.09	DSI	1.29	ODSCC TSP AXIAL	In Service via APC
3	32	33	H02+.19	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	32	33	H02+.30	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	32	34	H02+.17	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
3	32	34	H03+.00	DSI	1.34	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	32	34	H03+.15	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
3	32	42	H02+.00	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
3	32	42	H02+.30	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
3	32	48	H02+.00	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
3	32	54	H01+.15	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	32	54	H02-.06	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
3	32	57	H03-.12	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	32	76	H03-.06	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
3	32	76	H03+.08	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	32	77	H01+.00	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
3	32	78	H01+.03	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
3	33	25	H04+.06	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
3	33	27	H01+.18	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
3	33	31	H03+.09	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
3	33	36	H02+.03	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
3	33	36	H02+.13	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	33	36	H02+.15	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	33	36	H02+.20	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	33	36	H03+.00	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
3	33	40	H01+.03	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
3	33	40	H01+.15	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
3	33	44	H01+.09	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
3	33	45	H02+.17	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
3	33	49	H01+.06	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
3	33	49	H02+.09	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	33	49	H02+.04	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	33	49	H03+.12	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
3	33	67	H04-.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
3	33	70	H02-.03	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
3	34	19	H02+.03	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
3	34	19	H03+.03	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
3	34	22	H01+.03	DSI	1.77	ODSCC TSP AXIAL	In Service via APC
3	34	22	H01+.19	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
3	34	22	H01+.21	SAI	0.08	ODSCC TSP AXIAL	In Service via APC
3	34	22	H01+.23	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
3	34	22	H01+.24	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
3	34	22	H01+.26	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
3	34	25	H01+.00	DSI	1.44	ODSCC TSP AXIAL	In Service via APC
3	34	25	H01+.12	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
3	34	25	H01+.34	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
3	34	25	H03+.17	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
3	34	25	H04+.06	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
3	34	26	H01+.08	DSI	2.15	ODSCC TSP AXIAL	PLUGGED
3	34	26	H01+.20	SAI	0.8	ODSCC TSP AXIAL	PLUGGED
3	34	26	H01+.28	SAI	0.17	ODSCC TSP AXIAL	PLUGGED
3	34	26	H01+.29	SAI	0.13	ODSCC TSP AXIAL	PLUGGED
3	34	27	H03+.03	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
3	34	28	H04+.03	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
3	34	29	H01+.00	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
3	34	30	H01+.06	DSI	2.04	ODSCC TSP AXIAL	PLUGGED
3	34	30	H01+.32	SAI	0.13	ODSCC TSP AXIAL	PLUGGED
3	34	36	H03+.06	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
3	34	51	H02+.06	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
3	34	60	H04-.06	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
3	34	61	H01+.15	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
3	34	61	H03-.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
3	34	61	H04-.09	DSI	0.48	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	34	61	H04+.30	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
3	34	72	H01-.06	DSI	0.2	ODSCC TSP AXIAL	In Service via APC
3	34	72	H02+.00	DSI	1.32	ODSCC TSP AXIAL	In Service via APC
3	34	72	H02+.12	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
3	34	72	H02+.22	SAI	0.52	ODSCC TSP AXIAL	In Service via APC
3	35	21	H01+.12	DSI	1.35	ODSCC TSP AXIAL	In Service via APC
3	35	21	H01+.16	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
3	35	21	H01+.24	SAI	0.5	ODSCC TSP AXIAL	In Service via APC
3	35	23	H01+.12	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
3	35	24	H03+.08	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
3	35	27	H01+.09	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
3	35	44	H03+.12	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
3	35	47	H02+.03	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
3	35	47	H03+.11	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
3	35	47	H04+.14	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
3	35	55	H02-.09	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
3	35	58	H02+.06	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
3	35	58	H02+.02	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
3	35	58	H02+.25	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	35	58	H05-.18	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
3	36	21	C02-.21	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	36	24	H01+.03	DSI	1.41	ODSCC TSP AXIAL	In Service via APC
3	36	24	H01+.18	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
3	36	24	H01+.21	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	36	25	H02+.03	DSI	1.36	ODSCC TSP AXIAL	In Service via APC
3	36	31	H03+.06	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
3	36	31	H05+.12	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
3	36	33	H03+.06	DSI	1.2	ODSCC TSP AXIAL	In Service via APC
3	36	38	H02+.06	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
3	36	40	H04+.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
3	36	42	H04+.09	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
3	36	48	H02+.11	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
3	36	53	H03+.03	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
3	36	68	H02+.00	DSI	0.21	ODSCC TSP AXIAL	In Service via APC
3	37	21	C01+.23	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
3	37	23	H01-.06	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
3	37	26	H02+.03	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
3	37	26	H02+.12	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	37	27	H02+.06	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	37	28	H02+.00	DSI	1.27	ODSCC TSP AXIAL	In Service via APC
3	37	28	H02+.18	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	37	31	H01+.09	DSI	1.04	ODSCC TSP AXIAL	In Service via APC
3	37	31	H01-.18	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	37	31	H03+.03	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
3	37	42	H03+.09	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
3	37	66	H04-.09	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
3	37	67	H02-.09	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	37	68	H02-.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
3	38	22	H01+.16	DSI	2.27	ODSCC TSP AXIAL	PLUGGED
3	38	22	H01+.11	SAI	0.09	ODSCC TSP AXIAL	PLUGGED
3	38	22	H01+.21	SAI	0.16	ODSCC TSP AXIAL	PLUGGED
3	38	22	H01+.29	SAI	0.33	ODSCC TSP AXIAL	PLUGGED
3	38	22	H01+.34	SAI	0.15	ODSCC TSP AXIAL	PLUGGED
3	38	22	H01+.37	SAI	0.59	ODSCC TSP AXIAL	PLUGGED
3	38	25	H01+.20	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
3	38	25	H03+.15	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
3	38	29	H01+.09	DSI	0.8	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	38	29	H02+.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	38	32	H06+.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
3	38	36	H02+.03	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
3	38	40	H03+.06	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
3	38	40	H03+.32	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
3	38	42	H03+.06	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
3	38	44	H03+.12	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
3	38	46	H02+.09	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
3	38	46	H02-.01	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	38	46	H02+.05	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
3	38	58	H02-.06	DSI	1.71	ODSCC TSP AXIAL	In Service via APC
3	38	58	H03+.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
3	38	58	H04+.00	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
3	38	58	H05+.00	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
3	39	26	H01-.06	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
3	39	26	H01+.33	SAI	0.45	ODSCC TSP AXIAL	In Service via APC
3	39	26	H01+.34	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
3	39	26	H02-.03	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
3	39	26	H02+.15	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	39	26	H03+.09	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
3	39	48	H02+.14	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
3	39	68	H04+.00	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
3	39	71	H02-.03	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
3	40	24	H02+.00	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
3	40	24	H02+.33	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
3	40	24	H03+.06	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
3	40	25	H01+.06	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
3	40	25	H02+.06	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
3	40	25	H02+.26	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
3	40	25	H03+.03	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
3	40	41	H03+.06	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
3	40	43	H02-.17	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
3	40	62	H03-.03	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
3	40	67	H02-.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	40	69	H02-.12	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
3	41	30	H01+.06	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
3	41	30	H03+.06	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
3	41	33	H02+.06	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
3	41	36	H04+.06	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
3	41	39	H02+.06	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
3	41	68	H02+.00	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
3	42	33	H01+.03	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
3	42	43	H04+.12	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
3	42	53	H07-.14	DSI	1.53	ODSCC TSP AXIAL	PLUGGED
3	42	53	H07+.01	SAI	0.11	ODSCC TSP AXIAL	PLUGGED
3	42	63	H01+.00	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
3	43	36	H01+.12	DSI	1.33	ODSCC TSP AXIAL	In Service via APC
3	43	36	H01+.18	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
3	43	36	H01+.27	SAI	0.09	ODSCC TSP AXIAL	In Service via APC
3	43	36	H01+.32	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
3	43	44	H04+.12	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
3	43	47	H05+.09	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
3	43	50	H04+.11	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
3	43	59	H01-.06	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
3	44	33	H01+.09	DSI	1.32	ODSCC TSP AXIAL	In Service via APC
3	44	33	H01+.30	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	44	33	H01+.32	SAI	0.23	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

3	44	52	H02+.08	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
3	44	52	H02+.10	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
3	44	52	H02+.13	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
3	44	52	H02+.31	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
3	44	58	H01+.03	DSI	1.46	ODSCC TSP AXIAL	In Service via APC
3	44	58	H01+.09	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
3	44	58	H01+.11	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
3	44	58	H01+.14	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
3	44	58	H02-.09	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
3	44	58	H02+.23	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
3	44	58	H03-.06	DSI	0.19	ODSCC TSP AXIAL	In Service via APC
3	44	58	H03-.07	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
3	44	58	H03+.07	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
3	44	59	H01+.09	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
3	44	59	H01+.35	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
3	44	59	H02-.03	DSI	1.91	ODSCC TSP AXIAL	In Service via APC
3	44	59	H02+.19	SAI	0.07	ODSCC TSP AXIAL	In Service via APC
3	45	39	C04-.09	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
3	45	42	H02+.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
3	45	53	C03-.06	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
3	46	52	H01+.11	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
3	46	52	H02+.17	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
3	46	52	H03+.09	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	1	82	H01+.17	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	1	85	H01+.20	DSI	1.33	ODSCC TSP AXIAL	In Service via APC
4	2	9	C04+.00	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	2	9	H03+.03	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	2	14	H03-.11	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	2	15	H02+.00	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	2	15	H03+.03	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
4	2	25	H01-.06	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	2	38	H02+.14	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	2	38	H03+.06	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	2	47	H01+.00	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
4	2	53	H01+.06	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	2	53	H02+.15	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	2	53	H02+.21	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	2	53	H02+.27	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	2	54	H02-.03	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	2	54	H05-.09	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	2	55	H01+.03	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
4	2	55	H01+.14	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	2	55	H01+.25	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
4	2	56	H03+.15	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
4	2	57	H01+.12	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	2	57	H03+.26	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
4	2	58	H01+.00	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	2	64	H02+.03	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	2	67	H01+.06	DSI	1.48	ODSCC TSP AXIAL	In Service via APC
4	2	67	H01+.20	SAI	0.4	ODSCC TSP AXIAL	In Service via APC
4	2	67	H01+.30	SAI	0.51	ODSCC TSP AXIAL	In Service via APC
4	2	72	H02+.00	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
4	2	74	H01-.15	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	2	74	H02-.15	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
4	2	74	H02+.04	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	2	74	H02+.11	SAI	0.44	ODSCC TSP AXIAL	In Service via APC
4	2	75	H01-.03	DSI	0.52	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	2	76	H01+.09	DSI	1.63	ODSCC TSP AXIAL	In Service via APC
4	2	76	H01+.14	SAI	0.62	ODSCC TSP AXIAL	In Service via APC
4	2	76	H01+.27	SAI	0.52	ODSCC TSP AXIAL	In Service via APC
4	2	76	H01+.28	SAI	0.48	ODSCC TSP AXIAL	In Service via APC
4	2	84	H01+.15	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	2	84	H02-.03	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
4	2	85	H01-.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	2	85	H02+.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	2	86	H02+.00	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	2	88	H03-.03	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	2	90	H01-.06	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
4	2	92	H01+.00	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	2	94	H01+.00	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	3	16	H02+.09	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	3	16	H04-.17	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	3	18	H01+.06	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	3	18	H02-.03	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	3	18	H02+.00	SAI	0.69	ODSCC TSP AXIAL	In Service via APC
4	3	19	H02+.06	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	3	21	H02+.14	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	3	22	H02-.09	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	3	25	H01+.12	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	3	25	H02-.14	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
4	3	25	H03+.06	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	3	28	H03+.00	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
4	3	30	H01+.00	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	3	34	H02+.00	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	3	35	C03-.03	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	3	43	H01+.00	DSI	1.26	ODSCC TSP AXIAL	PLUGGED-Preventive
4	3	43	H01+.30	SAI	0.97	ODSCC TSP AXIAL	PLUGGED-Preventive
4	3	71	H01-.06	DSI	1.23	ODSCC TSP AXIAL	In Service via APC
4	3	71	H01+.20	SAI	0.58	ODSCC TSP AXIAL	In Service via APC
4	3	71	H02+.09	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	3	81	H02+.00	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	3	87	H01+.00	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	3	87	H02+.00	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
4	3	88	H01+.00	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
4	3	88	H02+.00	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	3	89	H02+.00	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	3	90	H01-.03	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	3	90	H02+.00	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	3	91	H01+.00	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	3	92	H01+.00	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	3	93	H02+.00	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
4	3	94	H01+.00	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	4	3	H02+.03	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	4	8	H03-.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	4	8	H05-.06	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	4	8	H06-.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	4	12	H02+.06	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	4	13	H02+.14	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	4	13	H02+.23	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
4	4	13	H03-.17	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
4	4	14	H03-.03	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	4	14	H06-.06	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	4	18	H01-.11	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	4	19	H02+.06	DSI	0.66	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	4	22	H02+.09	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	4	23	H01+.14	DSI	1.04	ODSCC TSP AXIAL	In Service via APC
4	4	23	H01+.30	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	4	25	H01+.00	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	4	27	H01-.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	4	27	H03+.00	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	4	28	H01+.00	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	4	28	H04-.03	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	4	28	H06+.03	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	4	30	H03+.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	4	40	H01+.00	DSI	1.18	ODSCC TSP AXIAL	In Service via APC
4	4	40	H01+.23	SAI	0.66	ODSCC TSP AXIAL	In Service via APC
4	4	41	H01-.08	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	4	47	H02+.00	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	4	74	H03-.03	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
4	4	77	H01+.00	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	4	78	H01+.03	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	4	78	H02-.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	4	80	H04+.03	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	4	82	H01+.06	DSI	1.51	ODSCC TSP AXIAL	In Service via APC
4	4	82	H01+.19	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	4	82	H01+.22	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
4	4	82	H02-.03	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	4	84	H02-.06	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	4	86	H03+.03	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
4	4	86	H03+.09	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	4	87	H01+.17	DSI	1.16	ODSCC TSP AXIAL	In Service via APC
4	4	87	H01+.02	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	4	87	H01+.21	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	4	87	H01+.30	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	4	87	H03-.06	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	4	87	H05-.03	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	4	88	H02+.06	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
4	4	88	H03-.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	4	89	H03+.06	DSI	1.13	ODSCC TSP AXIAL	In Service via APC
4	4	89	H03+.19	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	4	90	H01+.17	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
4	4	90	H01+.14	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	4	90	H01+.28	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
4	4	90	H01+.32	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	4	90	H02+.00	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
4	4	90	H03+.00	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	4	90	H06+.00	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	4	91	H01+.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	4	91	H02+.00	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	4	92	H03+.06	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
4	4	92	H03+.25	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	4	93	H02+.17	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	4	94	H01-.03	DSI	1.33	ODSCC TSP AXIAL	In Service via APC
4	4	94	H01+.17	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	4	94	H01+.26	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	5	1	H01-.09	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
4	5	1	H02-.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	5	1	H05-.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	5	26	H01-.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	5	28	H01-.03	DSI	1.28	ODSCC TSP AXIAL	In Service via APC
4	5	28	H01+.22	SAI	0.23	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	5	28	H01+.24	SAI	0.38	ODSCC TSP AXIAL	In Service via APC
4	5	28	H02-.20	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	5	29	H01+.06	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	5	29	H02+.03	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	5	29	H04-.14	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	5	30	H01-.03	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
4	5	30	H01-.01	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	5	30	H01+.20	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	5	30	H01+.21	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	5	32	H03+.00	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	5	33	H01+.09	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
4	5	34	H01-.08	DSI	1.33	ODSCC TSP AXIAL	In Service via APC
4	5	34	H01+.18	SAI	0.85	ODSCC TSP AXIAL	In Service via APC
4	5	35	H01-.09	DSI	1.14	ODSCC TSP AXIAL	In Service via APC
4	5	35	H01+.21	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	5	35	H01+.27	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
4	5	36	H01+.06	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	5	37	H01-.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	5	37	H02+.00	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	5	38	H01+.00	DSI	1.21	ODSCC TSP AXIAL	In Service via APC
4	5	38	H01+.10	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	5	38	H01+.23	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	5	39	H01+.03	DSI	1.37	ODSCC TSP AXIAL	In Service via APC
4	5	39	H01+.26	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	5	39	H01+.36	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	5	41	H01+.06	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	5	42	H01+.00	DSI	1.44	ODSCC TSP AXIAL	In Service via APC
4	5	42	H01+.10	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	5	42	H01+.16	SAI	0.08	ODSCC TSP AXIAL	In Service via APC
4	5	42	H01+.17	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	5	43	H01-.11	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	5	43	H02+.00	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	5	43	H02+.24	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	5	43	H03+.00	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	5	44	H01-.09	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
4	5	46	H01+.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	5	46	H03+.09	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	5	47	H01-.03	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	5	53	H01+.00	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	5	63	H01+.03	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	5	69	H01+.00	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	5	71	H01+.03	DSI	1.31	ODSCC TSP AXIAL	In Service via APC
4	5	71	H01+.06	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	5	71	H01+.19	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	5	71	H01+.26	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	5	72	H01+.06	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	5	73	H01+.06	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	5	74	H01-.14	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	5	75	H03+.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	5	76	H01-.11	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	5	77	H01+.00	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	5	78	H02-.09	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	5	79	H01+.06	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	5	80	H01+.03	DSI	1.43	ODSCC TSP AXIAL	In Service via APC
4	5	80	H01+.03	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	5	80	H01+.23	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	5	80	H01+.29	SAI	0.16	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	5	82	H01+.17	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	5	83	H01+.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	5	83	H01+.14	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	5	83	H01+.23	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	5	87	H04-.11	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
4	5	88	H02+.00	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
4	5	89	H01-.11	DSI	1.39	ODSCC TSP AXIAL	In Service via APC
4	5	89	H01+.10	SAI	0.33	ODSCC TSP AXIAL	In Service via APC
4	5	89	H01+.26	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	5	91	H01+.00	DSI	1.24	ODSCC TSP AXIAL	In Service via APC
4	5	91	H01+.10	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	5	91	H03+.03	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	5	92	H01+.06	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	5	92	H03+.06	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	5	93	H01+.09	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
4	5	93	H01+.26	SAI	0.43	ODSCC TSP AXIAL	In Service via APC
4	5	93	H01+.34	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	6	2	H02-.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	6	8	H01+.00	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	6	18	H03-.06	DSI	1.12	ODSCC TSP AXIAL	PLUGGED-Preventive
4	6	18	H03+.26	SAI	0.85	ODSCC TSP AXIAL	PLUGGED-Preventive
4	6	23	H02+.00	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
4	6	23	H02+.15	SAI	0.07	ODSCC TSP AXIAL	In Service via APC
4	6	23	H02+.32	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	6	24	H01+.00	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	6	25	H02-.12	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	6	28	H01-.03	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	6	30	H01+.00	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	6	32	H02+.09	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	6	38	H02+.00	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	6	39	H02+.03	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	6	42	H01-.03	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	6	45	H01+.06	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	6	47	H01-.03	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	6	66	H01+.00	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
4	6	68	H01-.03	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	6	69	H01-.09	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
4	6	72	H01-.06	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	6	73	H01+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	6	74	H01+.06	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
4	6	74	H01+.20	SAI	0.57	ODSCC TSP AXIAL	In Service via APC
4	6	75	H01+.09	DSI	1	ODSCC TSP AXIAL	In Service via APC
4	6	75	H01+.23	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	6	76	H01-.03	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	6	78	H01+.03	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	6	80	H01+.00	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
4	6	80	H01+.18	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	6	81	H02+.00	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	6	84	H01+.14	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	6	87	H02+.00	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	6	87	H03+.00	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	6	88	H01+.03	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
4	6	88	H01+.21	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	6	88	H02-.03	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	6	90	H01+.14	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	6	90	H02+.00	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	6	90	H03-.03	DSI	0.78	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	6	90	H04+.00	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
4	6	91	H01-.03	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
4	6	91	H01+.30	SAI	0.55	ODSCC TSP AXIAL	In Service via APC
4	6	91	H02-.06	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
4	6	92	H01+.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	6	94	H03-.03	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	7	18	H02-.03	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	7	22	H02-.03	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	7	33	H03+.00	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
4	7	46	H01+.00	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	7	47	H01+.06	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	7	48	H01-.03	DSI	1.85	ODSCC TSP AXIAL	In Service via APC
4	7	48	H01+.27	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
4	7	48	H01+.28	SAI	0.66	ODSCC TSP AXIAL	In Service via APC
4	7	54	H01+.00	DSI	1.2	ODSCC TSP AXIAL	In Service via APC
4	7	55	H01+.00	DSI	1.59	ODSCC TSP AXIAL	In Service via APC
4	7	55	H01+.15	SAI	0.61	ODSCC TSP AXIAL	In Service via APC
4	7	55	H01+.28	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	7	55	H01+.33	SAI	0.6	ODSCC TSP AXIAL	In Service via APC
4	7	56	H01-.11	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
4	7	57	H01+.00	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	7	58	H01-.09	DSI	1.23	ODSCC TSP AXIAL	In Service via APC
4	7	58	H01+.18	SAI	0.67	ODSCC TSP AXIAL	In Service via APC
4	7	59	H01+.03	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
4	7	59	H01+.15	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	7	59	H01+.23	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	7	61	H03-.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	7	61	H03+.15	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	7	62	H01-.06	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	7	64	H01+.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	7	68	H01+.00	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	8	2	H02+.00	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	8	2	H02+.19	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	8	2	H02+.22	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	8	2	H02+.33	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	8	4	H02-.03	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	8	4	H02+.07	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	8	4	H02+.13	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
4	8	4	H02+.23	SAI	0.07	ODSCC TSP AXIAL	In Service via APC
4	8	5	H02+.12	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	8	8	H02-.09	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	8	12	H01+.14	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	8	12	H03+.00	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	8	13	H01+.00	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	8	13	H05-.09	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	8	16	H03+.00	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	8	17	H02+.17	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
4	8	19	H01-.03	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	8	21	H02-.14	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	8	25	H01+.09	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	8	25	H04-.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	8	25	H04+.05	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	8	27	H01-.15	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	8	27	H02+.18	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	8	27	H03-.24	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
4	8	28	H01-.03	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	8	29	H01+.06	DSI	0.84	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	8	29	H02-.03	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	8	30	H01+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	8	31	H01+.09	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	8	31	H03+.03	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	8	33	H01+.00	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
4	8	34	H01+.09	DSI	1.66	ODSCC TSP AXIAL	In Service via APC
4	8	34	H01+.05	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
4	8	34	H01+.29	SAI	0.56	ODSCC TSP AXIAL	In Service via APC
4	8	34	H01+.30	SAI	0.34	ODSCC TSP AXIAL	In Service via APC
4	8	35	H01-.08	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	8	35	H04-.14	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
4	8	36	H01-.23	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
4	8	36	H02-.03	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
4	8	37	H01+.06	DSI	2.06	ODSCC TSP AXIAL	PLUGGED
4	8	37	H01+.22	SAI	0.22	ODSCC TSP AXIAL	PLUGGED
4	8	37	H01+.27	SAI	0.13	ODSCC TSP AXIAL	PLUGGED
4	8	37	H01+.33	SAI	0.39	ODSCC TSP AXIAL	PLUGGED
4	8	38	H01-.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	8	39	H01+.00	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
4	8	39	H01-.04	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	8	39	H01+.20	SAI	0.52	ODSCC TSP AXIAL	In Service via APC
4	8	39	H03+.00	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	8	40	H01+.08	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	8	41	H01+.06	DSI	1.43	ODSCC TSP AXIAL	In Service via APC
4	8	41	H01+.19	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
4	8	41	H04-.17	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	8	42	H01+.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	8	42	H01+.03	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	8	42	H01+.07	SAI	0.07	ODSCC TSP AXIAL	In Service via APC
4	8	42	H01+.09	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	8	42	H01+.19	SAI	0.4	ODSCC TSP AXIAL	In Service via APC
4	8	42	H03+.00	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	8	43	H01-.03	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
4	8	43	H04-.08	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	8	44	H02-.03	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	8	44	H03+.00	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	8	45	H01-.09	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
4	8	47	H01-.12	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
4	8	48	H01+.00	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
4	8	50	H01+.03	DSI	1	ODSCC TSP AXIAL	In Service via APC
4	8	50	H01+.18	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	8	50	H01+.20	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	8	52	H01-.14	DSI	1.28	ODSCC TSP AXIAL	In Service via APC
4	8	52	H01+.11	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	8	52	H01+.16	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	8	52	H01+.21	SAI	0.42	ODSCC TSP AXIAL	In Service via APC
4	8	55	H01+.03	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	8	56	H01+.03	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	8	58	H01-.09	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	8	59	H01-.06	DSI	1.24	ODSCC TSP AXIAL	In Service via APC
4	8	59	H01+.02	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	8	59	H01+.12	SAI	0.45	ODSCC TSP AXIAL	In Service via APC
4	8	59	H01+.14	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	8	60	H01-.09	DSI	1.54	ODSCC TSP AXIAL	In Service via APC
4	8	60	H01+.08	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	8	60	H01+.11	SAI	0.41	ODSCC TSP AXIAL	In Service via APC
4	8	60	H01+.12	SAI	0.13	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	8	62	H01+.06	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	8	67	H03+.03	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	8	70	H01+.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	8	71	H01+.03	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
4	8	71	H04-.09	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	8	73	H03+.06	DSI	1	ODSCC TSP AXIAL	In Service via APC
4	8	73	H03+.22	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	8	76	H03+.00	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	8	77	H02+.09	DSI	1.31	ODSCC TSP AXIAL	In Service via APC
4	8	78	H01+.09	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
4	8	78	H03-.14	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	8	79	H05-.03	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
4	8	80	H01+.00	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	8	80	H02-.23	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	8	81	H01-.03	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	8	81	H02+.09	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	8	82	H01+.03	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	8	82	H01+.02	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	8	82	H01+.26	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	8	83	H01-.14	DSI	1.65	ODSCC TSP AXIAL	In Service via APC
4	8	83	H01+.18	SAI	0.47	ODSCC TSP AXIAL	In Service via APC
4	8	83	H01+.21	SAI	0.48	ODSCC TSP AXIAL	In Service via APC
4	8	84	H02-.06	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	8	85	H01+.03	DSI	1.35	ODSCC TSP AXIAL	In Service via APC
4	8	85	H01+.04	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	8	85	H01+.25	SAI	0.51	ODSCC TSP AXIAL	In Service via APC
4	8	85	H02+.09	DSI	1.79	ODSCC TSP AXIAL	In Service via APC
4	8	85	H02+.08	SAI	0.48	ODSCC TSP AXIAL	In Service via APC
4	8	85	H02+.28	SAI	0.49	ODSCC TSP AXIAL	In Service via APC
4	8	86	H01+.00	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
4	8	89	H01+.09	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
4	8	89	H01+.14	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	8	89	H01+.20	SAI	0.37	ODSCC TSP AXIAL	In Service via APC
4	8	89	H02+.00	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	8	89	H03+.00	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	8	90	H02+.03	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	8	91	H02-.09	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	8	91	H03+.03	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	8	92	H01+.06	DSI	1.76	ODSCC TSP AXIAL	In Service via APC
4	8	92	H01+.26	SAI	0.59	ODSCC TSP AXIAL	In Service via APC
4	8	92	H02+.03	DSI	1.29	ODSCC TSP AXIAL	In Service via APC
4	8	92	H02+.30	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
4	8	92	H02+.33	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	8	92	H03+.00	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	8	92	H04-.06	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
4	8	93	H03+.14	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	9	2	H02+.00	DSI	1.21	ODSCC TSP AXIAL	In Service via APC
4	9	2	H02+.03	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	9	10	H02-.09	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	9	11	H01+.06	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	9	11	H03+.00	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	9	12	H01+.00	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	9	13	H01+.11	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	9	15	H01+.06	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	9	15	H06-.03	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
4	9	16	H02-.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	9	18	H02+.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	9	19	H02+.09	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	9	21	H02+.11	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	9	22	H02+.00	DSI	1.28	ODSCC TSP AXIAL	In Service via APC
4	9	22	H02+.30	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	9	22	H02+.33	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	9	23	H01-.26	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	9	23	H02-.06	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	9	24	H01-.06	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
4	9	25	H01+.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	9	28	H02-.17	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	9	29	H01-.03	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	9	30	H01+.03	DSI	1.3	ODSCC TSP AXIAL	In Service via APC
4	9	30	H01+.29	SAI	0.83	ODSCC TSP AXIAL	In Service via APC
4	9	30	H01+.34	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
4	9	31	H01-.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	9	33	H01-.11	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	9	33	H02+.00	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
4	9	34	H01-.20	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	9	35	H01-.17	DSI	1.42	ODSCC TSP AXIAL	In Service via APC
4	9	35	H01+.16	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
4	9	36	H01-.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	9	36	H02-.14	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	9	37	H01+.11	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	9	37	H02-.17	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	9	38	H01-.06	DSI	1.53	ODSCC TSP AXIAL	In Service via APC
4	9	38	H01+.06	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
4	9	38	H01+.09	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	9	38	H01+.15	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
4	9	39	H01+.08	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	9	40	H02+.03	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	9	42	H01+.08	DSI	1.65	ODSCC TSP AXIAL	In Service via APC
4	9	42	H01+.15	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	9	42	H01+.20	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	9	42	H01+.25	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	9	42	H01+.26	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	9	43	H01+.00	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
4	9	43	H01+.15	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	9	43	H01+.24	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	9	43	H01+.26	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
4	9	43	H02-.17	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	9	44	H01+.06	DSI	1.16	ODSCC TSP AXIAL	In Service via APC
4	9	44	H01+.22	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	9	44	H01+.24	SAI	0.41	ODSCC TSP AXIAL	In Service via APC
4	9	44	H01+.27	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	9	46	H01+.00	DSI	3.62	ODSCC TSP AXIAL	PLUGGED
4	9	46	H01+.17	SAI	0.23	ODSCC TSP AXIAL	PLUGGED
4	9	46	H01+.30	SAI	0.18	ODSCC TSP AXIAL	PLUGGED
4	9	46	H01+.31	SAI	2.53	ODSCC TSP AXIAL	PLUGGED
4	9	46	H03-.09	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
4	9	46	H04-.03	DSI	0.19	ODSCC TSP AXIAL	In Service via APC
4	9	46	H06+.00	DSI	0.18	ODSCC TSP AXIAL	In Service via APC
4	9	47	H01-.12	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	9	47	H03+.00	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	9	48	H01-.23	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
4	9	48	H01-.05	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	9	48	H01+.33	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	9	48	H01+.34	SAI	0.46	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	9	48	H03-.03	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	9	50	H01-.06	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	9	52	H01-.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	9	53	H01-.03	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
4	9	53	H01+.17	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	9	53	H01+.25	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	9	57	H01-.03	DSI	1.25	ODSCC TSP AXIAL	In Service via APC
4	9	57	H01+.06	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	9	57	H01+.08	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	9	57	H01+.17	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	9	61	H01+.06	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	9	63	H01-.14	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	9	64	H03-.06	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	9	70	H01+.03	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	9	73	H01+.03	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
4	9	74	H04-.03	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	9	74	H05-.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
4	9	77	C04-.08	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	9	83	H01-.03	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	9	89	H01-.09	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	9	89	H02+.00	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
4	9	93	H02+.00	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	10	3	H02+.12	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	10	12	H02+.11	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	10	12	H02+.29	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	10	20	H02+.14	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	10	29	H01+.11	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
4	10	31	H01+.08	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	10	35	H01-.11	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	10	36	H01+.00	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	10	42	H01+.06	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	10	42	H03+.08	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	10	52	H01+.00	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
4	10	68	H03+.00	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
4	11	42	H01+.08	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	11	68	H07+.11	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	11	69	H03+.00	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
4	11	69	H04-.03	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	11	75	H02-.06	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	11	84	H04-.08	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	12	2	H02+.12	DSI	1.13	ODSCC TSP AXIAL	In Service via APC
4	12	2	H02+.10	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	12	10	H03+.06	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
4	12	11	H03+.11	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
4	12	15	H04+.17	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	12	18	H02+.14	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	12	21	H01+.06	DSI	1.78	ODSCC TSP AXIAL	PLUGGED-Preventive
4	12	21	H01+.06	SAI	0.45	ODSCC TSP AXIAL	PLUGGED-Preventive
4	12	21	H01+.34	SAI	1.34	ODSCC TSP AXIAL	PLUGGED-Preventive
4	12	21	H02+.00	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
4	12	21	H02+.03	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	12	21	H02+.12	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	12	21	H02+.20	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	12	23	H01+.08	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	12	24	H01+.25	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
4	12	24	H01+.32	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	12	24	H01+.33	SAI	0.22	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	12	24	H02+.30	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	12	25	H03-.08	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	12	26	H01+.17	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	12	26	H02+.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	12	27	H01+.11	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	12	30	H01+.19	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	12	31	H03+.08	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	12	32	H01+.06	DSI	1.37	ODSCC TSP AXIAL	In Service via APC
4	12	32	H01+.13	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	12	32	H01+.19	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	12	32	H01+.24	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
4	12	32	H01+.25	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	12	33	H04+.22	DSI	1.13	ODSCC TSP AXIAL	In Service via APC
4	12	33	H04+.31	SAI	0.7	ODSCC TSP AXIAL	In Service via APC
4	12	34	H02-.11	DSI	1.56	ODSCC TSP AXIAL	In Service via APC
4	12	34	H02+.37	SAI	0.94	ODSCC TSP AXIAL	In Service via APC
4	12	35	H01+.11	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
4	12	36	H01+.11	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	12	36	H02+.20	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	12	37	H02-.14	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
4	12	38	H01+.00	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	12	38	H05+.14	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
4	12	39	H01+.03	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	12	39	H04+.06	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	12	39	H06+.03	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	12	40	H01+.08	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	12	41	H01+.06	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	12	41	H03+.11	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	12	42	H01+.08	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
4	12	43	H01+.20	DSI	1.48	ODSCC TSP AXIAL	In Service via APC
4	12	43	H01+.05	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	12	43	H01+.34	SAI	0.89	ODSCC TSP AXIAL	In Service via APC
4	12	43	H03+.14	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	12	44	H01+.14	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	12	59	H01+.00	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	12	59	H05+.15	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	12	61	H01+.00	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
4	12	61	H01+.09	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
4	12	61	H01+.14	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	12	62	H01-.17	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	12	63	H01+.00	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
4	12	63	H01-.05	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	12	63	H01+.00	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
4	12	63	H01+.01	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
4	12	71	H01-.06	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	12	74	H01-.14	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	12	74	H02-.06	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
4	12	75	H01-.20	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
4	12	75	H02-.03	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	12	76	H01-.20	DSI	1.39	ODSCC TSP AXIAL	In Service via APC
4	12	76	H01+.18	SAI	0.72	ODSCC TSP AXIAL	In Service via APC
4	12	76	H05-.03	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	12	81	H01-.03	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
4	12	81	H03-.12	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	12	82	H01-.03	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	12	83	H01-.06	DSI	1.42	ODSCC TSP AXIAL	In Service via APC
4	12	83	H01+.09	SAI	0.22	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	12	83	H01+.12	SAI	0.58	ODSCC TSP AXIAL	In Service via APC
4	12	85	H01-.15	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	13	14	H02+.20	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	13	15	H01+.22	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
4	13	15	H02-.14	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
4	13	15	H02+.22	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	13	17	H01-.17	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	13	17	H01+.25	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	13	17	H02-.14	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	13	17	H02+.28	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
4	13	17	H02-.09	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	13	17	H02+.32	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	13	17	H02+.33	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	13	17	H02+.37	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	13	17	H03+.06	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
4	13	29	H02-.03	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	13	30	H02-.14	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	13	31	H02-.14	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
4	13	33	H01+.14	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	13	34	H01+.11	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
4	13	34	H01+.33	SAI	0.37	ODSCC TSP AXIAL	In Service via APC
4	13	35	H02+.11	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	13	36	H02+.00	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
4	13	39	H02+.19	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	13	41	H03+.20	DSI	1.45	ODSCC TSP AXIAL	In Service via APC
4	13	41	H03+.25	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	13	41	H03+.26	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	13	42	H01+.06	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	13	43	H03+.08	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	13	44	H01+.06	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	13	44	H02+.14	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	13	45	H01+.06	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
4	13	46	H01+.11	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	13	46	H03-.03	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	13	47	H01+.00	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	13	47	H04-.08	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	13	48	H01-.06	DSI	1.74	ODSCC TSP AXIAL	In Service via APC
4	13	48	H01+.22	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
4	13	48	H01+.26	SAI	0.68	ODSCC TSP AXIAL	In Service via APC
4	13	48	H04-.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	13	49	H01-.03	DSI	1.33	ODSCC TSP AXIAL	In Service via APC
4	13	49	H01+.17	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	13	49	H01+.25	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	13	49	H03-.09	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	13	50	H03-.20	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
4	13	51	H01-.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	13	52	H01+.03	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	13	53	H01+.00	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
4	13	53	H01+.17	SAI	0.34	ODSCC TSP AXIAL	In Service via APC
4	13	53	H01+.25	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
4	13	54	H01+.00	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	13	57	H01-.06	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	13	57	H05-.15	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	13	59	H02+.00	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	13	62	H01+.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	13	68	H02-.03	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	13	70	H01-.14	DSI	0.57	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	13	77	H01-.23	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	13	81	H03-.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
4	13	82	H02-.14	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	13	84	H01+.09	DSI	1.97	ODSCC TSP AXIAL	In Service via APC
4	13	84	H02+.00	DSI	1.38	ODSCC TSP AXIAL	In Service via APC
4	13	86	H01+.08	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
4	13	86	H01-.11	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	14	13	H02+.00	DSI	0.2	ODSCC TSP AXIAL	In Service via APC
4	14	22	H01+.08	DSI	1.48	ODSCC TSP AXIAL	In Service via APC
4	14	22	H01+.18	SAI	0.49	ODSCC TSP AXIAL	In Service via APC
4	14	22	H02-.06	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	14	24	H01+.14	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	14	57	H01-.06	DSI	1.57	ODSCC TSP AXIAL	In Service via APC
4	14	57	H01+.12	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	14	57	H01+.15	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
4	14	57	H01+.19	SAI	0.34	ODSCC TSP AXIAL	In Service via APC
4	14	59	H01+.09	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	14	59	H01+.22	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	14	59	H01+.24	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	14	59	H01+.26	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	14	60	H01-.03	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	14	75	H02-.11	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	14	77	H01+.03	DSI	1.53	ODSCC TSP AXIAL	In Service via APC
4	14	77	H01-.06	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	14	77	H02+.00	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	14	77	H02+.15	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	14	77	H02+.35	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
4	14	79	H02-.23	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	14	81	H02-.06	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	14	82	H01-.03	DSI	1.48	ODSCC TSP AXIAL	In Service via APC
4	14	82	H01-.03	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	14	83	H01-.06	DSI	1.28	ODSCC TSP AXIAL	In Service via APC
4	14	83	H01+.15	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	14	83	H01+.23	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
4	14	85	H01+.00	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	14	86	H01-.03	DSI	1.29	ODSCC TSP AXIAL	In Service via APC
4	14	86	H01+.21	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	14	86	H01+.24	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	14	86	H02+.06	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
4	14	86	H02+.19	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	14	86	H04-.06	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
4	14	88	H01-.03	DSI	1.38	ODSCC TSP AXIAL	In Service via APC
4	14	88	H01+.01	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	14	88	H01+.32	SAI	0.34	ODSCC TSP AXIAL	In Service via APC
4	14	88	H03+.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	14	89	H01+.00	DSI	1.2	ODSCC TSP AXIAL	In Service via APC
4	14	89	H01+.06	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	14	90	H01+.20	DSI	1.21	ODSCC TSP AXIAL	In Service via APC
4	14	90	H01+.27	SAI	0.37	ODSCC TSP AXIAL	In Service via APC
4	14	90	H02+.20	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
4	14	91	H01-.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	14	92	H01+.00	DSI	1.58	ODSCC TSP AXIAL	In Service via APC
4	14	92	H01+.21	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	14	92	H01+.29	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	15	4	H02+.06	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
4	15	22	C05-.03	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	15	48	H01-.03	DSI	1.19	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	15	48	H01+.11	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	15	48	H01+.20	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	15	48	H03+.06	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	15	49	H01-.12	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	15	49	H03-.09	DSI	2.11	ODSCC TSP AXIAL	PLUGGED
4	15	49	H03+.11	SAI	0.3	ODSCC TSP AXIAL	PLUGGED
4	15	49	H04-.15	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	15	49	H05+.00	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
4	15	50	H01-.08	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	15	50	H02+.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	15	51	H01-.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	15	51	H01+.04	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	15	51	H01+.17	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	15	51	H01+.30	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	15	52	H01-.03	DSI	1.72	ODSCC TSP AXIAL	In Service via APC
4	15	52	H01+.11	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	15	52	H01+.24	SAI	0.38	ODSCC TSP AXIAL	In Service via APC
4	15	53	H01+.00	DSI	1.29	ODSCC TSP AXIAL	In Service via APC
4	15	53	H01+.07	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	15	53	H01+.16	SAI	0.4	ODSCC TSP AXIAL	In Service via APC
4	15	53	H01+.20	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	15	53	H01+.25	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	15	54	H01+.00	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	15	54	H02+.08	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
4	15	61	H01+.00	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	15	62	H01-.11	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	15	63	H01+.03	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
4	15	63	H05-.03	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	15	64	H01+.14	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	15	65	H01+.03	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	15	65	H03-.08	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	15	65	H05-.03	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	15	66	H01-.06	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	15	67	H01+.09	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
4	15	69	H01+.00	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	16	23	H05+.23	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	16	35	H01+.14	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	16	43	H01+.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	16	45	H01+.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
4	16	50	H01-.03	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
4	16	59	H01-.09	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
4	16	61	H01-.06	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
4	16	80	H03-.03	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	16	83	H01+.06	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	16	89	H01-.03	DSI	1.33	ODSCC TSP AXIAL	In Service via APC
4	16	89	H01+.28	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	16	91	H01+.00	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
4	17	9	H02+.20	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	17	13	H02+.20	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	17	15	H02+.03	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	17	15	H02+.04	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	17	15	H02+.31	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
4	17	21	H01+.14	DSI	1.35	ODSCC TSP AXIAL	In Service via APC
4	17	21	H01+.13	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	17	21	H01+.22	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	17	21	H01+.24	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	17	21	H01+.25	SAI	0.11	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	17	21	H04+.11	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	17	26	H02-.15	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	17	26	H02+.23	DSI	1.24	ODSCC TSP AXIAL	In Service via APC
4	17	26	H02-.09	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	17	26	H02+.20	SAI	0.33	ODSCC TSP AXIAL	In Service via APC
4	17	26	H02+.29	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
4	17	27	H01+.06	DSI	1.55	ODSCC TSP AXIAL	In Service via APC
4	17	27	H01+.13	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	17	27	H01+.16	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	17	27	H01+.17	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	17	27	H01+.24	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	17	27	H03-.09	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
4	17	29	H01+.08	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	17	30	H01+.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	17	30	H02-.08	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	17	31	H04-.06	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	17	32	H01+.11	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	17	55	H01+.00	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	17	55	H05-.06	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
4	17	56	H01-.06	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
4	17	56	H02+.00	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	17	57	H01-.09	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	17	58	H01-.03	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	17	58	H03-.06	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	17	61	H01-.03	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	17	62	H01+.00	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	17	72	H01-.03	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	17	75	H01-.03	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	17	76	H01-.06	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	17	78	H01+.03	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
4	17	80	H01-.14	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	17	81	H01+.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	17	81	H01+.18	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	17	82	H01-.03	DSI	1.51	ODSCC TSP AXIAL	In Service via APC
4	17	82	H01+.08	SAI	0.6	ODSCC TSP AXIAL	In Service via APC
4	17	82	H01+.12	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	17	82	H01+.28	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	17	83	H01+.00	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	17	84	H01+.00	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	17	85	H01-.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	17	87	H01-.03	DSI	1.61	ODSCC TSP AXIAL	In Service via APC
4	17	87	H01+.25	SAI	0.38	ODSCC TSP AXIAL	In Service via APC
4	17	87	H01+.30	SAI	0.57	ODSCC TSP AXIAL	In Service via APC
4	17	88	H02-.06	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	17	91	H01+.00	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	18	11	H04+.08	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
4	18	13	C05+.03	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	18	14	H02-.11	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	18	14	H02+.25	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
4	18	14	H02-.04	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
4	18	14	H02-.03	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	18	14	H02+.34	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	18	15	H01+.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	18	15	H02+.06	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
4	18	15	H03+.03	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
4	18	15	H04+.20	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
4	18	16	H05+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	18	21	H01+.11	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	18	21	H02+.17	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	18	24	H02+.14	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	18	25	H01+.08	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	18	29	H01+.17	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	18	32	H03+.08	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	18	33	H01-.11	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	18	33	H02+.20	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	18	33	H05+.03	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
4	18	36	H01+.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	18	36	H03+.03	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	18	38	H03+.06	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
4	18	40	H01+.11	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	18	40	H05+.11	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
4	18	41	H01+.00	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	18	42	H04+.06	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	18	46	H01+.06	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	18	48	H01-.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	18	49	H01-.15	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	18	50	H01-.06	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	18	51	H05-.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	18	57	H01-.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	18	57	H01+.00	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	18	57	H02+.00	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	18	58	H01+.00	DSI	1.25	ODSCC TSP AXIAL	In Service via APC
4	18	58	H01+.06	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	18	58	H01+.25	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	18	59	H01-.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	18	59	H01+.05	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	18	59	H01+.10	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	18	61	H01-.06	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	18	61	H01+.01	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	18	62	H01-.06	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
4	18	62	H01+.07	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	18	64	H01+.00	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	18	67	H01+.17	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
4	18	69	H02+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	19	8	H01+.09	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	19	12	H01-.03	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	19	29	H01+.08	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	19	29	H01+.09	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	19	34	H01-.11	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	19	35	H01+.00	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	19	37	H01+.08	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	19	42	H01+.11	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	19	43	H02-.11	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	19	50	H01-.03	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	19	51	H01-.09	DSI	1.37	ODSCC TSP AXIAL	In Service via APC
4	19	51	H01+.17	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	19	53	H04-.06	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	19	56	H01-.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	19	56	H01+.00	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	19	58	H07+.00	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
4	19	63	H01+.03	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
4	19	63	H01+.12	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	19	71	H01-.06	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	19	72	H02+.20	DSI	0.94	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	19	75	H01-.03	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	19	75	H02-.09	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	19	76	H02-.03	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	19	77	H01+.00	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
4	19	77	H02-.20	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	19	84	H01+.00	DSI	1.31	ODSCC TSP AXIAL	In Service via APC
4	19	84	H01-.01	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	19	84	H01+.15	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	19	87	H03-.18	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	19	89	H01-.03	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	19	90	H02+.00	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	20	12	H02+.11	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	20	15	H02+.03	DSI	1.59	ODSCC TSP AXIAL	In Service via APC
4	20	15	H02+.33	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
4	20	17	H06+.09	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
4	20	19	H02+.06	DSI	0.26	ODSCC TSP AXIAL	In Service via APC
4	20	20	H04+.08	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	20	25	H01+.09	DSI	1.62	ODSCC TSP AXIAL	In Service via APC
4	20	25	H01+.05	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	20	25	H01+.19	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	20	25	H01+.26	SAI	0.4	ODSCC TSP AXIAL	In Service via APC
4	20	25	H01+.33	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	20	25	H02+.06	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	20	26	H02+.06	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	20	27	H06+.06	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	20	29	H02+.22	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	20	29	H04-.03	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	20	30	H02+.00	DSI	1.63	ODSCC TSP AXIAL	In Service via APC
4	20	30	H02+.36	SAI	0.58	ODSCC TSP AXIAL	In Service via APC
4	20	30	H02+.37	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	20	31	H01+.22	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
4	20	31	H03+.06	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	20	31	H05-.08	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
4	20	32	H01+.11	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
4	20	32	H01+.10	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	20	32	H01+.15	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	20	32	H01+.16	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	20	32	H01+.20	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	20	34	H01+.14	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	20	34	H02+.17	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	20	36	H02-.06	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
4	20	37	H01+.06	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
4	20	37	H01+.05	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	20	37	H01+.18	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	20	37	H01+.26	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	20	37	H04+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	20	38	H06+.00	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	20	39	H01+.17	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	20	39	H01+.05	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	20	39	H01+.11	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	20	39	H01+.30	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	20	39	H03+.03	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	20	40	H01+.17	DSI	1.86	ODSCC TSP AXIAL	In Service via APC
4	20	40	H01+.28	SAI	0.41	ODSCC TSP AXIAL	In Service via APC
4	20	40	H01+.33	SAI	0.77	ODSCC TSP AXIAL	In Service via APC
4	20	40	H05+.09	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	20	44	H02+.08	DSI	0.48	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	20	44	H03+.00	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	20	46	H01+.11	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	20	46	H02-.14	DSI	1.23	ODSCC TSP AXIAL	In Service via APC
4	20	46	H02+.31	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	20	46	H02+.00	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	20	46	H02+.16	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	20	46	H02+.29	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
4	20	46	H02+.31	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	20	46	H03+.08	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	20	46	H06+.06	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	20	47	H01+.00	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	20	47	H02+.06	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	20	47	H03+.08	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	20	48	H01+.03	DSI	1.6	ODSCC TSP AXIAL	In Service via APC
4	20	48	H01+.02	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	20	48	H01+.23	SAI	0.47	ODSCC TSP AXIAL	In Service via APC
4	20	48	H01+.35	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	20	48	H02-.23	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	20	49	H01-.06	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	20	49	H02-.03	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	20	49	H02+.14	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	20	49	H02+.29	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	20	49	H03+.12	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
4	20	50	H01+.09	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	20	50	H01+.16	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	20	51	H01+.00	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
4	20	51	H01-.04	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
4	20	51	H01+.01	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	20	51	H01+.05	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	20	51	H03-.03	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	20	51	H04-.15	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	20	52	H01-.03	DSI	1.21	ODSCC TSP AXIAL	In Service via APC
4	20	52	H01+.18	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	20	52	H01+.20	SAI	0.34	ODSCC TSP AXIAL	In Service via APC
4	20	52	H01+.21	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	20	53	H02+.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	20	53	H03-.15	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	20	54	H01+.00	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	20	55	H02-.18	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
4	20	56	H01+.17	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	20	56	H03-.03	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	20	57	H01-.12	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	20	57	H01-.03	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	20	57	H01-.01	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	20	57	H01+.23	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	20	57	H01+.24	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	20	57	H02+.06	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	20	58	H01+.03	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
4	20	58	H01+.28	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
4	20	58	H02+.25	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	20	58	H06+.00	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	20	59	H01-.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	20	59	H04+.03	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	20	59	H05-.06	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
4	20	60	H01+.06	DSI	1.49	ODSCC TSP AXIAL	In Service via APC
4	20	60	H01-.11	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	20	60	H01+.20	SAI	0.29	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	20	60	H03+.00	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
4	20	60	H03+.08	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	20	61	H01+.00	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	20	62	H01-.22	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	20	63	H01-.03	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	20	64	H01-.03	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	20	64	H02-.14	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
4	20	65	H01-.03	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	20	66	H02-.03	DSI	0.19	ODSCC TSP AXIAL	In Service via APC
4	20	68	H01+.03	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	20	69	H01-.03	DSI	1.8	ODSCC TSP AXIAL	In Service via APC
4	20	69	H01+.22	SAI	0.44	ODSCC TSP AXIAL	In Service via APC
4	20	69	H01+.23	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	20	69	H01+.25	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
4	20	69	H02+.00	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
4	20	70	H02+.00	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
4	20	70	H02+.14	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	20	70	H02+.23	SAI	0.52	ODSCC TSP AXIAL	In Service via APC
4	21	12	H01+.11	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	21	15	H06+.00	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	21	19	C05-.03	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	21	21	H02+.28	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
4	21	39	H01+.20	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
4	21	39	H01+.18	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	21	39	H01+.26	SAI	0.4	ODSCC TSP AXIAL	In Service via APC
4	21	43	H01+.17	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	21	44	H01+.08	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	21	45	H01+.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	21	48	H01-.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	21	48	H02-.23	DSI	1.03	ODSCC TSP AXIAL	In Service via APC
4	21	48	H02-.16	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	21	48	H02-.15	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	21	48	H03+.00	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	21	51	H01-.03	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
4	21	51	H01+.03	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	21	51	H01+.27	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
4	21	51	H02-.09	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	21	85	H01+.03	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	21	87	H01+.06	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	21	88	H01-.03	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
4	21	89	H01-.03	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
4	22	8	H02+.12	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	22	17	C04-.08	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	22	17	C05-.17	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	22	17	H06+.11	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	22	18	H02+.16	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	22	23	H02+.00	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	22	24	H03+.08	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	22	25	H02+.14	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	22	25	H03+.00	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	22	33	H01+.17	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
4	22	33	H01-.07	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	22	33	H01+.28	SAI	0.43	ODSCC TSP AXIAL	In Service via APC
4	22	33	H02-.11	DSI	1.58	ODSCC TSP AXIAL	In Service via APC
4	22	33	H02+.36	SAI	0.43	ODSCC TSP AXIAL	In Service via APC
4	22	37	H02+.06	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	22	41	H01+.14	DSI	1.21	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	22	41	H01+.16	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	22	41	H01+.23	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
4	22	41	H02-.14	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
4	22	41	H02+.23	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	22	41	H02+.35	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
4	22	41	H02+.37	SAI	0.33	ODSCC TSP AXIAL	In Service via APC
4	22	41	H04+.08	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	22	45	H01+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	22	46	H01+.00	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	22	46	H02+.06	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	22	46	H03+.03	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	22	47	H02+.22	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
4	22	47	H02+.19	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	22	47	H02+.34	SAI	0.74	ODSCC TSP AXIAL	In Service via APC
4	22	59	H01-.15	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	22	59	H02+.00	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	22	65	H01-.17	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
4	22	67	H02+.00	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	22	67	H02-.08	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	22	68	H01-.11	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	22	70	H01-.06	DSI	4.74	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H01-.05	SAI	0.54	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H01+.02	SAI	0.23	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H01+.09	SAI	0.43	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H01+.24	SAI	1.98	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H01+.27	SAI	1.82	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H01+.32	SAI	0.28	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H02-.11	DSI	0.66	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H02+.17	SAI	0.09	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H02+.33	SAI	0.24	ODSCC TSP AXIAL	PULL/PLUGGED
4	22	70	H03+.14	DSI	0.4	ODSCC TSP AXIAL	PLUGGED
4	22	70	H03+.18	SAI	0.14	ODSCC TSP AXIAL	PLUGGED
4	22	71	H03+.00	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	23	12	H01+.11	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	23	12	H01+.22	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	23	14	C05+.00	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	23	40	H01+.03	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
4	23	41	H01+.14	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	23	42	H01+.08	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	23	43	H02+.03	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	23	44	H03+.06	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	23	45	H01+.06	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	23	45	H03+.11	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	23	54	H01+.03	DSI	1.75	ODSCC TSP AXIAL	In Service via APC
4	23	54	H01+.08	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	23	54	H01+.23	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	23	54	H02-.09	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	23	56	H02-.17	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	23	60	H01+.00	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
4	23	60	H01+.16	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	23	60	H01+.25	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	23	60	H01+.34	SAI	0.1	ODSCC TSP AXIAL	In Service via APC
4	23	60	H02+.03	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	23	61	H02+.03	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	23	63	H01-.20	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
4	23	63	H01-.04	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
4	23	63	H01+.27	SAI	0.21	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	23	63	H01+.33	SAI	0.48	ODSCC TSP AXIAL	In Service via APC
4	23	63	H02-.06	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
4	23	64	H01-.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	23	64	H01+.05	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	23	64	H01+.08	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
4	23	64	H01+.21	SAI	0.46	ODSCC TSP AXIAL	In Service via APC
4	23	65	H02-.03	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
4	23	65	H02+.13	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
4	23	65	H02+.27	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
4	23	66	H01+.00	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	23	66	H01+.04	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	23	66	H01+.28	SAI	0.65	ODSCC TSP AXIAL	In Service via APC
4	23	66	H02-.20	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	23	67	H02-.06	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	23	68	H01+.06	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	23	69	H01+.12	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	23	69	H02+.18	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	23	70	H01-.03	DSI	1.27	ODSCC TSP AXIAL	In Service via APC
4	23	70	H01+.21	SAI	0.63	ODSCC TSP AXIAL	In Service via APC
4	23	70	H02+.00	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	23	71	H01-.03	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
4	23	71	H02-.09	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	23	72	H01+.00	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
4	23	72	H01-.18	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	23	72	H01+.23	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	23	73	H01+.15	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	23	73	H02-.09	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
4	23	73	H02+.34	SAI	0.66	ODSCC TSP AXIAL	In Service via APC
4	23	73	H06+.00	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	23	74	H01+.00	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	23	75	H01-.03	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
4	23	75	H01+.02	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	23	75	H02-.18	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	23	75	H03-.06	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
4	23	86	H01+.00	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	23	86	H03+.00	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	23	87	H01-.06	DSI	1.69	ODSCC TSP AXIAL	In Service via APC
4	23	87	H01+.13	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	24	15	C05+.00	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	24	46	H01+.08	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	24	52	H02+.20	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	24	62	H02-.03	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	25	21	H01-.03	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
4	25	22	H02+.11	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	25	40	H01+.03	DSI	1.92	ODSCC TSP AXIAL	In Service via APC
4	25	40	H01+.25	SAI	0.59	ODSCC TSP AXIAL	In Service via APC
4	25	40	H01+.26	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	25	40	H02-.03	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	25	41	H01+.14	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
4	25	41	H01+.26	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	25	41	H02+.14	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	25	42	H01-.03	DSI	1.62	ODSCC TSP AXIAL	In Service via APC
4	25	42	H01+.34	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
4	25	43	H01+.08	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
4	25	43	H01+.24	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	25	46	C05-.03	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	25	47	H05+.03	DSI	0.23	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	25	49	H02-.06	DSI	1.45	ODSCC TSP AXIAL	In Service via APC
4	25	49	H02+.26	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	25	49	H02+.33	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	25	51	H01-.03	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	25	53	H01-.15	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
4	25	53	H01-.05	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
4	25	53	H01+.21	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	25	53	H01+.33	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	25	53	H02+.00	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
4	25	57	H01-.15	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
4	25	57	H01-.01	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	25	57	H02-.06	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	25	57	H04-.15	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	25	58	H01-.03	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	25	58	H02+.20	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
4	25	59	H01-.06	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	25	60	H01-.14	DSI	1.11	ODSCC TSP AXIAL	In Service via APC
4	25	60	H01+.30	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	25	60	H01+.33	SAI	0.39	ODSCC TSP AXIAL	In Service via APC
4	25	60	H02-.11	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	25	67	H04-.09	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	25	75	H02-.15	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	25	75	H05+.00	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	25	80	H01+.00	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	25	80	H01+.13	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	25	80	H02-.06	DSI	1.07	ODSCC TSP AXIAL	In Service via APC
4	25	83	H01+.00	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	25	85	H01+.00	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	26	14	H02-.17	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	26	14	H03+.17	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	26	19	H02+.19	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
4	26	19	H03+.16	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	26	20	H02+.00	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	26	20	H04+.11	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	26	21	H03+.11	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	26	24	H02+.17	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	26	27	H03+.09	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	26	27	H04+.03	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	26	27	H06+.03	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	26	29	H02+.14	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	26	31	H03+.08	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	26	31	H06+.00	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
4	26	33	H02-.18	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	26	35	H01+.14	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	26	36	H01-.08	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	26	47	H03+.06	DSI	0.19	ODSCC TSP AXIAL	In Service via APC
4	26	48	H01-.06	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	26	51	H01-.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	26	57	H07+.00	DSI	0.21	ODSCC TSP AXIAL	In Service via APC
4	26	62	H01+.00	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	26	64	H01-.14	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	26	65	H02+.00	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	26	66	H02+.00	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	26	68	H01+.06	DSI	1.5	ODSCC TSP AXIAL	In Service via APC
4	26	68	H01+.25	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
4	26	68	H01+.33	SAI	0.53	ODSCC TSP AXIAL	In Service via APC
4	26	69	H01+.00	DSI	1.01	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	26	69	H01+.19	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	26	71	H01+.03	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	26	71	H03+.00	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
4	26	72	H01-.06	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
4	26	73	H02-.15	DSI	1.26	ODSCC TSP AXIAL	In Service via APC
4	26	73	H02-.12	SAI	0.07	ODSCC TSP AXIAL	In Service via APC
4	26	73	H02-.02	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	26	73	H02+.20	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	26	83	H02+.00	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	26	85	H01-.03	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	27	14	H02+.20	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	27	14	H02+.21	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	27	15	H02+.11	DSI	1.18	ODSCC TSP AXIAL	In Service via APC
4	27	15	H02+.26	SAI	0.28	ODSCC TSP AXIAL	In Service via APC
4	27	17	H02+.08	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	27	18	H02+.05	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	27	20	H01+.00	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	27	21	H03+.08	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	27	22	H04+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	27	27	H02+.17	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
4	27	45	H01+.17	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	27	46	H01+.08	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
4	27	48	H01-.03	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
4	27	51	H02+.03	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	27	53	H01+.00	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	27	55	H01+.00	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	27	61	H01+.00	DSI	0.14	ODSCC TSP AXIAL	In Service via APC
4	27	62	H01+.00	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	27	63	H01-.09	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
4	27	63	H02-.06	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	27	63	H03-.06	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	27	65	H01-.18	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	27	65	H02-.12	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	27	65	H03-.06	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	27	66	H02+.06	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	27	66	H04+.00	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
4	27	67	H02-.09	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	27	69	H01+.03	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	27	71	H01+.00	DSI	1.7	ODSCC TSP AXIAL	In Service via APC
4	27	71	H01+.04	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	27	71	H01+.14	SAI	0.31	ODSCC TSP AXIAL	In Service via APC
4	27	71	H01+.21	SAI	0.54	ODSCC TSP AXIAL	In Service via APC
4	27	72	H02-.11	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	27	72	H03+.00	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	27	73	H02+.12	DSI	1.99	ODSCC TSP AXIAL	In Service via APC
4	27	73	H02+.08	SAI	0.47	ODSCC TSP AXIAL	In Service via APC
4	27	73	H02+.37	SAI	0.41	ODSCC TSP AXIAL	In Service via APC
4	27	73	H03-.09	DSI	0.77	ODSCC TSP AXIAL	In Service via APC
4	27	74	C05+.06	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
4	27	74	H01+.00	DSI	1.13	ODSCC TSP AXIAL	In Service via APC
4	27	74	H01+.06	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	27	74	H01+.19	SAI	0.32	ODSCC TSP AXIAL	In Service via APC
4	27	74	H02-.03	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	27	74	H03+.00	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
4	27	75	H01+.03	DSI	1.27	ODSCC TSP AXIAL	In Service via APC
4	27	75	H01+.11	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	27	75	H01+.21	SAI	0.11	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	27	75	H01+.22	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	27	75	H02+.09	DSI	0.84	ODSCC TSP AXIAL	In Service via APC
4	27	75	H03-.06	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	27	76	H01-.17	DSI	1.46	ODSCC TSP AXIAL	In Service via APC
4	27	76	H02+.00	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	27	76	H05-.14	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	27	77	H01-.03	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
4	27	77	H02+.00	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	27	77	H03+.06	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
4	27	77	H03-.03	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	27	77	H03+.17	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	27	77	H03+.18	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
4	27	77	H03+.24	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	27	77	H03+.27	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	27	77	H04+.03	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	27	78	H01+.03	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	27	78	H02+.11	DSI	1.13	ODSCC TSP AXIAL	In Service via APC
4	27	78	H02+.29	SAI	0.52	ODSCC TSP AXIAL	In Service via APC
4	27	79	H01+.00	DSI	1.27	ODSCC TSP AXIAL	In Service via APC
4	27	79	H01-.06	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	27	79	H02+.00	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
4	27	79	H02+.02	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	27	79	H02+.12	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	27	80	H02-.06	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	27	80	H03-.03	DSI	0.99	ODSCC TSP AXIAL	In Service via APC
4	27	81	H02-.06	DSI	1.28	ODSCC TSP AXIAL	In Service via APC
4	27	81	H03-.03	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
4	27	82	H03-.06	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
4	27	82	H05+.03	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	27	83	H02-.03	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	27	83	H03-.09	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	27	83	H04+.00	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	27	84	H01-.11	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	27	84	H02+.03	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
4	27	84	H02+.04	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	27	85	H05+.03	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	28	15	C07-.06	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
4	28	20	H01+.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	28	24	H04-.14	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	28	24	H06+.00	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
4	28	28	H04+.00	DSI	0.63	ODSCC TSP AXIAL	In Service via APC
4	28	33	H03+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	28	35	H02+.14	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
4	28	35	H02+.29	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	28	35	H02+.30	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	28	40	H02+.11	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	28	45	H01+.08	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	28	47	H02+.11	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	28	48	H01-.03	DSI	1.22	ODSCC TSP AXIAL	In Service via APC
4	28	48	H01-.12	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	28	48	H01+.07	SAI	0.13	ODSCC TSP AXIAL	In Service via APC
4	28	48	H01+.22	SAI	0.24	ODSCC TSP AXIAL	In Service via APC
4	28	48	H01+.33	SAI	0.34	ODSCC TSP AXIAL	In Service via APC
4	28	48	H03-.03	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	28	52	H02+.11	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	28	62	H02+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	28	63	H01+.03	DSI	0.73	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	28	63	H02+.00	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
4	28	63	H03+.00	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	28	64	H02-.06	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	28	65	H01-.09	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	28	66	H02-.06	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
4	28	66	H03-.19	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	28	67	H01+.03	DSI	1.59	ODSCC TSP AXIAL	In Service via APC
4	28	67	H01+.15	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	28	67	H01+.19	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	28	67	H01+.22	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
4	28	68	H01-.17	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
4	28	68	H01+.03	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	28	68	H01+.20	SAI	0.33	ODSCC TSP AXIAL	In Service via APC
4	28	68	H02+.00	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	28	68	H05-.08	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	28	70	H01+.03	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	28	70	H02+.17	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
4	28	71	H01-.09	DSI	1.02	ODSCC TSP AXIAL	In Service via APC
4	28	71	H01+.14	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	28	71	H01+.20	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	28	71	H02-.03	DSI	1.27	ODSCC TSP AXIAL	In Service via APC
4	28	71	H02-.03	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	28	71	H02+.18	SAI	0.14	ODSCC TSP AXIAL	In Service via APC
4	28	71	H02+.28	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	28	72	H01+.00	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	28	72	H01+.09	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	28	72	H01+.24	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	28	72	H02+.14	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
4	28	72	H03+.00	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	28	73	H01-.12	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	28	74	H02+.00	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	28	74	H03+.11	DSI	1.16	ODSCC TSP AXIAL	In Service via APC
4	28	74	H03+.06	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	28	74	H03+.34	SAI	0.44	ODSCC TSP AXIAL	In Service via APC
4	28	74	H05-.03	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	28	75	H01-.03	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
4	28	75	H01+.02	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	28	75	H02+.09	DSI	1.08	ODSCC TSP AXIAL	In Service via APC
4	28	75	H02+.15	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	28	75	H02+.21	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	28	75	H02+.33	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	28	76	H01-.06	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	28	76	H02+.06	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	28	77	H01-.03	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	28	77	H01+.07	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	28	77	H01+.15	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	28	77	H02-.03	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	28	78	H01+.00	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	28	78	H02+.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	28	79	H02+.00	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	28	79	H03+.03	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	28	79	H04-.09	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	28	80	H02+.11	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	28	80	H03-.03	DSI	0.89	ODSCC TSP AXIAL	In Service via APC
4	28	81	H01-.03	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	28	81	H02-.03	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
4	28	81	H03-.03	DSI	0.76	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	28	81	H05+.06	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	28	82	H02+.06	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	28	82	H02+.27	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	28	83	H02-.03	DSI	0.9	ODSCC TSP AXIAL	In Service via APC
4	28	84	H01-.06	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	29	14	H01-.03	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	29	18	H07+.03	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
4	29	19	H06+.17	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	29	27	H02+.00	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	29	27	H07+.03	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	29	28	H02+.03	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
4	29	30	H02-.06	DSI	1.39	ODSCC TSP AXIAL	In Service via APC
4	29	30	H02+.14	SAI	0.59	ODSCC TSP AXIAL	In Service via APC
4	29	30	H02+.37	SAI	0.35	ODSCC TSP AXIAL	In Service via APC
4	29	35	H01+.11	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	29	35	H02+.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	29	38	H01+.08	DSI	0.68	ODSCC TSP AXIAL	In Service via APC
4	29	38	H02+.08	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	29	42	H02-.03	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
4	29	43	H01+.17	DSI	0.88	ODSCC TSP AXIAL	In Service via APC
4	29	46	H02+.06	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	29	47	H01+.17	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	29	48	C06+.03	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	29	48	H01+.00	DSI	1.04	ODSCC TSP AXIAL	In Service via APC
4	29	48	H01+.13	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	29	50	H01-.03	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	29	50	H02+.12	DSI	0.94	ODSCC TSP AXIAL	In Service via APC
4	29	51	H01+.00	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	29	56	H02-.06	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	29	57	H01+.00	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	29	58	H01-.08	DSI	1.15	ODSCC TSP AXIAL	In Service via APC
4	29	58	H01+.10	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	29	59	H06-.12	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	29	63	H01+.00	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	29	71	H05+.03	DSI	0.16	ODSCC TSP AXIAL	In Service via APC
4	29	73	H03-.03	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
4	29	76	C05+.08	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
4	30	14	C01-.31	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	30	17	H03+.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	30	18	H02+.14	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	30	21	H02+.17	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	30	25	H02+.14	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	30	28	H04+.00	DSI	0.14	ODSCC TSP AXIAL	In Service via APC
4	30	54	H01-.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	30	54	H02+.00	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	30	71	H01-.03	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	30	74	C04+.03	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	30	76	C05+.03	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
4	30	76	C06+.00	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	30	77	H01+.00	DSI	1.21	ODSCC TSP AXIAL	In Service via APC
4	30	80	H06-.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	30	81	H02-.06	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	31	34	H02-.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	31	39	H01+.03	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	31	40	H02+.06	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	31	40	H04-.03	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	31	51	H06-.03	DSI	0.37	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	31	54	H01-.03	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	31	55	H02+.00	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	31	58	H02+.06	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	31	58	H03+.00	DSI	1.63	ODSCC TSP AXIAL	In Service via APC
4	31	58	H03+.14	SAI	0.23	ODSCC TSP AXIAL	In Service via APC
4	31	58	H03+.18	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	31	58	H03+.27	SAI	0.3	ODSCC TSP AXIAL	In Service via APC
4	31	59	H02+.06	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	31	59	H07-.15	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	31	71	H01-.03	DSI	1.04	ODSCC TSP AXIAL	In Service via APC
4	31	71	H01+.08	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	31	71	H01+.15	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	31	71	H01+.21	SAI	0.15	ODSCC TSP AXIAL	In Service via APC
4	31	71	H02+.00	DSI	1.12	ODSCC TSP AXIAL	In Service via APC
4	31	71	H02+.17	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	31	71	H02+.27	SAI	0.33	ODSCC TSP AXIAL	In Service via APC
4	31	71	H03-.12	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	31	72	H01+.00	DSI	0.91	ODSCC TSP AXIAL	In Service via APC
4	31	72	H02-.06	DSI	1.05	ODSCC TSP AXIAL	In Service via APC
4	31	72	H02+.28	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	31	72	H02+.29	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	31	72	H03-.03	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	31	76	H03+.00	DSI	0.75	ODSCC TSP AXIAL	In Service via APC
4	32	20	H02+.06	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	32	39	H01+.17	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	32	44	H04+.00	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
4	32	44	H04+.01	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	32	49	H01+.06	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	32	49	H02+.14	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	32	61	H02-.06	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
4	32	61	H02+.25	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	32	62	H01+.03	DSI	1.35	ODSCC TSP AXIAL	In Service via APC
4	32	62	H01+.15	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	32	62	H01+.19	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	32	62	H01+.20	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	32	62	H02+.06	DSI	1.01	ODSCC TSP AXIAL	In Service via APC
4	32	62	H02+.05	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	32	62	H02+.08	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	32	62	H02+.24	SAI	0.26	ODSCC TSP AXIAL	In Service via APC
4	32	63	H02+.03	DSI	0.98	ODSCC TSP AXIAL	In Service via APC
4	32	63	H04-.06	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	32	64	H01+.00	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	32	64	H02+.11	DSI	1.1	ODSCC TSP AXIAL	In Service via APC
4	32	64	H02+.08	SAI	0.12	ODSCC TSP AXIAL	In Service via APC
4	32	64	H02+.29	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	32	64	H02+.33	SAI	0.25	ODSCC TSP AXIAL	In Service via APC
4	32	64	H02+.35	SAI	0.16	ODSCC TSP AXIAL	In Service via APC
4	32	65	H01-.09	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	32	65	H02+.00	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	32	65	H03-.03	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	32	66	H01-.16	DSI	0.69	ODSCC TSP AXIAL	In Service via APC
4	32	66	H03+.14	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
4	32	66	H03+.08	SAI	0.27	ODSCC TSP AXIAL	In Service via APC
4	32	66	H03+.09	SAI	0.18	ODSCC TSP AXIAL	In Service via APC
4	32	67	H02+.00	DSI	1.35	ODSCC TSP AXIAL	In Service via APC
4	32	67	H02+.30	SAI	0.29	ODSCC TSP AXIAL	In Service via APC
4	32	67	H03+.00	DSI	0.62	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	32	68	H02-.03	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	32	69	H01-.09	DSI	0.82	ODSCC TSP AXIAL	In Service via APC
4	32	69	H02+.06	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	32	70	H01+.00	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	32	70	H02+.06	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	32	70	H03+.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	32	70	H04-.06	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	32	71	H01+.03	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	32	71	H03+.00	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	32	73	H01-.03	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	32	74	H01-.03	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	32	75	H02+.00	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	32	75	H04-.09	DSI	0.76	ODSCC TSP AXIAL	In Service via APC
4	32	77	H03+.00	DSI	1.06	ODSCC TSP AXIAL	In Service via APC
4	32	77	H04-.03	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	33	45	H01+.20	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	33	51	H02+.15	DSI	0.79	ODSCC TSP AXIAL	In Service via APC
4	33	54	H01+.00	DSI	0.37	ODSCC TSP AXIAL	In Service via APC
4	33	55	H01+.00	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	33	56	H01-.03	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	33	59	H02-.09	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	33	65	H02+.00	DSI	0.95	ODSCC TSP AXIAL	In Service via APC
4	33	67	H02+.00	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	33	68	H01+.00	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	34	24	H04+.06	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	34	25	H02+.08	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	34	28	H01+.19	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	34	30	H02+.14	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	34	32	H02+.14	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	34	33	H02+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	34	33	H03+.00	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
4	34	43	H01+.12	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
4	34	44	H02-.12	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	34	47	H01+.20	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	34	47	H03+.15	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	34	47	H04+.17	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	34	47	H04+.25	SAI	0.22	ODSCC TSP AXIAL	In Service via APC
4	34	48	H01+.06	DSI	0.36	ODSCC TSP AXIAL	In Service via APC
4	34	49	H02+.12	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	34	50	H03-.03	DSI	1.04	ODSCC TSP AXIAL	In Service via APC
4	34	50	H03+.07	SAI	0.17	ODSCC TSP AXIAL	In Service via APC
4	34	50	H03+.24	SAI	0.11	ODSCC TSP AXIAL	In Service via APC
4	34	50	H03+.27	SAI	0.36	ODSCC TSP AXIAL	In Service via APC
4	34	50	H04+.09	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
4	34	55	H03-.09	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	34	56	H01+.00	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	34	58	H02+.06	DSI	0.86	ODSCC TSP AXIAL	In Service via APC
4	34	59	H02+.00	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	34	64	H02-.14	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	34	65	H01-.06	DSI	0.87	ODSCC TSP AXIAL	In Service via APC
4	34	65	H02+.06	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	34	65	H03+.03	DSI	0.58	ODSCC TSP AXIAL	In Service via APC
4	34	66	H01+.08	DSI	0.71	ODSCC TSP AXIAL	In Service via APC
4	34	68	H02-.08	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	34	69	H02+.00	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	34	69	H03-.03	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	34	70	H03-.06	DSI	0.43	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	34	71	H02+.00	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	34	72	H01+.20	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	34	77	H03+.00	DSI	0.74	ODSCC TSP AXIAL	In Service via APC
4	34	78	H03-.08	DSI	0.83	ODSCC TSP AXIAL	In Service via APC
4	35	20	H03+.11	DSI	0.72	ODSCC TSP AXIAL	In Service via APC
4	35	33	H03+.11	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	35	35	H02+.03	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	35	38	H03+.06	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	35	43	H04+.03	DSI	0.25	ODSCC TSP AXIAL	In Service via APC
4	35	46	H06+.09	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	35	62	H02-.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	35	65	C03+.03	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
4	35	65	H03-.09	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
4	35	66	H02+.17	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	35	69	C06+.00	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	35	69	H01-.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	35	69	H02-.06	DSI	1.19	ODSCC TSP AXIAL	In Service via APC
4	35	71	H01-.06	DSI	1.09	ODSCC TSP AXIAL	In Service via APC
4	35	71	H01+.29	SAI	0.2	ODSCC TSP AXIAL	In Service via APC
4	35	72	H02+.03	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	35	73	H01-.12	DSI	0.57	ODSCC TSP AXIAL	In Service via APC
4	35	73	H02+.00	DSI	0.96	ODSCC TSP AXIAL	In Service via APC
4	35	74	H04+.00	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	36	24	H04+.08	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	36	26	H04+.03	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	36	36	H04-.06	DSI	0.55	ODSCC TSP AXIAL	In Service via APC
4	36	47	H01+.09	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	36	48	H02-.06	DSI	0.53	ODSCC TSP AXIAL	In Service via APC
4	36	52	H01+.12	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	36	52	H02+.23	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	36	52	H03+.03	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
4	36	54	H04+.03	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	36	56	H02+.08	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	36	57	H02+.12	DSI	0.56	ODSCC TSP AXIAL	In Service via APC
4	36	57	H03+.00	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	36	59	H01-.03	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	36	60	H02-.06	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	36	60	H03+.03	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	36	62	H02+.00	DSI	1.17	ODSCC TSP AXIAL	In Service via APC
4	36	62	H02+.04	SAI	0.49	ODSCC TSP AXIAL	In Service via APC
4	36	64	H02+.17	DSI	0.67	ODSCC TSP AXIAL	In Service via APC
4	36	65	H01+.00	DSI	0.93	ODSCC TSP AXIAL	In Service via APC
4	36	65	H02-.06	DSI	0.7	ODSCC TSP AXIAL	In Service via APC
4	36	67	H06-.09	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
4	36	68	H02-.03	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	36	71	H01-.06	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	36	72	H01+.06	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	37	35	H02+.11	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	37	45	H02+.12	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	37	45	H03+.06	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	37	46	C06+.00	DSI	0.38	ODSCC TSP AXIAL	In Service via APC
4	37	51	H02+.12	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	37	62	H04-.06	DSI	0.33	ODSCC TSP AXIAL	In Service via APC
4	37	63	H01+.00	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	37	63	H03+.00	DSI	0.23	ODSCC TSP AXIAL	In Service via APC
4	37	65	H02-.03	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	37	67	C05+.12	DSI	0.46	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	37	67	H01+.12	DSI	0.97	ODSCC TSP AXIAL	In Service via APC
4	37	71	H01-.03	DSI	0.4	ODSCC TSP AXIAL	In Service via APC
4	37	72	H01+.03	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	37	73	H02-.06	DSI	0.59	ODSCC TSP AXIAL	In Service via APC
4	38	21	H01+.08	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	38	24	H03+.11	DSI	0.42	ODSCC TSP AXIAL	In Service via APC
4	38	25	H02+.08	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	38	25	H05+.03	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	38	26	H02+.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	38	26	H04+.00	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
4	38	27	H01+.06	DSI	0.45	ODSCC TSP AXIAL	In Service via APC
4	38	27	H01+.07	SAI	0.21	ODSCC TSP AXIAL	In Service via APC
4	38	30	H02+.14	DSI	0.62	ODSCC TSP AXIAL	In Service via APC
4	38	32	H02+.14	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	38	34	H02+.11	DSI	0.78	ODSCC TSP AXIAL	In Service via APC
4	38	38	H04+.08	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	38	49	H02+.09	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	38	55	H02-.18	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	38	57	H02-.21	DSI	0.85	ODSCC TSP AXIAL	In Service via APC
4	38	62	H04+.00	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	38	71	H03+.00	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	38	71	H03+.27	SAI	0.19	ODSCC TSP AXIAL	In Service via APC
4	38	72	H02-.06	DSI	0.92	ODSCC TSP AXIAL	In Service via APC
4	38	74	H03-.03	DSI	0.6	ODSCC TSP AXIAL	In Service via APC
4	38	74	H04-.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	39	22	H01-.12	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	39	27	H03+.08	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	39	37	H03+.08	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	39	38	C05+.09	DSI	0.48	ODSCC TSP AXIAL	In Service via APC
4	39	41	H03+.14	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	39	41	H04+.03	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
4	39	42	H03-.03	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	39	42	H04+.00	DSI	0.29	ODSCC TSP AXIAL	In Service via APC
4	39	45	H02+.23	DSI	0.51	ODSCC TSP AXIAL	In Service via APC
4	39	45	H03+.12	DSI	0.43	ODSCC TSP AXIAL	In Service via APC
4	39	47	H02+.14	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
4	39	47	H03+.09	DSI	0.64	ODSCC TSP AXIAL	In Service via APC
4	39	49	H02+.17	DSI	0.8	ODSCC TSP AXIAL	In Service via APC
4	39	50	H02+.12	DSI	0.44	ODSCC TSP AXIAL	In Service via APC
4	39	64	H02+.00	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	39	66	H01+.00	DSI	0.27	ODSCC TSP AXIAL	In Service via APC
4	39	67	H02-.09	DSI	0.3	ODSCC TSP AXIAL	In Service via APC
4	39	68	H03+.11	DSI	0.61	ODSCC TSP AXIAL	In Service via APC
4	39	70	H03-.17	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	40	29	H03+.06	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	40	33	H02+.17	DSI	0.46	ODSCC TSP AXIAL	In Service via APC
4	40	57	H01+.03	DSI	0.81	ODSCC TSP AXIAL	In Service via APC
4	40	59	C03+.06	DSI	0.34	ODSCC TSP AXIAL	In Service via APC
4	40	67	H01-.06	DSI	0.65	ODSCC TSP AXIAL	In Service via APC
4	40	69	H02-.03	DSI	0.41	ODSCC TSP AXIAL	In Service via APC
4	40	71	H03-.03	DSI	0.54	ODSCC TSP AXIAL	In Service via APC
4	41	37	H03+.11	DSI	0.47	ODSCC TSP AXIAL	In Service via APC
4	41	52	H01+.09	DSI	0.52	ODSCC TSP AXIAL	In Service via APC
4	41	52	H02+.12	DSI	0.73	ODSCC TSP AXIAL	In Service via APC
4	41	57	H01+.06	DSI	0.66	ODSCC TSP AXIAL	In Service via APC
4	41	58	H01+.00	DSI	0.39	ODSCC TSP AXIAL	In Service via APC
4	41	58	H02+.00	DSI	0.65	ODSCC TSP AXIAL	In Service via APC

Table 7
ODSCC Tube Support Plate Axial

4	41	65	C02-.14	DSI	0.28	ODSCC TSP AXIAL	In Service via APC
4	42	38	H02+.08	DSI	0.5	ODSCC TSP AXIAL	In Service via APC
4	43	44	C05+.06	DSI	0.32	ODSCC TSP AXIAL	In Service via APC
4	43	53	C02-.20	DSI	0.35	ODSCC TSP AXIAL	In Service via APC
4	43	65	H01-.03	DSI	0.31	ODSCC TSP AXIAL	In Service via APC
4	45	48	C01-.37	DSI	0.24	ODSCC TSP AXIAL	In Service via APC
4	45	49	C01-.37	DSI	0.22	ODSCC TSP AXIAL	In Service via APC
4	45	51	H04-.09	DSI	0.49	ODSCC TSP AXIAL	In Service via APC
4	45	52	H04+.15	DSI	0.46	ODSCC TSP AXIAL	In Service via APC

Table 8
ODSCC Tube Support Plate Circumferential

The following indication is circumferential outside diameter stress corrosion cracking (ODSCC) at the tube support plates (TSP). This tube support plate intersection had two large dents. The stresses associated with the dents created circumferential cracking. These indications are detected by the plus point examination and are plugged on detection.

SG	ROW	COL	LOCATION	INDIC	VOLTAGE	CHARACTERIZATION	RESOLUTION
1	45	39	H07-.25	SCI	0.5	ODSCC TSP CIRC	PLUG/STAB

Table 9
OD Volumetric

The following indication was an OD Volumetric above the hot leg top-or-tubesheet. This indication was 0.37 volts and therefore in accordance with the EPRI In-Situ Pressure Test Guidelines did not require In-Situ Pressure testing because a 0.37 volt indication has at less a 95-percent probability of maintaining a safety factor greater than 3 against burst at normal operating pressure differential. It is also well below the In-Situ pressure test voltage threshold and therefore maintains a greater than 95-percent probability of not leaking at Main Steam Line Break pressure differential.

SG	ROW	COL	LOCATION	INDIC	VOLTAGE	CHARACTERIZATION	RESOLUTION
2	12	65	HTS+7.66	SVI	0.37	Volumetric	PLUGGED

Table 10
PWSCC Top of Tubesheet Axial

The indications below are axial (SAI) primary water stress corrosion cracking (PWSCC) below the top of the tubesheet. These indications were discussed in the 90 day Report. These indications are detected by the plus point examination and are plugged on detection.

SG	ROW	COL	LOCATION	INDIC	VOLTS	CHARACTERIZATION	RESOLUTION
4	4	25	HTS-10.64	SAI	3.04	PWSCC HTS AXIAL	PLUGGED
4	4	25	HTS-8.13	SAI	0.95	PWSCC HTS AXIAL	PLUGGED

Table 11
PWSCC Top of Tubesheet Circumferential

The indications below are circumferential (SCI) primary water stress corrosion cracking (PWSCC) at the top of the tubesheet. These indications are detected by the plus point examination and are plugged on detection.

SG	ROW	COL	LOCATION	INDIC	VOLTS	CHARACTERIZATION	RESOLUTION
2	20	70	HTS-.11	SCI	0.41	PWSCC HTS CIRC	PLUGGED

Table 12
PWSCC Tube Support Plate Axial

The indications below are axial (SAI) primary water stress corrosion cracking (PWSCC) at tube support plate intersections. These indications are detected by the plus point examination and are plugged on detection. The below locations were dented. SG3R12C4 indication's length was less than the L_{STR} and therefore an In-Situ proof test was not required in accordance with the EPRI In-Situ Pressure Test Guidelines. The other indications are below the 0.5 volt in-situ pressure screening voltage and therefore, maintain a greater than 95-percent probability of maintaining a safety factor of three against burst during normal operation.

SG	ROW	COL	LOCATION	INDIC	VOLTS	CHARACTERIZATION	RESOLUTION
1	29	78	H05+.19	SAI	0.41	PWSCC TSP AXIAL	PLUGGED
3	12	4	H01-.25	SAI	0.53	PWSCC TSP AXIAL	PLUGGED
3	24	86	H07-.02	SAI	0.37	PWSCC TSP AXIAL	PLUGGED

Table 13

PWSCC Tube Support Plate Circumferential

The indications below are circumferential (SCI) primary water stress corrosion cracking (PWSCC) tube support plate intersections. These indications are detected by the plus point examination and are plugged on detection. The below location was dented. The below indications CA was below the CA_{TWSL} and therefore a proof test was not required in accordance with the EPRI In-Situ Pressure Test Guidelines.

SG	ROW	COL	LOCATION	INDIC	VOLTS	CHARACTERIZATION	RESOLUTION
3	12	56	H07+.03	SCI	1.49	PWSCC TSP CIRC	PLUGGED
3	12	56	H07+.03	SCI	0.85	PWSCC TSP CIRC	PLUGGED

Table 14
PWSCC U-bend Axial

The indications below are axial (SAI) primary water stress corrosion cracking (PWSCC) in the U-bend region. These indications are detected by the plus point examination and are plugged on detection. This indication's length was less than the L_{STR} and therefore an In-Situ proof test was not required in accordance with the EPRI In-Situ Pressure Test Guidelines.

SG	ROW	COL	LOCATION	INDIC	VOLTS	CHARACTERIZATION	RESOLUTION
1	1	52	H07+3.94	SAI	1.86	PWSCC UBEND AXIAL	PLUGGED

Table 15
PWSCC U-Bend Circumferential

The indications below are circumferential (SCI) primary water stress corrosion cracking (PWSCC) in the U-bend region. These indications are detected by the plus point examination and are plugged on detection. The below indications CA was below the CA_{TWSL} and therefore a proof test was not required in accordance with the EPRI In-Situ Pressure Test Guidelines.

SG	ROW	COL	LOCATION	INDIC	VOLTS	CHARACTERIZATION	RESOLUTION
2	3	94	H07+18.72	SCI	0.77	PWSCC UBEND CIRC	PLUGGED
2	3	94	H07+16.23	SCI	0.54	PWSCC UBEND CIRC	PLUGGED
2	4	53	H07+22.26	SCI	0.61	PWSCC UBEND CIRC	PLUGGED