



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
James A. Fitzpatrick NPP
P.O. Box 110
Lycoming, NY 13093
Tel 315 342 3840

December 04, 2007
JAFP-07-0134

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Subject: Entergy Nuclear Operations, Inc.
James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
License No. DPR-59

**Clarification of previous response to Request for Additional Information
Regarding the James A. FitzPatrick Nuclear Power Plant Fourth Inservice
Inspection Interval Inspection Program Plan Relief Request RR-6 (TAC NO.
MD4758)**

- References:
1. Entergy letter JAFP-07-0030, Fourth Inservice Inspection Interval Inspection Program Plan, dated February 27, 2007.
 2. James A. FitzPatrick Nuclear Power Plant - NRC Request for Additional Information Related to Relief Request RR-6 (TAC NO. MD4758), dated August 1, 2007.
 3. Entergy letter JAFP-07-0102- Response to NRC Request for Additional Information Related to Relief Request RR-6 (TAC NO. MD4758), dated August 20, 2007.

Dear Sir or Madam:

Entergy Nuclear Operations Inc., (Entergy) submitted the Fourth Inservice Inspection Interval Inspection Program Plan, (Reference 1). Entergy received a Request for Additional Information (RAI) with three (3) questions in regard to Relief Request RR-6 (Reference 2). The revised relief request, (Reference 3) incorporated the responses to the RAI and provided the current schedule of inspections for the fourth ten year interval. Based on further review by the NRC, Entergy was requested to provide details of the planned inspection of the core plate rim hold down bolts during the first two inspection intervals. Entergy plans to complete VT-3 inspections of approximately 25% of the core plate rim hold down bolting during the first two inspection intervals.

There are no commitments contained in this letter. If you have any questions, please contact Mr. Jim Costedio at (315) 349-6358.

Very truly yours,


Jim Costedio
Manager, Licensing

A047
NRR

JAFP-07-0134

Page 2 of 2

cc:

Mr. Samuel J. Collins
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. John Boska, Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop O-8-C2
Washington, DC 20555-0001

NRC Resident Inspector
U.S. Nuclear Regulatory Commission
James A. FitzPatrick Nuclear Power Plant
P.O. Box 136
Lycoming, NY 13093