

#### GE Hitachi Nuclear Energy

James C. Kinsey Vice President, ESBWR Licensing

PO Box 780 M/C A-55 Wilmington, NC 28402-0780 USA

T 910 675 5057 F 910 362 5057 jim.kinsey@ge.com

Docket No. 52-010

MFN 06-299 Supplement 2

December 14, 2007

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555-0001

HITACHI

# Subject: Response to Portion of NRC Request for Additional Information Letter No. 75 Related To ESBWR Design Certification Application -- Evaluation of Postulated Pipe Breaks – RAI 3.6-6 S01

The purpose of this letter is to submit the GE Hitachi Nuclear Energy (GEH) response to a portion of the U.S. Nuclear Regulatory Commission (NRC) Request for Additional Information (RAI) sent by NRC letter No. 75 dated October 10, 2006, Reference 1. The previous response was submitted via Reference 2 in response to NRC Letter No. 45, Reference 3. RAI 3.6-6 S01 is addressed in Enclosure 1.

Please note that NRC letter no. 45, dated August 3, 2006, submitted NRC request 3.6-6b; however, the request did not specify a response date. Subsequently, NRC letter no. 75 identified a requested response date for this item. For processing and tracking purposes, GEH assigned RAI number 3.6-6 S01 to NRC request 3.6-6b.

If you have any questions or require additional information, please contact me.

Sincerely,

James C. Kinsey

Vames C. Kinsey Vice President, ESBWR Licensing



MFN 06-299 Supplement 2 Page 2 of 2

## References:

- 1. MFN 06-387, Letter from the U.S. Nuclear Regulatory Commission to David H. Hinds. *Request for Additional Information Letter No. 75, Related To ESBWR Design Certification Application*, dated October 10, 2006.
- 2. MFN 06-299, Letter from David Hinds to the U.S. Nuclear Regulatory Commission, *Response to Portion of NRC Request for Additional Information Letter No. 45 Related to ESBWR Design Certification Application - Protection against Dynamic Effects Associated with the Postulated Rupture of Piping - RAI Numbers 3.6-1 through 3.6-10*, dated August 28, 2006.
- 3. MFN 06-271, Letter from the U.S. Nuclear Regulatory Commission to David H. Hinds, *Request for Additional Information Letter No. 45, Related To ESBWR Design Certification Application*, dated August 3, 2006.

# Enclosure:

- MFN 06-299 Supplement 2, Response to Portion of NRC Request for Additional Information Letter No. 75 Related to ESBWR Design Certification Application Evaluation of Postulated Pipe Breaks -- RAI Number 3.6-6 S01
- cc:AE CubbageUSNRC (with enclosure)RE BrownGEH/Wilmington (with enclosure)GB StrambackGEH/San Jose (with enclosure)DE HindsGEH/Wilmington (with enclosure)eDRF 0000-0075-1590(RAI 3.6-6 S01)

**Enclosure 1** 

# MFN 06-299 Supplement 2

# Response to Portion of NRC Request for Additional Information Letter No. 75 Related to ESBWR Design Certification Application Evaluation of Postulated Pipe Breaks RAI Number 3.6-6 S01

MFN 06-299 Supplement 2 Enclosure 1

Page 2 of 3

# NRC RAI 3.6-6

In DCD Tier 2, Rev. 1, Section 3.6.2.2, GE states that blowdown forcing functions are determined by the method specified in Appendix B of ANSI/ANS-58.2. However, GE did not provide any details as to how the blowdown forces are calculated for the ESBWR design, and also did not provide any sample calculation to illustrate the adequacy of any analytical method. Also, there does not appear to be any consideration of how potential feedback between the jet and any nearby reflecting surface(s), which can increase substantially the dynamic jet forces impinging on the nearby target component and the dynamic thrust blowdown forces on the ruptured pipe through resonance, is considered.

Provide details (including the methods and computer programs, if any), with examples, for calculating the blowdown forcing functions at break locations that will be used by COL applicant. Also, include a description of how feedback amplification of dynamic blowdown forces will be considered in the calculation.

#### **GE Response**

Enclosure 2 provides sample calculations prepared for a typical ABWR Plant for the pipe break forcing functions for main steam pipe break at terminal ends, RPV nozzle and Turbine Stop Valve which is a representative method to be used for ESBWR Plant.

#### **DCD** Impact

No DCD change will be made in response to this RAI.

## NRC RAI 3.6-6 S01

*Part (b) of RAI 3.6-6 was not answered in the GE Response MFN 06-299, dated 8/28/06. Part (b) reads as follows:* 

(b) Also, include a description of how feedback amplification of dynamic blowdown forces will be considered in the calculation.

This portion dealing with ANS 58.2 issues was deferred pending further discussion. In NRC Letter #75 [MFN 06-387], NRC specified a response date of 11/22/06.

# **GEH Response**

The feedback amplification of dynamic blowdown forces to the broken pipe is calculated by nonlinear time history analysis of the piping system. The calculated time history responses automatically includes the appropriate amplification factors.

The feedback/resonance amplification for jet impingement to the component/structure interacting due to the blowdown loads is accounted for in the analysis by modeling the structure and applying the jet impingement time history load. Also, instead of a dynamic analysis, an equivalent static analysis can be performed with the use of a dynamic load factor as follows:

FS = DLF (Fimp max)

Where,

FS = Equivalent static impingement force DLF = Dynamic load factor Fimp max = Maximum value of the jet impingement force

The impingement force may conservatively be assumed to occur instantaneously and a DLF = 2.0 is used. A separate value for DLF may be analytically established based on DLF = dynamic deflection/ static deflection of the object being impinged upon.

# **DCD Impact**

No DCD changes will be made in response to this RAI.