

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY										
SR 3.5.2.4	Verify each ECCS pump's developed head at the test flow point is greater than or equal to the required developed head.	In accordance with the Inservice Testing Program										
SR 3.5.2.5	Verify each ECCS automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	24 months										
SR 3.5.2.6	Verify each ECCS pump starts automatically on an actual or simulated actuation signal.	24 months										
SR 3.5.2.7	Verify each ECCS throttle valve listed below is in the correct position. <table border="0" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th style="text-align: left;"><u>Unit 1 Valve Number</u></th> <th style="text-align: left;"><u>Unit 2 Valve Number</u></th> </tr> </thead> <tbody> <tr> <td>SI-15-6</td> <td>2SI-15-6</td> </tr> <tr> <td>SI-15-7</td> <td>2SI-15-7</td> </tr> <tr> <td>SI-15-8</td> <td>2SI-15-8</td> </tr> <tr> <td>SI-15-9</td> <td>2SI-15-9</td> </tr> </tbody> </table>	<u>Unit 1 Valve Number</u>	<u>Unit 2 Valve Number</u>	SI-15-6	2SI-15-6	SI-15-7	2SI-15-7	SI-15-8	2SI-15-8	SI-15-9	2SI-15-9	24 months
<u>Unit 1 Valve Number</u>	<u>Unit 2 Valve Number</u>											
SI-15-6	2SI-15-6											
SI-15-7	2SI-15-7											
SI-15-8	2SI-15-8											
SI-15-9	2SI-15-9											
SR 3.5.2.8	Verify, by visual inspection, each ECCS train containment sump suction inlet is not restricted by debris and the suction inlet strainers show no evidence of structural distress or abnormal corrosion.	24 months										

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.5.4.1 Verify RWST borated water volume is $\geq 265,000$ gallons (90%).	7 days
SR 3.5.4.2 Verify RWST boron concentration is ≥ 2600 ppm and ≤ 3500 ppm.	7 days