

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

June 20, 1980

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - STEAM GENERATOR WATER LEVEL
REFERENCE COLUMN ERROR - NCR MEB 79-33 - THIRD INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector
M. Thomas on July 6, 1979, in accordance with 10 CFR 50.55(e).
Interim reports were submitted on July 30, 1979, and September 27, 1979.

Two potential solutions to the reference leg heatup problem were
originally foreseen: (1) insulate the transmitter sensing lines,
or (2) provide temperature compensation of the level output signal.
Insulation of the lines is the quicker solution and was planned to
be installed initially. However, because of operational restrictions
of this solution, it was envisioned that temperature compensation
could be installed later and that the insulation could be removed.

Because of the high cost of insulation for the Sequoyah unit 1 narrow
range level instrumentation sensing lines, TVA is now investigating
the feasibility of initially installing the temperature compensation
and not utilizing the insulation for Sequoyah unit 2 and Watts Bar
units 1 and 2. The temperature compensation solution would utilize
electronic instrumentation to compensate for the density changes
in the reference column and in the steam generator vessel. The
temperatures of the water in the column and in the vessel would be
measured and be fed into a microprocessor or an analog summation unit
which would develop an output level signal corrected for density
changes caused by temperature. TVA has been in touch with two pro-
spective vendors of the proposed instrumentation, and Westinghouse
has been asked to review the proposed systems. Potential problems

B019
S
1/0

8006250198

S

Mr. James P. O'Reilly, Director

June 20, 1980

associated with the systems, such as environmental qualification, accuracy, and interfacing with existing equipment, are being evaluated. We expect to supply additional information by August 22, 1980.

If you have any questions concerning this matter, please get in touch with D. L. Lambert at FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager
Nuclear Regulation and Safety

cc: Mr. Victor Stello, Jr., Director ✓
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555