

USNRC REGION  
ATLANTA, GEORGIA

15 MAIL/19/15

79 JUN 5 TELEPHONE REPORT

FACILITY: Watts Bar 1 & 2

DOCKET #: 50-390, 391

DATE: 6/4/79

TIME: 4:00 p. m.

LTC. OCC. #: CEB 79-21

SUBJECT: CDR Reactor Vessel Insulation Supports  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

DESCRIPTION OF OCCURRENCE: The support structure for the thermal insulation

is not adequate to withstand the design seismic event. This is a

Westinghouse supplied item. The impact of the insulation on the

incore instrumentation nozzles exceeds the design allowable stresses.

Part 21 determination needed.

I informed them that North Anna first reported this August 3, 1978 and

TVA should inquire why Westinghouse did not inform TVA before June 1979.

SIGNATURE

7906190353

7906190353

2019  
A002  
S 0/1

790178  
OFFICIAL COPY