

**TENNESSEE VALLEY AUTHORITY**

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

September 27, 1979

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - STEAM GENERATOR WATER LEVEL  
REFERENCE COLUMN ERROR - NCR MEB 79-33 - SECOND INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector M. Thomas on July 6, 1979, in accordance with 10 CFR 50.55(e). Our first interim report was submitted on July 30, 1979. The detailed analysis by Westinghouse of a main feedwater line break has not been completed. A setpoint change in the low-low steam generator water level, and possibly other changes, will have to be made. We expect to submit our next report by June 20, 1980. This deficiency was reported for Sequoyah Nuclear Plant as NCR QEB 79-32.

If you have any questions concerning this matter, please get in touch with D. L. Lambert at FTS 854-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager  
Nuclear Regulation and Safety

cc: Mr. Victor Stello, Jr., Director ✓  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

7910 040 264

Boia  
S/P