

RECEIVED
JAN 10 1981
50
TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

January 6, 1981

80-059-036✓

80-056-034✓

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 AND SEQUOYAH NUCLEAR PLANT UNIT 2 -
SEISMIC ANALYSIS OF CHECK VALVE IN CVCS - NCR SQN CEB 8028 AND NCR WBN CEB
8007 - SECOND INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector
M. Thomas on October 2, 1980, in accordance with 10 CFR 50.55(e). A first
interim report was submitted on October 31, 1980. We expect to submit our
next report by February 10, 1981.

TVA has determined that loads from the 3-inch check valve at Sequoyah are
not significant. Therefore, no hardware changes will be required. The
results of the reanalysis at Watts Bar will not be available until
mid-January.

If you have any questions, please get in touch with D. L. Lambert at
FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills

L. M. Mills, Manager
Nuclear Regulation and Safety

cc: Mr. Victor Stello, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

3019
S
1/0

810 1260427
S

OFFICIAL COPY