

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

April 9, 1981



Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - SEISMIC QUALIFICATION OF CONTROL
EQUIPMENT - NCR WBN EEB 8005 - SECOND INTERIM REPORT

The subject deficiency was initially reported to NRC-OIE Inspector M. Thomas on September 22, 1980. Our first interim report was submitted on October 22, 1980. We expect to provide additional information by July 22, 1981.

Wyle Laboratories has not yet completed the testing of control equipment mounted in boxes to document the seismic qualification of this equipment. This equipment is used to control MOV's, motors, fans, and similar equipment.

If you have any questions concerning this matter, please get in touch with D. L. Lambert at FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager
Nuclear Regulation and Safety

cc: Mr. Victor Stello, Jr., Director ✓
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

5 8104170 249

B3019
S 1/0