## **TENNESSEE VALLEY AUTHORITY**

**CHATTANOOGA. TENNESSEE 37401**

**400** Chestnut Street Tower II

**August 28, 1981** 



Director of' Nuclear Reactor Regulation Attention: Ms. **E.** Adensam, Chief Licensing Branch No. 4 Division of Licensing U.S. Nuclear Regulatory Commission Washington, DC 20555

Dear Ms. Adensam:

In the Matter of the Application of ) Docket Nos. 50-390 Tennessee Valley Authority (30-391)

Enclosed is TVA's response to NRC requests for information concerning the potential for liquefaction of soils at the Watts Bar Nuclear Plant site. Included are responses to NRC questions 362.29 through 362.35 provided by R. L. Tedesco's letter to H. G. Parris dated March 30, 1981 and question 362.36 provided by R. L. Tedesco's letter to H. G. Parris dated May 7, 1981.

If you have any questions concerning these responses, please get in touch with D. L. Lambert at FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager Nuclear Regulation and Safety

Sworn to and subscribed before me this 28th day of **Uugust** 1981 Notary Public

My Commission Expires  $\frac{9-5-84}{5}$   $\frac{8-8}{5}$   $\frac{80}{5}$   $\frac{1}{1}$ 

Enclosure the contract of the



#### Question **362.29** (2.5.4)

The measured settlement data given in Figures Q362.19-1 through Q362.19-5 of the PSAR is provided only up to June **1978.** Provide time vs settlement plots of up-to-date settlement data obtained for all Category I structures where settlements are being monitored. Tabulate values of the measured maximum differential settlements and show comparisons of the measured data with anticipated settlements assumed in the analysis of these structures and their appurtenances, and evaluate the impact of any differences between the measured and anticipated settlements on the design and construction of these structures and appurtenances. Staff requires that the settlement of safety related structures and appurtenances be monitored for a period of at least five years after the issuance of the operating license and the impact of observed settlement, if any, on the design limits of Category I structures be evaluated periodically.

#### Response

The time vs settlement plots of Unit **1** and 2 Reactor Building **of** Figure Q362.19-1 and Q362.19-2 reflect the latest data available. Readings were discontinued June 1978, because settlement stations became inaccessible. The updated time vs settlement plots are provided in Figures **Q362.29-1** and -2 for the Auxiliary-Control Building, the Diesel Generator Building, and the Intake Pumping Station.

Tables **Q362.29-1** through **Q362.29-3** provide all the maximum and minimum movements for all the settlement stations in Category I structures. The differential settlement readings for the rock supported structures are provided in Table **Q362-29-4.** Settlement stations location are provided in Figure **3.8.4-66** and **3.8.4-67.** The maximum settlement of **.057** feet and the maximum differential settlement of **.038** feet between the Reactor Building Unit 1 and the Auxiliary Building were recorded on August 3, 1977. This maximum value is virtually unchanged through April **1980.** The measured differential settlement of **.060** feet between settlement stations **(SS) 18** and **23** was judged to be a measurement error for three reasons. First the differential settlements one month before and after were recorded to be **.008** feet and .024 feet respectively, second the latest reading between **SS18** and **SS23** was recorded to be **.018** feet of differential settlement, and third the maximum settlement recorded a year before and after the error was **.033,** feet between **SS18** and **SS23.**

The measured settlements have not approached the design criteria of **1** inch of differential settlement between buildings or 1 to 2 inches of total settlements with respect to the surrounding area. In general the maximum settlements of rock-supported structures had occurred **by 1977,** and thereafter the settlements have been stable or decreasing.

242,294

302

ma shekara<br>Timo a shekara ta 19

in the same company

بالمستك المتقاقص الممالحة

**-. 29-1**

أركوا فالمساعدين المشابطة

ال الموسيقات الأولاد.<br>الموسيقات الموسيقات

المتوقفة لالات المراب المحاجب واستثنائه المقاربة وعلى المحافظ المتعالم المعارفة المتحدة المتحدة المتحدة المتحدة المتحدة المتحدة ال<br>المحافظ المعارفية المحافظة المتحدة المتحدة المتحدة المحافظة المتحدة المتحدة المتحدة

ina ka

.. **362..29-2....**

For the Auxiliary-Control Building and the Intake Pumping Station readings were discontinued April 29, 1980. The Diesel Generator Building is a soil supported structure and is still being monitored. We have fulfilled our commitment of monitoring rock supported structures since the structure loading is essentially complete on all rock supported buildings, all the total and differential settlements are well within the design criteria allowables, and settlements have not increased in the rock supported structures during the past 2 years of monitoring.

Based on our evaluation, the total and differential settlements are not<br>significant; there are no trends being exhibited; there has been no adverse structural performance; and there are not any anticipated problems from the settlement of Category I structures.

## TABLE Q362.29-1

# SETTLEMENT STATION READINGS

# FOR THE REACTOR BUILDING UNITS 1 AND 2

## AND THE AUXILIARY-CONTROL BUILDING



## TABLE Q362.29-2

## SETTLEMENT STATION READINGS

#### FOR THE INTAKE PUMPING STATION

	Most Recent Reading		Maximum Downward		Maximum Upward		
Settlement Station	المستورين *Settlement (Feet)	Date	Movement (Feet)	Date	Movement (Feet)	Date	Initial Reading Date
	$-0.004$	$06 - 06 - 77$	0.009	$05 - 10 - 77$	0.036	$05 - 11 - 76$	$10 - 17 - 74$
1 <sub>A</sub>	$-0.010$	$04 - 23 - 80$	0.026	$02 - 02 - 79$	0.007	$07 - 10 - 78$	$03 - 15 - 77$
$\sim$ 2	$-0.010$	$06 - 06 - 77$	0.018	$05 - 10 - 77$	0.013	$03 - 15 - 77$	$10 - 17 - 74$
3	$+0.001$	$06 - 06 - 77$	0.018	$03 - 21 - 75$	0.011	$05 - 09 - 75$	$12 - 19 - 74$
3 <sub>A</sub>	$-0.011$	$04 - 23 - 80$	0.032	$02 - 02 - 79$	0.003	$07 - 10 - 78$	$08 - 03 - 77$
4	$-0.002$	$04 - 23 - 80$	0.019	$02 - 02 - 79$	0.012	$07 - 10 - 78$	$03 - 15 - 77$

\*Positive settlement is up.

 $\ddot{\hspace{1ex}}$ 

## TABLE Q362.29-3

### SETTLEMENT STATION READINGS

#### FOR THE DIESEL GENERATOR BUILDING

**0**



\*Positive settlement is up.

Note A: The Initial Reading was the maximum upward value.

## TABLE Q362.29-4

#### DIFFERENTIAL SETTLEMENT BETWEEN ROCK SUPPORTED STRUCTURES



\*This is the second highest differential settlement for SS18 and SS23, the highest is peculiarly<br>high in August of 1977.

S=Settlement . AS=Differential Settlement

B61187.10

#### Question 362.30(2.5.4)

Indicate how much settlement of the structures has occurred since the connections between structures and safety-related utilities were made. Evaluate the effect of the past and anticipated future setttlement of structures on safety related utility connections.

#### 362.30 Response

S. problems.<br>S.p. 1992.<br>S.p. 1993.

أنكو المتعارف والمتحارب

Connections between the structures and the safety related utilities were made at various times. The ERCW piping connections were made betuveen November 1977 and June 1978. Safety-related IE electrical conduits were connected to structures from June 1976 to March 1978. The past settlement performance of the structures are provided in Question 362.29. The anticipated future settlement is expected to be less than 1 inch for the structures.

Direct settlement recordings of the safety-related utilities were not made. It is anticipated that very little differential settlement will occur at the connections for the following reasons:

- 1. When interfacing with the structures, the electrical comduit banks rest on reinforced concrete brackets, and the brackets prevent differential settlement at the interface.
- 2. The ERCW pipes enter the Die el Generator Building (DGE) through an encasement that rests on reinforced concrete brackets; at the interface with the DGB. Similiar to the electrical conducits, the brackets will prevent differential settlement at the interface.
- 3. The ERCW pipes enter the Auxiliary-Control Building through a pipe tunnel approximately 200 feet long, which rests on in situ gravel and eliminates any differential settlement problems.
- 4. The electrical conduit banks and ERCW pipes have a pile supported concrete slab to alleviate any differential settlement at the Intake Pumping Station.
- 5. When an ERCW pipe connects with a structure, a 2 to 6 imch clearance is maintained between the pipe and sleeve. The clearance if filled with a flexible watertight sealant..
- 6. The total settlements of the structures are less than E inch which means that the structures will not cause any significamt differential settlements at the connections.

a a shi kati ta ta wakazi

Differential settlements of the connections between structures and safetyrelated utilities is not anticipated to result in any significant problems.

 $50 + 1$ 

a<br>Santa Santa<br>Santa Santa Santa

**362'30-..** .. . , *-* .... ,..1. .-.. 7• .,"... *:" "* \* ,.• *'.* .. *-* - : *-* . . • . .. .. \* r l•, **.3.0..** .. .. -7, *o.• . •.* \_ .. . <sup>z</sup>*. .* \_ . .• . .

WBNP-45

Question:

 $362.31$  Your response to Question Number  $371.23$  indicates that you are  $(2.5.4)$ relying on proper performance of weep holes to maintain water level at elevation 685 for retaining walls at the intake pumping station and that, based on the performance of weep holes, you have used this water elevation in the design of retaining walls. Provide the following information:

- (i) The factors of safety for sliding and overturning of the walls based on water elevation of 685. Please provide analysis method and bases for assumptions made in the analysis.
- (ii) The safety factors in the design of retaining walls, if weep holes were ccnsidered inoperative due to blockage or plugging?
- (iii) Details of monitoring program, if any, to assure the proper performance of weep holes during the life of the plant.

#### Response:

Sheet Pile Wall.

(i) Although in "Response to Question 371.23 (2)" it is stated that the 685.0 elevation is maintained by weep holes, this fact was not used in determining the stability of the sheet pile retaining walls. The following were two of the assumptions considered in the design of the retaining walls: **(1)** Saturated soil up to elevation 700 with no water on opposite side. (2) Dry soil on one side, no water on other. Since these assumtions provide conservative results, no factors of safety were calculated for walls based on water elevation 685. The method used in the analysis of retaining walls was provided by C. W. Dunham's book, Foundations of Structures, Second Edition, pages 468-474.

(ii) In Dunham's book he acknowledges the need for conservation in design and therefore has provided a certain amount in his design procedures. The anchorage used in bracing the retaining walls has a-factor of safety of 1.25 for the controlling

 $-362.31 - 1$ 

**3 3 2 -1** . . . . . . **<sup>2</sup>**

design case of **SSE.** .~..-

(iii) No monitoring system is provided.

Concrete Wall:

**.. .... ....**

(i) With water at elevation **685.0** the retaining walls are submerged : no differential water pressure. Factor of safety against overturning  $3.96$ . Wall keyed into rock . no problem from sliding.

**362-31** 2

- (ii) Same as above.
- (iii) No monitoring program provided.

#### Question 362.32(2.5.4)

The information provided for the foundation soil conditions underneath several Category I structures, e.g., ERCW Discharge Overflow Structure, Refueling Water Storage Tanks and Waste Packaging Area is not sufficient to complete the review. Where applicable, provide the depth to bedrock, properties of in situ gravel, properties and thickness of granular fill under the structure, and excavation and backfill details for these Category I structures. Provide details of pile foundation design and installation for category I structures founded on piles (e.g., Condenser Demineralizing Building and ERCW Pipe Slabs).

#### Response

FSAR Figures 2.5-225, 2.5-226, and 2.5-226a show depth to bedrock and thickness of granular fill under the structure with backfill details for Category I structures.

The response to question 362.28 provides the properties of in situ gravel. Granular fill properties are provided in Table Q362.26-2. Table Q362.32-1 provides details of pile foundation design and installation for the Condensate Demineralizer Waste Evaporator Building and the ERCW Piping and IE Electrical Conduit Support Slab.

- - j - ~ - . **362.32-i**

Condensate Demineralizer



ERCW Piping and Conduit Support Slab

 $\sim$ 



Note **E:** Designed for end-bearing only. Skin friction was not used in design.

Note F: 48 Blow/inch of 30,000 ft-lb hammer at full listed speed producing penetration less than 1 inch.

Note-C:-Pield-used-15,000-ft-lb-rather-than-30,000-ft-lb hammer, NCR CDB 79-3 was submitted with no corrective action

#### Question 362.33(2.5.4)

Provide quantitative and procedural details of the basis for the dynamic soil properties used for horizontal and vertical soil-structure interaction analysis of the diesel generator building. Indicate the design water table used in seismic analysis and describe how the effect of water table was considered in the vertical seismic analysis.

#### Response

Single Control of Control of the Second Products

The procedure in the analysis for soil-supported structures is to consider the soil deposit as an elastic medium, and to make a dynamic analysis of a slice of unit thickness considering only the horizontal shearing resistance of the soil.

The shear wave velocity in the analysis was influenced by the in situ soil measurements, ground water, slanted soil layers, soil density variations, and variations in bedrock elevation. The shear wave velocity  $(V_s)$  of the in situ firm gravel is approximately 1650 fps from the FSAR Table 2.5-16. Also see Q362.12 response for technique used for downhole seismic velocity. The shear wave velocity of the crushed stone backfill is assumed equal to. the firm gravel. Due to uncertainties in the determination of the soil properties, the shear wave velocity of soil is varied ±30 percent to calculate the horizontal ground surface motions. A soil damping ratio of **10** percent is used for the soil deposit.

The maximum ground surface accelerations, based on 0.09 g horizontal and 0.06 g vertical accelerations at the top of rock, were 0.27 g horizontal and 0.18 g vertical for the 1/2 Safe Shutdown Earthquake. The vertical motion is considered to be two-thirds of the horizontal.

The shear wave velocity of the soil was also varied  $\pm 30$  percent to calculate the soil springs used in the analysis of the structure. Analysis of Foundation Vibrations by R. V. Whitman was used to calculate the soil springs. Table Q362.33-1 lists the normal modes of vibration of the structure using the different soil springs. Using the ground surface motions, the analysis of the structure indicated the primary motion of the structure to be a translatory rigid body motion. This motion is predominant because approximately 70 percent of the structure's weight is concentrated at the base, and also because of the soil on which the structure is supported. Vibrations of Soils and Foundations by F. E. Richart explains that motion of this type results in a high damping ratio. Only **10** percent damping is used in the structural analysis, which results in conservative responses.

Due to the soil-structure interaction, the effects of the structure and soil springs amplify the horizontal ground surface acceleration at the base of the structure to 0.54 g for the 1/2 Safe Shutdown Earthquake.

**362 33-! .I. ..** .

# $TABLE Q362.33-1$

## NORMAL MODES OF VIBRATION

 $V_S = 1155$  FPS

	N-S Motion	E-W Motion		
	$K_T = 147 \times 10^4$ K/Ft	$K_T = 141 \times 10^4$ K/Ft		
Mode $\underline{\text{No}}$ .	$K_R = 300 \times 10^7$ ft-K/rad Period, Second	$K_R = 425 \times 10^7$ ft-K/rad Period, Second		
	0.154	0.156		
$\mathbf{2}$	0.103	0.111		
	0.029	0.035		

 $V_S = 1650$  FPS

	N-S Motion	E-W Motion		
Mode $\underline{\text{No}}$ .	$K_T = 308 \times 10^4$ K/Ft $K_R = 614 \times 10^7$ ft-K/rad Period, Second	$K_T = 294 \times 10^4$ K/Ft $K_R = 887 \times 10^7$ ft-K/rad Period, Second		
	0.108	0.110		
	0.072	and the 0.077		
	0.028	0.034		

 $V_S = 2145$  FPS



#### Question 362.34 (2.5.4)

In response to question 371.23 you indicate that use of a permanent<br>dewatering system is required to permanently lower ground water levels at<br>safety-related structures. Provide an evaluation of the effect of the lowered water table on the stability and settlement of Category I structural foundations.

#### Response

Category I structural foundations at Watts Bar Nuclear Plant are supported<br>on 1032 crushed stone fill, basal gravel and rock. Information on site geology, material properties and foundation conditions is available in<br>section 2.5. Briefly, however, rock at the site consists of consolidated,<br>low porosity, interbedded limestone and shale of the Conasauga formation. Basal gravel extends to partially weathered rock and is essentially a firm to dense granular soil. The 1032 crushed stone fill extends to either rock or basal gravel and is also a dense granular soil.

Permanent lowering of the ground water table to the design level should not adversely affect Category I foundation performance. More specifically, the Conasauga formation is essentially unaffected by the lowered ground wat level. However, the basal gravel and 1032 crushed stone should exhibit a positive response to the lowered water table typical of firm and dense granular soil. Basically, the bearing capacity of such granular soils increase with the increase of their effective unit weights. Also, the<br>modulus of elasticity of firm granular soils increases with the increase of<br>the effective confining pressure. This offsets the tendency for increased<br>de foundation performance when compared to the design forecasts.

> $\mathbb{R}^{n+1}$  $\mathcal{F}$ i...  $\mathcal{F}$ I

-~~~ ... ,32. **6** q•9 34-l. N'..

#### WBNP -45

Question:

**362.35** In June **of 1979,** you reported that the piles supporting category  $(2.5.4)$ I ERCW pipe slabs were not driven to drawing requirements. In March **1980,** based on load tests on six piles driven to the same criteria you concluded that no corrective action is required. You also indicated at that time that field measurements show no settlement of the slabs. Provide the following information:

- (a) quantitative and procedural details of the pile load tests conducted to verify the adequacy of installed piles. Provide the design loads, test loads, the location of-test piles, comparison of soil conditions at the location of test piles and the piles installed under the ERCW pipe slabs and load test results.
- **(b)** up-to-date time vs settlement plots at various locations **of** the slabs where settlements are being monitored. Tabulate the values of the measured maximum differential settlement of the slabs and evaluate its effect on the allowable stress levels in these slabs.

#### Response:

(a) Load tests were performed to establish **(1)** pile load capacity for the existing piles supporting the slab and (2) allowable design load for any additional piling that might be required. Two tests were performed for each of the following pile sizes:

.. **~~362.35-1....**

For Load Capacity For Allowable Design Load<br>of Existing Piles For Additional Piles

HP 12 x 53 Hl 12 **<sup>x</sup>**<sup>74</sup> HP 12 x 74

count.

representative of the Civil Engineering and Design Branch (CDB) witnessed the driving and load tests.

Locations of the six test piles and other procedural details are shown on  $t_igures$  Q362.35-1 and 362.35-2. (Deviation of pile location did not exceed 3 inches. Vertical deviation for all piles was less than 1/4 inch per foot of longitudinal axis.)

The driving criteria varied according to the function of pile testing, i.e., **(1)** determining load capacity or (2) determining allowable design load. The four piles tested to determine load capacity were driven to a penetration count of 48 blows for the last inch with a Vulcan Iron Works piledriver, model **1,** developing 15,000 foot-pounds of energy with a hammer weight of 5,000 pounds and a 3.3-foot stroke. Cushion material for the Vulcan **<sup>1</sup>**hammer was 1-1/2 inches of plywood. The two piles tested to determine allowable design load were driven to penetration counts as shown in the table below with a Kobe K-22 diesel hammer. Note that the actual hammer stroke attained while setting the pile controls' the specified blow

**362.35-2.**



Cushion material for the Kobe K-22 hanmer was 3 inches of micarta. Piles which have not reached the required penetration rate per blow when the top has been driven to within 18 inches of grade were spliced in accordance with detail shown on Figure Q362.35-2.

After the piles were driven, there was a waiting period of 14 days before the piles were tested. The piles have a maximum test load as shown below:



The load tests were performed and reported as outlined in section 4.0 of Civil Design Guide DG-Cl.6, "Design Guide End-Bearing H-Piles."

Results of the pile load tests are presented in the form of settlement versus load plots. These graphs are shown on figures Q362.35-3 through --6. Design loads and test loads are found in table  $Q362.35-1$ .

To eliminate the effect of different soil conditions, the piles tested were located in the same general area as the piles under the ERCW pipe support slab.

362.35-3

.......... **.**

(b) To obtain the field measurements of the elevations of the slabs, the field had to dig through **18±** inches of earth, chip through 18 inches of missile protection slab,and then dig through the earth surrounding the pipe to the top of the slabs. At that time the slab had been in place approximately 2 years. These field measurements showed no settlement of the slab even though subjected to crane and equipment loadings during construction of the intake pumping station. The slabs are adequate structures as designed and constructed. Since the time of the measurements, repairs have been made without provisions being made to monitor any settlement. Therefore the information in question 362.35(b) is not available. However, the elevations measured by the field and the required elevation of the slabs are shown in table Q 362.35-2.

362.35 **,- . . . . .... ....**

'I





\* SETTLEMENT (INCLUDING ELASTIC COMPRESSION)

WATTS BAR NUCLEAR PLANT<br>FINAL SAFETY<br>ANALYSIS REPORT

TABLE 0362 35-1







FIG. Q362.35-5



**FIGURE 0362.35-5** 



FIG. Q362.35- **6**

PILE NO. *r* HP 12,x74

 $P_4 = 260 \text{ K}$ 

VULCAN HAMMER

*-/.93*



**FIGURE (1362.35-6**



 $*$  SEE  $F_{IG. Q}$ 362.35-7



FIG Q362.35-7



#### Question 362.36

Your response to Q362.27, in Ammendment 2 has not provided sufficient information to establish that the zone of alluvial silty sands and sandy silts within the foundation of the Class IE Electrical Conduit and the Essential Raw Cooling Water pipeline are not loose and potentially susceptible to liquefaction. The information required by the staff for an adequate review was requested earlier in  $Q362.14$ ,  $Q362.24$  and  $Q362.27$ , but has not been provided to the staff. We request again that you provide the following information in sufficient detail for an independent staff review.

- 1. Provide following plots drawn to scale on two large size drawing;s (approximately 22 inches by 34 inches) for category I Essential Raw Cooling Water pipeline and Class IE Electrical Conduit. Provide one drawing for essential Raw Cooling Water pipeline and the other for Class IE Electrical Conduit.
	- (a) Locations and routing from one end of the utility to the otiber, clearly identifying the lines.
	- (b) Locations of the borings along the route of the pipeline and the conduit. Indicate by legend the type of sampling in these borings (split spoon or undisturbed sampling) and show the spacing between individual borings. Show the locations of the pertinent borings that provide information about the liquefaction potential of soils under question.
	- (c) Show the contours of the as-built ground surface along these utilities after placement of fill.
- 2. Explain your basis for using borings spaced as much as 200 to 4M0 feet apart along the routes of these lines to provide reasonable assurance that the soil profile underneath the utilities does not contain materials susceptible to liquefaction. Note that boring log SS-30 shows about 10 feet of loose alluvial material below water table and because of the wide spacing of the borings, the lateral extent of the loose zone cannot be established in this area. Explain how the extent of loose alluvial material was determined from the widely spacedi borings in different sections along the routes.
- 3. On two large size drawings (approximately 22 inches by 34 inchexs), provide the following details to scale for Category I EssentiaL Raw Cooling Water pipeline and Class IE Electrical Conduit. Provid'e one drawing for ERCW pipeline and the other for Class IE conduit.
	- (a) The pertinent boring logs along the routes of the conduit and pipeline showing the fill above the pipeline and conduit. The spacing between the logs should be to scale as well. Provide the classification and blow count information on this plot. If some of the borings along the routes are not used in the liquefaction potential evaluation (e.g., borings 52, 66, 89, 91, 98, 100, and  $102$ , identify and provide logs for these borings. Provide justification for not using these borings in your analysis. **S** 362...... **:-6-1** " . ... 7! -'•,: '':. • - ...... ... .. . ,,,•-.,,. :,-,...... . . 3 62 .36-1 ... , , . ........ • .... . .•.. . . . . .

المتحد سأتنفذ

- (b) Show soil stratification and top of shale boundary on the profile.
- **(c)** Draw 25-year high water level on profile and discuss how it corresponds to the water table information presented in Section 2.4.13.2.
- **(d)** Draw the invert and top of Class IE-Electrical Conduit and ERCW pipeline on these logs.
- (e) Show the as-built fill above the pipeline and the conduit and indicate the ground surface elevation on the logs.
- 4. Based on the information provided in items **1,** 2, and 3, discuss in detail the probable vertical and lateral extent of the alluvial solid with *N* 30 that is below the 25-year high water table. Discuss the gradation, relative density and cyclic strength characteristics of material in this strata.
- 5. Provide details of the dynamic response computatioms and the factors of safety for liquefaction potential of alluvial soils in the profile along the routes of the utilities. Include the following information:
	- (a) The cross-section of the one dimensional soil profile analyzed.<br>Indicate the water table elevation used in the analysis. Discuss any conservatism in selecting the profile.
	- (b) The dynamic soil moduli and damping values of the various soils in the profile. Provide the value of the coefficient of earth pressure at rest used for the analysis.
	- (c) The characteristics of the seismic input used. for liquefaction analysis, viz, response spectrum of the input notion, and its point of application in the soil profile.
	- (d) The method of dynamic response analysis, varicus assumptions used for converting the irregular shear stress time history to 5 cycles of equivalent uniform cyclic stress. Show typical results.
	- (e) Provide the results of analysis for the entire profile.
	- **(f)** Justify the use of the cyclic strength properties curve given in response to Q362.27. Explain the scatter in the laboratory test data and justify your interpretation of the data.
	- (g) Provide a table of factors of safety for the alluvial material at various depths against liquefaction potential.

## Response

المتعدد والمتعالم والمستحدث

**<sup>1</sup>**1. The Category I Essential Raw Cooling Water pipeline and Class IE Electrical Conduit locations are provided in Figure Q362.36-1. The plan view provides the following: when  $\frac{1}{2}$ 

 $(a)$  Location and routing from one end of the utility to the other end. - 562.36-2

 $\begin{pmatrix} 1 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \\ 0 &$ 

nas<br>William Holdens Anti-State (1970) – Something (1971) – Something (1971) – Something (1971) – Something (1971)

- **(b)** Location of the borings along the route of the pipeline and the conduit.
- (c) And contours of the as-built ground surface.
- 2. The original borings along the ERCW route were spaced at 200 to 400 foot centers. A later (November 1979) investigation reduced the spacing between borings to approximately **100** feet. These boring, locations and data are shown on Figure Q362.36-1.

The original borings for the **IE** Electrical Conduit route (when different from ERCW route) were spaced on 200 foot grid centers. The IE Electrical Conduits pass diagonally through part of this area and traverse a course through the switchyard to the main plant area. The spacing of these holes is sufficient to define the soil profile for routing of the conduit banks. No low blow count sand or potentially liqueficable material was identified in these higher elevation residual soils.

- 3. A profile of the ERCW pipes are provided in Figures Q362.36-2 thmugh Q262.36-5. The **1E** Electrical conduit p:rofiles are provided in Figures Q362.36-7 through Q362.36-9. The profiles provide the following information:
	- (a) Pertinent boring logs along the routes showing blow counts and the material classification of the in situ soil.
	- (b) The elevation of original grade, final grade, and the top off rock. (Note: Fill material was used to backfill around the pipes and to achieve final grade.)
	- **(c)** The electrical conduit and ERCW pipelines and their elevation to scale.
	- $(d)$  The 24 hour water table.

tan Protokol (1988) <del>shekara</del> basaye

Borings 52, 66, 89, 91, 98, 100, and 102 were not drilled. Some of the borings were back-fitted with borings 137, 143, 146, 154, 157, amd 160. A generalized soil stratification is provided in Figures Q362.36-10.

A 25-year water table was not established. In section 2.4.13 off the FSAR the ground water is discussed in detail. The Knox Dolomite is the principle source of flow to streams of the region. Other formations within the site region, described in detail in section 2.5.1.1, include the Rome Formation, a poor water-bearing formation; the Conasauga Shale, a poor water-bearing formation; and the Chickamauga Limestone, a poor-to-moderate water-bearing formation that normally yields only 25 gpm to wells.

The plant site is underlain by the Conasauga Shale, which is made up of  $F$ <sup>2</sup> *Four-Four-Four-Referent informations. Which occurs as this* **C\_ E-** .con01nueU.5 **DeCd.** Surficia maEera" a cidCe **terraCE** ceDoE-::. ant recent alluvial soils mostly finegrained, poorly sorted, and poorly water-bearing. water-bearing.  $362.36-3$ 

المنصر السلا

All recharge to the ground water system is from local precipitation. There is no regional subsurface transport of water. All ground water discharge from the site is to Chickamauga Lake, either directly or via Yellow Creek.

Six observation wells were set up in 1973 at the site to monitor the ground water. The wells in FSAR Figure 2.4-104 are not in the near vicinity of the ERCW piping or electrical conduits.

Monitoring of the wells show that they fluctuate ±5 feet due to seasonal change. The water level in the wells will rise in the winter and spring and drop in the summer and fall, typical of the local precipitation.

- 4. The blow counts of the alluvial soils are given in Figures Q362.36-2 through Q362.36-9. The extent of the alluvial sand are provided in Figure Q362.36-10. The characteristics of alluvial soil susceptible to liquefaction are given in Figures Q362.27-1 through Q362.27-15 and tables Q362.27-1 and Q362.27-2.
- 5. (a) The profile selected and analyzed is based on boring SS-50-1. This boring is shown in Figure Q362.27-1. This boring contained the most SM Material. Surface elevation is 716.9 feet. Around elevation 685 and 690 the blow count increases to +50 and is identified as "top of weathered shale." This is assumed as "top of rock" for the liquefaction evaluation. Thus the depth of the profile is 30 feet. The water table is about 15 to 20 feet below the ground surface in boring SS-50, SS-50-1, SS-65, and SS-65-l. Thus the water table is assumed to be 15 to 20 feet below the ground surface. The profile analyzed is fairly typical of those along the ERCW route. This generalized soil profile is shown graphically in Figure Q362.36-11.
	- (b) The soil unit weight (moist) is taken as 120 pcf. The shear wave velocity of the soil is taken as 1000 ft/s. This value is in agreement with data obtained from the intake channel and elsewhere on the site. The strain dependent shear modulus and damping ratio properties of these soils are assumed to conform with the relationships developed by Seea for sand. The coefficient of earth pressure at rest  $(K_0)$  is conservatively taken as 0.5. All soil properties are assumed to be constant with depth.

The rock has a unit weight of 165 pcf and a shear wave velocity of 5900 ft/s.

(c) The seismic input at the site is defined as a 0.18g earthquake at top of rock. Four artificial accelerograms are used to define this event. This is inappropriate for use in a liquefaction evaluation and is not used. The liquefaction evaluation is performed using another artifical accelerogram which conforms to Reg. Guide 1.60 requirements. Peak accelerations of 0.18g, *C.* 225g. and *C.* 25g are considered. The accelerogram was also high

 $\pi_{\mathcal{P}}$ 

**-362.36-** .

**Contract Contract** 

A TUTT TRANSPORT SON AND LATER ان کے سندھ کی کہانی پارچائی پارچائیں ہے۔<br>1997ء کی میڈیا کہ اس کے اس کے اس کے اس کے ان

 $\sim$  4  $\sim$  4  $\sigma$ id show and band pass filtered to eliminate frequencies greater than 5 Hz for three cases and 25 Hz for two cases. In all, five different analyses are performed and are listed below.



The most appropriate seismic loading is case 1 where the 0.25g accelerogram is applied at top of ground with a 5 Hz uppper frequency cutoff. Its results essentially envelope all cases except for case 5 where the input is at top of rock.

- (d) The dynamic response analysis is performed using the computer program SHAKE. Irregular shear stress time histories are not calculated. The equivalent uniform cyclic stress is taken as 65% of the maximum cyclic shear stress within each layer of the profile as calculated by SHAKE.
- (e) The results of the analyses are given in the attached table. The maximum and equivalent uniform stresses within each layer and the peak accelerations at the top of each layer are summarized in Table Q362.36-1 for all five earthquake input conditions.

For material located about 17.5 feet below the surface (approximately the elevation of the samples tested cyclically), the max shear stress is:

 $Z_{\text{max}}$  = 500 psf

The average shear stress is:

 $\mathcal{F}_{\text{avg}}$  = 0.65  $\mathcal{F}_{\text{max}}$  = 325 psf

The vertical pressure at 17.5 feet is:

 $\bar{U}_v = Y_h = (120 \text{ pcf})(17.5 \text{ feet}) = 2100 \text{ psf}$ 

Assuming a  $K_0 = 0.5$ , the horizontal stress is:

 $\bar{\sigma}_h = 0.5 \bar{\sigma}_v = 1050 \text{ psf}$  use 1000 psf

The cyclic stress ratio is:

می از بار میافتند.<br>این دولت میان آفراز از این می از بار وال برابردهد in Baltimore.<br>The State of State o

$$
\frac{C_Z}{2 \t C_3} = \frac{2}{C_3} = \frac{325 \text{ psf}}{1000 \text{ psf}} = 0.32
$$

From Figure Q362.27-15 the most susceptible sample will survive seix load cycles with this stress ratio. We expect only five  $362.36 - 5 \times 3$ 

uniform load cycles from our **0.18g** to **0.25g** event. This event is an intensity VIII earthquake and is characterized as a m **big 5.8.** Extrapolating Seed and Idriss's data,



we conservatively have **5** cycles of uniform load for a magnitude **5.5** to **6.0** event. Factors of safety against the development of **5** percent strain are given in Tables **Q362.36-2** and **Q362.36-3** and for seismic loading case 1. Results are presented for cases where the water table is not considered and where it is located **16.5** feet below the surface. The **16.5** is in the upper range as given in the borings and the exact number 16.5 is chosen for convenience only. Factors of safety are calculated for both the reconstituted sample-(sample No. **3)** and for the in situ sample (sample No. 2). The in situ sample is more representative of field behavior. It should **be** repeated that these factors of safety are against the development of **5** percent strain and not against actual liquefaction which, if it occurs, occurs at strains in excess of **10** percent for the samples tested.

(f) The scatter of the test data is to be expected. These tests were .conducted on in situ soil samples. Variations in the soil and the results were anticipated. Only the soil judged most susceptibleto liquefaction were selected for testing. **Of** the three samples selected for testing, all available specimens were tested. Sample No,. **3** shows some scatter. **All** specimens from sample No. **3** are reconstituted due to the presence of a large gravel particle.

Three of the four test points form the classical cyclic curve. However, the fourth point (the lower point at three cycles) is out of place. The curve was constructed giving extra weight to the upper point at three cycles and then giving equal weight to both test points at stress ratios of **0.26** and **0.27.** The other two curves are constructed essentially parallel to this first curve.

**(g)** See response to Part **E.**

**36.367**

## TABLE Q362.36-1

# ERCW ROUTE LIQUEFACTION EVALUATION

## Maximum and Average Element Stresses and Peak Accleration at the Top of Each Layer



Average element stress = 0.65\* max element stress.  $**$ Assume 500 psf at 17,5 feet.

TABLE Q362.36-2

Factors of Safety with Depth When the Water Table is not Considered



## Notation:

 $\tilde{\sigma}_{\text{v}}$  = effective vertical stress

 $\hat{\sigma_h}$  = effective horizontal stress

 $\frac{27}{3}$  = cyclic stress ratio

 $Z_f^2$  = cyclic shear stress corresponding to 5% strain

 $\mathcal{Z}_{avg}$  = average on effective shear stress

 $FS$  = Factor of Safety against  $5\overline{z}$  cyclic strain potential

## TABLE Q362.36-3

## Factors of Safety with Depth Assuming the Water Table is 16.5 feet Below Ground Surface



Notation:

 $\widetilde{C}_v$  = effective vertical stress

 $\widehat{C_{\rm h}}$  = effective horizontal stress

 $\frac{2}{\sqrt{9}}$  = cyclic stress ratio

 $\mathcal{Z}_f$  = cyclic shear stress corresponding to 5% strain

?avg **<sup>=</sup>**average on effective shear stress

FS = Factor of Safety against 5% cyclic strain potential





Figure **Q362.36-11** $\ddot{\phantom{a}}$ 



**Comparison of Induced Shear Stress** (7avg) and **Shear** Stress Required to cause **5%** strain **(2t)** and Resulting Factors of Safety with Depth Below Ground Surface.