

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

June 21, 1982

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Ms. Adensam:


In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

In a letter to you from M. R. Wisenburg dated March 10, 1982, we stated that TVA was still reviewing the options for compensation of the steam generator reference leg at Watts Bar Nuclear Plant. This letter is to inform you that, similar to Sequoyah, TVA has elected to insulate the reference leg to alleviate the temperature dependence problem.

If you have any questions concerning this matter, please get in touch with D. P. Ormsby at FTS 858-2682.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Licensing

Sworn to and subscribed before me
this 21st day of June 1982

Paulette D. White

Notary Public

My Commission Expires 9-5-84

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

8001

8206240286 820621
PDR ADOCK 05000390
PDR
A