

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

November 10, 1982

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

During an April 1, 1982 telephone conference call with the NRC's Mechanical Engineering Branch, TVA was requested to provide additional information on Watts Bar Nuclear Plant. At the NRC's request, TVA performed a sampling program to verify that the buckling stresses in axial compression members used in pipe support configurations do not exceed 90 percent of the yield strength when their slenderness ratio is less than 30.

TVA investigated 515 randomly selected supports in 19 different systems. The results show that all 252 supports with slenderness ratios less than 30 met the applicable requirements for prevention of critical buckling. The remaining supports sampled had slenderness ratios greater than or equal to 30. Enclosed is a tabular summary of the results of TVA's evaluation.

If you have any questions concerning this matter, please get in touch with D. P. Ormsby at FTS 858-2682.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills
L. M. Mills, Manager
Nuclear Licensing

Sworn to and subscribed before me
this 10th day of November 1982

Paulette H. White
Notary Public
My Commission Expires 9-5-84

Enclosure
cc: See page 2

8211160237 821110
PDR ADOCK 05000390
A PDR

Boor

Director of Nuclear Reactor Regulation

November 10, 1982

cc: U.S. Nuclear Regulatory Commission (Enclosure)
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 8-26-82

CHECKED RLIC/DATE 10-1-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. BY DATE	COMMENT	SYSTEM		
		MAXI. AXIAL.	LOADS MOMENT.	Kl F	BUCKLING STRESS	INT. VALUE	FULL INT. VAL.						
1	12-1AAB-R17 (BP)	COLUMN	3.92 K	47.6 ^{11/16}	23.1	$f_a = 1.02$.64	1.5	MAC 8/25	GLP 9-15	AUX BOILER		
2	62-1CVC-R12 (BP)	"	.03 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	CVC'S			
3	62-1LCV-R71 (BP)	"	.112 K	0	> 30	/			MAC 8/25	GLP 9-15	L.P. CVC'S		
4	" -R75 (BP)	"	.208 K	0	> 30				MAC 8/25	GLP 9-15	"		
5	" -R76 (BP)	"	.240 K	0	> 30				MAC 8/25	GLP 9-15	"		
6	" -R83 (BP)	"	.250 K	0	> 30				MAC 8/25	GLP 9-15	"		
7	" -R90 (BP)	"	.304 K	0	> 30				MAC 8/25	GLP 9-15	"		
8	" -R91 (BP)	"	.160 K	0	> 30				MAC 8/25	GLP 9-15	"		
9	47A406-7-64 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED				MAC 8/25	GLP 9-15	CVC'S		
10	" -7-66 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED				MAC 8/25	GLP 9-15	"		
11	" -7-67 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
12	" -7-68 (TVA)	"	.048 K	.152 ^{5/8}	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
13	" -7-69 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
14	" -7-70 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
15	" -7-71 (TVA)	"	.048 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
16	" -7-72 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	CVC'S			
17	1-70-979 (BP)	"	.658 K	1.65 ^{5/8}	13.83	$f_a = .414$.119	1.5	MAC 8/25	GLP 9-15	COMP COOL		
18	70-1CC-R249 (BP)	COLUMN	39.84 K	0	12.12	$f_a = 5.42$.265	1.5	MAC 8/26	GLP 9-15	COMP COOL		

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 8-27-82

CHECKED RILIN DATE 10-1-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING							DES. BY DATE	CHK. BY DATE	COMMENT			
		MAXI. LOADS		K _L F	BUCKLING STRESS	INT. VALUE	P.LL. INT. VAL.	F _a						
		AXIAL.	MOMENT.											
(BP)	COLUMN	22.24	K	0	7.6	f _a = 1.87	.088	1.5	MAC	8/26	GLP	9-16	ITEM # 3 ITEM # 5	ESSENTIAL RAW COOLING WATER
67-1ERCW-R343		53.44	K	0	3.92	f _a = 4.49	.209	1.5						
(BP)		11.04	K	0	20.58	f _a = 2.89	.142	1.5	MAC	8/26	GLP	9-16		ESSENTIAL RAW COOLING WATER
67-1ERCW-R96		22.35	K	0	7.52	f _a = 3.04	.143	1.5	MAC	8/26	GLP	9-16		FEED WATER
(EDS)		20.77	K	0	8.72	f _a = 2.82	.133	1.5	MAC	8/26	GLP	9-16		FEED WATER
1-03A-209		9.1	K	0	8.8	f _a = 1.24	.058	1.5	MAC	8/26	GLP	9-16		FEED WATER
(EDS)		4.95	K	0	6.58	f _a = .81	.038	1.5	MAC	8/26	GLP	9-16		FEED WATER
1-03A-246		11.73	K	0	8.18	f _a = 1.6	.075	1.5	MAC	8/26	GLP	9-16		FEED WATER
(EDS)		33.06	K	0	6.18	f _a = 4.06	.19	1.5	MAC	8/26	GLP	9-16		FEED WATER
1-03A-249		12.3	K	6.92% _W	8.8	f _a = 1.67	.146	1.5	MAC	8/26	GLP	9-16		FEED WATER
(EDS)		12.42	K	0	7.88	f _a = 1.69	.08	1.5	MAC	8/26	GLP	9-16		FEED WATER
1-03A-291		42.64	K	0	6.52	f _a = 6.04	.284	1.5	MAC	8/26	GLP	9-16		FEED WATER
(EDS)		7.91	K	7.41% _W	6.84	f _a = 1.73	.187	1.5	MAC	8/26	GLP	9-16		FIRE PROTEC
1-03A-329		12.45	K	7.05% _W	8.63	f _a = 1.69	.147	1.5	MAC	8/26	GLP	9-16		FEED WATER
(TVA)		.24	K	1.95% _W	21.3	f _a = .151	.13	1.5	MAC	8/27	RLE	9/15		FIRE PROTECTION
47A491-10-1		.24	K	1.95% _W	21.3	f _a = .151	.13	1.5	MAC	8/27	RLE	9/15		FIRE PROTECTION
(TVA)		.064	K	3.5% _W	18.3	f _a = .4	.237	1.5	MAC	8/27	RLE	9/15		FIRE PROTECTION
47A491-10-2		4.8	K	0	30	f _a = .36	.04	1.5	MAC	8/27	RLE	9/15		H.P. FIRE PROTECTION
(BP)		4.8	K	0	30.1	f _a = .86	.04	1.5	MAC	8/27	RLE	9/15		H.P. FIRE PROTECTION
26-1FP-R56		2.56	K	0	14.04	f _a = 1.0	.06	1.5	MAC	8/27	RLE	9/15		H.P. FIRE PROTECTION
(BP)	COLUMN													

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 8-27-87

CHECKED RILICH DATE 10-1-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT.	
		MAXI. LOADS		KL r	BUCKLING STRESS	INT. VALUE	ALL-INT. VAL.				
		AXIAL.	MOMENT.								
(TVA)											
47A491-8-10	COLUMN	.096 K	.87%	30	$f_a = .022$.062	1.5	MAC 8/27	R/E 9/15	SYSTEM FIRE PROTECTION	
(TVA)											
47A491-8-12	"	.24 K	1.29%	14.6	$f_a = .068$.018	1.5	MAC 8/27	R/E 9/15	FIRE PROTECTION	
(TVA)											
47A491-8-14	"	.24 K	1.31%	21.3	$f_a = .15$.082	1.5	MAC 8/27	R/E 9/15	FIRE PROTECTION	
(BP)											
78-IFPC-R73	"	32 K	0	13.7	$f_a = 10.6$.51	1.5	MAC 8/27	R/E 9/15	FUEL COOLING	
(BP)											
78-IFPC-R59	"	.96 K	0	30	$f_a = .43$.021	1.5	MAC 8/27	R/E 9/15	FUEL POOL COOLING	
(BP)											
78-IFPC-R58	"	.32 K	0	30	$f_a = .143$.007	1.5	MAC 8/27	R/E 9/15	FUEL POOL COOLING	
(BP)											
78-IFPC-R46	"	2A K	0	13.7	$f_a = 479$.038	1.5	MAC 8/27	R/E 9/16	FUEL POOL COOLING	
(TVA)											
47A462-8-39	"	.09 K	11.8%	30	$f_a = .054$.052	1.5	MAC 8/30	R/E 9/16	ICE CONDENSER	
(TVA)											
47A462-8-40	"	.09 K	8.45%	20	$f_a = .05$.515	1.5	MAC 8/30	R/E 9/16	ICE CONDENSER	
(TVA)											
47A462-8-38	"	.15 K	12.5%	30	$f_a = .104$.79	1.5	MAC 8/30	R/E 9/16	ICE CONDENSER	
(TVA)											
47A462-8-37	"	.15 K	12.5%	30	$f_a = .107$.79	1.5	MAC 8/30	R/E 9/16	ICE CONDENSER	
(TVA)											
47A462-8-17	"	.72 K	0	30	$f_a = .2$.01	1.5	MAC 8/30	R/E 9/16	ICE CONDENSER	
(EDS)										ITEM # 3	
1-01A-426	"	206.5 K	0	1.86	$f_a = 26.1$	1.21	1.5	MAC 9/1	R/E 9/16	MAIN STEAM	
(EDS)											
1-01A-385	"	82.3 K	0	4.65	$f_a = 10.4$.483	1.5	MAC 9/1	R/E 9/16	MAIN STEAM	
(EDS)											
1-01A-345	"	56.7 K	0	4.65	$f_a = 7.17$.333	1.5	MAC 9/1	R/E 9/16	MAIN STEAM	
(EDS)											
1-01A-347	"	137.0 K	0	7.0	$f_a = 16.8$.79	1.5	MAC 9/1	R/E 9/16	MAIN STEAM	
(EDS)											
1-01A-315	"	92.2 K	0	19.5	$f_a = 7.8$.38	1.5	MAC 9/1	R/E 9/16	MAIN STEAM	
(EDS)											
1-01A-311	"	96.7 K	0	20.9	$f_a = 13.7$.67	1.5	MAC 9/2	R/E 9/16	MAIN STEAM	
(EDS)											
1-01A-310	COLUMN	168.3	0	22.3	$f_a = 11.7$.57	1.5	MAC 9/2	R/E 9/16	MAIN STEAM	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9/14

CHECKED R/E DATE 10/1/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		K/L	BUCKLING INT. STRESS	INT. VALUE	ALL. INT. VAL.				
		AXIAL	MOMENT								
(EDS) 2-01A-385	COLUMN	38.0K	0	4.6	$f_a = 4.78$.22	1.5	MAC 9/15	R/E 9/16		MAIN STEAM
(EDS) 2-01A-347	"	17.2K	0	16.4	$f_a = 2.1$	1.01	1.5	MAC 9/13	R/E 9/16		MAIN STEAM
(EDS) 2-01A-345	"	31.5K	0	3.7	$f_a = 3.96$.184	1.5	MAC 9/13	R/E 9/16		MAIN STEAM
(EDS) 2-01A-315	"	214.1K	0	20.2	$f_a = 18.15$.83	1.5	MAC 9/14	R/E 9/16		MAIN STEAM
(EDS) 2-01A-311	"	96.7K	0	20.9	$f_a = 13.63$.67	1.5	MAC 9/14	R/E 9/16		MAIN STEAM
(EDS) 2-01A-306	"	18.02K	0	3.7	$f_a = 2.87$.11	1.5	MAC 9/14	R/E 9/16		MAIN STEAM
(EDS) 1-68-270	"	.43	6.95%	30	$f_a = .21$.43	1.5	MAC 9/14	R/E 9/16		REACTOR COOLANT
(EDS) 1-68-273	"	.443K	0	19.27	$f_a = .171$.008	1.5	MAC 9/14	GLP 9/16		REACTOR COOLANT
(EDS) 1-68-320	"	.677K	4.85%	8.65	$f_a = .43$.312	1.5	MAC 9/14	GLP 9-16		REACTOR COOLANT
(TYA) 47A465-8-1	"	.816K	0	13.77	$f_a = 1.65$.079	1.5	MAC 9/14	GLP 9-16		REACTOR COOLANT
(TYA) 47A465-8-17	"	.032K	0	7.30				MAC 9/14	GLP 9-16		REACTOR COOLANT
(BP) 47A432-3-1	"	.099K	.225%	4.25	$f_a = .06$.016	1.5	MAC 9/14	GLP 9-16		R/R
(EDS) PROB(15-02) 1-87-037	"	1.76K	0	4.57	$f_a = 1.65$.077	1.5	MAC 9/14	GLP 9-16	ITEM #1 200 150.	SAFETY INJECTION
(EDS) PROB(15-02) 1-87-058	"	1.76K	0	12.78	$f_a = 1.04$.05	1.5	MAC 9/14	GLP 9-16	ITEM #2 200 150.	SAFETY INJECTION
(EDS) PROB(15-02) 1-87-59	"	20.8K	0	10.34	$f_a = 4.41$.208	1.5	MAC 9/14	GLP 9-16		UPPER HEAD INJECTION
(EDS) PROB(15-02) 1-87-60	"	6.28K	0	1.76	$f_a = 1.65$.076	1.5	MAC 9/14	GLP 9-16		UPPER HEAD INJECTION
(EDS) PROB(15-02) 1-87-61	"	13.70K	0	10.86	$f_a = 2.92$.138	1.5	MAC 9/14	GLP 9-16		UPPER HEAD INJECTION
(EDS) PROB(15-02) 1-87-63	COLUMN	16.0K	0	30.0	$f_a = 3.39$.16	1.5	MAC 9/14	R/E 9/16		UPPER HEAD INJECTION
(EDS) PROB(15-02) 1-87-63	COLUMN	13.8K	0	17.6	$f_a = 2.79$.135	1.5	MAC 9/14	R/E 9/16		UPPER HEAD INJECTION
(EDS) PROB(15-02) 1-87-63	COLUMN	47.7K	0	30.5	$f_a = 10.11$.51	1.5	MAC 9/14	R/E 9/16		UPPER HEAD INJECTION

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9/29

CHECKED RLI DATE 10/1/82

HANSEIZ NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT.	SYSTEM
		MAXI. LOADS		K/L	BUCKLING INT. STRESS	INT. VALUE	ALL INT. VAL.				
		AXIAL.	MOMENT.	r							
(EDS) PK 08: (15-02) 1-87-64	COLUMN	28.3K	0	30	$f_a = 6.0$.30	1.5	MAC 9/4	RLI 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-02) 1-87-067	"	2.88K	0	30	$f_a = .76$.07	1.5	MAC 9/15	RLI 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-02) 1-87-79	"	3.85K	92.4	19.7	$f_a = .545$.788	1.5	MAC 9/15	RLI 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-02) 1-87-078	"	5.88K	0	30	$f_a = 1.29$.061	1.5	MAC 9/15	RLI 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-01) 1-87-036	"	39.8K	0	30	$f_a = 8.43$.42	1.5	MAC 9/15	RLI 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-01) 1-87-032	COLUMN	5.48K	0	30	$f_a = 2.29$.12	1.5	MAC 9/15	RLI 9/16		UPPER HEAD INJECTION
03B-1AFW-R82	"	.112K	0	77.84	$f_a =$			JRH 8/26	MAC 9/27	$K/L > 30$	AFW
1-03A-324	"	27.62K	0	2.25	3.77ksi	.18	1.5	JRH 8/31	MAC 9/27		FW
1-01B-16	"	.14K	0	21.0				GP 9/7	MAC 9/27	OK BY INSPECTION	BLOW DOWN
1-03A-245	"	19.6K	0	3.4	9.71	.45	1.5	DWO 9/17	MAC 9/28		FEED WATER
1-01A-432	"	231	0	37	11.8	.61	1.5	RLI 9/29	MAC 9/29	$K/L > 30$	MAIN STEAM
1-01A-388	"	197	0	87	8.77	.6	1.5	RLI 9/29	MAC 9/29	$K/L > 30$	MAIN STEAM
2-01A-388	"	1.42	0	32	1.89	.1	1.5	RLI 9/29	MAC 9/29	$K/L > 30$	AUXILIARY BOILER
12-1AAB-R027	"	"	"	"	"	"	"	RLI 9/29	MAC 9/29	"	AUXILIARY BOILER
12-1AAB-R052	"	"	"	"	"	"	"	RLI 9/29	MAC 9/29	"	AUXILIARY BOILER
72-1CS-R31	"	2.72	0	9	1.2	.06	1.5	RLI 9/29	MAC 9/29		CONTAIN - MOUNTS SPRAY
1-74-7	"	58.8	0	18	13	.63	1.5	RLI 9/29	MAC 9/29		RESIDUAL HEAT REMOVAL
1-03A-242	"	51.5	0	47	3.8	.21	1.5	RLI 9/29	MAC 9/29	$K/L > 30$	FEED WATER
1-03A-202	"	"	"	"	"	"	"	RLI 9/29	MAC 9/29	"	FEED WATER
1-01A-430	"	139	0	40	11.8	.61	1.5	RLI 9/29	MAC 9/29	$K/L > 30$	MAIN STEAM

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING

PROGRAM OF PIPE SUPPORTS

COMPUTED EJP DATE 8/16/82
CHECKED RLI DATE 10-1-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM	
		MAXI. AXIAL.	LOADS (1.6) MOMENT.	K/L F	BUCKLING STRESS	INT. VALUE					ALL. INT. VAL.
PROB: (06-01) 1-01A-319 (EDS)	SLEEVE	45.5 ^K	/	.075	f ₀ = 3.0 ^{ksi}	0.14	1.5	EJP 8/16	GLP 9-22-82	RADIAL GRND FLAT PLATE	MN STM
(06-02) 1-01A-356 (EDS)	"	95.4 ^K	/	.075	f ₀ = 6.3 ^{ksi}	0.30	"	EJP 8/16	GLP 9-22-82	"	"
(06-03) 1-01A-398 (EDS)	"	46.5 ^K	/	.075	f ₀ = 3.1 ^{ksi}	0.14	"	EJP 8/16	GLP 9-22-82	"	"
(06-04) 1-01A-433 (EDS)	"	89.2 ^K	/	.075	f ₀ = 2.1 ^{ksi}	0.09	"	EJP 8/16	GLP 9-22-82	"	"
(04-08) 1-70-386 (EDS)	"	0.230 ^K	0.172 ^{"-K}	BUCKLING NOT INVOLVED			EJP 8/16	GLP 9-22-82	LS IN BENDING	COMP COOL.	
(04-04) 2-70-126 (EDS)	"	1.58 ^K	0.79 ^{"-K}	BUCKLING NOT INVOLVED			EJP 8/16	GLP 9-22-82	RADIAL GRND LS W/R IN BUNDA	"	
(04-04) 2-70-157 (EDS)	"	0.09 ^K	/	BUCKLING NOT INVOLVED			EJP 8/16	GLP 9-22-82	RADIAL GRND LS ONLY	"	
(02-02) 1-03A-243 (EDS)	"	17.8 ^K	/	0.33	f ₀ = 0.5 ^{ksi}	0.02	1.5	EJP 8/16	GLP 9-22-82	RADIAL GRND FLAT PLATE	FEED WATER
(01-03) 1-03A-282 (EDS)	"	17.1 ^K	/	0.33	f ₀ = 0.4 ^{ksi}	0.02	1.5	EJP 8/16	GLP 9-22-82	RADIAL GRND FLAT PLATE	FEED WATER
(02-00) 1-03A-322 (EDS)	"	34.6 ^K	/	0.33	f ₀ = 0.85 ^{ksi}	0.04	1.5	EJP 8/16	GLP 9-22-82	"	"
(09-01) 1-63-010 (EDS)	"	17.2 ^K	/	2.45	f ₀ = 2.87 ^{ksi}	0.13	1.5	EJP 8/16	GLP 9-22-82	Short 12 RAD GRND ON BD	SIS
(03-01) 1-74-2 (EDS)	"	40.8 ^K	/	2.45	f ₀ = 4.08 ^{ksi}	0.19	1.5	EJP 8/16	GLP 9-22-82	"	RH
150:47W432-206 74-1RHR-R163 (BP)	"	4.8 ^K	/	BUCKLING NOT INVOLVED			EJP 8/16	GLP 9-22-82	RADIAL GRND LS ONLY	RHR	
150:47W432-205 74-1RHR-R158 (BP)	"	4.8 ^K	/	BUCKLING NOT INVOLVED			EJP 8/16	GLP 9-22-82	"	"	
Anal: N3-26-3A 47A491-6-1 (TVA)	"	0.32 ^K	/	BUCKLING NOT INVOLVED			EJP 8/16	GLP 9-22-82	LS ON OUTSIDE OF SLV	FP	
Anal: N3-81-1A 47A492-2-9 (TVA)	"	1.23 ^K	/	BUCKLING NOT INVOLVED			EJP 8/16	GLP 9-22-82	"	PRIMARY WATER	
Anal: N3-81-1R 47A492-2-5 (TVA)	"	0.34 ^K	/	BUCKLING NOT INVOLVED			EJP 8/16	GLP 9-22-82	"	"	
Anal: W3-33-1A 47A492-2-15 (TVA)	SLEEVE	0.9 ^K	/	1.3	f ₀ = 0.3 ^{ksi}	0.01	1.5	EJP 8/16	GLP 9-22-82	R welded on ground inside SLV	SERVICE AIR
19 2-70-515 (EDS)	SLEEVE	0.09 ^K	/	BUCKLING NOT INVOLVED			EJP 8/22	GLP 9-22-82	RADIAL GRND LS ONLY	COMP COOL	

ANNUAL EVALUATION REPORT FOR BUCKLING SAMPLES

PROGRAM OF PIPE SUPPORTS

COMPUTED RUC DATE 10-14-82

CHECKED MAC DATE 9-21-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT.	SYSTEM COMPONENT
		MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE	FLL. INT. VAL.				
		AXIAL.	MOMENT.								
1-70-095	RIGID FRAME	1568 #	/	NO	BUCKLING INVOLVED			JRH 8/28	MAC 9/20	ok	COOLING
1-70-816	"	3067.2 #	/	7.08	1.31 KSI	.362	1.5	JRH 8/28	MAC 9/20	hand calc's ok	"
70-1CC-R312	"	42080 #	/	5.44	4.96 KSI	.355	"	JRH 8/28	MAC 9/20	"	"
1-74-6	"	50801.6 #	/	6.90	10.0 KSI	.470	"	JRH 9/20	MAC 9/20	ok	RESIDUAL HEAT REMOVAL
1-62A-307	"	1892.8 #	/	NO	BUCKLING INVOLVED			JRH 8/28	MAC 9/20	ok	H.P. Chem & VOL. CONTROL
1-87-035	"	7505.6 #	/	NO	BUCKLING INVOLVED			JRH 8/28	MAC 9/20	ok	UPPER HEAD INJECTION
1-74-5	"	88216 #	/	6.98	17.37 KSI	.816	1.5	JRH 8/28	MAC 9/20	hand calc's ok	RESIDUAL HEAT REMOVAL
1-74-10	"	30372.8 #	/	5.09	5.98 KSI	.281	"	JRH 8/28	MAC 9/20	"	"
1-74-1	"	12321.6 #	/	3.89	2.43 KSI	.114	"	JRH 8/30	MAC 9/20	"	"
70-1CC-R505	"	3200 #	/	3.16	3.20 KSI	.329	"	JRH 8/30	MAC 9/20	"	COMPONENT COOLING
1-62A-301	"	2816 #	/	2.03	1.02 KSI	.425	"	JRH 8/30	MAC 9/20	"	H.P. Chem & VOLUME CONTROL
1-62A-302	"	"	/	"	"	"	"	JRH 8/30	MAC 9/20	"	"
62-1CVC-R13	"	2400 #	/	3.49	.619 KSI	.199	"	JRH 8/30	MAC 9/20	"	"
1-74-4	"	24910.4 #	/	2.30	2.49 KSI	.742	"	JRH 8/31	MAC 9/20	"	RESIDUAL HEAT REMOVAL
1-87-62	"	18400 #	/	1.10	0.87 KSI	.041	"	JRH 8/31	MAC 9/21	"	UPPER HEAD INJECTION
47A454-2-46	"	6940.8 #	/	4.51	/	.995	"	JRH 9/2	MAC 9/21	STRUCL CODE CHECK	SFPC
47A454-1-15	"	"	/	4.51	/	"	"	JRH 9/2	MAC 9/21	"	FUEL POOL COOL & CLEAN
1-87-80	"	5920 #	/	19.38	3.56 KSI	1.17	"	JRH 9/2	MAC 9/21	hand calc's ok	UPPER HEAD INJECTION
47A406-3-11	"	192 #	/	21.80	.32 KSI	.087	"	JRH 9/3	MAC 9/21	"	UP CVC

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 9-8-82

CHECKED RLT DATE 10-14-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. AXIAL	LOADS MOMENT	KL	BUCKLING STRESS	INT. VALUE	FALL. INT. VAL.				
47A454-3-10	RIGID FRAME	5604.8 #	/	10.16	1.5 KSI	.229	1.5	JRH 9/3	MAC 9/21	hand calc's ok	SFPS
26-1FP-R232	"	3200 #	/	22.39	.79 KSI	.039	"	JRH 9/7	MAC 9/21	"	H.P. FIRE PROTECTION
47A492-2-11	"	1443.2 #	/	6.61	.75 KSI	.213	"	JRH 9/7	MAC 9/21	"	PRIMARY WATER
47A431-9-7	"	1025.6 #	/	6.91	.36 KSI	.093	"	JRH 9/7	MAC 9/21	"	AUX BOILER
03B-1AFW-R23	"	6400 #	/	5.67	.84 KSI	.039	"	JRH 9/7	MAC 9/21	"	AUX FEEDWATER
78-1FAC-R-38	"	3200 #	/	17.95	1.14 KSI	.67	"	JRH 9/7	MAC 9/21	"	FUEL POOL COOLING
62-1LCV-R81	"	896 #	/	12.42	.13 KSI	.451	"	JRH 9/8	MAC 9/23	"	L.P. CHEM & VOL CONTR
72-1CS-R20	"	3200 #	/	5.32	.69 KSI	.188	"	JRH 9/8	MAC 9/23	"	COMPANON SPRAY
70-1CC-R577	"	240 #	/	3.99	.12 KSI	.046	"	JRH 9/8	MAC 9/23	"	COMPANON COOLING
62-1LCV-R86	"	208 #	/	21.44	.05 KSI	.144	"	JRH 9/8	MAC 9/23	"	L.P. CHEM & VOL CONTR
2-70-804	"	1073.6 #	/	8.56	.39 KSI	.294	"	JRH 9/8	MAC 9/23	"	COMPANON COOLING
12-1AAB-R57	"	2240 #	/	7.01	1.10 KSI	.799	"	JRH 9/8	MAC 9/23	"	AUX BOILER
12-1AAB-R67	"	"	/	"	"	"	"	JRH 9/8	MAC 9/23	"	"
12-1AAB-R053	"	"	/	"	"	"	"	JRH 9/8	MAC 9/23	"	"
12-1AAB-R052	"	"	/	"	"	"	"	JRH 9/8	MAC 9/23	"	"
47A435-2-11	"	288 #	/	10.27	.183 KSI	.199	"	JRH 9/8	MAC 9/23	"	SIS
26-1FA-R61	"	6400 #	/	3.16	.734 KSI	.034	"	JRH 9/8	MAC 9/23	"	H.P. FIRE PROTECTION
26-1FA-R63	"	2400 #	/	6.35	.813 KSI	.61	"	JRH 9/9	MAC 9/23	"	"
62-1LCV-R80	"	480 #	/	21.05	.114 KSI	.01	"	JRH 9/9	MAC 9/23	"	L.P. CHEM & VOL CONTR

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 9/9/82
CHECKED RLJ DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE	ALL. INT. VAL.				
		AXIAL.	MOMENT.	r							
78-1FPC-R18	RIGID FRAME	1280 #	/	17.26	.806 KSI	.288	1.5	JRH 9/19	MAC 9/23	hand calc's OK	FUEL POOL COOLING
67-1EAW-R416	"	"	/	"	"	"	"	JRH 9/19	MAC 9/23	"	ESSENTIAL RAW COOLING WATER
62-1LCV-R84	"	NO BUCKLING INVOLVED						JRH 9/19	RLJ 10/7	"	L.P. SCHEM & VOL. CONT.
78-1FPC-R7	"	640 #	/	21.42	.676 KSI	.60	"	JRH 9/19	MAC 9/23	"	FUEL COOLING
78-1FPC-R4	"	"	/	21.42	"	.60	"	JRH 9/19	MAC 9/23	"	"
78-1FPC-R19	"	1280 #	/	26.39	2.02 KSI	1.03	"	JRH 9/19	MAC 9/23	"	"
62-1LCV-R87	"	"	/	"	"	"	"	JRH 9/19	MAC 9/23	"	L.P. SCHEM VOL. CONT.
62-1LCV-R82	"	"	/	"	"	"	"	JRH 9/19	MAC 9/23	"	"
47A435-2-8	"	848 #	/	26.15	1.25 KSI	1.01	"	JRH 9/19	MAC 9/23	"	SAFETY INJECTION
63-1SIS-R24	"	"	/	"	"	"	"	JRH 9/19	MAC 9/23	"	"
70-1CC-R186	"	400 #	/	BUCKLING NOT INVOLVED			JRH 9/19	MAC 9/23	OK	COMPONENT COOLING	
70-1CC-R118	"	304 #	/	.722	.034 KSI	.002	1.5	JRH 9/19	MAC 9/23	hand calc's OK	
47A555-10-2	"	96 #	/	21	.192	.01	1.5	JRH 9/19	RLJ 10/8	OK	LP CVCS
47A555-10-4	"	160 #	/	21	.32	.02	1.5	JRH 9/19	RLJ 10/8	OK	LP
1-03B-9	"	3505.6 #	/	3.99	/	.364	1.5	JRH 9/10	MAC 9/23	strudl code check	AUX. FEEDWATER
	-3516	"	/	"	/	"	"	JRH 9/10	MAC 9/23	"	SAFETY INJECTION
	-351	"	/	"	/	"	"	JRH 9/10	MAC 9/23	"	"

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED RLT DATE 9/23/82

CHECKED MAC DATE 9/23/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		K _L	BUCKLING STRESS	INT. VALUE	WELL. INT. VAL.				
		AXIAL.	MOMENT.								
47A431-9-21	RIGID FRAME	259.2 #	/	30.99	/	/	JRH 9/15	MAC 9/23	K _L > 30 ok	AUX BOILER COMPONENT COOLING	
2-70-067	RIGID FRAMES	5589 #	/	3.01	1164	1.5	JRH 9/16	MAC 9/23	STRUCL CODE CHECK		
47A462-8-27	RIGID FRAME	2980.8 #	/	15.50	2.01 ksi	7.13	JRH 9/10	MAC 9/23	hand calc ok	I.C.	

FINAL EVALUATION REPORT FOR BUCKLING PROGRAM OF PIPE SUPPORTS

COMPUTED DWG DATE 9/7/82
CHECKED RLI DATE 10/14/82

TVA	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING				DES. DATE	CHK. DATE	COMMENT	SYSTEM		
			MAXI. LOADS		KL	BUCKLING INT. STRESS					INT. VALUE	FULL INT. VAL.
			AXIAL.	MOMENT.								
	47A43-9-10	RIGID FRAME	.675K	/	9.13	.177	.957	1.5	GLP 9-8-82	JRH 9/27	AUX BOILER	
EDS	1-63-001	RIGID FRAME	8.68 K	/	54.5	5.46	.305		GLP 9-8-82	JRH 9/27	SI	
EDS	1-01A-352		13.28 K	/	2.21	3.48	.162		GLP 9-9-82	JRH 9/27	MS	
EDS	2-01A-352		236.24 K	/	.23	1.64	.076		GLP 9-9-82	JRH 9/27	MS	
EDS	1-01A-394		37.88 K	/	.18	2.37	.11		GLP 9-9-82	JRH 9/27	MS	
EDS	1-63-007		92.4 K	/	.281	4.29	.199		GLP 9-9-82	JRH 9/27	SI	
EDS	1-63-007		11.88 K	/	.488	2.813	.488		GLP 9-13-82	JRH 9/27	SI	
EDS	1-63-006		74.25 K	/	.314	3.956	.316		GLP 9-13-82	JRH 9/27	SI	
	1-71-12		23.76	0	3.64	9.17	.43		GLP 9-13-82	RLI 9/30/82	RHR	
	1-87-006		11.88	86.1	16.5	1.68	.27		JRH 10-7-82	GLP 10-8-82	UHI	
	17A586-1-12		10788.8*	/	3.88	/	.677		JRH 8/26	MAC 9/82	STRUDL CODE CHECK ERCW	
	17A586-1-13		"	/	"	/	"		JRH 8/26	MAC 9/82	"	
	17A586-1-35		"	/	"	/	"		JRH 8/26	MAC 9/82	"	
	17A586-5-13		"	/	"	/	"		JRH 8/26	MAC 9/82	"	
	47A462-8-6		3327*	/	8.79	9.2 = 1.20ksi	.775		DWO 8/27	JBS 9/14	STRUDL CODE CHECK ICE CONDENSATE	
	47A462-8-14		"	/	"	"	"		DWO 9/27	JBS 9/14	"	
	47A462-8-13		"	/	"	"	"		DWO 8/27	JBS 9/14	"	
	47A462-8-5		"	/	"	"	"		DWO 8/27	JBS 9/14	"	
	1-03B-39		4320*	/	10.8	/	/		GP 9/7	MAC 9/27	AFW	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED RVE DATE 9/20/82

CHECKED MAC DATE 9-20-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		$\frac{KL}{r}$	BUCKLING STRESS	INT. VALUE	ALL-INT. VAL.				
		AXIAL.	MOMENT.								
1-68-340	RIGID FRAME	379 #	/	Buckling not	involved		JRH 8/14	MAC 9/20	ok	RC	
26-1FP-R75	"	/	/	"	"		JRH 8/14	MAC 9/20		HPFP	
26-1FP-R77	"	"	/	"	"		JRH 8/14	MAC 9/20	"	"	
	"	"	/	"	"						
26-1FP-R65	"	"	/	"	"		JRH 8/14	MAC 9/20	"	"	
26-1FP-R69	"	"	/	"	"		JRH 8/14	MAC 9/20	"	"	
26-1FP-R71	"	"	/	"	"		JRH 8/14	MAC 9/20	"	"	
26-1FP-R73	"	"	/	"	"		JRH 8/14	MAC 9/20	"	"	
26-1FP-R67	"	"	/	"	"		JRH 8/14	MAC 9/20	"	"	
17-A586-1-1	"	5379 #	/	11.6	.733	1.5	JRH 8/16	MAC 9/20	STRUDL CODE CHECK	ERCW	
17-A586-1-2	"	"	/	"	"	"	JRH 8/16	MAC 9/20	"	"	
17-A586-1-5	"	"	/	"	"	"	JRH 8/16	MAC 9/20	"	"	
17-A586-1-70	"	"	/	"	"	"	JRH 8/16	MAC 9/20	"	"	
17-A586-5-3	"	"	/	"	"	"	JRH 8/16	MAC 9/20	"	"	
17-A586-5-4	"	"	/	"	"	"	JRH 8/16	MAC 9/20	"	"	
17-A586-5-5	"	"	/	"	"	"	JRH 8/16	MAC 9/20	"	"	
17-A586-5-26	"	"	/	"	"	"	JRH 8/16	MAC 9/20	"	"	
17-A586-5-33	"	5680 #	/	.91	.347	"	JRH 8/16	MAC 9/20	"	"	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED RLT DATE 9-20-82

CHECKED MAC DATE 9-20-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. DATE	COMMENT	SYSTEM
		MAXI. LOADS		K _L	BUCKLING INT. STRESS	INT. VALUE	FALL. INT. VAL.				
		AXIAL.	MOMENT.								
47A465-1-33	RIGID FRAME	24 #	/	Buckling not involved			JRH 8/18	MAC 9/20	OK	RC	
47A450-4-29	"	998 #	/	9.00	f _a =247KSI	.031	1.5	JRH 8/18	MAC 9/20	SAGS OK	ERCW
1-03B-11	"	816 #	/	3.99		.299	"	JRH 8/19	MAC 9/20	"	A
47A450-5-157	"	8480 #	/	6.67	f _a =1.24KSI	.63	"	JRH 8/19	MAC 9/20	"	ERCW
47A450-3-105	"	10400 #	/	6.67	f _a =1.64KSI	.77	"	JRH 8/19	MAC 9/20	"	"
47A450-21-201	"	1648 #	/	10.19		.524	"	JRH 8/19	MAC 9/20	Strudl code check	"
03B-18FW-R10	"	1680 #	/	6.80		.082	"	JRH 8/20	MAC 9/20	"	"
1-03B-7	"	2880 #	/	3.99		.344	"	JRH 8/25	MAC 9/20	SAGS OK	AFW
1-03B-12	"	"	/	"		"	"	JRH 8/25	MAC 9/20	"	"
1-03B-13	"	"	/	"		"	"	JRH 8/25	MAC 9/20	"	"
1-03B-14	"	"	/	"		"	"	JRH 8/25	MAC 9/20	"	"
1-03B-60	"	3580.8 #	/	"		.840	"	JRH 8/25	MAC 9/20	"	"
1-03B-10	"	"	/	"		"	"	JRH 8/25	MAC 9/20	"	"
1-03B-8	"	"	/	"		"	"	JRH 8/25	MAC 9/20	"	"
1-63-355	"	"	/	"		"	"	JRH 8/25	MAC 9/20	"	SAFETY INJECTION
1-63-357	"	"	/	"		"	"	JRH 8/25	MAC 9/20	"	"
1-63-358	"	"	/	"		"	"	JRH 8/25	MAC 9/20	"	"
17A586-5-27	"	2924.8 #	/	7.59		.499	"	JRH 8/25	MAC 9/20	STRUDL CODE CHECK	ERCW

BRACED CANTILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JBJ DATE 8/24/82

CHECKED RLI DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. BY DATE	COMMENT	
		MAXI. AXIAL	LOADS K	MOMENT.	K _L F	BUCKLING INT. STRESS	INT. VALUE			ALL. INT. VAL.	GT
47A454-1-12	Br. Cant.	1.246	1.061	12.58	-	.059	1.5	JBJ 8/18	GLP 9-25-82	Passal Code Check	Fuel Pool Cooling System
47A454-2-44	"	1.245	-	23	-	.08	1.5	JBJ 8/18	GLP 9-28-82	"	"
47A454-2-36	"	5.32	-	25	-	.87	1.5	JBJ 8/19	GLP 9-25-82	"	"
1-63 ⁽⁰¹⁻⁰¹⁾ 004	"	7.08	-	11	-	.37	1.5	JBJ 8/20	GLP 9-25-82	"	Safety Injection
1-03A ⁽⁰²⁻⁰³⁾ = 365	"	.400	-	19	AXIAL	Load is Negligible		JBJ 8/20	GLP 9-25-82	Feedwater	OK
1-03A ⁽⁰²⁻⁰⁵⁾ = 366	"	14.32	-	13		Actual stress = 3.75 KSI < 9 (36 KSI) ∴ OK		JBJ 8/20	GLP 9-25-82	"	OK
1-03A ⁽⁰²⁻⁰⁶⁾ = 367	"	31.28	-	19		Actual stress = 6.86 KSI < 9 (36 KSI) ∴ OK		JBJ 8/20	GLP 9-25-82	"	OK
1-03B ⁽⁰⁵⁻⁰¹⁾ = 27	"	3.415	-	18.4		Actual stress = .894 KSI < 9 (36 KSI) ∴ OK		JBJ 8/23	GLP 9-25-82	Auxiliary feedwater	OK
67-1ERCW-R13	"	7.012	-	17		Actual stress = 1.4 KSI < 9 (36 KSI) ∴ OK		JBJ 8/23	GLP 9-25-82	ERCW	OK
47A450-3-76	"	-	-	45		OK because K _L > 30		JBJ 8/23	GLP 9-25-82	ERCW	OK
L 30 67-1ERLW-R34	"	13.290	50.320			Combined stress in compression K _L = 15.8 member < 9 (36 KSI) ∴ OK		JBJ 8/23	GLP 9-25-82	ERCW factor of 1.6 still OK	
> 30 67-1ERLW-R34	"	9.274	-			K _L = 30 MAX STRESS = 1.6 (22 KSI) < 9 (36 KSI) ∴ OK		JBJ 8/23	GLP 9-25-82	ERCW	OK
03B-1AFN-R2	"	-	-	32.38		K _L > 30 ∴ OK		JBJ 8/24	GLP 9-25-82	Aux Feedwater	OK
03B-1AFN-R11	"	-	-	46.5		K _L > 30 ∴ OK		JBJ 8/24	GLP 9-25-82	Aux Feedwater	OK
V O I D											
70-2C-R42	"	-	-	37.5		K _L > 30 ∴ OK		JBJ 8/24	GLP 9-25-82	Component Cooling	OK
L 30 62-1LEU-R89	"	.091	-			K _L = 85 AXIAL LOAD NEGLIGIBLE		JBJ 8/24	GLP 9-25-82	L.P. Chemical Volume Control	OK
V O I D											
62-1LEU-R88	"	1.81	-	29.79		.86 ksi .043 1.5		JBJ 8/24	GLP 9-25-82	L.P. Chemical Volume Control	OK

BRACED CAULILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JB DATE 8-31-82

CHECKED RLT DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. DATE	COMMENT		
		MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE	FLL. INT. VAL.					
		AXIAL.	MOMENT.					r				
04-10 1-10-800	Braced Cont	5K	-	11.06	4.79 ksi	.228	1.5	JB/8-24	GLP 9-27-82	Component Cooling Sys	OK	
12-1AAB-R13	"	1.58K		23.7	.414 ksi	.02	1.5	JB/8-25	GLP 9-28-82	Aux Boiler	OK	
03B-1AFA-R18	"			30.4	KL 730	OK		JB/8-25	GLP 9-27-82	Aux Feedwater	OK	
78-1FPL-R13	"			34.2	KL 730	OK		JB/8-25	GLP 9-27-82	Fuel Pool Cooling	OK	
47A435-2-10	"	1.4K		23.1	.62 ksi	.03	1.5	JB/8-25	GLP 9-27-82	SIS	OK	
63-1515-R07	"			31.2	KL 730	OK		JB/8-25	GLP 9-27-82	SIS	OK	
72-105-R38	"			52	KL 730	OK		JB/8-25	GLP 9-27-82	Containment Spray	OK	
63-1515-R29	"			63.3	KL 730	OK		JB/8-25	GLP 9-27-82	Safety Injection	OK	
72-105-R10	"			78	KL 730	OK		JB/8-25	GLP 9-27-82	Containment Spray	OK	
47A435-2-2	"			45	KL 730	OK		JB/8-25	GLP 9-27-82	SIS	OK	
47A435-1-2	"			45	KL 730	OK		JB/8-25	GLP 9-27-82	SIS	OK	
47A451-1-37	"			58.8	KL 730	OK		JB/8-26	GLP 9-27-82	Fuel Pool Cool & cleaning	OK	
17A586-5-7	"			passed	Struall Code	OK		JB/8-26	GLP 9-28-82	ERCW	OK	
17A586-1-30	"			65	Struall Code	OK	.9	1.5	JB/8-26	GLP 9-28-82	ERCW	OK
17A586-1-7	"			passed	Struall Code	OK	.9	1.5	JB/8-26	GLP 9-28-82	ERCW	OK
17A586-1-19	"			passed	Struall Code	OK	.11	1.5	JB/8-31	GLP 9-28-82	ERCW	OK
17A586-1-88	"			passed	Struall Code	OK	.11	1.5	JB/8-31	GLP 9-28-82	ERCW	OK
17A586-1-42	"			passed	Struall Code	OK	.11	1.5	JB/8-31	GLP 9-28-82	ERCW	OK
1-68-215	"			125		.73	1.5	DWD/9/15	JB 9/14	REACTOR COOLANT	OK	

BRACED CAUTILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED DWO DATE 9/27/82

CHECKED RLI DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT
		MAXI. LOADS		K/L	BUCKLING STRESS	INT. VALUE	ALL. INT. VAL.			
		AXIAL.	MOMENT.					Y		
47A450-21-203 A & B	BRACED CENT.	4.6K		80	/	14	1.5	DWO 9/9	JBT 9/24	K _f > 30 ERW
47A454-1-5	"	"		"	/	"	"	DWO 9/9	JBT 9/24	" FIRE
47A454-1-29	"	7.3K		10.18	/	.71	1.5	DWO 9/10	GLP 9-23-82	FUEL POOL COOL & CLEAN
47A494-10-9	"	"		15.47	/	"	"	DWO 9/10	GLP 9-23-82	FIRE PROTECTION
47A432-1-28	"	41.6 K		24	11.75 ksi	.92	1.5	DWO 9/13	GLP 9-24-82	RHR
1-87-031	"	"		"	"	"	"	DWO 9/13	GLP 9-24-82	UPPER HEAD INJECTION
47A454-3-25	"	"		"	"	"	"	DWO 9/13	GLP 9-24-82	S.F.P.C.
74-1RHR-R160	"	36.6K		26	9.6 ksi	.86	1.5	DWO 9/13	GLP 9-23-82	RHR
74-1RHR-R155	"	"		"	"	"	"	DWO 9/13	GLP 9-23-82	RHR
70-1CC-R100	"	"		"	"	"	"	DWO 9/13	GLP 9-23-82	COMP. COOLING
70-1CS-R91	"	"		"	"	"	"	DWO 9/13	GLP 9-23-82	COMP. COOLING
1-03A-360	"	5.54		>30	1.45 ksi	.27	1.5	DWO 9/10	GLP 9-24-82	FEED WATER
72-1CS-R25	"	38.4 K		15.1	/	1.1	1.5	DWO 9/10	JRH 9/29	CONTAINMENT SPRAY
1-03A-368	"	4.5 K		>30	/			DWO 9/10	GLP 9-24-82	FEEDWATER
63-1516-R40 R30 & R32	"	3.77	4.8	34.3	2.77	.77	1.5	DWO 9/27	MAC 9/28	K _f > 30 SAFETY INJECTION
1-03B-53	"	8.2		53.2	.83	.37	1.5	DP 9/25	MAC 9/28	K _f > 30 AUX. FEED WATER
1-03B-3	"	"		"	"	"	"	DP 9/25	MAC 9/28	"

DWGS ARE SIMILAR

DWGS ARE SIMILAR

DWGS ARE SIMILAR

DWGS ARE SIMILAR

BRACED CAUTILEVER

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED DWO DATE 9/27/82
CHECKED RLT DATE 10-14-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT.
		MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE	ALL. INT. VAL.			
		AXIAL.	MOMENT.							
1-87-073	BRACED CANT	11.5	NEGLECTABLE	7.5	1.1	.05	1.5	DWO 9/10/82	RLT 9/28/82	SYS UHI
107-1ERCW-RS18	"	3.41	12.2	20.9	.9	.36	1.5	DWO 9/10/82	RLT 9/28/82	ERCW
26-1FP-R58	"	4.56	-	730	1.2	.3	1.5	DWO 9/10/82	RLT 9/28/82	HP
12-1AAB-R60	"	1.73		730		1.7	1.5	GP 9/27/82	RLT 9/28/82	* SUPPORT IS OVERSTRESSED
1-63-005	"	14.84	13.8	31.3	5.9	.57	1.5	DWO 9/27/82	RLT 9/29/82	KD / 730 SAFETY INVESTIG

BRACED CAUTILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED GLP DATE 9-30-82

CHECKED RLI DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT
		MAXI. LOADS		KL	BUCKLING STRESS	INT. VALUE	ALL-INT. VAL.			
		AXIAL.	MOMENT.							
17A586-1-23	Braced Cantilever	—	—	7	Passed Code	Standl. Ck. .56	1.5	GRG/9-2	GLP/9-29-82	OK ERCW
17A586-1-69	Braced Cantilever	—	—	7	Passed Code	Standl. Ck. .56	1.5	GRG/9-2	GLP/9-29-82	OK ERCW
47A462-8-65	"	—	—	>30		1.60	1.5	GLP/9/26	RUE/9/30/82	OVERSTRESSED 1
47A462-8-52	"	—	—	>30		.44	1.5	GLP/9/30/82	RUE/9/30/82	12.

BRACED CAUTILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED DW DATE 9/29/82

CHECKED RLJ DATE 10-14-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE	ALL-INT. VAL.				
		AXIAL.	MOMENT.								
1-74-8	BRACED CANT.	26.27 K	/	14.3	/	.23	1.5	DWO 9/25	JRH 9/27	STRUDL CODE CHECK	RESIDUAL HEAT REMOVAL
67-IERCW-R510	"	3.17 K	/	55.	/	/	"	DWO 9/25	JRH 9/28	"	ERCW
67-IERCW-R511	"	/	/	40.6	/	/	"	DWO 9/25	JRH 9/28	"	ERCL
47A454-1-44	"	.448 K	/	26.45	/	.40	"	DWO 9/25	JRH 9/28	"	FPC
47A454-2-31	"	1.86 K	/	28.4	/	.06	"	DWO 9/25	JRH 9/28	"	SFPC
1-70-338	"	/	/	43.2	/	/	"	DWO 9/25	JRH 9/28	"	CONDENSER COOLING
1-01A-424	"	85.1 K	/	4.5	/	.94	"	DWO 9/25	JRH 9/28	"	MAIN STEAM
47A492-24	"	.675 K	/	30.5	.424	/	"	DWO 9/29	JRH 9/29	"	PRIMARY WATER
62-1LGV-R78	"	.166	/	11.8	.634	.81	"	GLP 9-8-82	JRH 9/27	"	(LP) CVC

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED 90 DATE 9-3-82
 CHECKED MAC/RLI DATE 9-20-82

(UNIQUE FRAMES)

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. BY DATE	CHK. BY DATE	COMMENT		
			MAXI. LOADS AXIAL	MOMENT	KL/r	BUCKLING STRESS	INT. VALUE				ALL. INT. VAL.	
Blowdown	1-01B-142	Simple Frame	Support subject to Bending only					90/8/12	MAC/9-16-82	No. Buckling evaluation req'd		
"	1-01B-144	Simple Frame	1647*	16740.0 10-#	60	1003.0 psi	0.52	1.5	90/8/12/82	MAC/9-16-82	MEM. is adequate & o.k.	
Chem & (HP) Val control	1-62A-310	"	984*	-	13.64	-	0.12	1.5	90/8/13	MAC/9-16-82	KL/L30 o.k.	
Comp. Cooling	70-100-R259	Simple Frame	Support subject to Axial tension & pure bending NO. Compression.					90/8/12/82	RLI/9/17/82	No Buckling evaluation req'd		
CVC9 (LP)	47A555-10.5	Simple Frame	MEM. subject to very small Axial loading & o.k.					90/8/12/82	RLI/9/17/82	o.k for buckling stress. KL=22		
Feedwater	1-03A-327	Simple Frame	5674*	-	21.2	-	.07 o.k.	-	90/8/13/82	RLI/9/17/82	MEM. is o.k for buckling.	
"	1-03A-204	Free- col.	29775*	-	24.3	-	.23 o.k.	-	90/8/13/82	RLI/9/17/82	MEM. is o.k & adequate.	
ERLW	47A450-21-226 & 226A	Braced frame	MULTI-Loaded (Bowl Comp)		-	730	1.11	1.1 o.k.	1.5	90/8/24/82	RLI/9/17/82	MEM. is o.k. for buckling.
Feedwater	1-03A-290	cant & short column						730		90/8/13/82	RLI/9/17/82	OUT OF SCOPE
Reactor Coolant	1-68-240	cant.	MEM. support is free conti. w/ axial & bending. o.k by inspection.					90/8/14/82	RLI/9/17/82	Axial load & moment too small o.k.		
"	1-68-251	platform beams	NO BUCKLING INVOLVED					90/8/14/82	RLI/9/17/82	o.k No buckling by e.s.		
"	1-68-410	cant. bracket	717*	=	17	Small	22.5	1.5	90/8/14/82	RLI/9/17/82	NO evaluation req'd	
UPPER HEAD INJECTION	1-87-075	Simple Frame	MEM. subject to major bending & small compression					90/8/17/82	RLI/9/17/82	Small buckling stress involved.		
"	1-87-065	Braced Frame	9900*	297330 10-#	37	19.42 psi	1.35	1.5	90/8/14/82	MAC/9-16-82	Analysis is much conservative. o.k.	
ERLW	47A-450-4-45	double cant. frame	876*	-	46	551 psi	0.22	1.5	90/8/17/82	MAC/9-20-82	SUPPORT MEM. OK FOR BUCKLING	
"	47A450-3-158	Simple Frame	NO BUCKLING INVOLVED					90/8/17/82	GLP/9-17-82	OK BY INSPECTION		
"	47A450-21-219	Braced frame	538*	-	138	0.27 psi	0.34	1.5	90/8/17/82	GLP/9-17-82	Buckling stress is very low & o.k.	
ICE COMPENSER	47A462-8-29	Simple Frame	1120*	9890 10-#	22	0.704 psi	6.632	1.5	90/8/17/82	GLP/9-17-82	MEM. are o.k for buckling	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING

PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9/24/82
 CHECKED RJ DATE 10-14-82

(UNIQUE FRAMES)

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING							DES. BY DATE.	CHK. BY DATE.	COMMENT.
		MAXI. LOADS		K/L	BUCKLING INT.	ALL INT.	STRESS VALUE	VAL.			
		AXIAL.	MOMENT.	r							
I.C. 47A462-8-19	SIMPLE CANT. FRAME	MEM. O.K.		730	SEE SUPPORT 47A462-8-23				8/20/82	GLP 9-17-82	OK
" 47A462-8-20	SIMPLE CANT. FRAME	MEM. O.K.		730	SEE SUPPORT 47A462-8-23				8/20/82	GLP 9-17-82	OK
" 47A462-8-23	SIMPLE CANT. FRAME	3651	78.62	48	778	0.76	1.5		8/21/82	GLP 9-17-82	O.K. FOR BUCKLING
" 47A462-8-24	"	MEM. O.K.		730	SEE SUPPORT 47A462-8-23				8/20/82	GLP 9-17-82	
HPFP 47A491-8-13	CANTI. FRAME	240	13772	20	160	1.7	1.5		8/24/82	RJI 9/17	MEM. O.K. FOR BUCKLING
SERVICES AIR 47A492-2-13	CANTI. FRAME	SEE CALC. & COMPUTER RUN		730	1.20	1.5			8/9/82	RJI 9/17	MEM. O.K. FOR BUCKLING
ERCW 17A586-1-68	BRACED CANTI. FR.	MEM. O.K.		730	SEE ATTACHED COMPUTER RUN				8/31/82	RJI 9/17	O.K.
" 67-1ERCW-R362	CANTI. FRAME			730					9/14/82	JRH 10-6	OUT OF SCOPE
" 67-1ERN-R362	BRACED CANTI.	SEE CALC.		63.2	2.2	0.32	1.5		8/31/82	RJI 9/18/82	MEM. O.K. FOR BUCKLING
AUX. FEEDWATER (L) CVCS 1-03B-5	RIGID FRAME	SEE COMPUTER RUN		20.1		.11	1.5		8/9/82	RJI 9/18/82	
" 62-1CV-V13	DS-WITH FRAME	.2	.23	82	Low	Low	1.5		9/29/82	MAC 9-29-82	KP / r 730 Low Loads
RHR 1-74-11	UNIQUE FRAME-DS	M1 18.9		62	4.14	.24	1.5		9/29/82	MAC 9-29-82	KP / r 730
		M2 18.9	89.8	78	4.15	.77	1.5				

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9/28/82

CHECKED RLI DATE 10-14-82

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING							DES. BY DATE.	CHK. BY DATE.	COMMENT.
			MAXI. LOADS		K/L r	BUCKLING STRESS	INT. VALUE	ALL. INT. VAL.				
			AXIAL.	MOMENT.								
REACTOR COOL.	47A465-8-22	CANTILEVER	SMALL	SMALL	8	SMALL	SMALL	1.5	DP 9/29/82	RLI 9/28/82	OK BY INSPECTION	
"	47A465-8-9	"	SMALL	SMALL	8	SMALL	SMALL	1.5	GP 9/25/82	RLI 9/28/82	OK BY INSPECTION	
"	47A465-8-14	"	-	3.52	-	-	-	1.5	GP 9/25/82	RLI 9/28/82	No BUCKLING INVOLVED	
"	47A465-8-20	"	-	SMALL	-	-	-	1.5	DP 9/29/82	RLI 9/28/82	No BUCKLING INVOLVED	
HPFP	47A491-10-3	"	.16 ^K	-	178	.06	.01	1.5	GP 9/25/82	RLI 9/28/82		
"	47A491-6-2	"	-	10.3	-	-	.62	1.5	GP 9/25/82	RLI 9/28/82	No BUCKLING INVOLVED	
REACTOR COOL	47A465-8-27	"	.03 ^K	2.9	63	-	-	1.5	GP 9/25/82	RLI 9/28/82	O.K. BY INSPECTION SMALL LOADS	
PRIM WATER	47A492-2-23	"	.03	.63	46	-	-	1.5	DP 9/25/82	RLI 9/28/82	OK BY INSPECTION	
"	47A492-2-2	"	.46	4.97	27	.18	.32	1.5	DP 9/29/82	RLI 9/28/82		
SERVICE AIR	47A492-2-17	"	.21	9.26	85	.08	.21	1.5	DP 9/29/82	RLI 9/28/82		
VH I	1-87-074	"	-	Moment ONLY	-	-	-	1.5	GP 9/25/82	RLI 9/28/82	No BUCKLING INVOLVED	
"	1-87-071	"	10.7	136	30.2	1.74	.53	1.5	GP 9/24/82	RLI 9/28/82		
"	1-87-039	"	-	Moment ONLY	-	-	-	1.5	RLI 9/28/82	MAC 9/28/82	No BUCKLING INVOLVED	
"	1-87-077	"	-	Moment ONLY	-	-	-	1.5	RLI 9/28/82	MAC 9/28/82	No BUCKLING INVOLVED	
REACTOR COOLANT	1-68-299	"	.48	3.02	42.1	.07	1.32	1.5	RLI 9/28/82	MAC 9/28/82	CHECKED STIFFNESS ONLY	
RHR	47A432-2-1	"	1.79 ^K	11.9	135.4	.4	.78	1.5	RLI 9/28/82	MAC 9/28/82		
REACTOR COOLANT	1-68-310	"	.022	15	44	.32	.42	1.5	RLI 9/28/82	MAC 9/28/82		
"	47A465-1-29	"	-	Moment ONLY	-	-	-	1.5	RLI 9/28/82	MAC 9/28/82	No BUCKLING INVOLVED	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9-28-82

CHECKED RLI DATE 10/4/82

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT
			MAXI. LOADS		K/L	BUCKLING STRESS	INT. VALUE	ALL INT. VAL.			
			AXIAL	MOMENT					r		
Reac. Coolant	47A465-1-35	CANT	-	ONLY	-	-	-	1.5	RLI 9/28/82	MAC 9/28/82	No BUCKLING INVOLVED
"	47A465-1-31	"	-	ONLY	-	-	-	1.5	RLI 9/28/82	MAC 9/28/82	No BUCKLING INVOLVED
UHI	1-87-038	"	-	ONLY	-	-	-	1.5	RLI 9/28/82	MAC 9/28/82	No BUCKLING INVOLVED
Reac. Coolant	47A465-8-24	"	Small	Small	61	Small	Small	1.5	RLI 9/28/82	MAC 9/28/82	O.K. BY INSPECTION SMALL LOADS
ERCW	47A450-3-171	"	1.12	27	36	.02	.034	1.5	RLI 9/27/82	MAC 9/28/82	$\frac{K/L}{r} > 30$
RHR	47A432-1-4	"	.045	.186	166	.06	.19	1.5	RLI 9/24/82	MAC 9/28/82	$\frac{K/L}{r} > 30$
SIS	47A435-2-5	"	-	ONLY	-	-	-	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
"	63-1515-231	"	-	ONLY	-	-	-	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
"	1-63-008	"	2.05	26.1	18	1.02	.75	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
"	1-63-003	"	-	ONLY	-	-	-	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
"	1-63-002	"	-	ONLY	-	-	-	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
FUEL POOL COOLING	78-1FPC-R50	"	3.2	-	18.1	1.43	.07	1.5	RLI 9/26/82	MAC 9/28/82	No BUCKLING INVOLVED
"	78-1FPC-R2	"	.13	2.64	38	-	-	1.5	RLI 9/26/82	MAC 9/28/82	OK BY INSPECTION
"	78-1FPC-R1	"	.05	1.1	38	-	-	1.5	RLI 9/25/82	MAC 9/28/82	O.K BY INSPECTION
"	47A434-1-14	"	.67	47.3	18	.26	1.05	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
FEEDWATER	1-03A-36f	"	.7	34.4	29	.27	.77	1.5	RLI 9/23/82	MAC 9/28/82	No BUCKLING INVOLVED
"	1-03A-363	"	12.1	85.2	39.4	1.97	.8	1.5	RLI 9/23/82	MAC 9/28/82	1) MEMBER $\frac{K/L}{r} > 30$
"	1-03A-361	"	12.1	-	47	4.8	.26	1.5	RLI 9/23/82	MAC 9/28/82	2) LUG $\frac{K/L}{r} > 30$
"	1-03A-361	"	5.9	109.3	36	.59	.57	1.5	RLI 9/24/82	MAC 9/28/82	$\frac{K/L}{r} > 30$

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 9/28/82
CHECKED RLT DATE 10-14-82

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. BY DATE	COMMENT
			MAXI. LOADS		KL/r	BUCKLING STRESS	INT. VALUE	ALL. INT. VAL.			
			AXIAL.	MOMENT.							
ERCW	47A450-21-20	CANT	1.65	45.5	34.4	.16	1.04	1.5	RLT 9/21/82 MAC 9-28-82	$\frac{KL}{r} > 30$	
"	67-1ERCW-R522	"	2.24	85.8	51	.36	.61	1.5	RLT 9/21/82 MAC 9-28-82	$\frac{KL}{r} > 30$	
CONT. SPRAY	72-1CS-R33	"	-	ONLY	-	-	-	1.5	RLT 9/21/82 MAC 9-28-82	NO BUCKLING INVOLVED	
"	72-1CS-R36	"	-	ONLY	-	-	-	1.5	RLT 9/21/82 MAC 9-28-82	NO BUCKLING INVOLVED	
Comp. COOLING	70-1CC-R507	"	-	ONLY	-	-	-	1.5	RLT 9/21/82 MAC 9-28-82	NO BUCKLING INVOLVED	
"	70-1CC-R76	"	-	ONLY	-	-	-	1.5	RLT 9/21/82 MAC 9-28-82	NO BUCKLING INVOLVED	
"	2-70-844	"	.05	1.65	29	.03	.1	1.5	RLT 9/21/82 MAC 9-28-82		
"	2-70-824	"	.09	2.6	55.4	.03	.06	1.5	RLT 9/21/82 MAC 9-28-82	$\frac{KL}{r} > 30$	
"	1-70-258	"	1.02	11.9	72.4	.04	.37	1.5	RLT 9/21/82 MAC 9-28-82	$\frac{KL}{r} > 30$	
"	1-70-186	"	'OK BY INSPECTION'		29			1.5	RLT 9/21/82 MAC 9-28-82	Small Loads	
65) Chem. Vol Control	47A555-10-3	"	.05	.82	73	.03	.05	1.5	RLT 9/21/82 MAC 9-28-82	$\frac{KL}{r} > 30$	
"	47A555-10-1	"	.06	3.03	130	.01	.03	1.5	RLT 7/27/82 MAC 9-28-82	$\frac{KL}{r} > 30$ 1) MEMBER 2) LUG	
LP	47A555-3-10	"	Small	-	12	Small	Small	1.5	RLT 9/21/82 MAC 9-28-82	OK BY INSPECTION Small Loads	
"	47A555-3-9	"	Small	-	12	Small	Small	1.5	RLT 9/21/82 MAC 9-28-82	OK BY INSPECTION Small Loads	
"	47A555-3-8	"	-	ONLY	-	-	-	1.5	RLT 9/21/82 MAC 9-28-82	NO BUCKLING INVOLVED	
"	47A555-3-7	"	-	ONLY	-	-	-	1.5	RLT 9/21/82 MAC 9-28-82	NO BUCKLING INVOLVED	
"	47A555-3-6	"	Small	-	18	Small	Small	1.5	RLT 9/21/82 MAC 9-28-82	OK BY INSPECTION Small Loads	
HP	47A406-7-67	CANT	.048	3.74	52	.03	.23	1.5	RLT 9/21/82 JRH 9-28-82	$\frac{KL}{r} > 30$	
HP	47A406-7-73	"	"	"	"	"	"	"	RLT 9/21/82 JRH 9-28-82		

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING

PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9-30-82

CHECKED RJT DATE 10-14-82

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. DATE	COMMENT	
			MAXI. LOADS		KL	BUCKLING STRESS	INT. VALUE	ALL. INT. VAL.				
			AXIAL.	MOMENT.								
HP chon. v. d. can	47A406-3-9	CANT	-	ONLY	-	-	-	1.5	RJE 9/21/82	JRH 9/28/82	No BUCKLING INVOLVED	
"	47A406-3-10	"	-		-	-	-	1.5	RJE 9/21/82	JRH 9/28/82	}	
LP "	62-11CV-R79	"	-		-	-	-	1.5	RJE 9/21/82	JRH 9/28/82		
LP "	62-11CV-R74	"	-		-	-	-	1.5	RJE 9/21/82	JRH 9/28/82		
HP "	62-11CV-R11	"	-		-	-	-	1.5	RJE 9/21/82	JRH 9/28/82		
HP "	62-11CV-R10	"	-		-	-	-	1.5	RJE 9/21/82	JRH 9/28/82		
HP "	1-62A-305	"	-		-	-	-	1.5	RJE 9/21/82	JRH 9/28/82		
HP "	1-62A-304	"	-		-	-	-	1.5	RJE 9/21/82	JRH 9/28/82		
AUX. BOILER	12-1AAB-R056	"	-		-	-	-	1.5	RJE 9/21/82	JRH 9/28/82		
HP chon. v. d. can	1-62A-306	"	.84	28.7	35.3	.32	.65	1.5	RJE 9/21/82	JRH 9/28/82		KL / r > 30
LP chon. v. d. can	62-11CV-R77	"	.42	41	35	.12	.48	1.5	RJE 9/21/82	JRH 9/28/82		
AUX. BOILER	12-1AAB-R51	"	1.06	-	183.3	.41	<1.5	1.5	RJE 9/21/82	JRH 9/28/82	KL / r > 30	
"	47A431-9-4	"	.723	-	35	1.54	<1.5	1.5	RJE 9/21/82	JRH 9/28/82	KL / r > 30	
SAFETY INT.	1-63-011	"	No	BUCKLING INVOLVED					RJE 9/30/82	MAC 9-30-82		
REAR COOLER	47A405-8-25	"	No	BUCKLING INVOLVED					RJE 9/30/82	MAC 9-30-82		
RHR	77-1RHR-R139	"	No	BUCKLING INVOLVED					RJE 9/30/82	MAC 9-30-82		

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 10/1/82

CHECKED RJI DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT	
		MAXI. LOADS		KL	BUCKLING STRESS	INT. VALUE	ALL. INT. VAL.				
		AXIAL.	MOMENT.								
FEEDWATER	1-03A-206	L-CANT	4.69	23.75	24	1.23	.26	1.5	GP 9/23/82	RJI 9/21/82	
RHR	47A432-1-3	"	.048	—	94	SMALL	SMALL	1.5	GP 9/22/82	RJI 9/24/82	OK BY INSPECTION
CONT. SPRAY	72-1CS-R35	"	4.0	84.0	30.9	SMALL	.17	1.5	GP 9/22/82	RJI 9/24/82	
SIS	47A435-1-3	"	No BUCKLING INVOLVED						GP 9/22/82	RJI 9/21/82	
"	47A435-2-4	"	.37 ^L	4.44	73	.143	.11	1.5	GP 9/22/82	RJI 9/24/82	$\frac{KL}{r} > 30$
HDFP	47A491-10-5	"	.32 ^F	3.42	12.3	.09	.17	1.5	GP 9/22/82	RJI 9/24/82	
AUX BOILER	47A431-9-27	"	1.9	79.117	17.2	.34	.29	1.5	GP 9/22/82	RJI 9/21/82	
Comp. Cooling	70-ICC-R15	"	2.4	18.0	187	.53	.21	1.5	GP 9/21/82	RJI 9/25/82	$\frac{KL}{r} > 30$
Reac. Coolant	1-68-260	"	.5	10.65	55	.06	.05	1.5	GP 9/20/82	RJI 9/25/82	$\frac{KL}{r} > 30$
"	1-68-290	"	.17	3.3	70	.08	.09	1.5	GP 9/20/82	RJI 9/25/82	$\frac{KL}{r} > 30$
"	1-68-380	"	.09	5.7	57	.04	.16	1.5	GP 9/20/82	RJI 9/25/82	$\frac{KL}{r} > 30$
"	47A465-8-18	"	.2	1.2	73	.08	.11	1.5	GP 9/18/82	RJI 9/25/82	$\frac{KL}{r} > 30$
ICE CONDENSER	47A462-8-25	"	1.02	4.59	37	.39	.12	1.5	GP 9/18/82	RJI 9/25/82	$\frac{KL}{r} > 30$
"	47A462-8-35	"	2.97 ^F		12	1.15	1.1	1.5	DWB 10/1/82	JRH 10/1/82	
"	47A462-8-36	"	"		"	"	"	"	DWB 10/1/82	JRH 10/1/82	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED GLP DATE 9-21-82 (VENDOR COMPONENTS)

CHECKED RUI DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING				ALL INT. VAL.	DES. DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. AXIAL.	LOADS MOMENT.	K _L	BUCKLING INT. STRESS VALUE					
47A462-8-9	SNUBBER	NO	BUCKLING	CONSIDERED		GLP	RUI		ICE COND.	
47A462-8-1	SNUBBER	NO	BUCKLING	CONSIDERED		GLP	RUI		ICE COND.	
47A491-8-11	ROD	NO	BUCKLING	CONSIDERED		GLP	RUI		FP	
47A491-8-9	ROD	NO	BUCKLING	CONSIDERED		GLP	RUI		FP	
47A465-8-12	SNUBBER	NO	BUCKLING	CONSIDERED		GLP	RUI		REACTOR COOLANT	
1-68-370	SNUBBER	NO	BUCKLING	CONSIDERED		GLP	RUI		REACTOR COOLANT	
1-87-076	CONSTANT SUPPORT	NO	BUCKLING	CONSIDERED		GLP	RUI		UHI	
1-87-072	VARIABLE SUPPORT	NO	BUCKLING	CONSIDERED		GLP	RUI		UHI	
1-87-068	SNUBBER	NO	BUCKLING	CONSIDERED		GLP	RUI		UHI	
1-87-040	ROD	NO	BUCKLING	CONSIDERED		GLP	RUI		UHI	
1-87-034	SPRING	NO	BUCKLING	CONSIDERED		GLP	RUI		UHI	
1-87-033	SNUBBER	NO	BUCKLING	CONSIDERED		GLP	RUI		UHI	
1-87-030	SNUBBER	NO	BUCKLING	CONSIDERED		GLP	RUI		UHI	
74-1RHR-156	SWAY STRUT	NO	BUCKLING	CONSIDERED		GLP	RUI		RHR	
74-1RHR-161	SWAY STRUT	NO	BUCKLING	CONSIDERED		GLP	RUI		RHR	
74-1RHR-164	SWAY STRUT	NO	BUCKLING	CONSIDERED		GLP	RUI		RHR	
74-1RHR-165	SWAY STRUT	NO	BUCKLING	CONSIDERED		GLP	RUI		RHR	
74-1RHR-168	SWAY STRUT	NO	BUCKLING	CONSIDERED		GLP	RUI		RHR	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED GLP DATE 9-21-82

(Vendor Components)

CHECKED RLI DATE 10/4/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. BY DATE	CHK. BY DATE	COMMENT	
		MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE				FULL INT. VAL.
		AXIAL.	MOMENT.							
47A432-1-1A	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	RHR	
47A432-1-2A	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	RHR	
63-1515-R33	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	SIS	
63-1515-R31	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	SIS	
72-1CS-R23	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
72-1CS-R21	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
72-1CS-R24	ROD	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
72-1CS-R27	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
72-1CS-R28	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
72-1CS-R32	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
72-1CS-R34	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
72-1CS-R37	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
72-1CS-R39	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
72-1CS-R41	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CS	
70-1CL-R491	SHEAR LUGS	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	CC	
47A406-3-8	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RLI 9/29/82	HP / CVC	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED BY GLP DATE 9-21-82
 CHECKED BY RJE DATE 10/14/82
 (Vendor Components)

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		KL	BUCKLING STRESS	INT. VALUE				
		AXIAL.	MOMENT.				Y			
47A406-3-7	SWAY STRUT						GLP 9-21-82	RJE 9/29/82	HP	CVC
62-11LV-R72	STRUT						GLP 9-21-82	RJE 9/29/82	LP	CVC
62-12VC-R14	ROD						GLP 9-21-82	RJE 9/29/82	HP	CVC
1-62A-311	SNUBBER						GLP 9-21-82	RJE 9/29/82	HP	CVC
1-01A-356	SWAY STRUT						GLP 9-21-82	RJE 9/27/82		MS
1-01A-354	SWAY STRUT						GLP 9-21-82	RJE 9/29/82		MS
2-01A-354	SWAY						GLP 9-21-82	RJE 9/29/82		MS
1-01A-318	STRUT						GLP 9-21-82	RJE 9/27/82		MS
2-01A-318							GLP 9-21-82	RJE 9/27/82		MS
1-01A-307	SNUBBER						JRH 8-26-82	MAY 9-27-82		SI
1-63-590	SNUBBER						JRH 8-26-82	MAY 9-27-82		SI
1-63-591	SNUBBER						JRH 8-26-82	MAY 9-27-82		SI
1-63-592	SNUBBER						JRH 8-26-82	MAY 9-27-82		SI
03B-1AFW-R7	STRUT						JRH 8-26-82	MAY 9-27-82		AFW

BUCKLING CONSIDERED

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 6/7/82
CHECKED RJE DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT.	SYST.
		MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE	ALL INT. VAL.				
		AXIAL.	MOMENT.								
47A450-3-28	Braced Rigid frame	1248 #	/	31.36	/	/	/	JRH 8/20	MAC 9/27	KL = 730 OK	ERCW
47A450-3-100	"	11040 #	/	7.81	fa = 1.34 KSI	.128	1.5	JRH 8/24	MAC 9/27	SAGS OK	"
67ERCW-R289	"	6720 #	/	15.02	fa = 1.47 KSI	.24	"	JRH 8/24	MAC 9/28	"	"
67ERCW-R95	"	37120 #	/	9.62	/	.267	"	DWO 8/24	MAC 9/28	STRUDL CODE CHECK	"
03B-1AFW-R4	"	17600 #	/	8.54	/	.427	"	DWO 8/24	MAC 9/29	"	AFW
03B-1AFW-R22	"	"	/	"	/	"	"	DWO 8/24	MAC 9/28	"	"
03B-1AFW-R5	"	"	/	"	/	"	"	DWO 8/24	MAC 9/28	"	"
47A450-4-33	"	4960 #	/	22.25	fa = 1.83 KSI	.096	"	JRH 8/26	MAC 9/28	SAGS OK	ERCW
70-1CC-R446	"	15520 #	/	9.47	/	.366	"	DWO 8/26	MAC 9/28	STRUDL CODE CHECK	COMPONENT COOLING
17A586-5-25	"	2665.6 #	/	18.87	fa = 1.48 KSI	.217	"	JRH 9/10	MAC 9/23	HAND CALCS OK	ERCW
26-1FP-R60	"	11040 #	/	14.61	/	.307	"	JRH 9/15	MAC 9/23	STRUDL CODE CHECK	HPF
17A586-5-20	"	9646.4 #	/	9.7	/	1.12	"	JRH 9/17	MAC 9/23	"	ERCW
17A586-1-20	"	"	/	"	/	"	"	JRH 9/27	MAC 9/26	"	ERCW
78-1FFC-R15	"	"	/	730	/	/	"	JRH 9/27	RJE 10/6	OUT OF SCOPE	Final Proj. Com.

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED DWO DATE 3/1/82
CHECKED RLE DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT	
		MAXI. LOADS		KL r	BUCKLING STRESS	INT. VALUE	ALL. INT. VAL.				
		AXIAL.	MOMENT.								
1-03B-25	BRACED RIGID FRAME	5379 #	/	63	/	/	/	DWO 3/30	JBS 9/15	KL - 30.0K	SYSTEM AUX FEEDW.
26-1FP-R233	"	"	/	"	/	/	/	DWO 3/30	JBS 9/15	"	H.P. FIRE PROTECT.
47A454-2-25	"	"	/	"	/	/	/	DWO 3/30	JBS 9/15	"	SFPC
47A454-2-26	"	"	/	"	/	/	/	DWO 3/30	JBS 9/15	"	SFPC
17A586-1-100	"	17626 #	/	44	/	/	/	DWO 3/30	JBS 9/24	KL - 44.30	INT & EXH ERCW
17A586-1-101	"	"	/	"	/	/	/	DWO 3/30	JBS 9/24	"	INT & EXH ERCW
12-1AAB-R42	"	"	/	"	/	/	/	DWO 3/30	JBS 9/24	"	AUX BOILER
12-1AAB-R12	"	"	/	"	/	/	/	DWO 3/30	JBS 9/24	"	AUX BOILER
12-1AAB-R016	"	4600 #	/	30.4	/	/	/	DWO 3/31	JBS 9/16	KL - 30.4 > 30.0K	AUX BOILER
67-1ERCW-R556	"	"	/	"	/	/	/	DWO 3/31	JBS 9/16	"	ERCW
67-1ERCW-R515	"	"	/	"	/	/	/	DWO 3/31	JBS 9/16	"	ERCW
12-1AAB-R019	"	1470 #	/	16.06	/	.0227	1.5	DWO 3/31	GLP 9-24	STRUDL CORE CHECK	AUX BOILER
73-1FPK-R17	"	"	/	"	/	"	"	DWO 3/31	GLP 9-24	"	FUEL POOL COOL.
17A586-1-8T	"	5.41 5344 #	/	26	/	.36	1.5	DWO 9/1	GLP 9-24	STRUDL CODE CHECK	ERCW
17A586-1-13	"	"	/	"	/	"	"	DWO 9/1	GLP 9-25	"	ERCW
47A462-8-3	"	"	/	"	/	"	"	DWO 9/1	GLP 9-25	"	ICE COND. SYSTEM
47A462-8-4	"	"	/	"	/	"	"	DWO 9/1	GLP 9-25	"	ICE COND. SYSTEM
47A462-8-12	"	"	/	"	/	"	"	DWO 9/1	GLP 9-25	"	ICE COND. SYSTEM

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA TENNESSEE 37401
400 Chestnut Street Tower II

November 10, 1982

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

During an April 1, 1982 telephone conference call with the NRC's Mechanical Engineering Branch, TVA was requested to provide additional information on Watts Bar Nuclear Plant. At the NRC's request, TVA performed a sampling program to verify that the buckling stresses in axial compression members used in pipe support configurations do not exceed 90 percent of the yield strength when their slenderness ratio is less than 30.

TVA investigated 515 randomly selected supports in 19 different systems. The results show that all 252 supports with slenderness ratios less than 30 met the applicable requirements for prevention of critical buckling. The remaining supports sampled had slenderness ratios greater than or equal to 30. Enclosed is a tabular summary of the results of TVA's evaluation.

If you have any questions concerning this matter, please get in touch with D. P. Ormsby at FTS 858-2682.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills
L. M. Mills, Manager
Nuclear Licensing

Sworn to and subscribed before me
this 10th day of November 1982

Paulette H. White
Notary Public
My Commission Expires 9-5-84

Enclosure
cc: See page 2

8211160237 821110
PDR ADCK 05000390
A PDR

3001

Director of Nuclear Reactor Regulation

November 10, 1982

cc: U.S. Nuclear Regulatory Commission (Enclosure)
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 8-26-82
CHECKED RL DATE 10-1-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. BY DATE	COMMENT.	SYSTEM		
		MAXI. AXIAL.	LOADS MOMENT.	K/L	BUCKLING STRESS	INT. VALUE	FULL INT. VAL.						
1	12-1AAB-R17 (BP)	COLUMN	3.92 K	47.0 ^{1/4}	731	$f_b = 1.02$.64	1.5	MAC 8/25	GLP 9-15	Aux Boiler		
2	62-1CVC-R12 (BP)	"	.03 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	CVCS			
3	62-1LCV-R71 (BP)	"	.112 K	0	> 30	/			MAC 8/25	GLP 9-15	L.P. CVCS		
4	" -R75 (BP)	"	.208 K	0	> 30				MAC 8/25	GLP 9-15	"		
5	" -R76 (BP)	"	.240 K	0	> 30				MAC 8/25	GLP 9-15	"		
6	" -R83 (BP)	"	.250 K	0	> 30				MAC 8/25	GLP 9-15	"		
7	" -R90 (BP)	"	.304 K	0	> 30				MAC 8/25	GLP 9-15	"		
8	" -R91 (BP)	"	.160 K	0	> 30				MAC 8/25	GLP 9-15	"		
9	47A406-7-64 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED				MAC 8/25	GLP 9-15	CVCS		
10	" -7-66 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED				MAC 8/25	GLP 9-15	"		
11	" -7-67 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
12	" -7-68 (TVA)	"	.048 K	152 ^{5/8}	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
13	" -7-69 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
14	" -7-70 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
15	" -7-71 (TVA)	"	.048 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	"			
16	" -7-72 (TVA)	"	.032 K	0	BUCKLING NOT INVOLVED			MAC 8/25	GLP 9-15	CVCS			
17	1-70-979 (BP)	"	.658 K	1.65 ^{5/8}	13.03	$f_b = .414$.110	1.5	MAC 8/25	GLP 9-15	COMP COOL		
18	70-1CC-R249 (BP)	COLUMN	39.80 K	0	12.12	$f_b = 5.42$.265	1.5	MAC 8/26	GLP 9-15	COMP COOL		

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 8-27-82

CHECKED R ILLICH DATE 10-1-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING				K _L	BUCKLING STRESS	INT. VALUE	ALL-INT. VAL.	DES. DATE	CHK. BY DATE	COMMENT
		MAXI. AXIAL.	LOADS MOMENT.	r								
(BP) 67-IERCW-R343	COLUMN	22.24 K	0	7.6	f _a = 1.87	.088	1.5	MAC 8/26	GLP 9-16	ITEM # 3	ESSENTIAL RAW COOLING WATER	
(BP) 67-IERCW-R96	"	53.44 K	0	3.92	f _a = 4.49	.209	1.5	MAC 8/26	GLP 9-16	ITEM # 5	ESSENTIAL RAW COOLING WATER	
(EDS) 1-03A-209	"	11.04 K	0	20.58	f _a = 2.89	.142	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-208	"	22.38 K	0	7.52	f _a = 3.04	.143	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-247	"	20.77 K	0	8.72	f _a = 2.82	.133	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-246	"	9.1 K	0	8.8	f _a = 1.24	.058	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-249	"	4.95 K	0	6.58	f _a = .81	.038	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-284	"	11.73 K	0	8.18	f _a = 1.6	.075	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-286	"	33.06 K	0	6.18	f _a = 4.06	.19	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-291	"	12.3 K	6.92 ^{1/4}	8.8	f _a = 1.61	.146	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-325	"	12.42 K	0	7.88	f _a = 1.69	.08	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-329	"	42.64 K	0	6.52	f _a = 6.04	.284	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(EDS) 1-03A-331	"	7.91 K	7.41 ^{1/4}	6.84	f _a = 1.73	.187	1.5	MAC 8/26	GLP 9-16		FIRE PROTECTION	
(TVA) 47A491-10-1	"	12.45 K	7.05 ^{1/4}	8.63	f _a = 1.69	.147	1.5	MAC 8/26	GLP 9-16		FEED WATER	
(TYA) 47A491-10-2	"	.24 K	1.95 ^{1/4}	21.3	f _a = .151	.13	1.5	MAC 8/27	RUE 9/15		FIRE PROTECTION	
(TVA) 47A491-10-6	"	.24 K	1.95 ^{1/4}	21.3	f _a = .151	.13	1.5	MAC 8/27	RUE 9/15		FIRE PROTECTION	
(BP) 26-IFP-R56	"	.004 K	3.5 ^{1/4}	18.3	f _a = .4	.237	1.5	MAC 8/27	RUE 9/15		FIRE PROTECTION	
(BP) 26-IFP-R57	"	4.8 K	0	30	f _a = .36	.04	1.5	MAC 8/27	RUE 9/15		H.P. FIRE PROTECTION	
(BP) 26-IFP-R57	"	4.8 K	0	30.1	f _a = .86	.04	1.5	MAC 8/27	RUE 9/15		H.P. FIRE PROTECTION	
(BP) 26-IFP-R57	COLUMN	2.56 K	0	14.04	f _a = 1.0	.06	1.5	MAC 8/27	RUE 9/15		H.P. FIRE PROTECTION	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 8-27-82

CHECKED RILICH DATE 10-1-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING							DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		KL F	BUCKLING STRESS	INT. VALUE	REL. INT. VAL.					
		AXIAL.	MOMENT.									
(TVA) 47A491-8-10	COLUMN	.096 K	.87%	30	$f_a = .025$.007	1.5	MAC 8/27	R/E 9/15		FIRE PROTECTION	
(TVA) 47A491-8-12	"	.24 K	1.20%	14.6	$f_a = .068$.014	1.5	MAC 8/27	R/E 9/15		FIRE PROTECTION	
(TVA) 47A491-8-14	"	.24 K	1.31%	21.3	$f_a = .15$.082	1.5	MAC 8/27	R/E 9/15		E.I.R.F. PROTECTION	
(BP) 78-IFPC-R73	"	32 K	0	13.7	$f_a = 10.6$.51	1.5	MAC 8/27	R/E 9/15		FUEL P. COOLING	
(BP) 78-IFPC-R59	"	.96 K	0	30	$f_a = .43$.021	1.5	MAC 8/27	R/E 9/15		FUEL POOL COOLING	
(BP) 78-IFPC-R58	"	.32 K	0	30	$f_a = .143$.007	1.5	MAC 8/27	R/E 9/15		FUEL POOL COOLING	
(BP) 78-IFPC-R45	"	2A K	0	13.7	$f_a = .79$.038	1.5	MAC 8/27	R/E 9/16		FUEL POOL COOLING	
(TVA) 47A462-8-39	"	.09 K	11.8%	30	$f_a = .054$.052	1.5	MAC 8/30	R/E 9/16		ICE CONDENSER	
(TVA) 47A462-8-40	"	.09 K	8.0%	30	$f_a = .05$.515	1.5	MAC 8/30	R/E 9/16		ICE CONDENSER	
(TVA) 47A462-8-38	"	.15 K	12.5%	30	$f_a = .107$.79	1.5	MAC 8/30	R/E 9/16		ICE CONDENSER	
(TVA) 47A462-8-37	"	.15 K	12.5%	130	$f_a = .107$.79	1.5	MAC 8/30	R/E 9/16		ICE CONDENSER	
(TVA) 47A462-8-17	"	.72 K	0	30	$f_a = .2$.01	1.5	MAC 8/30	R/E 9/16	ITEM # 3	ICE CONDENSER	
(EDS) 1-01A-426	"	206.5 K	0	1.86	$f_a = 26.1$	1.21	1.5	MAC 9/7	R/E 9/16		MAIN STEAM	
(EDS) 1-01A-385	"	82.3 K	0	4.65	$f_a = 10.4$.483	1.5	MAC 9/7	R/E 9/16		MAIN STEAM	
(EDS) 1-01A-345	"	56.7 K	0	4.65	$f_a = 7.17$.552	1.5	MAC 9/7	R/E 9/16		MAIN STEAM	
(EDS) 1-01A-347	"	137.0 K	0	7.6	$f_a = 16.8$.79	1.5	MAC 9/7	R/E 9/16		MAIN STEAM	
(EDS) 1-01A-315	"	92.2 K	0	18.5	$f_a = 7.8$.38	1.5	MAC 9/7	R/E 9/16		MAIN STEAM	
(EDS) 1-01A-311	"	96.7 K	0	20.9	$f_a = 13.7$.67	1.5	MAC 9/2	R/E 9/16		MAIN STEAM	
(EDS) 1-01A-310	COLUMN	168.3	0	22.3	$f_a = 11.7$.57	1.5	MAC 9/2	R/E 9/16		MAIN STEAM	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9/14

CHECKED RLI DATE 10/1/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING							DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		KL Y	BUCKLING STRESS	INT. VALUE	REL. INT. VAL.					
		AXIAL.	MOMENT.									
(EDS) 2-01A-385	COLUMN	38.0K	0	46.6	$f_a = 4.78$.227	1.5	MAC 9/15	RLI 9/16		MAIN STEAM	
(EDS) 2-01A-347	"	176.2K	0	16.4	$f_a = 21$	1.01	1.5	MAC 9/13	RLI 9/16		MAIN STEAM	
(EDS) 2-01A-345	"	31.5K	0	3.7	$f_a = 3.96$.184	1.5	MAC 9/13	RLI 9/16		MAIN STEAM	
(EDS) 2-01A-315	"	214.1K	0	20.2	$f_a = 18.15$.88	1.5	MAC 9/14	RLI 9/16		MAIN STEAM	
(EDS) 2-01A-311	"	96.7K	0	20.9	$f_a = 13.63$.67	1.5	MAC 9/14	RLI 9/16		MAIN STEAM	
(EDS) 2-01A-306	"	18.02K	0	3.7	$f_a = 2.87$.11	1.5	MAC 9/14	RLI 9/16		MAIN STEAM	
(EDS) 1-68-270	"	.43	6.95%	30.0	$f_a = .21$.43	1.5	MAC 9/14	RLI 9/16		REACTOR COOLANT	
(EDS) 1-68-273	"	1443K	0	19.27	$f_a = .171$.008	1.5	MAC 9/14	GLP 9/16		REACTOR COOLANT	
(EDS) 1-68-320	"	.677K	4.8%	8.65	$f_a = .43$.310	1.5	MAC 9/14	GLP 9-16		REACTOR COOLANT	
(TVA) 47A445-8-1	"	.816K	0	13.77	$f_a = 1.65$.078	1.5	MAC 9/14	GLP 9-16		REACTOR COOLANT	
(TVA) 47A465-8-17	"	.022K	0	7.30				MAC 9/14	GLP 9-16		REACTOR COOLANT	
(TVA) 47A432-3-1	"	.099K	.22%	4.25	$f_a = .06$.016	1.5	MAC 9/14	GLP 9-16		RHR	
(BP) 63-1515-R28	"	1.76K	0	4.57	$f_a = 1.65$.077	1.5	MAC 9/14	GLP 9-16	ITEM #1 00-150.	SAFETY	
(EDS) PROB(15-02) 1-87-037	"	1.76K	0	12.78	$f_a = 1.04$.05	1.5	MAC 9/14	GLP 9-16	ITEM #2 00-150.	INJECTION	
(EDS) PROB(15-02) 1-87-058	"	20.8K	0	10.34	$f_a = 4.47$.208	1.5	MAC 9/14	GLP 9-16		UPPER HEAD INJECTION	
(EDS) PROB(15-02) 1-87-058	"	6.28K	0	1.76	$f_a = 1.65$.076	1.5	MAC 9/14	GLP 9-16		UPPER HEAD INJECTION	
(EDS) PROB(15-02) 1-87-59	"	13.70K	0	10.86	$f_a = 2.92$.138	1.5	MAC 9/14	GLP 9-16		UPPER HEAD INJECTION	
(EDS) PROB(15-02) 1-87-60	"	16.0K	0	30.0	$f_a = 3.39$.16	1.5	MAC 9/14	RLI 9/16		UPPER HEAD INJECTION	
(EDS) PROB(15-02) 1-87-61	"	13.8K	0	17.6	$f_a = 2.79$.135	1.5	MAC 9/14	RLI 9/16		UPPER HEAD INJECTION	
(EDS) PROB(15-02) 1-87-63	COLUMN	47.7K	0	30.0	$f_a = 10.11$.51	1.5	MAC 9/14	RLI 9/16		UPPER HEAD INJECTION	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9/29

CHECKED RLE DATE 10/1/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE	ALL-INT. VAL.				
		AXIAL.	MOMENT.	r							
(EDS) PROB: (15-02) 1-87-64	COLUMN	28.3K	0	30	$f_a = 6.0$.30	1.5	MAC 9/14	RLE 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-02) 1-87-067	"	2.88K	0	30	$f_a = .76$.04	1.5	MAC 9/15	RLE 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-02) 1-87-79	"	3.85K	92.4%	19.7	$f_a = .545$.788	1.5	MAC 9/15	RLE 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-02) 1-87-078	"	5.88K	0	30	$f_a = 1.29$.061	1.5	MAC 9/15	RLE 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-01) 1-87-036	"	39.8K	0	30	$f_a = 8.43$.42	1.5	MAC 9/15	RLE 9/16		UPPER HEAD INJECTION
(EDS) PROB: (15-01) 1-87-032	COLUMN	5.48K	0	30	$f_a = 2.29$.12	1.5	MAC 9/15	RLE 9/16		UPPER HEAD INJECTION
03B-1AFW-R02	"	.112K	0	77.84	$f_a =$			JRH 8/26	MAC 9/27	$K/r > 30$	AFW
1-03A-324	"	27.62K	0	2.25	3.77ksi	.18	1.5	JRH 8/31	MAC 9/27		FW
1-01B-16	"	.14K	0	21.0				GP 9/7	MAC 9/27	OK BY INSPECTION	SLOW DOWN
1-03A-245	"	19.6 K	0	3.4	9.71	.45	1.5	DWO 9/17	MAC 9/28		FEED WATER
1-01A-432	"	231	0	37	11.8	.61	1.5	RLE 9/29	MAC 9/29	$K/r > 30$	MAIN STEAM
1-01A-388	"	197	0	87	8.77	.6	1.5	RLE 9/29	MAC 9/29	$K/r > 30$	MAIN STEAM
2-01A-388	"	1.42	0	32	1.89	.1	1.5	RLE 9/29	MAC 9/29	$K/r > 30$	AUXILIARY BOILER
12-1AAB-R027	"	"	"	"	"	"	"	RLE 9/29	MAC 9/29	"	AUXILIARY BOILER
12-1AAB-R052	"	"	"	"	"	"	"	RLE 9/29	MAC 9/29	"	AUXILIARY BOILER
72-1CS-R31	"	2.72	0	9	1.2	.06	1.5	RLE 9/29	MAC 9/29		CONTAINMENT SPIN RESIDUAL HEAT REMOVAL
1-74-7	"	58.8	0	18	13	.63	1.5	RLE 9/29	MAC 9/29		FEED WATER
1-03A-242	"	51.5	0	47	3.8	.21	1.5	RLE 9/29	MAC 9/29	$K/r > 30$	FEED WATER
1-03A-202	"	"	"	"	"	"	"	RLE 9/29	MAC 9/29	"	FEED WATER
1-01A-430	"	139	0	40	11.8	.61	1.5	RLE 9/29	MAC 9/29	$K/r > 30$	MAIN STEAM

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED EJP DATE 8/16/82
CHECKED RLI DATE 10-1-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT	
		MAXI. AXIAL.	LOADS (K) MOMENT.	K/L	BUCKLING STRESS	INT. VALUE	ALL INT. VAL.				SYSTEM
PROB: (06-01) 1-01A-319 (EDS)	SLEEVE	45.5 ^K	/	.075	f ₂ = 3.0 ^{KSI}	0.14	1.5	EJP 8/16	GLP 9-22-82	RADIAL GRND FLAT PLATE	MN STM
(06-02) 1-01A-356 (EDS)	"	95.4 ^K	/	.075	f ₂ = 6.36 ^{KSI}	0.30	"	EJP 8/16	GLP 9-22-82	"	"
(06-03) 1-01A-398 (EDS)	"	46.5 ^K	/	.075	f ₂ = 3.1 ^{KSI}	0.14	"	EJP 8/16	GLP 9-22-82	"	"
(06-04) 1-01A-433 (EDS)	"	89.2 ^K	/	.075	f ₂ = 2.0 ^{KSI}	0.09	"	EJP 8/16	GLP 9-22-82	"	"
(09-08) 1-70-336 (EDS)	"	0.230 ^K	0.172 ^{"-K}	BUCKLING NOT INVOLVED				EJP 8/16	GLP 9-22-82	LS IN BENDING	COMP COOL.
(04-04) 2-70-136 (EDS)	"	1.58 ^K	0.79 ^{"-K}	BUCKLING NOT INVOLVED				EJP 8/16	GLP 9-22-82	LS W/R N BND'S	"
(04-04) 2-70-157 (EDS)	"	0.094 ^K	/	BUCKLING NOT INVOLVED				EJP 8/16	GLP 9-22-82	RADIAL GRND LS ONLY	"
(02-02) 1-03A-243 (EDS)	"	17.8 ^K	/	0.33	f ₂ = 0.5 ^{KSI}	0.02	1.5	EJP 8/16	GLP 9-22-82	RADIAL GRND FLAT PLATE	FEED WATER
(01-03) 1-03A-282 (EDS)	"	17.1 ^K	/	0.33	f ₂ = 0.4 ^{KSI}	0.02	1.5	EJP 8/16	GLP 9-22-82	RADIAL GRND FLAT PLATE	FEED WATER
(02-02) 1-03A-322 (EDS)	"	34.6 ^K	/	0.33	f ₂ = 0.85 ^{KSI}	0.04	1.5	EJP 8/16	GLP 9-22-82	"	"
(09-01) 1-63-010 (EDS)	"	17.2 ^K	/	2.45	f ₂ = 2.87 ^{KSI}	0.13	1.5	EJP 8/16	GLP 9-22-82	Short IR RAD GRND ON BND	SIS
(03-01) 1-74-2 (EDS)	"	40.8 ^K	/	2.45	f ₂ = 4.08 ^{KSI}	0.19	1.5	EJP 8/16	GLP 9-22-82	"	RHR
ISO: 47W432-206 74-IRHR-8163 (BP)	"	4.8 ^K	/	BUCKLING NOT INVOLVED				EJP 8/16	GLP 9-22-82	RADIAL GRND LS ONLY	RHR
ISO: 47W432-205 74-IRHR-8158 (BP)	"	4.8 ^K	/	BUCKLING NOT INVOLVED				EJP 8/16	GLP 9-22-82	"	"
Anal: N3-26-3A 47A491-2-1 (TVA)	"	0.32 ^K	/	BUCKLING NOT INVOLVED				EJP 8/16	GLP 9-22-82	LS ON OUTSIDE OF SLV	FP
Anal: N3-81-1A 47A492-2-9 (TVA)	"	1.23 ^K	/	BUCKLING NOT INVOLVED				EJP 8/16	GLP 9-22-82	"	PRIMARY WATER
Anal: N3-81-1R 47A492-2-5 (TVA)	"	0.34 ^K	/	BUCKLING NOT INVOLVED				EJP 8/16	GLP 9-22-82	"	"
Anal: N3-33-1A 47A492-2-15 (TVA)	SLEEVE	0.9 ^K	/	1.3	f ₂ = 0.3 ^{KSI}	0.01	1.5	EJP 8/16	GLP 9-22-82	R welded on ground inside SLV	SERVICE AIR
11 2-70-215 (EDS)	SLEEVE	0.09 ^K	/	BUCKLING NOT INVOLVED				EJP 9/22	GLP 9-22-82	RADIAL GRND LS ONLY	COMP COOL.

FINAL EVALUATION REPORT FOR BUCKLING SAMPLES

PROGRAM OF PIPE SUPPORTS

COMPUTED R/L DATE 10-14-82

CHECKED MAC DATE 9-21-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING		K _L Y	BUCKLING INT. STRESS	INT. VALUE	ALL-INT. VAL.	DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS AXIAL.	MOMENT.								
1-70-095	RIGID FRAME	1568 #	/		NO BUCKLING INVOLVED			JRH 8/28	MAC 9/20	ok	COMPONENT COOLING
1-70-816	"	3067.2 #	/	7.08	1.31 KSI	.362	1.5	JRH 8/28	MAC 9/20	hand calc. ok	"
70-1CC-R312	"	42080 #	/	5.44	4.96 KSI	.355	"	JRH 8/28	MAC 9/20	"	"
1-74-6	"	50801.6 #	/	6.90	10.0 KSI	.470	"	JRH 9/20	MAC 9/20	ok	RESIDUAL HEAT REMOVAL
1-62A-307	"	1892.8 #	/		NO BUCKLING INVOLVED			JRH 8/28	MAC 9/20	ok	H.P. CHEM & VOL. CONTROL
1-87-035	"	7505.6 #	/		NO BUCKLING INVOLVED			JRH 8/28	MAC 9/20	ok	UPPER HEAD INJECTION
1-74-5	"	88216 #	/	6.98	17.37 KSI	.816	1.5	JRH 8/28	MAC 9/20	hand calc. ok	RESIDUAL HEAT REMOVAL
1-74-10	"	30372.8 #	/	5.09	5.98 KSI	.281	"	JRH 8/28	MAC 9/20	"	"
1-74-1	"	12321.6 #	/	3.89	2.43 KSI	.114	"	JRH 8/30	MAC 9/20	"	"
70-1CC-R505	"	3200 #	/	3.16	3.20 KSI	.329	"	JRH 8/30	MAC 9/20	"	COMPONENT COOLING
1-62A-301	"	2816 #	/	2.03	1.02 KSI	.425	"	JRH 8/30	MAC 9/20	"	H.P. CHEM & VOL. CONTROL
1-62A-302	"	"	/	"	"	"	"	JRH 8/30	MAC 9/20	"	"
62-1CVC-R13	"	2400 #	/	3.49	.619 KSI	.199	"	JRH 8/30	MAC 9/20	"	"
1-74-4	"	24910.4 #	/	2.30	2.49 KSI	.742	"	JRH 8/31	MAC 9/20	"	RESIDUAL HEAT REMOVAL
1-87-62	"	18400 #	/	1.10	0.87 KSI	.041	"	JRH 8/31	MAC 9/21	"	UPPER HEAD INJECTION
47A454-2-46	"	6940.8 #	/	4.51	/	.995	"	JRH 7/2	MAC 9/21	STRUDL CODE CHECK	FPC
47A454-1-15	"	"	/	4.51	/	.11	"	JRH 7/2	MAC 9/21	"	FUEL POOL COOL & CLEAN
1-87-80	"	5920 #	/	19.38	3.56 KSI	1.17	"	JRH 7/2	MAC 9/21	hand calc. ok	UPPER HEAD INJECTION
47A406-3-11	"	192 #	/	21.80	.32 KSI	.087	"	JRH 7/3	MAC 9/21	"	UP CVC

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 9-8-82

CHECKED RLT DATE 10-14-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						RES. DATE	CHK. DATE	COMMENT	SYSTEM
		MAXI. LOADS		K/L	BUCKLING INT. STRESS	INT. VALUE	FULL INT. VAL.				
		AXIAL	MOMENT	F							
47A454-3-10	RIGID FRAME	5604.8 #	/	10.16	1.5 KSI	.229	1.5	JRH 9/3	MAC 9/21	hand calc's of	SFPS
26-1FP-R232	"	3200 #	/	22.39	.79 KSI	.039	"	JRH 9/7	MAC 9/21	"	H.P. PIPE PROTECTION
47A492-2-11	"	1443.2 #	/	6.61	.75 KSI	.213	"	JRH 9/7	MAC 9/21	"	PRIMARY WATER
47A431-9-7	"	1025.6 #	/	6.91	.36 KSI	.093	"	JRH 9/7	MAC 9/21	"	AUX BOILER BURNER
03B-1AFW-R23	"	6400 #	/	5.67	.84 KSI	.039	"	JRH 9/7	MAC 9/21	"	AUX FEEDWATER
78-1FAC-R-38	"	3200 #	/	17.95	1.14 KSI	.67	"	JRH 9/7	MAC 9/21	"	FUEL POOL COOLING
62-1LCV-R81	"	896 #	/	12.42	.13 KSI	.451	"	JRH 9/8	MAC 9/23	"	L.P. CHEM & VOL CONTR
72-1CE-R20	"	3200 #	/	5.32	.69 KSI	.188	"	JRH 9/8	MAC 9/23	"	CONTAINMENT SPRAY
70-1CC-R577	"	240 #	/	3.99	.12 KSI	.046	"	JRH 9/8	MAC 9/23	"	COMPONENT COOLING
62-1LCV-R86	"	208 #	/	21.44	.05 KSI	.144	"	JRH 9/8	MAC 9/23	"	L.P. CHEM & VOL CONTR
2-70-804	"	1073.6 #	/	8.56	.39 KSI	.294	"	JRH 9/8	MAC 9/23	"	COMPONENT COOLING
12-1AAB-R57	"	2240 #	/	7.01	1.10 KSI	.799	"	JRH 9/8	MAC 9/23	"	AUX BOILER
12-1AAB-R67	"	"	/	"	"	"	"	JRH 9/8	MAC 9/23	"	"
12-1AAB-R053	"	"	/	"	"	"	"	JRH 9/8	MAC 9/23	"	"
12-1AAB-R052	"	"	/	"	"	"	"	JRH 9/6	MAC 9/23	"	"
47A435-2-11	"	288 #	/	10.27	.183 KSI	.197	"	JRH 9/8	MAC 9/23	"	SIS
26-1FP-R61	"	6400 #	/	3.16	.734 KSI	.034	"	JRH 9/8	MAC 9/23	"	H.P. PIPE PROTECTION
26-1FP-R63	"	2400 #	/	6.35	.813 KSI	.61	"	JRH 9/9	MAC 9/23	"	"
62-1LCV-R80	"	480 #	/	21.05	.114 KSI	.01	"	JRH 9/9	MAC 9/23	"	L.P. CHEM & VOL CONTR

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 9/9/82

CHECKED RLI DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. DATE	COMMENT	SYSTEM
		MAXI. AXIAL.	MOMENT.	K _L T	BUCKLING STRESS	INT. VALUE	REL. INT. VAL.				
78-1FPC-R18	RIGID FRAME	1280 #	/	17.26	.806 KSI	.288	1.5	JRH 9/9	MAC 9/23	hard calc's OK	FUEL POOL COOLING
67-1ERW-R16	"	"	/	"	"	"	"	JRH 9/9	MAC 9/23	"	ESSENTIAL RADIATION COOLING
62-1LCV-R84	"	No BUCKLING INVOLVED						JRH 9/9	RLI 10/7	"	L.P. SYSTEM & VOL. C
78-1FPC-R7	"	640 #	/	21.42	.676 KSI	.60	"	JRH 9/9	MAC 9/23	"	FUEL POOL COOLING
78-1FPC-R4	"	"	/	21.42	"	.60	"	JRH 9/9	MAC 9/23	"	"
78-1FPC-R19	"	1280 #	/	26.39	2.02 KSI	1.03	"	JRH 9/9	MAC 9/23	"	"
62-1LCV-R87	"	"	/	"	"	"	"	JRH 9/9	MAC 9/23	"	L.P. SYSTEM
62-1LCV-R82	"	"	/	"	"	"	"	JRH 9/9	MAC 9/23	"	"
47A435-2-8	"	848 #	/	26.15	1.25 KSI	1.01	"	JRH 9/9	MAC 9/23	"	SAFETY INJECTION
63-1SYS-R24	"	"	/	"	"	"	"	JRH 9/9	MAC 9/23	"	"
70-1CC-R186	"	400 #	/	BUCKLING NOT INVOLVED				JRH 9/9	MAC 9/23	OK	COMPONENT COOLING
70-1CC-R118	"	304 #	/	.722	.034 KSI	.002	1.5	JRH 9/9	MAC 9/23	hand calc's OK	"
47A555-10-2	"	96 #	/	21	.192	.01	1.5	JRH 9/9	RLI 10/8	OK	LP CVCS
47A555-10-4	"	160 #	/	21	.32	.02	1.5	JRH 9/9	RLI 10/8	OK	LP
1-03B-9 -356 1-63-16 -351	"	3505.6 #	/	3.99	/	.364	1.5	JRH 9/10	MAC 9/23	strudl code check	AUX. FEEDWATER
	"	"	/	"	/	"	"	JRH 9/10	MAC 9/23	"	SAFETY INJECTION
	"	"	/	"	/	"	"	JRH 9/10	MAC 9/23	"	"

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED DWG DATE 9/7/82
CHECKED RUC DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. AXIAL.	MOMENT.	K/L	BUCKLING STRESS	INT. VALUE	FULL. INT. VAL.				
TVA ETA ATA43-9-10	RIGID FRAME	.675K	/	9.13	.177	.957	1.5	GLP 9-8-82	JRH 9/27		AUX BOILER
EDS 1-63-001	RIGID FRAME	8.68 K	/	54.5	5.46	.305		GLP 9-8-82	JRH 9/27		SI
EDS 1-01A-352		13.28 K	/	2.21	3.48	.162		GLP 9-9-82	JRH 9/27		MS
EDS 2-01A-352		236.24 K	/	.23	1.64	.076		GLP 9-9-82	JRH 9/27		MS
EDS 1-01A-394		37.88 K 92.4 K	/	.18 .281	2.37 4.29	.11 .199		GLP 9-9-82	JRH 9/27		MS
EDS 1-63-007		11.88 K 74.25 K	/	.488 .314	2.813 3.956	.488 .316		GLP 9-13-82	JRH 9/27		SI
EDS 1-63-006		10.86 K	/	8.125	2.19 K	.103		GLP 9-13-82	JRH 9/27		SI
1-71-12		23.76 11.88	0 36.1	3.64 16.5	9.17 1.68	.43 .27		GLP 9-29-82	RUC 9/30/82		RHR
1-87-006		/	/	12.1	/	1.34		JRH 10-7-82	GLP 10-8-82		UHI
17A586-1-12		10788.8*	/	3.88	/	.677		JRH 8/26	MAC 9/82	STRUDL CODE CHECK	ERCW
17A586-1-13		"	/	"	/	"		JRH 8/26	MAC 9/82	"	"
17A586-1-35		"	/	"	/	"		JRH 8/26	MAC 9/82	"	"
17A586-5-13		"	/	"	/	"		JRH 8/26	MAC 9/82	"	"
47A462-8-6		3327*	/	8.79	9 ₀ = 1.28ksi	.735		DWO 8/27	JBS 9/14	STRUDL CODE CHECK	ICE CONDENSER
47A462-8-14		"	/	"	"	"		DWO 9/27	JBS 9/14	"	"
47A462-8-13		"	/	"	"	"		DWO 8/27	JBS 9/14	"	"
47A462-8-5		"	/	"	"	"		DWO 8/27	JBS 9/14	"	"
1-03B-34		4320*	/	10.8	/	/		GP 9/7	MAC 9/27	"	AFW

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED RVE DATE 9/20/82

CHECKED MAC DATE 9-20-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. DATE	CHK. DATE	COMMENT	SYSTEM
		MAXI. AXIAL.	LOADS MOMENT.	KL	BUCKLING INT. STRESS	INT. VALUE				
1-68-340	RIGID FRAME	379 #	/		Buckling not involved		JRH 8/14	MAC 9/20	OK	RC
26-1FP-R75	"	/	/		" "		JRH 8/14	MAC 9/20		HPEP
26-1FP-R77	"	"	/		" "		JRH 8/14	MAC 9/20	"	"
26-1FP-R65	"	"	/		" "		JRH 8/14	MAC 9/20	"	"
26-1FP-R69	"	"	/		" "		JRH 8/14	MAC 9/20	"	"
26-1FP-R71	"	"	/		" "		JRH 8/14	MAC 9/20	"	"
26-1FP-R73	"	"	/		" "		JRH 8/14	MAC 9/20	"	"
26-1FP-R67	"	"	/		" "		JRH 8/14	MAC 9/20	"	"
17-A586-1-1	"	5379 #	/	11.6	/	.733 1.5	JRH 8/16	MAC 9/20	STRUDL CODE CHECK	ERCW
17-A586-1-2	"	"	/	"	/	" "	JRH 8/16	MAC 9/20	"	"
17-A586-1-5	"	"	/	"	/	" "	JRH 8/16	MAC 9/20	"	"
17-A586-1-70	"	"	/	"	/	" "	JRH 8/16	MAC 9/20	"	"
17-A586-5-3	"	"	/	"	/	" "	JRH 8/16	MAC 9/20	"	"
17-A586-5-4	"	"	/	"	/	" "	JRH 8/16	MAC 9/20	"	"
17-A586-5-5	"	"	/	"	/	" "	JRH 8/16	MAC 9/20	"	"
17-A586-5-26	"	"	/	"	/	" "	JRH 8/16	MAC 9/20	"	"
17-A586-5-33	"	5680 #	/	.91	/	.347	JRH 8/16	MAC 9/20	"	"

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED RLE DATE 9-20-82

CHECKED MAC DATE 9-20-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT.	SYSTEM
		MAXI. LOADS		KL r	BUCKLING INT. STRESS	INT. VALUE	ALL-INT. VAL.				
		AXIAL.	MOMENT.								
47A465-1-33	RIGID FRAME	24 #	/		Buckling not involved			JRH 8/18	MAC 9/20	OK	RC
47A450-4-29	"	928 #	/	9.00	$f_a = 24.78$.031	1.5	JRH 8/18	MAC 9/20	SAGS OK	ERCW
1-03B-11	"	816 #	/	3.99	.299	"	"	JRH 8/19	MAC 9/20	"	AF
47A450-3-157	"	8480 #	/	6.67	$f_a = 1.24$.63	"	JRH 8/19	MAC 9/20	"	ERCW
47A450-3-105	"	10400 #	/	6.67	$f_a = 1.64$.77	"	JRH 8/19	MAC 9/20	"	"
47A450-21-201	"	1648 #	/	10.17	.524	"	"	JRH 8/19	MAC 9/20	STRUDL code check	"
03B-1AFW-RIG	"	1680 #	/	6.80	.082	"	"	JRH 8/20	MAC 9/20	"	"
1-03B-7	"	2880 #	/	3.99	.344	"	"	JRH 8/25	MAC 9/20	SAGS OK	AFW
1-03B-12	"	"	/	"	"	"	"	JRH 8/25	MAC 9/20	"	"
1-03B-13	"	"	/	"	"	"	"	JRH 8/25	MAC 9/20	"	"
1-03B-14	"	"	/	"	"	"	"	JRH 8/25	MAC 9/20	"	"
1-03B-60	"	3580.8 #	/	"	.840	"	"	JRH 8/25	MAC 9/20	"	"
1-03B-10	"	"	/	"	"	"	"	JRH 8/25	MAC 9/20	"	"
1-03B-8	"	"	/	"	"	"	"	JRH 8/25	MAC 9/20	"	"
1-63-355	"	"	/	"	"	"	"	JRH 8/25	MAC 9/20	"	SAFETY INJECTION
1-63-357	"	"	/	"	"	"	"	JRH 8/25	MAC 9/20	"	"
1-63-358	"	"	/	"	"	"	"	JRH 8/25	MAC 9/20	"	"
17A586-5-27	"	2924.8 #	/	7.59	.499	"	"	JRH 8/25	MAC 9/20	STRUDL CODE CHECK	ERCW

BRACED CANTILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JBJ DATE 8/24/82

CHECKED RLI DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. BY DATE	COMMENT		
		MAXI. AXIAL	LOADS K	MOMENT.	K _L T	BUCKLING STRESS	INT. VALUE			ALL. INT. VAL.	GT	STAND System
47A454-1-12	Br. Cant.	1.246		1.081	12.58	-	.057	1.5	JBJ 8/18	GLP 9-25-82	Passout Code Check	Feed Pool Cooling Water
47A454-2-44	"	1.245		-	23	-	.08	1.5	JBJ 8/18	GLP 9-28-82	"	"
47A454-2-36	"	5.32		-	25	-	.87	1.5	JBJ 8/19	GLP 9-25-82	"	"
1-63 ⁽⁰¹⁻⁰¹⁾ 004	"	7.08		-	11	-	.37	1.5	JBJ 8/20	GLP 9-25-82	"	Safety Injection
1-03A ⁽⁰²⁻⁰⁵⁾ 365	"	.400		-	19	AXIAL	Load is Negligible		JBJ 8/20	GLP 9-25-82	Feedwater	OK
1-03A ⁽⁰²⁻⁰⁵⁾ 366	"	14.32		-	13		Actual Stress = 3.78 KSI < 9 (36 KSI) ∴ OK		JBJ 8/20	GLP 9-25-82	"	OK
1-03A ⁽⁰²⁻⁰⁶⁾ 367	"	31.28		-	19	L	Actual Stress = 6.86 KSI < 9 (36 KSI) ∴ OK		JBJ 8/20	GLP 9-25-82	"	OK
1-03B ⁽⁰⁵⁻⁰¹⁾ 27	"	3.415		-	16.4		Actual Stress = .89 KSI < 9 (36 KSI) ∴ OK		JBJ 8/23	GLP 9-25-82	Auxiliary Feedwater	OK
67-HERN-R13	"	7.012		-	17		Actual Stress = 1.89 KSI < 9 (36 KSI) ∴ OK		JBJ 8/23	GLP 9-25-82	ERCA	OK
47A450-3-76	"			-	45		OK because K _L > 30		JBJ 8/23	GLP 9-25-82	ERCA	OK
< 30 67-HERN-R34	"	13.290		50.320			Combined stress in compression < 9 (36 KSI) ∴ OK		JBJ 8/23	GLP 9-25-82	ERCA Factor of 1.6	still OK
> 30 67-HERN-R34	"	9.274		-			Max Stress = 1.6 (22 KSI) < 9 (36 KSI) ∴ OK		JBJ 8/23	GLP 9-25-82	ERCA	OK
03B-HERN-R2	"			-	32.38	K _L	> 30 ∴ OK		JBJ 8/24	GLP 9-25-82	Aux Feedwater	OK
03B-HERN-R11	"			-	46.5	K _L	> 30 ∴ OK		JBJ 8/24	GLP 9-25-82	Aux Feedwater	OK
VOID												
< 30 70-201-R42	"			-	37.5	K _L	> 30 ∴ OK		JBJ 8/24	GLP 9-25-82	Component Cooling	OK
< 30 62-HERN-R89	"	.091		-		AXIAL	LOADS NEGLIGIBLE		JBJ 8/24	GLP 9-25-82	L.P. Chemical Volume Control	OK
VOID												
< 30 62-HERN-R88	"	1.81		-	29.79		.86 ksi, .043	1.5	JBJ 8/24	GLP 9-25-82	L.P. Chemical & Volume Control	OK

BRACED CAUTILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED BY DATE 8-31-82

CHECKED RLT DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT
		AXIAL LOADS	MOMENT	K _L	BUCKLING STRESS	INT. VALUE	FLL. INT. VAL.			
04-10 1-70-800	Braced Cont	5K		11.06	4.79 ksi	.228	1.5	JBJ/8-24	GLP/9-27-82	Component Cooling Sys OK
12-1AAB-R13	"	1.58K		23.7	4.14 ksi	.02	1.5	JBJ/8-25	GLP/9-28-82	Aux Boiler OK
03B-1AFW-R18	"			30.4	4.730	OK		JBJ/8-25	GLP/9-27-82	Aux Feedwater OK
78-1FPL-R13	"			34.2	4.730	OK		JBJ/8-25	GLP/9-27-82	Fuel Pool Cooling OK
47A435-2-10	"	1.4K		23.1	4.62 ksi	.03	1.5	JBJ/8-25	GLP/9-27-82	SIS OK
63-1S15-R17	"			31.2	4.730	OK		JBJ/8-25	GLP/9-27-82	SIS OK
72-1CS-R38	"			52	4.730	OK		JBJ/8-25	GLP/9-27-82	Containment Spray OK
63-1S15-R24	"			63.3	4.730	OK		JBJ/8-25	GLP/9-27-82	Safety Injection OK
72-1CS-R40	"			78	4.730	OK		JBJ/8-25	GLP/9-27-82	Containment Spray OK
47A435-2-2	"			45	4.730	OK		JBJ/8-25	GLP/9-27-82	SIS OK
47A435-1-2	"			45	4.730	OK		JBJ/8-25	GLP/9-27-82	SIS OK
47A454-1-37	"			58.8	4.730	OK		JBJ/8-26	GLP/9-27-82	Fuel Pool Cool a cleaning OK
17A586-5-7	"			passed	Small Code	OK		JBJ/8-26	GLP/9-28-82	EREW OK
17A586-1-30	"			65	.9	1.5		JBJ/8-26	GLP/9-28-82	EREW OK
17A586-1-7	"			passed	Small Code	OK		JBJ/8-26	GLP/9-28-82	EREW OK
17A586-1-19	"			65	.9	1.5		JBJ/8-26	GLP/9-28-82	EREW OK
17A586-1-88	"			passed	Small Code	OK		JBJ/8-31	GLP/9-28-82	EREW OK
17A586-1-88	"			43	.11	1.5		JBJ/8-31	GLP/9-28-82	EREW OK
17A586-1-42	"			passed	Small Code	OK		JBJ/8-31	GLP/9-28-82	EREW OK
17A586-1-42	"			43	.11	1.5		JBJ/8-31	GLP/9-28-82	EREW OK
1-68-215	"			12.5		.73	1.5	DWD/9/15	JBS/9/14	REACTOR COOLANT OK

BRACED CAUTILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED DWO DATE 3/27/82
CHECKED RJI DATE 10/14/82

DWGS ARE SIMILAR

DWGS ARE SIMILAR

DWGS ARE SIMILAR

DWGS ARE SIMILAR

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT
		MAXI. LOADS		K _L / Y	BUCKLING STRESS	INT. VALUE	ALL-INT. VAL.			
		AXIAL.	MOMENT.							
47A450-21-203 A & B	BRACED CAUT.	4.6K		80	/	14	1.5	DWO 9/9 JBS 9/24	RHR > 30 EREW	
47A434-1-5	"	"		"	/	"	"	DWO 9/9 JBS 9/24	" FIRE	
47A434-1-29	"	7.3K		10.18	/	.71	1.5	DWO 9/10 GLP 9-23-82	FUEL. POOL COOL. & CLEAN	
47A491-K-4	"	"		15.47	/	"	"	DWO 9/10 GLP 9-23-82	FIRE PROTECTION	
47A432-1-2B	"	41.6 K		24	11.75 ksi	.92	1.5	DWO 9/13 GLP 9-24-82	RHR	
1-B7-031	"	"		"	"	"	"	DWO 9/13 GLP 9-24-82	UPPER REAR OF JETROW	
47A454-3-23	"	"		"	"	"	"	DWO 9/13 GLP 9-24-82	SFPC	
74-1RHR-R160	"	36.6 K		26	9.6 ksi	.86	1.5	DWO 9/13 GLP 9-23-82	RHR	
74-1RHR-R155	"	"		"	"	"	"	DWO 9/13 GLP 9-23-82	RHR	
70-1CC-R100	"	"		"	"	"	"	DWO 9/13 GLP 9-23-82	COMP. COOLING	
70-1CC-R91	"	"		"	"	"	"	DWO 9/13 GLP 9-23-82	COMP. COOLING	
1-03A-360	"	5.54		730	1.45 ksi	.27	1.5	DWO 9/10 GLP 9-24-82	FEED WATER	
72-1CS-R25	"	38.4 K		15.1	/	1.1	1.5	DWO 9/10 JRH 9/29	CONTAINMENT SPRAY	
1-03A-368	"	4.5 K		> 30				DWO 9/10 GLP 9-24-82	FEED WATER	
63-1516-R40, R30 & R32	"	3.77	4.8	34.3	2.77	.77	1.5	DWO 9/27 MAC 9/28	K _L /Y > 30 SAFETY INJECTION	
1-03B-53	"	8.2		53.82	.83	.31	1.5	DP 9/25 MAC 9/28	K _L /Y > 30 AUX. FEED WATER	
1-03B-3	"	"	"	"	"	"	"	DP 9/25 MAC 9/28	"	

BRACED CAUTILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED DWO DATE 9/21/82

CHECKED RLT DATE 10-14-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT
		MAXI. AXIAL.	LOADS MOMENT.	KL/r	BUCKLING STRESS	INT. VALUE	ALL-INT. VAL.			
1-87-073	BRACED CANT	11.5	NEG. LIABE	7.5	1.1	.05	1.5	DWO 9/10/82	RLT 9/28/82	SMS OHI
107-1ERCW-RS18	"	3.41	123	20.9	.9	.36	1.5	DWO 9/10/82	RLT 9/28/82	ERCW
26-1FP-R58	"	4.56	-	730	1.2	.3	1.5	DWO 9/10/82	RLT 9/28/82	HPF
12-1AAB-R60	"	1.73		730		1.7	1.5	GP 9/21/82	RLT 9/28/82	* SUPPORT IS OVERSTRESSED AUK BOILER
1-63-005	"	14.84	13.8	39.3	5.9	.57	1.5	DWO 9/21/82	RLT 9/29/82	KD C 730 SAFETY INVESTIG

BRACED CAUTILEVER

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING

PROGRAM OF PIPE SUPPORTS

COMPUTED GLP DATE 9-30-82

CHECKED RLI DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT
		MAXI. LOADS		KL	BUCKLING STRESS	INT. VALUE	ALL. INT. VAL.			
		AXIAL.	MOMENT.							
17A586-1-23	Braced Cantilever	---	---	7	Passed Code Ck	Strudl .56	1.5	ABG/9-2	GLP/9-29-82	OK ERCW
17A586-1-69	Braced Cantilever	---	---	7	Passed Code Ck	Strudl .56	1.5	ABG/9-2	GLP/9-29-82	OK ERCW
47A462-8-65	"	---	---	>30		1.60	1.5	GP/9/82	RLT/9/30/82	OVERSTRESSED I.C.
47A462-8-52	"	---	---	>30		.44	1.5	GLP/9/30/82	RLT/9/30/82	I.C.

BRACED CAUTILEVER FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED DW DATE 9/29/82

CHECKED RL DATE 10-14-82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. DATE	COMMENT
		MAXI. AXIAL.	LOADS MOMENT.	KL F	BUCKLING STRESS	INT. VALUE	ALL. INT. VAL.			
1-74-8	BRACED CANT	26.27 K	/	14.3	/	.23	1.5	DWO 9/25	JRH 9/27	STRUDL CODE CHECK RESIDUAL HEAT REMOVAL
67-IERCW-R510	"	3.12 K	/	55.	/	/	"	DWO 9/25	JRH 9/28	" ERCW
67-IERCW-R511	"	/	/	40.6	/	/	"	DWO 9/25	JRH 9/28	" ERCW
47A454-1-44	"	.448 K	/	26.45	/	.40	"	DWO 9/25	JRH 9/28	" FPC
47A454-2-31	"	1.86 K	/	28.43	/	.05	"	DWO 9/25	JRH 9/28	" SFPC
1-70-338	"	/	/	43.3	/	/	"	DWO 9/25	JRH 9/28	" COMPONENT COOLING
1-01A-424	"	85.1 K	/	4.5	/	.94	"	DWO 9/25	JRH 9/28	" MAIN STEAM
47A492-2-2	"	.675 K	/	30.5	.424	/	"	DWO 9/29	JRH 9/29	PRIMARY WATER
62-1LCV-R78	"	.166	/	11.8	.634	.81	"	GLP 9-8-82	JRH 9/27	(LP) CVC

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED BY DATE 9-3-82
 CHECKED BY RLI DATE 9-20-82

(UNIQUE FRAMES)

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. BY DATE	CHK. BY DATE	COMMENT	
			MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE				RLL. INT. VAL.
			AXIAL	MOMENT							
Blowdown	1-01B-142	Simple Frame	Support subject to Bending only					8/8/82	MAC/9-16-82	No buckling evaluation req'd.	
"	1-01B-144	Simple Frame	1647#	16740# 17-#	6.0	10030 PSI	0.52	1.5	8/8/82	MAC/9-16-82	MEM. is adequate & o.k.
Chem & (HP) Vol control	1-02A-310	"	984#	-	13.64	0.0	0.12	1.5	8/8/82	MAC/9-16-82	KL 230 o.k.
Comp. Cooling	70-100-R259	Simple Frame	Support subject to Axial tension & pure bending no compression.					8/8/82	RLI/9/11/82	No buckling evaluation req'd.	
CVC's (LP)	47A55-0.5	Simple Frame	MEM. subject to very small Axial loading & o.k.					8/8/82	RLI/9/17/82	o.k for buckling stress. KL=22	
Feedwater	1-03A-327	Simple Frame	5674#	-	21.2	-	.07 0.0	-	8/8/82	RLI/9/17/82	MEM. is o.k for buckling.
"	1-03A-20A	Free Col.	29775#	-	24.3	-	.23 0.0	-	8/8/82	RLI/9/17/82	MEM. is o.k & adequate.
ERLW	47A450-21-226 & 226A	Braced frame.	MULTI-Loaded (Bend Comp)		730	1-11	1.1 0.0	1.5	8/8/82	RLI/9/17/82	MEM. is ok for buckling.
Feedwater	1-03A-290	1-Unit Short Column			730				8/8/82	RLI/9/17/82	OUT OF SCOPE
Recircul Cooler	1-68-240	Contn.	Support is free contn. w/ axial & bending. o.k by inspection.					8/8/82	RLI/9/17/82	Axial load & moment too small o.k.	
"	1-68-251	Platform Beams	No buckling involved					8/8/82	RLI/9/17/82	o.k No buckling by e.s.	
"	1-68-410	cont. bracket	717#	=	17	Small	21.5	1.5	8/8/82	RLI/9/17/82	No evaluation req'd
UPPER HEAD INJECTION	1-87-075	Simple Frame	MEM. subject to major bending & small compression					8/8/82	RLI/9/17/82	Small buckling stress involved.	
"	1-87-065	Braced Frame.	9900#	29733# 19-#	37	19.42 PSI	1.35	1.5	8/8/82	MAC/9-16-82	Analysis is much conservative. o.k
ERLW	47A-450-4-45	DOUBLE CONT. FRAME	876#	-	46	551 PSI	0.22	1.5	8/8/82	MAC/9-20-82	SUPPORT MEM. OK FOR BUCKLING
"	47A450-3-158	Simple Frame	No buckling involved					8/8/82	GLP/9-17-82	OK BY INSPECTION	
"	47A450-21-219	Braced frame.	538#	-	138	0.27 KSI	0.34	1.5	8/8/82	GLP/9-17-82	Buckling stress is very low & o.k
ICG CONTROLLER	47A162-8-29	Simple Frame	1120#	9890# 11-#	22	0.704 KSI	1.632	1.5	8/8/82	GLP/9-17-82	MEM. are ok for buckling

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING

PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9/24/82
CHECKED RLI DATE 10-14-82

(UNIQUE FRAMES)

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. BY DATE	CHK. BY DATE	COMMENT	
			MAXI. AXIAL	LOADS MOMENT	KL	BUCKLING STRESS	INT VALUE				ALL INT. VAL.
I.C.	47A462-8-19	SIMPLE CANT. FRAM	MEM. O.K.	O.K.	73	SEE SUPPORT 47A462-8-23	80 8/20/82	GLP 9-17-82	O.K.		
"	47A462-8-20	SIMPLE CANT. FRAM -5	MEM. O.K.	O.K.	23	SEE SUPPORT 47A462-8-23	80 8/20/82	GLP 9-17-82	O.K.		
"	47A462-8-23	SIMPLE CANT. FRAM	3851 #	78.62	48	778 RI	0.76	1.5	80 8/21/82	GLP 9-17-82	O.K. FOR BUCKLING
"	47A462-8-24	"	MEM. O.K.	O.K.	23	SEE SUPPORT 47A462-8-23	80 8/20/82	GLP 9-17-82			
HPFP	47A491-8-13	CANTI. LEVEL	240 #	13772	20	160 RV	.17	1.5	80 9/12/82	RLI 9/17	MEM. O.K. FOR BUCKLING
SURVIVE AIR	47A492-2-13	CANTI. FRAME	SEE CALC.	COMPUTER RUN	1.20	1.5	80 9/11/82	RLI 9/17		MEM. O.K. FOR BUCKLING	
ERCW	17A586-1-68	BRACED CANT. FR.	MEM. O.K.	O.K.	21	SEE ATTACHED COMPUTER RUN	80 8/31/82	RLI 9/17	O.K.		
"	67-1ERCW-R315	CANTI. FRAME			730		RLI 9/24/82	JRH 10-6	OUT OF SCOPE		
"	67-1ERN-R362	BRACED CANTI.	SEE CALC		163.2	2.2 RV	0.38	1.5	80 8/31/82	RLI 9/18/82	MEM. O.K. FOR BUCKLING
AUX. FEEDWATER	1-03B-5	RIGID FRAME	SEE COMPUTER RUN		20.1		.11	1.5	80 9/10/82	RLI 9/15/82	
(LP) CVCS	62-11CV-V13	DS - WITH FRAME	.2	.23	82	Low	Low	1.5	RLI 9/29/82	MAC 9-29-82	KD / T 730 Low Loads
RHTZ	1-74-11	UNIQUE FRAME -DS	M1 18.9		62	4.14	.24	1.5	RLI 9/29/82	MAC 9-29-82	KD / T 730
			M2 18.9	89.8	78	4.15	.77	1.5			

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING

PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9/28/82
CHECKED RLI DATE 10-14-82

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. BY DATE	CHK. BY DATE	COMMENT
			MAXI. AXIAL.	LOADS MOMENT.	K/L	BUCKLING STRESS	INT. VALUE	ALL INT. VAL.			
Reactor Cool.	47A465-8-22	CANTILEVER	SMALL	SMALL	8	SMALL	SMALL	1.5	DP 9/29/82	RLI 9/28/82	OK BY INSPECTION
"	47A465-8-9	"	SMALL	SMALL	8	SMALL	SMALL	1.5	GP 9/25/82	RLI 9/28/82	OK BY INSPECTION
"	47A465-8-14	"	—	3.52	—	—	—	1.5	GP 9/25/82	RLI 9/28/82	NO BUCKLING INVOLVED
"	47A465-8-20	"	—	SMALL	—	—	—	1.5	DP 9/29/82	RLI 9/28/82	NO BUCKLING INVOLVED
HPFP	47A491-10-3	"	.16 ^K	—	178	.06	.01	1.5	GP 9/25/82	RLI 9/28/82	
"	47A491-6-2	"	—	10.3	—	—	.62	1.5	GP 9/25/82	RLI 9/28/82	NO BUCKLING INVOLVED
Reactor Cool	47A465-8-27	"	.03 ^K	2.9	63	—	—	1.5	GP 9/25/82	RLI 9/28/82	O.K. BY INSPECTION SMALL LOADS
PRIM WATER	47A492-2-23	"	.03	.63	46	—	—	1.5	DP 9/25/82	RLI 9/28/82	OK BY INSPECTION
"	47A492-2-2	"	.46	4.97	27	.18	.32	1.5	DP 9/29/82	RLI 9/28/82	
SERVICE AIR	47A492-2-17	"	.21	9.26	85	.08	.21	1.5	DP 9/25/82	RLI 9/28/82	
VH I	1-87-074	"	—	Moment only	—	—	—	1.5	GP 9/25/82	RLI 9/28/82	NO BUCKLING INVOLVED
"	1-87-071	"	10.7	136	30.2	1.34	.53	1.5	GP 9/24/82	RLI 9/28/82	
"	1-87-039	"	—	Moment only	—	—	—	1.5	RLI 9/28/82	MAC 9/28/82	NO BUCKLING INVOLVED
"	1-87-077	"	—	Moment only	—	—	—	1.5	RLI 9/28/82	MAC 9/28/82	NO BUCKLING INVOLVED
REACTOR COOLANT	1-68-299	"	.48	3.02	42.1	.07	1.32	1.5	RLI 9/28/82	MAC 9/28/82	CHECKED STIFFENER ONLY
RHR	47A432-2-1	"	1.79 ^K	11.9	135.4	.4	.78	1.5	RLI 9/28/82	MAC 9/28/82	
REACTOR COOLANT	1-68-310	"	.022	15	44	.32	.42	1.5	RLI 9/28/82	MAC 9/28/82	
"	47A465-1-29	"	—	Moment only	—	—	—	1.5	RLI 9/28/82	MAC 9/28/82	NO BUCKLING INVOLVED

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9-28-82
CHECKED RLI DATE 10/4/82

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. B. DATE.	CHK. BY DATE.	COMMENT.	
			MAXI. LOADS		KL/r	BUCKLING STRESS	INT. VALUE				ALL INT. VAL.
			AXIAL.	MOMENT.							
Reac. Coolant	47A465-1-35	CANT	-	ONLY	-	-	-	1.5	RLI 9/28/82	MAC 9/28/82	No BUCKLING INVOLVED
"	47A465-1-31	"	-	ONLY	-	-	-	1.5	RLI 9/28/82	MAC 9/28/82	No BUCKLING INVOLVED
UHI	1-87-038	"	-	ONLY	-	-	-	1.5	RLI 9/28/82	MAC 9/28/82	No BUCKLING INVOLVED
Reac. Coolant	47A465-8-24	"	Small	Small	61	Small	Small	1.5	RLI 9/28/82	MAC 9/28/82	O.K. BY INSPECTION SMALL LOADS
ERCLW	47A450-3-171	"	1.12	27	36	.02	.03	1.5	RLI 9/27/82	MAC 9/28/82	$\frac{KL}{r} > 30$
RHR	47A438-1-4	"	.045	.186	166	.06	.19	1.5	RLI 9/24/82	MAC 9/28/82	$\frac{KL}{r} > 30$
SIS	47A435-2-5	"	-	ONLY	-	-	-	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
"	63-1515-231	"	-	ONLY	-	-	-	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
"	1-63-008	"	2.05	26.1	18	1.02	.75	1.5	RLI 9/25/82	MAC 9/28/82	
"	1-63-003	"	-	ONLY	-	-	-	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
"	1-63-002	"	-	ONLY	-	-	-	1.5	RLI 9/25/82	MAC 9/28/82	No BUCKLING INVOLVED
SWR Pool COOLING	78-1FPC-R50	"	3.2	-	18.1	1.43	.07	1.5	RLI 9/26/82	MAC 9/28/82	
"	78-1FPC-R2	"	.13	2.64	38	-	-	1.5	RLI 9/26/82	MAC 9/28/82	OK BY INSPECTION
"	78-1FPC-R1	"	.05	1.1	38	-	-	1.5	RLI 9/25/82	MAC 9/28/82	O.K BY INSPECTION
"	47A454-1-14	"	.67	47.3	18	.26	1.05	1.5	RLI 9/26/82	MAC 9/28/82	
Feedwater	1-03A-36f	"	.7	34.4	29	.27	.77	1.5	RLI 9/25/82	MAC 9/28/82	
"	1-03A-363	"	12.1	85.2	39.4	1.97	.8	1.5	RLI 9/25/82	MAC 9/28/82	1) MEMBER $\frac{KL}{r} > 30$
"	1-03A-361	"	12.1	-	47	4.8	.26	1.5	RLI 9/25/82	MAC 9/28/82	2) LUG
"	1-03A-361	"	5.9	109.3	36	.59	.57	1.5	RLI 9/24/82	MAC 9/28/82	$\frac{KL}{r} > 30$

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 9/28/82

CHECKED RLT DATE 10-14-82

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. BY DATE	COMMENT
			MAXI. LOADS		KL	BUCKLING STRESS	INT. VALUE	ALL INT. VAL.			
			AXIAL	MOMENT							
ERCW	47A450-21-UG	CANT	1.65	45.5	34.4	.06	1.04	1.5	RLT 9/21/82	MAC 9-28-82	$\frac{KL}{r} > 30$
"	67-1ERCW-R522	"	2.24	85.8	51	.36	.61	1.5	RLT 9/21/82	MAC 9-28-82	$\frac{KL}{r} > 30$
CONT. SPRAY	72-1CS-R33	"	-	ONLY	-	-	-	1.5	RLT 9/27/82	MAC 9-28-82	NO BUCKLING INVOLVED
"	72-1CS-R36	"	-	ONLY	-	-	-	1.5	RLT 9/27/82	MAC 9-28-82	NO BUCKLING INVOLVED
Comp. Cooling	70-1CC-R56T	"	-	ONLY	-	-	-	1.5	RLT 9/27/82	MAC 9-28-82	NO BUCKLING INVOLVED
"	70-1CC-R76	"	-	ONLY	-	-	-	1.5	RLT 9/27/82	MAC 9-28-82	NO BUCKLING INVOLVED
"	2-70-844	"	.05	1.65	29	.03	.1	1.5	RLT 9/21/82	MAC 9-28-82	
"	2-70-824	"	.09	2.6	55.4	.03	.06	1.5	RLT 9/21/82	MAC 9-28-82	$\frac{KL}{r} > 30$
"	1-70-258	"	1.02	11.9	72.4	.04	.37	1.5	RLT 9/21/82	MAC 9-28-82	$\frac{KL}{r} > 30$
"	1-70-186	"	OK BY INSPECTION		29			1.5	RLT 9/21/82	MAC 9-28-82	Small Loads
ES Elem. Vol Control	47A555-10-3	"	.05	.82	73	.03	.05	1.5	RLT 9/27/82	MAC 9-28-82	$\frac{KL}{r} > 30$
"	47A555-10-1	"	.06	3.03	130	.01	.03	1.5	RLT 9/27/82	MAC 9-28-82	$\frac{KL}{r} > 30$ 1) MEMBER 2) LUG
LP	47A555-3-10	"	Small	-	12	Small	Small	1.5	RLT 9/21/82	MAC 9-28-82	OK BY INSPECTION Small Loads
"	47A555-3-9	"	Small	-	12	Small	Small	1.5	RLT 9/21/82	MAC 9-28-82	OK BY INSPECTION Small Loads
"	47A555-3-8	"	-	ONLY	-	-	-	1.5	RLT 9/21/82	MAC 9-28-82	NO BUCKLING INVOLVED
"	47A555-3-7	"	-	ONLY	-	-	-	1.5	RLT 9/21/82	MAC 9-28-82	NO BUCKLING INVOLVED
"	47A555-3-6	"	Small	-	18	Small	Small	1.5	RLT 9/21/82	MAC 9-28-82	OK BY INSPECTION Small Loads
HP	47A400-7-69	CANT	.048	3.74	59	.03	.23	1.5	RLT 9/21/82	JRH 9-28-82	$\frac{KL}{r} > 30$
HP	47A400-7-73	"	"	"	"	"	"	"	RLT 9/27/82	JRH 9-28-82	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED MAC DATE 9-30-82

CHECKED RUT DATE 10-14-82

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. DATE	CHK. DATE	COMMENT.	
			MAXI. AXIAL.	LOADS MOMENT.	K _L F	BUCKLING INT. STRESS	INT. VALUE				REL. INT. VAL.
HP Chem. Vd. Cont.	47A406-3-9	CANT	—	ONLY	—	—	—	1.5	RUE 9/21/82 JRH 9/28/82	No BUCKLING INVOLVED	
"	47A406-3-10	"	—		—	—	—	1.5	RUE 9/21/82 JRH 9/28/82	}	
LP "	62-11CV-R19	"	—		—	—	—	1.5	RUE 9/21/82 JRH 9/28/82		
LP "	62-11CV-R14	"	—		—	—	—	1.5	RUE 9/21/82 JRH 9/28/82		
HP "	62-11CV-R11	"	—		—	—	—	1.5	RUE 9/21/82 JRH 9/28/82		
HP "	62-11CV-R10	"	—		—	—	—	1.5	RUE 9/21/82 JRH 9/28/82		
HP "	1-62A-305	"	—		—	—	—	1.5	RUE 9/21/82 JRH 9/28/82		
HP "	1-62A-304	"	—		—	—	—	1.5	RUE 9/21/82 JRH 9/28/82		
AUX. BOILER	12-1AAB-R056	"	—	↓	—	—	—	1.5	RUE 9/21/82 JRH 9/28/82		
HP Chem. Vd. Cont.	1-62A-306	"	.84 1.55	28.7	35.3	.32	.65	1.5	RUE 9/21/82 JRH 9/28/82		K _L / r > 30 1) MEMBER 2) LUG
LP Chem. Vd. Cont.	62-11CV-R17	"	.42 .42	—	43	.3	<1.5	1.5	RUE 9/21/82 JRH 9/28/82		
AUX. BOILER	12-1AAB-R51	"	1.06	—	183.3	.41	<1.5	1.5	RUE 9/21/82 JRH 9/28/82	K _L / r > 30	
"	47A43-9-4	"	.723 .723	—	35	1.54	<1.5	1.5	RUE 9/21/82 JRH 9/28/82		
SAFETY INT.	1-63-011	"	No	BUCKLING	INVOLVED				RUE 9/30/82 MAC 9-30-82	K _L / r > 30	
ROX COOLANT	47A405-B-25	"	No	BUCKLING	INVOLVED				RUE 9/30/82 MAC 9-30-82		
RHR	74-1RHR-R139	"	No	BUCKLING	INVOLVED				RUE 9/30/82 MAC 9-30-82		

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 10/1/82

CHECKED RLI DATE 10/14/82

	HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. DATE	COMMENT
			MAXI. AXIAL.	LOADS MOMENT.	K _L F	BUCKLING STRESS	INT. VALUE	ALL. INT. VAL.			
FEEDWATER	1-03A-206	L-CANT	4.69	23.75	24	1.23	.26	1.5	GP 9/23/82	RLI 9/24/82	
RHR	47A432-1-3	"	.048	—	94	SMALL	SMALL	1.5	GP 9/22/82	RLI 9/24/82	OK BY INSPECTION
CONT. SPRAY	72-1CS-R35	"	4.0	84.0	30.9	SMALL		1.5	GP 9/22/82	RLI 9/24/82	
SIS	47A435-1-3	"	NO BUCKLING INVOLVED						GP 9/22/82	RLI 9/24/82	
"	47A435-2-4	"	.37 ^c	4.44	73	.143	.11	1.5	GP 9/22/82	RLI 9/24/82	$\frac{K_D}{r} > 30$
HPEP	47A491-10-5	"	.32 ^c	8.42	12.3	.09	.17	1.5	GP 9/22/82	RLI 9/24/82	
AUX BOILER	47A431-9-27	"	1.9	99.17	17.2	.34	.29	1.5	GP 9/22/82	RLI 9/24/82	
Comp. Cooling	70-ICC-R15	"	2.4	18.0	187	.53	.21	1.5	GP 9/21/82	RLI 9/25/82	$\frac{K_D}{r} > 30$
ROSC COOLANT	1-68-260	"	.5	10.65	55	.06	.05	1.5	GP 9/20/82	RLI 9/25/82	$\frac{K_D}{r} > 30$
"	1-68-290	"	.17	3.3	70	.08	.09	1.5	GP 9/20/82	RLI 9/25/82	$\frac{K_D}{r} > 30$
"	1-68-380	"	.09	5.7	57	.04	.16	1.5	GP 9/20/82	RLI 9/25/82	$\frac{K_D}{r} > 30$
"	47A465-8-18	"	.2	1.2	73	.08	.11	1.5	GP 9/18/82	RLI 9/25/82	$\frac{K_D}{r} > 30$
ICE CONDENSER	47A462-8-25	"	1.02	4.59	37	.39	.12	1.5	GP 9/18/82	RLI 9/25/82	$\frac{K_D}{r} > 30$
"	47A462-8-35	"	2.97 ^c		12	1.15	1.1	1.5	DWB 10/1/82	JRH 10/1/82	
"	47A462-8-36	"	"		"	"	"	"	DWB 10/1/82	JRH 10/1/82	

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED GLP DATE 9-21-82 (VENDOR COMPONENTS)

CHECKED RLT DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING				RES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. LOADS		K _L	BUCKLING INT. STRESS VALUE				
		AXIAL.	MOMENT.	F					
47A462-8-9	SNUBBER	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		ICE COND.
47A462-8-1	SNUBBER	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		ICE COND.
47A491-8-11	ROD	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		FP
47A491-8-9	ROD	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		FP
47A465-8-12	SNUBBER	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		REACTOR COOLANT
1-68-370	SNUBBER	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		REACTOR COOLANT
1-87-076	CONSTANT SUPPORT	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		UHI
1-87-072	VARIABLE SUPPORT	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		UHI
1-87-068	SNUBBER	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		UHI
1-87-040	ROD	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		UHI
1-87-034	SPRING	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		UHI
1-87-033	SNUBBER	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		UHI
1-87-030	SNUBBER	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		UHI
74-1RHR-R156	SWAY STRUT	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		RHR
74-1RHR-R161	SWAY STRUT	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		RHR
74-1RHR-R164	SWAY STRUT	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		RHR
74-1RHR-R165	SWAY STRUT	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		RHR
74-1RHR-168	SWAY STRUT	NO BUCKLING		CONSIDERED		GLP 9-21-82	RLT 9/29/82		RHR

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED BY GLP DATE 9-21-82

(Vendor Components)

CHECKED BY RUE DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING					DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. AXIAL.	LOADS MOMENT.	K _L F	BUCKLING STRESS	INT. VALUE				
47A432-1-1A	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		RHR
47A432-1-2A	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		RHR
63-1515-R33	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		SIS
63-1515-R31	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		SIS
72-1CS-R23-1	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
72-1CS-R21	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
72-1CS-R24	ROD	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
72-1CS-R27	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
72-1CS-R28	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
72-1CS-R32	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
72-1CS-R34	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
72-1CS-R37	SNUBBER	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
72-1CS-R39	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
72-1CS-R41	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CS
70-1CL-R491	SHEAR LUGS	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		CL
47A400-3-8	SWAY STRUT	No	BUCKLING	CONSIDERED			GLP 9-21-82	RUE 9/29/82		HP CLK

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED BY GLP DATE 9-21-82

(Vendor Components)

CHECKED BY RLF DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING				BUCKLING STRESS	INT. VALUE	ALL-INT. VAL.	DES. BY DATE	CHK. BY DATE	COMMENT	SYSTEM
		MAXI. AXIAL.	LOADS MOMENT.	K/L	r							
47A906-3-7	SWAY STRUT							GLP 9-21-82	RLF 9/29/82	HP CVC		
62-11CV-R72	STRUT							GLP 9-21-82	RLF 9/29/82	LP CVC		
62-12VC-R14	ROD							GLP 9-21-82	RLF 9/29/82	HP CVC		
1-62A-311	SNUBBER							GLP 9-21-82	RLF 9/29/82	HP CVC		
1-01A-356	SWAY STRUT							GLP 9-21-82	RLF 9/29/82	MS		
1-01A-354	SWAY STRUT							GLP 9-21-82	RLF 9/29/82	MS		
2-01A-354	SWAY STRUT							GLP 9-21-82	RLF 9/29/82	MS		
1-01A-318	STRUT							GLP 9-21-82	RLF 9/29/82	MS		
2-01A-318	STRUT							GLP 9-21-82	RLF 9/29/82	MS		
1-01A-307	SNUBBER							GLP 9-21-82	RLF 9/29/82	MS		
1-63-590	SNUBBER							JRH 8-26-82	MAV 9-27-82	SI		
1-63-591	SNUBBER							JRH 8-26-82	MAV 9-27-82	SI		
1-63-592	SNUBBER							JRH 8-26-82	MAV 9-27-82	SI		
03B-1AFW-R7	STRUT							JRH 8-26-82	MAV 9-27-82	AFW		

BUCKLING CONSIDERED

FINAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED JRH DATE 6/7/82

CHECKED RJE DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING		KL	BUCKLING STRESS	INT. VALUE	ALL INT. VAL.	DES. BY DATE	CHK. BY DATE	COMMENT	SY.
		MAXI. AXIAL.	LOADS MOMENT.								
47A450-428	Braced Rigid frame	1248 #	/	31.36	/	/	/	JRH 8/20	MAC 7/27	KL F 730 OK	ERCW
47A450-3-100	"	11040 #	/	7.81	fa = 1.34 ksi	.128	1.5	JRH 8/24	MAC 9/27	SAGS OK	"
67ERCW-R289	"	60720 #	/	15.02	fa = 1.47 ksi	.24	"	JRH 8/24	MAC 9/28	"	"
67ERCW-R95	"	37120 #	/	9.62	/	.267	"	DWO 8/24	MAC 9/28	STRUDL CODE CHECK	"
03B-1AFW-R4	"	17600 #	/	8.54	/	.427	"	DWO 8/24	MAC 9/28	"	AFW
03B-1AFW-R22	"	"	/	"	/	"	"	DWO 8/24	MAC 9/28	"	"
03B-1AFW-R5	"	"	/	"	/	"	"	DWO 8/24	MAC 9/28	"	"
47A450-433	"	4960 #	/	22.25	fa = 1.83 ksi	.096	"	JRH 8/26	MAC 9/28	SAGS OK	ERCW
70-1CC-R446	"	15520 #	/	9.47	/	.366	"	DWO 8/26	MAC 9/28	STRUDL CODE CHECK	COMPONENT COOLING
17A586-5-25	"	2665.6 #	/	18.87	fa = 1.48 ksi	.21	"	JRH 9/10	MAC 9/23	HAND CALC'S OK	ERCW
26-1FP-R60	"	11040 #	/	14.61	/	.307	"	JRH 9/15	MAC 9/23	STRUDL CODE CHECK	HDFP
17A586-5-20	"	9046.4 #	/	9.7	/	1.12	"	JRH 9/17	MAC 9/23	"	ERCW
17A586-1-20	"	"	/	"	/	"	"	JRH 9/27	MAC 9/26	"	ERCW
78-1FFC-R15	"	"	/	730	/	"	"	JRH 9/27	RJE 10/6	OUT OF SCOPE	From Prop Cons

ANNUAL EVALUATION REPORT FOR BUCKLING SAMPLING PROGRAM OF PIPE SUPPORTS

COMPUTED DWO DATE 9/1/82

CHECKED RLI DATE 10/14/82

HANGER NO.	SUPPORT TYPE	MEMBER SUBJECT TO BUCKLING						DES. DATE	CHK. DATE	COMMENT	
		MAXI. LOADS		KL	BUCKLING INT. STRESS	INT. VALUE	FALL. INT. VAL.				
		AXIAL.	MOMENT.					Y			
1-03B-25	BRACED RIGID FRAME	5379	/	63	/	/	/	DWO 8/30	JBS 9/15	KL > 30.0 OK	AUX FEEDW. H.P. FIRE PROTECT. SFPC
26-1FP-R233	"	"	/	"	/	/	/	DWO 8/30	JBS 9/15	"	"
47A454-2-25	"	"	/	"	/	/	/	DWO 8/30	JBS 9/15	"	SFPC
47A454-2-26	"	"	/	"	/	/	/	DWO 8/30	JBS 9/15	"	SFPC
17A586-1-100	"	17626	/	44	/	/	/	DWO 8/30	JBS 9/24	KL - 44 > 30.0 OK	INT & EXH ERCW
17A586-1-101	"	"	/	"	/	/	/	DWO 8/30	JBS 9/24	"	INT & EXH ERCW
12-1AAB-R42	"	"	/	"	/	/	/	DWO 8/30	JBS 9/24	"	AUX BOILER
12-1AAB-R12	"	"	/	"	/	/	/	DWO 8/30	JBS 9/24	"	AUX BOILER
12-1AAB-R016	"	4600	/	30.4	/	/	/	DWO 8/31	JBS 9/16	KL - 30.4 > 30.0 OK	AUX BOILER ERCW
67-1EREW-R556	"	"	/	"	/	/	/	DWO 8/31	JBS 9/16	"	ERCW
67-1EREW-R515	"	"	/	"	/	/	/	DWO 8/31	JBS 9/16	"	ERCW
12-1AAB-R019	"	1470	/	16.06	/	1.5	/	DWO 8/31	GLP 9-24	STRNDL CODE CHECK	AUX BOILER
73-1FR-R17	"	"	/	"	/	"	"	DWO 8/31	GLP 9-24	"	FUEL POOL CODE
17A586-1-87	"	5344	/	26	/	.36	1.5	DWO 9/1	GLP 9-24	STRNDL CODE CHECK	ERCW
17A586-1-13	"	"	/	"	/	"	"	DWO 9/1	GLP 9-25	"	ERCW
47A762-8-3	"	"	/	"	/	"	"	DWO 9/1	GLP 9-25	"	ICE COND. SYSTEM
47A762-8-4	"	"	/	"	/	"	"	DWO 9/1	GLP 9-25	"	ICE COND. SYSTEM
47A762-8-12	"	"	/	"	/	"	"	DWO 9/1	GLP 9-25	"	ICE COND. SYSTEM

