

Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Rope Ferry Road, Waterford, CT 06385



DEC 07 2007

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Serial No. 07-0789
MPS Lic/MLC R0
Docket Nos. 50-336
50-423
License No. DPR-65
NPF-49

DOMINION NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNITS 2 AND 3
INSERVICE TESTING PROGRAM 10-YEAR INTERVAL END DATE CHANGES

The purpose of this letter is to inform the NRC staff of changes in the end date for the Millstone Power Station Units 2 and 3 (MPS2 and MPS3) third and second, respectively, 10-year Inservice Testing (IST) intervals. These changes are being made in accordance with Section XI of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, 1989 edition (no Addenda) pursuant to 10 CFR 50.55a(f).

As specified within ASME IWA-2430 paragraph (d), "Each inspection interval may be reduced or extended by as much as one year. Adjustments shall not cause successive intervals to be altered by more than one year from the original pattern of intervals." The end of the MPS2 third 10-year IST interval will be extended from March 31, 2008 to December 1, 2008, and the end of the MPS3 second 10-year IST interval will be extended from March 31, 2008 to December 1, 2008.

The MPS2 and MPS3 IST 10-year interval end dates are being extended to allow sufficient time for NRC's review and approval of all required relief requests needed for the next 10-year interval. These extensions do not cause successive intervals to be altered by more than one year from the original pattern of intervals.

If you have any questions or require additional information, please contact Mr. William D. Bartron at (860) 444-4301.

Sincerely,


A. J. Jordan, Jr.
Plant Manager - Nuclear

A047
NRR

Attachments: None

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406-1415

Ms. C. J. Sanders
NRC Project Manager, Mail Stop 08B3
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

NRC Senior Resident Inspector
Millstone Power Station