

2.5 Electrical Power

2.5.1 Class 1E Emergency Power Supply System

1.0 Description

The emergency power supply system (EPSS) provides electrical power for systems that are essential to reactor shutdown, containment isolation and heat removal, reactor core cooling, and preventing a significant release of radioactive material to the environment. The EPSS distributes power to safety-related and non-safety-related plant loads during normal and abnormal operations.

EPSS divisions are independent and physically separated during normal bus alignments. An alternate feed is provided between EPSS divisions 1 and 2, and between divisions 3 and 4 to provide the normal and standby source of power to required safety systems, safety support systems, or components that do not have the required redundancy when certain electrical components, including emergency diesel generators, are out of service. With an alternate feed installed, independence is maintained between the EPSS divisions with the alternate feed installed and the divisions without an alternate feed installed. The divisions without the alternate feed installed are independent of each other.

2.0 Arrangement

2.1 The functional arrangement of EPSS equipment is shown in Figure 2.5.1-1—Class 1E Emergency Power Supply System Functional Arrangement.

2.2 Equipment identified as Class 1E in Table 2.5.1-2—Class 1E Emergency Power Supply System Electrical Equipment Design are located as listed in Table 2.5.1-1—Class 1E Emergency Power Supply System Electrical Equipment Location.

2.3 There are four EPSS divisions.

3.0 Mechanical Design Features, Electrical and Seismic Classifications

3.1 Equipment listed as Class 1E in Table 2.5.1-2 are qualified as Seismic Category I and can withstand seismic design basis loads without loss of safety function.

4.0 I&C Design Features, Alarms, Displays and Controls

4.1 Displays listed in Table 2.5.1-2 are retrievable in the main control room (MCR) and remote shutdown station (RSS) as listed in Table 2.5.1-2.

4.2 EPSS equipment controls are provided in the MCR and RSS as listed in Table 2.5.1-2.

5.0 Electrical Considerations

5.1 Physical separation exists between EPSS Class 1E equipment listed in Table 2.5.1-2 and non-Class 1E equipment.

-
- 5.2 Non-safety-related loads connected to the EPSS (e.g., charging pumps, severe accident heat removal pump, emergency lighting and emergency pressurizer heaters) are separated by a Class 1E isolation device.
- 5.3 Without the alternate feed installed, independence is maintained between the four EPSS divisions.
- 5.4 With the alternate feed installed from EPSS division 1 to division 2; independence is maintained between the load group created by divisions 1 and 2, and divisions 3 and 4. EPSS divisions 3 and 4 are independent of each other.
- 5.5 With the alternate feed installed from EPSS division 2 to division 1; independence is maintained between the load group created by divisions 1 and 2, and divisions 3 and 4. EPSS divisions 3 and 4 are independent of each other.
- 5.6 With the alternate feed installed from EPSS division 3 to division 4; independence is maintained between the load group created by divisions 3 and 4, and divisions 1 and 2. EPSS divisions 1 and 2 are independent of each other.
- 5.7 With the alternate feed installed from EPSS division 4 to division 3; independence is maintained between the load group created by divisions 3 and 4, and divisions 1 and 2. EPSS divisions 1 and 2 are independent of each other.
- 5.8 Control power for EPSS switchgear and load centers listed in Table 2.5.1-2 is provided by the Class 1E emergency uninterruptible power supply (EUPS) system from the respective division.
- 5.9 Class 1E cables and cable raceways are marked according to their respective division color-code.
- 5.10 Physical separation or electrical isolation exists between Class 1E divisions and between Class 1E divisions and non-Class 1E cables.
- 5.11 EPSS switchgear, load centers, motor control centers (MCC), and transformers as listed in Table 2.5.1-2 and their feeder breakers and load breakers are sized to supply their load requirements.
- 5.12 EPSS cables and buses are sized to supply their assigned load requirements.
- 6.0 Equipment and System Performance**
- 6.1 Each EPSS division has an assigned EDG that provides power if there is a loss of offsite power.
- 6.2 Each EPSS 6.9 kV switchgear offsite power supply circuit breaker is opened by a protection system signal.
- 6.3 The EPSS provides voltage at the supplied safety-related equipment terminals that is greater than the minimum voltage.



-
- 6.4** EPSS loads are sequentially energized by the protection system during loss of offsite power (LOOP) or loss of coolant accident (LOCA) conditions.
- 7.0** **Inspection, Tests, Analyses and Acceptance Criteria**
- 7.1** Table 2.5.1-3—Emergency Power Supply System Inspections, Tests, Analyses, and Acceptance Criteria provides the ITAAC for the EPSS.

**Table 2.5.1-1—Class 1 E Emergency Power Supply
Electrical Equipment Location (3 Sheets)**

Equipment Description	Equipment Tag Number (1)	Equipment Location
6.9 kV Switchgear	31BDA	Division 1 Safeguard Building
6.9 kV Switchgear	32BDA	Division 2 Safeguard Building
6.9 kV Switchgear	33BDA	Division 3 Safeguard Building
6.9 kV Switchgear	34BDA	Division 4 Safeguard Building
6.9 kV Switchgear	31BDB	Division 1 Safeguard Building
6.9 kV Switchgear	32BDB	Division 2 Safeguard Building
6.9 kV Switchgear	33BDB	Division 3 Safeguard Building
6.9 kV Switchgear	34BDB	Division 4 Safeguard Building
6.9 kV Switchgear	31BDC	Division 1 Safeguard Building
6.9 kV Switchgear	34BDC	Division 4 Safeguard Building
6.9 kV Switchgear	31BDD	Division 1 ESW Pump Building
6.9 kV Switchgear	32BDD	Division 2 ESW Pump Building
6.9 kV Switchgear	33BDD	Division 3 ESW Pump Building
6.9 kV Switchgear	34BDD	Division 4 ESW Pump Building
480V Load Center	31BMA	Division 1 Safeguard Building
480V Load Center	32BMA	Division 2 Safeguard Building
480V Load Center	33BMA	Division 3 Safeguard Building
480V Load Center	34BMA	Division 4 Safeguard Building
480V Load Center	31BMB	Division 1 Safeguard Building
480V Load Center	32BMB	Division 2 Safeguard Building
480V Load Center	33BMB	Division 3 Safeguard Building
480V Load Center	34BMB	Division 4 Safeguard Building
480V Load Center	31BMC	Division 1 Safeguard Building
480V Load Center	34BMC	Division 4 Safeguard Building
480V Load Center	31BMD	Division 1 ESW Pump Building
480V Load Center	32BMD	Division 2 ESW Pump Building
480V Load Center	33BMD	Division 3 ESW Pump Building
480V Load Center	34BMD	Division 4 ESW Pump Building
480V MCC	31BNA01	Division 1 EDG Building
480V MCC	32BNA01	Division 2 EDG Building
480V MCC	33BNA01	Division 3 EDG Building

**Table 2.5.1-1—Class 1 E Emergency Power Supply
Electrical Equipment Location (3 Sheets)**

Equipment Description	Equipment Tag Number (1)	Equipment Location
480V MCC	34BNA01	Division 4 EDG Building
480V MCC	31BNA02	Division 1 Safeguard Building
480V MCC	32BNA02	Division 2 Safeguard Building
480V MCC	33BNA02	Division 3 Safeguard Building
480V MCC	34BNA02	Division 4 Safeguard Building
480V MCC	31BNB01	Division 1 Safeguard Building
480V MCC	32BNB01	Division 2 Safeguard Building
480V MCC	33BNB01	Division 3 Safeguard Building
480V MCC	34BNB01	Division 4 Safeguard Building
480V MCC	31BNB02	Division 1 Safeguard Building
480V MCC	32BNB02	Division 2 Safeguard Building
480V MCC	33BNB02	Division 3 Safeguard Building
480V MCC	34BNB02	Division 4 Safeguard Building
480V MCC	31BNB03	Division 1 Safeguard Building
480V MCC	32BNB03	Division 2 Safeguard Building
480V MCC	33BNB03	Division 3 Safeguard Building
480V MCC	34BNB03	Division 4 Safeguard Building
480V MCC	31BNC01	Division 1 Safeguard Building
480V MCC	34BNC01	Division 4 Safeguard Building
480V MCC	31BND01	Division 1 ESW Pump Building
480V MCC	32BND01	Division 2 ESW Pump Building
480V MCC	33BND01	Division 3 ESW Pump Building
480V MCC	34BND01	Division 4 ESW Pump Building
Transformer	31BMT01	Division 1 Safeguard Building
Transformer	32BMT01	Division 2 Safeguard Building
Transformer	33BMT01	Division 3 Safeguard Building
Transformer	34BMT01	Division 4 Safeguard Building
Transformer	31BMT02	Division 1 Safeguard Building
Transformer	32BMT02	Division 2 Safeguard Building
Transformer	33BMT02	Division 3 Safeguard Building
Transformer	34BMT02	Division 4 Safeguard Building

**Table 2.5.1-1—Class 1 E Emergency Power Supply
Electrical Equipment Location (3 Sheets)**

Equipment Description	Equipment Tag Number (1)	Equipment Location
Transformer	31BMT03	Division 1 Safeguard Building
Transformer	34BMT03	Division 4 Safeguard Building
Transformer	31BMT04	Division 1 ESW Pump Building
Transformer	32BMT04	Division 2 ESW Pump Building
Transformer	33BMT04	Division 3 ESW Pump Building
Transformer	34BMT04	Division 4 ESW Pump Building
Transformer	31BNT01	Division 1 Safeguard Building
Transformer	32BNT01	Division 2 Safeguard Building
Transformer	33BNT01	Division 3 Safeguard Building
Transformer	34BNT01	Division 4 Safeguard Building

(1) Equipment tag numbers are provided for information only and are not part of the certified design.

Table 2.5.1-2—Class 1 E Emergency Power Supply System Electrical Equipment Design (6 Sheets)

Equipment Description	Equipment Tag Number (1)	IEEE Class 1E	MCR / RSS Displays	MCR / RSS Controls
6.9 kV Switchgear	31BDA	Yes	Bus Voltage / Bus Voltage	Incoming Source Breaker Control / Incoming Source Breaker Control
6.9 kV Switchgear	32BDA	Yes	Bus Voltage / Bus Voltage	Incoming Source Breaker Control / Incoming Source Breaker Control
6.9 kV Switchgear	33BDA	Yes	Bus Voltage / Bus Voltage	Incoming Source Breaker Control / Incoming Source Breaker Control
6.9 kV Switchgear	34BDA	Yes	Bus Voltage / Bus Voltage	Incoming Source Breaker Control / Incoming Source Breaker Control
6.9 kV Switchgear	31BDB	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
6.9 kV Switchgear	32BDB	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
6.9 kV Switchgear	33BDB	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
6.9 kV Switchgear	34BDB	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
6.9 kV Switchgear	31BDC	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
6.9 kV Switchgear	34BDC	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
6.9 kV Switchgear	31BDD	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
6.9 kV Switchgear	32BDD	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control

Table 2.5.1-2—Class 1 E Emergency Power Supply System Electrical Equipment Design (6 Sheets)

Equipment Description	Equipment Tag Number (1)	IEEE Class 1E	MCR / RSS Displays	MCR / RSS Controls
6.9 kV Switchgear	33BDD	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
6.9 kV Switchgear	34BDD	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	31BMA	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	32BMA	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	33BMA	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	34BMA	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	31BMB	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	32BMB	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	33BMB	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	34BMB	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	31BMC	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	34BMC	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control

Table 2.5.1-2—Class 1 E Emergency Power Supply System Electrical Equipment Design (6 Sheets)

Equipment Description	Equipment Tag Number (1)	IEEE Class 1E	MCR / RSS Displays	MCR / RSS Controls
480V Load Center	31BMD	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	32BMD	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	33BMD	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V Load Center	34BMD	Yes	Bus Voltage / Bus Voltage	Feeder Breaker Control / Feeder Breaker Control
480V MCC	31BNA01	Yes	N/A / N/A	N/A / N/A
480V MCC	32BNA01	Yes	N/A / N/A	N/A / N/A
480V MCC	33BNA01	Yes	N/A / N/A	N/A / N/A
480V MCC	34BNA01	Yes	N/A / N/A	N/A / N/A
480V MCC	31BNA02	Yes	N/A / N/A	N/A / N/A
480V MCC	32BNA02	Yes	N/A / N/A	N/A / N/A
480V MCC	33BNA02	Yes	N/A / N/A	N/A / N/A
480V MCC	34BNA02	Yes	N/A / N/A	N/A / N/A
480V MCC	31BNB01	Yes	N/A / N/A	N/A / N/A
480V MCC	32BNB01	Yes	N/A / N/A	N/A / N/A
480V MCC	33BNB01	Yes	N/A / N/A	N/A / N/A
480V MCC	34BNB01	Yes	N/A / N/A	N/A / N/A
480V MCC	31BNB02	Yes	Bus Voltage / Bus Voltage	N/A / N/A

Table 2.5.1-2—Class 1 E Emergency Power Supply System Electrical Equipment Design (6 Sheets)

Equipment Description	Equipment Tag Number (1)	IEEE Class 1E	MCR / RSS Displays	MCR / RSS Controls
480V MCC	32BNB02	Yes	Bus Voltage / Bus Voltage	N/A / N/A
480V MCC	33BNB02	Yes	Bus Voltage / Bus Voltage	N/A / N/A
480V MCC	34BNB02	Yes	Bus Voltage / Bus Voltage	N/A / N/A
480V MCC	31BNB03	Yes	Bus Voltage / Bus Voltage	N/A / N/A
480V MCC	32BNB03	Yes	Bus Voltage / Bus Voltage	N/A / N/A
480V MCC	33BNB03	Yes	Bus Voltage / Bus Voltage	N/A / N/A
480V MCC	34BNB03	Yes	Bus Voltage / Bus Voltage	N/A / N/A
480V MCC	31BNC01	Yes	N/A / N/A	N/A / N/A
480V MCC	34BNC01	Yes	N/A / N/A	N/A / N/A
480V MCC	31BND01	Yes	N/A / N/A	N/A / N/A
480V MCC	32BND01	Yes	N/A / N/A	N/A / N/A
480V MCC	33BND01	Yes	N/A / N/A	N/A / N/A
480V MCC	34BND01	Yes	N/A / N/A	N/A / N/A
Transformer	31BMT01	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	32BMT01	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	33BMT01	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	34BMT01	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control

Table 2.5.1-2—Class 1 E Emergency Power Supply System Electrical Equipment Design (6 Sheets)

Equipment Description	Equipment Tag Number (1)	IEEE Class 1E	MCR / RSS Displays	MCR / RSS Controls
Transformer	31BMT02	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	32BMT02	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	33BMT02	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	34BMT02	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	31BMT03	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	34BMT03	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	31BMT04	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	32BMT04	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	33BMT04	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Transformer	34BMT04	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Voltage Regulating Transformer	31BNT01	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control

Table 2.5.1-2—Class 1 E Emergency Power Supply System Electrical Equipment Design (6 Sheets)

Equipment Description	Equipment Tag Number (1)	IEEE Class 1E	MCR / RSS Displays	MCR / RSS Controls
Voltage Regulating Transformer	32BNT01	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Voltage Regulating Transformer	33BNT01	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control
Voltage Regulating Transformer	34BNT01	Yes	N/A / N/A	Feeder Breaker Control / Feeder Breaker Control

(1) Equipment tag numbers are provided for information only and are not part of the certified design.

Table 2.5.1-3—Class 1 E Emergency Power Supply System Inspections, Tests, Analyses, and Acceptance Criteria (4 Sheets)

	Commitment	Inspection, Test or Analysis	Acceptance Criteria
2.1	The functional arrangement of the EPSS is as shown on Figure 2.5.1-1.	An inspection will be performed.	The as-built EPSS conforms to the functional arrangement as shown in Figure 2.5.1-1.
2.2	Equipment identified as Class 1E in Table 2.5.1-2 is located as listed in Table 2.5.1-1.	An inspection will be performed.	The equipment listed as Class 1E in Table 2.5.1-2 is located as indicated in Table 2.5.1-1.
2.3	There are four EPSS divisions.	An inspection will be performed.	The EPSS has four divisions.
3.1	Equipment listed as Class 1E in Table 2.5.1-2 are qualified as Seismic Category I and can withstand seismic design basis loads without loss of safety function.	<ul style="list-style-type: none"> a. An inspection will be performed. b. Type testing, analysis, or a combination of type testing and analysis will be performed. 	<ul style="list-style-type: none"> a. A report exists and concludes that the equipment designated as Class 1E in Table 2.5.1-2 is installed as designed. b. A report exists and concludes that the equipment listed as Class 1E in Table 2.5.1-2 can withstand seismic design basis loads without loss of safety function.
4.1	Displays listed in Table 2.5.1-2 are retrievable in the MCR and RSS as listed in Table 2.5.1-2.	An inspection will be performed.	Displays listed in Table 2.5.1-2 as being retrieved in the MCR can be retrieved in the MCR. Displays listed in Table 2.5.1-2 as being retrieved in the RSS can be retrieved in the RSS.
4.2	EPSS equipment controls are provided in the MCR and RSS as listed in Table 2.5.1-2.	A test will be performed.	Controls listed in Table 2.5.1-2 as being in the MCR exist in the MCR. Controls listed in Table 2.5.1-2 as being in the RSS exist in the RSS.
5.1	Physical separation exists between EPSS Class 1E equipment listed in Table 2.5.1-2 and non-Class 1E equipment.	An inspection will be performed.	There is physical separation between EPSS Class 1E equipment listed in Table 2.5.1-2 and non-Class 1E equipment.

Table 2.5.1-3—Class 1 E Emergency Power Supply System Inspections, Tests, Analyses, and Acceptance Criteria (4 Sheets)

	Commitment	Inspection, Test or Analysis	Acceptance Criteria
5.2	Non-safety-related loads connected to the EPSS (e.g., charging pumps, severe accident heat removal system pump, emergency lighting and emergency pressurizer heaters) are separated by a Class 1E isolation device.	An inspection will be performed.	EPSS Class 1E and non-Class 1E equipment are separated by a Class 1E isolation device.
5.3	Without an alternate feed installed, independence is maintained between the four EPSS divisions.	Testing will be performed by providing a test signal in each EPSS division, one division at a time.	Without an alternate feed installed, the test signal exists only in the EPSS division under test when a test signal is applied in each EPSS division.
5.4	With the alternate feed installed from EPSS division 1 to division 2; independence is maintained between the load group created by divisions 1 and 2, and divisions 3 and 4. EPSS divisions 3 and 4 are independent of each other.	Testing will be performed by providing a test signal in each EPSS division; one division at a time while the alternate feed is installed from EPSS division 1 to division 2.	A test signal exists only in the load group created by Class 1E divisions 1 and 2 when the test signal is provided in Class 1E division 1 or 2. A test signal exists only in the division under test when the test signal is provided in Class 1E division 3 or 4.
5.5	With the alternate feed installed from EPSS division 2 to division 1; independence is maintained between the load group created by divisions 1 and 2, and divisions 3 and 4. EPSS divisions 3 and 4 are independent of each other.	Testing will be performed by providing a test signal in each EPSS division; one division at a time while the alternate feed is installed from EPSS division 2 to division 1.	A test signal exists only in the load group created by Class 1E divisions 1 and 2 when the test signal is provided in Class 1E division 1 or 2. A test signal exists only in the division under test when the test signal is provided in Class 1E division 3 or 4.
5.6	With the alternate feed installed from EPSS division 3 to division 4; independence is maintained between the load group created by divisions 3 and 4, and divisions 1 and 2. EPSS divisions 1 and 2 are independent of each other.	Testing will be performed by providing a test signal in each EPSS division; one division at a time while the alternate feed is installed from EPSS division 3 to division 4.	A test signal exists only in the load group created by Class 1E divisions 3 and 4 when the test signal is provided in Class 1E division 3 or 4. A test signal exists only in the division under test when the test signal is provided in Class 1E division 1 or 2.

Table 2.5.1-3—Class 1 E Emergency Power Supply System Inspections, Tests, Analyses, and Acceptance Criteria (4 Sheets)

	Commitment	Inspection, Test or Analysis	Acceptance Criteria
5.7	With the alternate feed installed from EPSS division 4 to division 3; independence is maintained between the load group created by divisions 3 and 4, and divisions 1 and 2. EPSS divisions 1 and 2 are independent of each other.	Testing will be performed by providing a test signal in each EPSS division; one division at a time while the alternate feed is installed from EPSS division 4 to division 3.	A test signal exists only in the load group created by Class 1E divisions 3 and 4 when the test signal is provided in Class 1E division 3 or 4. A test signal exists only in the division under test when the test signal is provided in Class 1E division 1 or 2.
5.8	Control power for EPSS switchgear and load centers listed in Table 2.5.1-2 is provided by the EUPS system from the respective division.	Tests are conducted by providing a test signal in each Class 1E division separately.	A test signal exists only in the EPSS division under test.
5.9	Class 1E cables and cable raceways are marked according to their respective division color-code.	An inspection will be performed.	As-built Class 1E cables and cable trays are marked according to their respective color code.
5.10	Physical separation or electrical isolation exists between Class 1E divisions and between Class 1E divisions and non-Class 1E cables.	An inspection will be performed.	Physical separation or electrical isolation exists between Class 1E divisions and between Class 1E divisions and non-Class 1E cables.
5.11	EPSS switchgear, load centers, MCCs, and transformers as listed in Table 2.5.1-2 and their feeder breakers and load breakers are sized to supply their load requirements.	An inspection will be performed.	The EPSS switchgear, load centers, MCCs, and transformers as listed in Table 2.5.1-2 and their feeder breakers and load breaker ratings are greater than their load requirements.
5.12	EPSS cables and buses are sized to supply their assigned load requirements.	An inspection will be performed.	The as-built EPSS cables and buses are sized to supply their assigned load requirements.
6.1	Each EPSS division has an assigned EDG that provides power if there is a loss of offsite power.	Tests will be performed.	Each EPSS division has an assigned EDG that provides power if there is a loss of offsite power.

Table 2.5.1-3—Class 1 E Emergency Power Supply System Inspections, Tests, Analyses, and Acceptance Criteria (4 Sheets)

	Commitment	Inspection, Test or Analysis	Acceptance Criteria
6.2	Each EPSS 6.9 kV switchgear offsite power supply circuit breaker is opened by a protection system signal.	Tests will be performed.	Each EPSS division automatically separates from the offsite power supply on a signal from the protection system.
6.3	The EPSS provides voltage at the supplied safety-related equipment terminals that is greater than the minimum voltage.	Tests on the as-built EPSS are conducted in configurations without an alternate feed installed, and each configuration with an alternate feed installed.	The voltage supplied at the as-built safety-related equipment terminals is greater than the minimum voltage.
6.4	EPSS loads are sequentially energized by the protection system during LOOP or LOCA conditions.	Tests will be performed.	EPSS loads are sequentially energized by the protection system during LOOP or LOCA conditions.