

Director of Nuclear Reactor Regulation

July 20, 1984

If you have any questions concerning this matter, please get in touch with D. B. Ellis at FTS 858-2681.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

D S Kammer

D. S. Kammer
Nuclear Engineer

Sworn to and subscribed before me
this 20th day of July 1984

Paulette H. White
Notary Public
My Commission Expires 9-5-84

Enclosures (2)

cc: U.S. Nuclear Regulatory Commission (Enclosures)
Region II
Attn: Mr. James P. O'Reilly Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

ENCLOSURE 1

WATTS BAR NUCLEAR PLANT
NUREG-0737 ITEM III.D.1.1
INITIAL LEAK TEST RESULTS FOR
THE WASTE GAS SYSTEM

Waste Gas System - Leak Test Results

System Pressure - to 100 psig

Leak Rate - 15.5 standard cubic feet per hour