

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

October 16, 1984

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

- References: 1. L. M. Mills' letter to you dated September 6, 1984.
2. D. S. Kammer's letter to you dated September 24, 1984.

By reference 1, TVA provided responses to NRC questions concerning fire protection at Watts Bar Nuclear Plant. By reference 2, TVA notified the NRC that schedules previously provided in response to item 15 and deviation 13 had been revised to November 29, 1984 and that the schedule for color-coded drawings had been delayed until December 19, 1984. Reference 2 also withdrew deviation request No. 6 since it is no longer applicable.

TVA has since identified additional changes to schedules provided in reference 1. In deviation 1, TVA specified that water curtains would be installed per Engineering Change Notice (ECN) 5087 and one and one-half hour rated fire dampers would be installed in HVAC ducts per ECN 5087 by September 21, 1984. Deviation 12 had also indicated that TVA would extend the sprinkler protection to two mezzanine areas on E1.713.0 per ECN 5087 by September 5, 1984. The ECN 5087 modifications are now scheduled for completion by November 1, 1984. TVA is also revising the completion of ECNs 5062 and 5063. The schedule for completion of the detection and actuation systems per these ECNs as specified in deviation 4 of reference 1 have been changed from September 21, 1984 to November 1, 1984.

8410220047 841016
PDR ADDCK 05000390
F PDR

Boo!
1/0

Director of Nuclear Reactor Regulation

October 16, 1984

If you have any questions concerning this matter, please get in touch with D. P. Ormsby at FTS 858-2682.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

R. H. Shell

R. H. Shell, Supervisor
Pressurized Water Reactors

Sworn to and subscribed before me
this 16th day of Oct. 1984

Paulette H. White

Notary Public

My Commission Expires 8-24-88

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323