

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

October 19, 1984

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

- References: 1. L. M. Mills' letter to you dated September 6, 1984.
2. D. S. Kammer's letter to you dated September 24, 1984.

By reference 1, TVA provided responses to NRC questions concerning fire protection at Watts Bar Nuclear Plant. By reference 2, TVA notified the NRC that schedules previously provided in response to item 15 and deviation 13 had been revised to November 29, 1984 and that the schedule for color-coded drawings had been delayed until December 19, 1984. Reference 2 also withdrew deviation request No. 6 since it is no longer applicable.

TVA had identified additional changes to schedules provided in reference 1 and provided revised schedules in reference 2 as follows. In deviation 1, TVA specified that water curtains would be installed per Engineering Change Notice (ECN) 5087, and one and one-half hour rated fire dampers would be installed in HVAC ducts per ECN 5087 by September 21, 1984. Deviation 12 had also indicated that TVA would extend the sprinkler protection to two mezzanine areas on EL.713.0 per ECN 5087 by September 5, 1984. The ECN 5087 modifications are now scheduled for completion by November 1, 1984. TVA is also revising the completion of ECNs 5062 and 5063. The schedule for completion of the detection and actuation systems per these ECNs as specified in deviation 4 of reference 1 has been changed from September 21, 1984 to November 1, 1984.

Reference 2 provided information concerning item 1 related to redundant shutdown-related systems inside containment with a commitment to provide information on corrective actions by October 19, 1984. The schedule for providing this information is now January 4, 1985.

8410300270 841019
PDR ADOCK 05000390
F PDR

3002
/10


Director of Nuclear Reactor Regulation

October 19, 1984

If you have any questions concerning this matter, please get in touch with D. P. Ormsby at FTS 858-2682.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Licensing

Sworn to and subscribed before me
this 19th day of Oct. 1984



Notary Public

My Commission Expires 4/8/86

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323