

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

March 21, 1985

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

Please refer to TVA's letter dated June 19, 1984 which provided our initial response to "Specific Concern 7b" on 125V DC Vital Batteries. In that response, TVA committed to replace the present end rails with adjustable end rails by December 1, 1984. As requested in Section 3.10.2.7.b of Supplement No. 3 to the Watts Bar Nuclear Plant Safety Evaluation Report, TVA is, by means of this letter, notifying NRC that the promised modification is now complete.

If you have any questions concerning this matter, please get in touch with K. Mali at FTS 858-2682.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Domer

J. A. Domer
Nuclear Engineer

Sworn to and subscribed before me
this 21st day of Mar. 1985.

Paulette H. White
Notary Public

My Commission Expires 8-24-88

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Dr. J. Nelson Grace, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

8503270081 850321
PDR ADOCK 05000390
A PDR

*Bool
1/0*