

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1630 Chestnut Street Tower II

March 26, 1985

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

Please refer to TVA letter dated March 24, 1985 by which, in part, we clarified the use of the environmental qualification (EQ) report in the preventive maintenance (PM) program at Watts Bar Nuclear Plant (WBN). This letter provides additional information concerning our schedule regarding the PM program.

Administrative procedures for WBN require that PM requirements shall be identified and placed on a periodic schedule within 30 days following turnover of equipment to the operations staff. PM procedures are developed before the initial PM of the affected equipment.

The PM program, both procedures and activities, is comprehensively in place for WBN, with the following exceptions, which are currently under development:

- | | |
|--|--|
| Vital Battery Boards and Chargers | Periodic maintenance procedure for instrumentation and protective relays (complete by initial criticality) |
| Diesel Generator Battery Boards and Chargers | Periodic maintenance procedure for instrumentation and protective relays (complete by initial criticality) |

For mechanical maintenance, more than 95 percent of several hundred PM procedures have been approved. All other procedures are under development pending acquisition of vendor information. Periodic maintenance of the affected equipment has been placed on the PM schedule.

8503290144 850326
PDR ADOCK 05000390
A PDR

A048
/0

Director of Nuclear Reactor Regulation

March 26, 1985

If you have any questions concerning this matter, please get in touch with K. Mali of my staff at FTS 858-2682 in Chattanooga.


Very truly yours,

TENNESSEE VALLEY AUTHORITY



D. E. McCloud
Nuclear Engineer

Sworn to and subscribed before me
this 26th day of March 1985


Notary Public

My Commission Expires 4/8/86

cc: U.S. Nuclear Regulatory Commission
Region II
Attn: Dr. J. Nelson Grace, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323