

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

SEP 11 1989

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of)
Tennessee Valley Authority)

Docket Nos. 50-390
50-391

WATTS BAR NUCLEAR PLANT (WBN) - CONTAINMENT ISOLATION - SUPPLEMENTAL RESPONSE
TO NRC'S REQUEST FOR ADDITIONAL INFORMATION

Reference: Letter from TVA to NRC dated May 12, 1989, "Containment Isolation -
Response to NRC's Request for Additional Information"

In a teleconference, August 9, 1989, the NRC staff reviewer requested the building locations of the closed loop outside containment (CLOC) systems identified in Table 2 of the reference letter. The reviewer indicated this information was needed to confirm that the CLOC systems are located in controlled leakage areas. TVA has reviewed the locations of the systems on Table 2 of the reference letter and verified that these CLOCs reside in controlled leakage areas, i.e., the annulus and/or auxiliary building.

Any questions should be directed to T. W. Horning at (615) 365-3381.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

MJ Ray Jr
Manager, Nuclear Licensing
and Regulatory Affairs

cc: See page 2

8909180231 890911
PDR ADDCK 05000390
A PDC

2030
1/0

U.S. Nuclear Regulatory Commission

SEP 11 1989

cc: Ms. S. C. Black, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. B. A. Wilson, Assistant Director
for Inspection Programs
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region-II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

NRC Resident Inspector
Watts Bar Nuclear Plant
P.O. Box 700
Spring City, Tennessee 37381