

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

SEP 21 1989

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

WATTS BAR NUCLEAR PLANT (WBN) UNITS 1 AND 2 - CFR 50.55a(a)(3) - PROPOSED
ALTERNATIVE ACCEPTANCE TO AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
SECTION III

This letter requests NRC approval in accordance with 10 CFR 50.55a(a)(3) of an
alternative to ASME Section III requirements.

In December 1986, TVA committed to reviewing the radiographs provided by
certain vendors. Pittsburgh-Des Moines (PDM), the supplier of the refueling
water storage tanks (RWSTs), was one of these vendors.

The RWSTs are ASME Section III Class 2 manufactured to the requirements of
ASME Section III 1974 edition up to and including the winter 1975 addenda.
There were 635 weld sectors radiographed for each RWST. TVA has rereviewed
the radiographs for both units. Radiograph technique deficiencies were
identified in 61 sectors for Unit 1 and 58 sectors for Unit 2. Weld defects
were identified in 34 sectors for Unit 1 and 38 sectors for Unit 2.

Except as discussed below, all discrepant sectors which did not comply with
the requirements of ASME Section III for radiographic or weld quality were
reradiographed and, where necessary, repaired.

The purpose of this letter is to request an exception to the ASME Section III
requirement to radiograph the RWST vortex nozzle assembly welds (piece 8B).
These vortex nozzle assemblies located in the bottom of each RWST are
fabricated from SA 240 type 304 stainless steel. Each assembly consists of a
cone subassembly (piece 14A) formed from 4 segments of 5/16 inch thick plate
welded with vertical seam welds, and a pipe subassembly (piece 8H), which is
seam-welded 3/8 inch thick rolled plate. The cone and pipe subassemblies are
joined with a full-penetration groove weld (see Enclosure 1).

8909280094 890921
PDR ADOCK 05000390
A PDC

A047
11

SEP 21 1989

U.S. Nuclear Regulatory Commission

Subsubarticle NC-5280 of ASME Section III requires Class 2 butt joints of nozzles to be fully radiographed. Our review identified the following discrepancies:

1. The seam welds in the cone subassemblies (14A) for both units were not radiographed, nor was radiography specified on the PDM drawings. This discrepancy has been documented on Condition Adverse to Quality Reports (CAQRs) WBP 890317 and WBP 890318 for Units 1 and 2, respectively.
2. The radiographic techniques for the Unit 1 circumferential weld, attaching the cone to the pipe, and the pipe seam weld, do not fully comply with the requirements of ASME Section III for the film quality and coverage.

NOTE: The quality of the radiographs for Unit 2 is acceptable.

3. Weld defects which do not meet the acceptance criteria of ASME Section III have been identified in both vortex nozzle assemblies (see Enclosure 2).
 - a. In the Unit 1 assembly, lack of fusion, approximately 3 inches long, exists in one of the cone subassembly's seam welds. This weld defect was identified in the radiograph of the circumferential weld attaching the cone subassembly to the pipe subassembly. Consequently, the entire length of the weld is not included on the radiograph (3 of 14 inches are shown). No other defects are apparent in the circumferential or seam welds.
 - b. In the Unit 2 assembly, unacceptable slag, approximately 3/8 inch long, and two linear indications which are transverse to the weld, each approximately 1/4 inch long, exist in the circumferential weld. Unacceptable slag, approximately 1/4 inch long, exists in one of the cone subassembly's seam welds, and 6 indications, each approximately 1/8 inch long, exist adjacent to the circumferential weld (3 of 14 inches are shown). The latter indications appear to be surface.

The operating pressures of the RWSTs are atmospheric pressure. Design temperature is 200°F, with an operating temperature of 60°F minimum. The RWSTs fulfill 2 basic requirements:

1. Provide an adequate supply of borated water for use during refueling operations; and
2. Provide an adequate source of borated water to the Chemical and Volume Control System (CVCS) pumps, the Safety Injection System (SIS) pumps, the Residual Heat Removal System (RHR) pumps, and the Containment Spray System (CSS) pumps in the event of a loss of coolant accident.

The cone subassembly, a portion of the pipe subassembly, and the attaching circumferential weld are embedded in concrete (see Enclosure 1). Except for the portion of pipe extending beyond the concrete's surface into the pipe tunnel, these welds would be extremely difficult to make accessible for reradiography or repair. For this reason TVA has performed fracture mechanics

SEP 21 1989

U.S. Nuclear Regulatory Commission

analyses of the subject welds. The calculation, identified by TVA as WBP-MTB-001, is included as Enclosure 3. The calculations do not consider the structural support provided by the concrete backing. The calculations were performed using the method described in ASME Section XI, paragraph IWB-3640 and Appendix C, and Code Case N-436.

The results of the calculations demonstrate that the cone subassembly can withstand a longitudinal through-wall flaw up to 48.9 inches and still maintain structural integrity. The cone subassembly-to-pipe weld can withstand a through-wall flaw up to 70 percent of circumference and still maintain structural integrity. Enclosure 4 provides various fabrication checklists and nondestructive examination reports including hydrostatic test reports. These document fabrication and inspection activities including inspection reports certifying surface examinations were performed. The acceptable results of these examinations demonstrate that the welds do not contain through-wall flaws. Based on these examinations and the calculations, TVA concludes that the flaws will not result in failure of the nozzle assemblies.


Full compliance with ASME Section III requirements for radiographic acceptance of these welds would, as stated in 10 CFR 50.55a(a)(3), "result in hardship and unusual difficulties without a compensating increase in the level of quality and safety." Therefore, TVA requests NRC's approval in accordance with 10 CFR 50.55a(a)(3) of utilizing a calculation and existing inspections as an alternative to ASME Section III requirements. After receiving approval for this proposed alternative, TVA will add a paragraph to the WBN Final Safety Analysis Report (FSAR) Section 9.2.7 to document TVA's deviation from ASME Section III and to provide justification for acceptance of this condition.

Enclosure 5 lists the new commitments made in this report.

If there are any questions, please telephone G. R. Ashley at (615) 365-8527.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



Manager, Nuclear Licensing
and Regulatory Affairs

Enclosures
cc: See page 4

SEP 21 1989

U.S. Nuclear Regulatory Commission

cc (Enclosures):


Ms. S. C. Black, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. B. A. Wilson, Assistant Director
for Inspection Programs
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323


NRC Resident Inspector
Watts Bar Nuclear Plant
P.O. Box 700
Spring City, Tennessee 37381

ENCLOSURE 1
REFUELING WATER STORAGE TANK (RWST) VORTEX ASSEMBLY

VORTEX NOZZLE ASSEMBLY
(PIECE 8B)



VORTEX ASSEMBLY EMBEDDED IN GROUT



Attachment D

CIRCUMFERENTIAL WELD

IWA-WBNP

VENDOR WELD RADIOGRAPHIC REEVALUATION DATA SHEET

IWA Class NA ASME Class 2 Acceptance Criteria PDM RT-10 Weld No.: Sh-Mc Unit 1Design Pipe Size NA x NA DWP NA Cut No: NA Repair No: NAPDM
Drawing Thickness 312" - .375" Measurement Method NA Welder Identifier: NAMaterial Specification Type and Grade NA to NAX-Ray Machine: MFG _____ Model _____ Radioisotope: Type _____ S/N _____
Actual KV _____ HA _____ Size _____ Curies _____
Focal Spot Size _____

Film Size: _____ Hfg: _____ Type: _____ Exposure Time: _____

Exposure Technique: _____ Blocking or Masking _____

Penetrameter: Designation _____ Grade _____ Film Side ☐ Source Side ☐

Shim Thickness _____ Screens _____ Source to Film Distance _____




Radiographer _____ ASNT Level _____ Exposure Date _____

Sector	Cass	Film	Interpretation	Results	Codes Used in
Id.	ID	NO.	Remarks	A/R	Remarks Column
0-1	NA	NA	Yellowed, FA, Scratches, ID, SU	Reheat	BT - Burn Through
1-2			Double 0-1 double exposed, decr. ext	-	CC - Crater Cracks
2-3			Unpatch	-	CR - Cracks
3-4			Missing	Reheat	CV - Concave Root
4-5			Too light, UC, FA, PD	Reheat	IF - Incomplete
5-6			Too light, PD, SC #, JP in Adj. seam	Reheat	Fusion
6-7			Weld	-	IP - Incomplete
7-8			FA, PM, PD, SC #	Reheat	Penetration
8-9				-	OX - Oxidation
9-10				-	PO - Porosity
10-11				-	SL - Slag
11-12				-	SU - Surface
12-13				-	TN - Tungsten
13-14				-	UC - Undercut
14-15				-	FA - Film Artifacts
15-16				-	IPM - Processing Marks
16-17				-	LL - Light Leak
17-18				-	UF - Underfill
18-19				-	CM - Clamp marks in
19-20				-	ID - Identifier Base M

LOCATION MARKER 1/2"

EACH SIDE OF WELD.

TECHNIQUES

FILM HOLDER IN CONTACT
WITH PART UNLESS NOTED

Inspected in accordance with ASME Section III

Persons Consulted (If None so Indicate) NonePrimary
Acceptance Reviewer NA ASNT Level II Date NA Accept ☐ Reject ☒Final
Acceptance Reviewer CEV ASNT Level III Date 6/22/82 Accept ☐ Reject ☒

Attachment D

PIPE SEAM WELD

IVA-WBMP

VENDOR WELD RADIOGRAPHIC REEVALUATION DATA SHEET

IVA Class NA ASME Class 2 Acceptance Criteria PDM ET-10 Weld No.: Sh-Sh, Unit 1Design Pipe Size NA x NA DWP NA Cut No: NA Repair No: NA
Diameter WallPDM
Drawing Thickness .375 in. Measurement Method NA Welder Identifier: NAMaterial Specification Type and Grade NA to NAX-Ray Machine: MFG _____ Model _____ Radioisotope: Type _____ S/N _____
Actual KV _____ MA _____ Size _____ Curies _____
Focal Spot Size _____

Film Size: _____ Mfg: _____ Type: _____ Exposure Time: _____

Exposure Technique: _____ Blocking or Masking _____

Penetrameter: Designation _____ Grade _____ Film Side ☐ Source Side ☐

Shim Thickness _____ Screens _____ Source to Film Distance _____

Radiographer _____ ASNT Level _____ Exposure Date _____

Sector	Cass	Film	Interpretation	Results	Codes Used in
Id	ID	NO.	Remarks	A/R	Remarks Column
1-2	NA	NA	Forged, J-welds, Too Light	Reheat	BT - Burn Through
2-3			Too Light, UC, FA	Reheat	CC - Crater Cracks
3-4			FA, PM, Too Light at ends, SL, R	Reheat	CR - Cracks
4-5			Too Light, PM, FA, J-welds, SL	Reheat	CV - Concave Root
5-6			Too Light, PM, FA	Reheat	IF - Incomplete
6-7			Too Light, J-welds, SL, FA	Reheat	Fusion
					IP - Incomplete
					Penetration
					OX - Oxidation

LOCATION MARKER 1/2"

EACH SIDE OF WELD.

TECHNIQUES

FILM HOLDER IN CONTACT
WITH PART UNLESS NOTED

PO - Porosity

SL - Slag

SU - Surface

TN - Tungsten

UC - Undercut

FA - Film Artifacts

PM - Processing Marks

LL - LIGHT LEAK

UF - Underfill

CM - clamp marks in

ID - Identifier

Inspected in accordance with ASME Section III

Persons Consulted (If None so Indicate) None
Primary
Acceptance Reviewer NA ASNT Level II Date NA Accept ☐ Reject ☐Final
Acceptance Reviewer [Signature] ASNT Level III Date 6/22/87 Accept ☐ Reject ☒

Attachment D

PIPE SEAM WELD

TVA-WBNP

VENDOR WELD RADIOGRAPHIC REEVALUATION DATA SHEET

TVA Class NA ASME Class 2 Acceptance Criteria PDM RT-10 Weld No.: 8h-8h Unit 2Design Pipe Size NA x NA DWP NA Cut No: NA Repair No: NA
Diameter WallPDM
Drawing Thickness .375" Measurement Method NA Welder Identifier: NAMaterial Specification Type and Grade NA to NAX-Ray Machine: MFG _____ Model _____ Radioisotope: Type _____ S/N _____
Actual KV _____ MA _____ Size _____ Curies _____
Focal Spot Size _____

Film Size: _____ Mfg: _____ Type: _____ Exposure Time: _____

Exposure Technique: _____ Blocking or Masking _____



Penetrameter: Designation _____ Grade _____ Film Side ☐ Source Side ☐

Shim Thickness _____ Screens _____ Source to Film Distance _____

Radiographer _____ ASNT Level _____ Exposure Date _____

Sector	Cass	Film	Interpretation	Results	Codes Used in
Id	ID	NO.	Remarks	A/R	Remarks Column
0-1	NA	NA	FA, PD, SL, PM	A	BT - Burn Through
1-2			FA, PM, SL	A	CC - Crater Cracks
2-3			FA, PM	A	CR - Cracks
3-4			FA, PM, PD	A	CV - Concave Root
4-5			FA, PM, PD	A	IF - Incomplete
5-6			FA, PM, PD	A	Fusion
					IP - Incomplete
					Penetration
					OX - Oxidation

LOCATION MARKER' 1/2" EACH SIDE OF WELD. TECHNIQUES FILM HOLDER IN CONTACT WITH PART UNLESS NOTED



Inspected in accordance with ASME Section III

Persons Consulted (If None so Indicate) NONE
Primary
Acceptance Reviewer NA ASNT Level II Date NA Accept ☐ Reject ☐
Final
Acceptance Reviewer 2089 ASNT Level III Date 6/13/89 Accept ☒ Reject ☐
ID - Identification Base Mx
CM - Clamp marks in
LL - Light Leak
UF - Underfill
FA - Film Artifacts
PM - Processing Marks
CC - Crater Cracks
CR - Cracks
CV - Concave Root
IF - Incomplete
Fusion
IP - Incomplete
Penetration
OX - Oxidation
PO - Porosity
SL - Slag
SU - Surface
TN - Tungsten
UC - Undercut