

**TENNESSEE VALLEY AUTHORITY**

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

**NOV 03 1989**

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of )  
Tennessee Valley Authority )

Docket Nos. 50-390  
50-391

WATTS BAR NUCLEAR PLANT (WBN) - SEISMIC DESIGN CONSIDERATION FOR CERTAIN  
SAFETY-RELATED VERTICAL STEEL TANKS (NRC REQUEST FOR INFORMATION) (TAC NOS.  
73097/73098)

Reference: Letter from NRC to TVA dated June 27, 1989, requesting information  
on the subject tanks

This is in response to NRC's June 27, 1989, request for information on the  
safety significance of above-ground, vertical liquid storage tanks related to  
the consideration of tank flexibility, specifically, the Condensate Storage  
Tank and the Refueling Water Storage Tank.

For WBN, the Auxiliary Feedwater (AFW) System is normally aligned to a  
non-safety grade, condensate quality water supply from the condensate storage  
tanks. In the event that low suction pressure occurs in any of the AFW pump  
supply lines, safety grade IE powered pressure switches automatically align  
the pump to the safety grade essential raw cooling water (ERCW) supply. The  
ERCW is not used, except in emergencies when the condensate supply is not  
available. Since the ERCW provides a safety-grade water supply, the  
condensate storage tank is not required to be seismically qualified or  
safety-related and, therefore, does not require the seismic design  
consideration requested in the referenced letter.

The Refueling Water Storage Tank is safety-related seismic category I, and the  
original analysis did consider tank wall flexibility.

When the referenced letter was received, an analysis was already underway by  
Bechtel to upgrade the current analysis utilizing current soil structure  
interaction techniques. This analysis is being done as part of the WBN  
Seismic Assessment Program effort. Responses to the questions raised by NRC  
regarding the structural and functional integrity of tanks during postulated  
earthquake events will be prepared as part of this effort. TVA will provide  
NRC by January 31, 1990, with the results of the analysis and how items a  
through i of the referenced letter were considered.

0030

1/b

8911140141 891103  
PDR ADOCK 05000390  
P PDC

NOV 03 1989

-2-

U.S. Nuclear Regulatory Commission

Commitments made in this submittal, which will be identified in TVA's commitment tracking systems, are summarized in the enclosure. Please direct any questions regarding this submittal to T. W. Horning, WBN Site Licensing, at (615) 365-3381.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

  
Manager, Nuclear Licensing  
and Regulatory Affairs

Enclosure

cc (Enclosure):

Ms. S. C. Black, Assistant Director  
for Projects  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852

Mr. B. A. Wilson, Assistant Director  
for Inspection Programs  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

NRC Resident Inspector  
Watts Bar Nuclear Plant  
P.O. Box 700  
Spring City, Tennessee 37381

ENCLOSURE

COMMITMENTS

- TVA will provide NRC by January 31, 1990, with the results of the Refueling Water Storage Tank wall flexibility analysis and how items a through i of the referenced letter were considered.