

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

NOV 21 1989

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of ) Docket Nos. 50-390  
Tennessee Valley Authority ) 50-391

WATTS BAR NUCLEAR PLANT (WBN) UNITS 1 AND 2 - 10 CFR 50.55a(a)(3) - PROPOSED  
ALTERNATIVE ACCEPTANCE TO AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)  
SECTION III

This letter requests NRC approval in accordance with 10 CFR 50.55a(a)(3) of an  
alternative to ASME Section III requirements.

During construction of Watts Bar Unit 1, it was discovered that the vendor of  
certain containment penetration assemblies had exercised specific provisions  
of the ASME Code Section III that permitted them to substitute the system  
hydrostatic tests for the component hydrostatic test. This fact was not  
discovered by the WBN construction forces until the Unit 1 system hydrostatic  
tests of the systems in which the penetration assemblies had been installed  
were completed. Therefore, although the system pressure tests were performed  
and the penetration assemblies were exposed to the required ASME Section III  
hydrostatic test pressure, no provisions were made to examine the vendor welds  
during this test. Nonconformance Report (NCR) 5609 was initiated to document  
this condition.

NCR 5609 was originally dispositioned use-as-is. It was subsequently decided  
that the NCR 5609 disposition did not result in a request for an exemption  
from our commitments to ASME Section III. Condition Adverse to Quality Report  
(CAQR) WBP 870310 was issued to change the disposition of NCR 5609 to require  
that the hidden vendor welds on the penetration assemblies be brought to the  
ASME Section III examination pressure and visually examined for leakage in  
accordance with ASME Section III. It has now been determined that this  
disposition will, as stated in 10 CFR 50.55a(a)(3), "result in hardship and  
unusual difficulties without a compensating increase in the quality and  
safety" of Watts Bar.

TVA wishes to request relief pursuant to 10 CFR 50.55a(a)(3) to apply an  
alternative to the ASME Section III requirements for visual examinations  
during hydrostatic testing for the vendor welds that are not accessible and  
were not examined during the original field hydrostatic test. TVA proposes to  
accept the original use-as-is disposition which provides an acceptable level  
of safety.

8911290094 891121  
PDR ADDOCK 05000390  
A PIC

D030  
11

U.S. Nuclear Regulatory Commission

**NOV 21 1989**

In order to make the welds in question accessible for examination, as proposed in the disposition to CAQR WBP 870310, it will require cutting several "windows" in the guard pipe protecting the process pipe. Experience gained during similar work on Unit 2 indicates that this effort will be very difficult, especially replacing the "windows." Even with the "windows" cut in the guard pipe, some of the unexamined welds will only be accessible for examination by using remote viewing devices such as mirrors or fiberoptics. This type of examination is difficult to execute to ensure both completeness and accurate interpretation.

The penetration assemblies for which relief is being requested are tabulated in the enclosed Table 1 along with various information about the assemblies. Sketches depicting the physical configuration of the various types of penetration assemblies are included as Enclosure 1 following Table 1. TVA believes that a use-as-is disposition of these welds is technically acceptable for the following reasons:

1. The circumferential welds in question were fabricated and inspected in accordance with ASME III, Division 1, with Authorized Nuclear Inspector (ANI) involvement at the manufacturer.
2. A hydrostatic or pneumatic test to ASME III, NC-6000 was performed on the field welds installing the penetration assemblies in the piping system. Each of these was visually examined in accordance with ASME Section III and accepted.
3. Pressure boundary pipe containing longitudinal weld seams used by the manufacturer to fabricate the penetration assemblies was hydrostatically tested by the material manufacturer in accordance with the ASME material specification. Therefore, all longitudinal welds were pressure tested and inspected as required by the ASME code.
4. Many of the vendor welds not visually inspected during field hydrostatic testing are so close to TVA field welds which were inspected that it is reasonable to assume leakage from these welds would have been detected during the inspection of field welds. The distance from the field weld to the unexamined vendor weld is listed in Table 1.
5. The circumferential welds in question were volumetrically examined (radiography) and accepted by the vendor in accordance with ASME Section III, Class 2 requirements. These radiographs were subsequently reviewed and accepted by TVA.
6. The systems involved include the Safety Injection, Residual Heat Removal, Containment Spray, and Auxiliary Feedwater Systems. These systems are safety-related and are necessary to achieve and maintain cold shutdown. Also affected are the relief valve discharge line from the Safety Injection System which carries relief valve discharge back to the Reactor Coolant Drain Tank and is classified as part of the Reactor Coolant System, and the reactor coolant pump seal water injection lines. The other systems involved (main steam, ventilation, control air,

U.S. Nuclear Regulatory Commission

NOV 21 1989

demineralized water, ice condensor, chemical and volume control, waste disposal, fuel handling, primary makeup water, and spares originally associated with the upper head injection system) either isolate or are already isolated during accidents. The likelihood of compromising the safe function of any of the affected systems by accepting this condition is believed to be minimal for the following reasons.

- a. As stated previously, all penetrations involved were part of a system test and therefore have been to hydrostatic or pneumatic test pressure. If a discontinuity large enough to cause total loss of function existed and was of such a nature as to cause failure during operation, it would have failed during testing whether or not the visual examination was performed.
- b. As stated previously, all involved penetrations were radiographed. It is extremely unlikely that a defect which would have caused leakage during testing could exist and not be visible on the RT film. Therefore, since the film was acceptable, it is extremely unlikely that such a defect exists.

For certain penetration assemblies (Types I and II) a spool piece was attached to the outboard side of the flued head by the vendor in order to meet overall dimensional requirements for the design. These welds will be examined during hydrostatic testing currently scheduled for the affected systems. Penetration assemblies having an outboard spool piece are identified in Table 1.

Upon receiving approval for these exceptions, TVA will revise the Final Safety Analysis Report (FSAR) and CAQR WBP 870310 to document deviation from ASME Section III for visual examinations of welds during hydrostatic testing and to provide justification for acceptance of this condition.

Enclosure 2 lists the new commitments made in this report.

If there are any questions, please telephone G. R. Ashley at (615) 365-8527.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*Ralph H. Shell*  
Manager, Nuclear Licensing  
and Regulatory Affairs

Enclosures  
cc: See page 4

U.S. Nuclear Regulatory Commission

**NOV 21 1989**

cc (Enclosures):

Ms. S. C. Black, Assistant Director  
for Projects  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852

Mr. B. A. Wilson, Assistant Director  
for Inspection Programs  
TVA Projects Division  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

NRC Resident Inspector  
Watts Bar Nuclear Plant  
P.O. Box 700  
Spring City, Tennessee 37381

TABLE 1

Penetration Number	System	Type	TVA Class	Distance to Inboard TVA Weld
1K-14	74	XI	B	5'-7"
1K-15	74	XI	B	5'-7"
1K-16	72	XI	B	5'-7"
1K-17	72	XI	B	5'-7"
1X-8A ***	03A	II	B	10'-7" & 24'-3"
1X-8B ***	03A	II	B	24'-3"
1X-8C ***	03A	II	B	24'-3"
1X-8D ***	03A	II	B	10'-7" & 24'-3"
1X-12A ***	03A	II	B	23'-6"
1X-12B ***	03A	II	B	23'-6"
1X-12C ***	03A	II	B	23'-6"
1X-12D ***	03A	II	B	23'-6"
1X-13A ***	01A	I	B	10'-6" & 24'-6"
1X-13B ***	01A	I	B	10'-6" & 24'-6"
1X-13C ***	01A	I	B	10'-6" & 24'-6"
1X-13D ***	01A	I	B	10'-6" & 24'-6"
1X-14A	01B	IV	B	3'-7"
1X-14B	01B	IV	B	3'-7"
1X-14C	01B	IV	B	3'-7"
1X-14D	01B	IV	B	3'-7"
1X-15	62	IV	B	3'-7 5/8"
1X-16	62	VII	B	1'-4"
1X-17	63	III	B	10'-1"
1X-20A	63	V	B	3'-5"
1X-20B	63	V	B	3'-5"
1X-21	63	V	B	3'-6 3/4"
1X-22	63	V	B	3'-7"
1X-24	68	V	B	3'-7 1/4"
1X-30	63	IV	B	4'-8"
1X-32	63	V	B	3'-6 3/4"
1X-33	63	V	B	3'-6 3/4"
1X-34 *	32	VI	B	1'-4 1/2"
1X-40A	03B	VIII	B	0'-9"
1X-40B	03B	VIII	B	0'-9"
1X-41	77	VI	B	1'-4 1/2"
1X-42	81	VII	B	1'-4 1/2"
1X-43A	62	VI	B	1'-4 1/2"
1X-43B	62	VI	B	1'-4 1/2"
1X-43C	62	VI	B	1'-4 1/2"
1X-43D	62	VI	B	1'-4 1/2"
1X-44	62	VII	B	1'-3"
1X-45	77	IV	B	3'-8"
1X-46	77	V	B	3'-7 1/2"
1X-47A	61	V	B	3'-7 1/2"
1X-47B	61	V	B	3'-7 1/2"
1X-48A	72	IX	B	2'-11"
1X-48B	72	IX	B	2'-11"
1X-49A	72	IX	B	3'-0"
1X-49B	72	IX	B	3'-0"

TABLE 1 (continued)




Penetration Number	System	Type	TVA Class	Distance to Inboard TVA Weld
1X-77	59	VI	B	1'-4 1/2"
1X-81	77	IV	B	3'-8"
1X-82	78	VII	B	1'-4"
1X-83	78	VII	B	1'-4"
1X-90 *	32	VI	B	1'-4 1/2"
1X-91 *	32	VI	B	1'-4"
1X-97 *	30	VI	B	1'-4"
1X-107	74	III	B	10'-6"
1X-108 **	87	XIV	B	2'-5"
1X-109 **	87	XIV	B	2'-5"

\* These penetration assemblies were pneumatically tested rather than hydrostatically tested. The requested relief is for examination during pneumatic testing rather than hydrostatic testing.





\*\* These penetration assemblies have been converted to spares, however, we are requesting relief in the event that we may use them in the future.

\*\*\* These penetration assemblies have a spool welded to the outboard side of the flued head which will be examined during hydrostatic testing.

ENCLOSURE 1



# ENCLOSURE 1





ENCLOSURE 2

LIST OF COMMITMENTS

1. TVA will revise the Final Safety Analysis Report (FSAR) to document deviation from ASME Section III for visual examinations of welds during hydrostatic testing.
2. Spool piece welds on the outboard of Type I and II penetration assemblies will be examined during hydrostatic testing.
3. Upon receiving approval of these exemptions, TVA will revise Condition Adverse to Quality Report (CAQR) WBP 870310 to document these exceptions.