

**Southern Nuclear  
Operating Company, Inc.**  
Post Office Box 1295  
Birmingham, Alabama 35201-1295  
Tel 205.992.5000



December 20, 2007

Docket Nos.: 50-424  
50-425

NL-07-2332

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555-0001

**Vogtle Electric Generating Plant - Units 1 and 2  
Completion of Corrective Actions for Generic Letter 96-06,  
Assurance of Equipment Operability and  
Containment Integrity During Design Basis Accident Conditions**

Ladies and Gentlemen:

By letter dated December 22, 2004, the Nuclear Regulatory Commission (NRC) staff notified Southern Nuclear Operating Company (SNC) that the NRC staff's review of the SNC response to Generic Letter 96-06 for the Vogtle Electric Generating Plant (VEGP) was complete. For the purpose of documentation, the NRC staff requested that SNC provide a brief summary of any additional modifications that were found to be necessary, including the current status of implementation. The additional modifications and status of implementation was provided by SNC in a letter dated January 26, 2005. This letter stated that SNC had determined that two pipe supports on VEGP Unit 2 require modification. The pipe support modifications were planned for implementation in the spring of 2007. No additional modifications were required for VEGP Unit 1. SNC stated they would notify the NRC staff when the modifications associated with Generic Letter 96-06 for Unit 2 have been completed.

This letter serves to notify the NRC that the field work for the modifications described above is complete. All corrective actions addressing Generic Letter 96-06 are complete.

This letter contains no NRC commitments. If you have any questions, please advise.

Sincerely,

A handwritten signature in black ink, appearing to read "B. J. George". The signature is written in a cursive, flowing style.

B. J. George  
Manager, Nuclear Licensing

BJG/DWM/daj

cc: Southern Nuclear Operating Company  
Mr. J. T. Gasser, Executive Vice President  
Mr. T. E. Tynan, Vice President – Vogtle  
Mr. D. H. Jones, Vice President – Engineering  
RType: CVC7000

U. S. Nuclear Regulatory Commission  
Mr. V. M. McCree, Acting Regional Administrator  
Mr. S. P. Lingam, NRR Project Manager – Vogtle  
Mr. G. J. McCoy, Senior Resident Inspector – Vogtle