

Central File

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

October 20, 1980 9:49

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

AQ/2

Dear Mr. O'Reilly:

OFFICE OF INSPECTION AND ENFORCEMENT BULLETIN 79-04 - RII:JPO
50-390, 50-391 AND NCR MEB 79-20 - WATTS BAR NUCLEAR PLANT

In response to your March 30, 1979, letter which transmitted OIE Bulletin 79-04 on Velan valves, we are enclosing the final results of our investigation for Watts Bar Nuclear Plant. TVA reported the Velan valve problem at Watts Bar to NRC-OIE Region II Inspector M. Thomas on May 22, 1979 (NCR MEB 79-20), in accordance with 10 CFR 50.55(e). The enclosed information completes TVA's response to this NCR for Watts Bar Nuclear Plant. Interim reports on the bulletin and/or the NCR were submitted on March 31, May 31, June 22, November 9, and November 13, 1979, and February 27, May 1, and August 6, 1980.

If you have any questions, please get in touch with D. L. Lambert at FTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L M Mills by [Signature]
L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosure

cc: Mr. Victor Stello, Director (Enclosure)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8011110699

Q

ENCLOSURE

FINAL RESPONSE TO IE BULLETIN 79-04 AND NCR MEB 79-20
FOR WATTS BAR NUCLEAR PLANT
INCORRECT VELAN VALVE WEIGHTS USED IN SEISMIC ANALYSIS

The following is a response to each item as listed under "Action To Be Taken by Licensees and Permit Holders" for the subject bulletin.

1. Chemical and Volume Control System (CVCS)
Reactor Coolant Auxiliary and Miscellaneous System (RCS)
Table 1 provides a summary of the Velan valves installed in Watts Bar with pertinent information.
2. The 12 Velan valves (six in each unit) shown in table 1 are those installed in seismic category I systems at the Watts Bar Nuclear Plant. The values of valve weight shown in the table 1 column "Design Weight" are those that were used in the original design of the piping systems and their supports. The corrected valve weights shown in the table 1 column "Actual Weights" are for those Velan valves installed in Watts Bar. These data were obtained from Westinghouse on May 15, 1979.
- 3-5. The following summarizes what was done to review piping and supports at Watts Bar using the corrected valve weights.

Chemical and Volume Control System (CVCS)

Table 1 shows a total of five Velan valves in each unit in this system.

Piping problems containing these valves were reanalyzed utilizing the computer program TPIPE. Isometric drawings of these systems are attached, and the Velan valves are circled. Changes to pipe stresses were found to be minimal and still within the allowable limits. New support loads were tabulated and all supports were reevaluated. The adequacy of all supports were reevaluated. The adequacy of all supports was reaffirmed by the following methods:

1. For standard mechanical supports, the revised support loads were compared with the allowable loads from the manufacturer's catalog.
2. For noncatalog item supports, the revised support loads were compared with allowable loads based on allowable stresses.

Table 2 provides a comparison of old and new support design loads. Design loads changes and minor revisions to supports were required by these reanalyses.

Reactor Coolant Auxiliary and Miscellaneous (RCS)

Table 1 shows a total of two valves (one in each unit) in this system.

Piping problems containing these valves were reanalyzed utilizing the computer program TPIPE. An isometric drawing of this system is attached, and the Velan valve circled in red. Changes to the pipe stresses were found to be minimal and still within the allowable limits. Other minor design changes were incorporated into this reanalysis. New support loads were tabulated, and all supports were reevaluated. The adequacy of all supports was reaffirmed by the above method.

Table 2 provides a comparison of old and new support design loads. Design load changes and minor revisions to supports were required by this reanalysis.

TPIPE Computer Program

The piping was analyzed for the deadweight, thermal, and seismic conditions using the TPIPE computer program. (A description of the TPIPE computer program is presented in the Bellefonte Nuclear Plant FSAR, section 3.9.1.2.) Stress combinations were computed for ASME section III, equations 8, 9U, 9E, 9F, 10, and 11. These combinations were then compared to the appropriate allowable stresses. The output of the TPIPE computer program provides a summary of stresses and their allowable limits for the reanalyzed piping.

Summary

Our investigation and reanalysis indicated that the corrected valve weights do not create any overstressing in pipes because of the conservation in the original design. Design documentation of load changes and minor design revisions to some supports which were marginal have been completed. All construction revisions will be made in the field before initial criticality.

TABLE 1
SUMMARY OF VELAN VALVES INSTALLED AT WATTS BAR

Plant	Valve Tag No.	Location No. (Westinghouse)	System	Design Wt. (lb)	Actual Wt. (lb)	Valve size (in)
WBN	3T78	1-,2-8383	CVCS	180	285	3
WBN	3T78	1-,2-8387A	CVCS	180	285	3
WBN	3T78	1-,2-8387B	CVCS	180	285	3
WBN	3T78	1-,2-8388	CVCS	180	285	3
WBN	3T78	1-,2-8403	CVCS	180	285	3
WBN	3T88	1-,2-8085	RCS	180	285	3

All corrected valve weights were obtained on May 15, 1979, from Westinghouse.

TABLE 2
COMPARISON OF OLD AND NEW SUPPORT DESIGN LOADS

Valve Location No.	Valve MFG No.	System	Problem/ D.P. No.	Direction	Maximum Load (Lb.)		Support Type	Support Dwg. No.	Support Fabricator
					New	Old			
1-8383	E73-034R	CVCS	47W406-06 30A	Lateral	80	80	Rigid	62-1CVC-R183	BP, TVA
				Vertical	115	120	Spring	62-1CVC-V184	
			516	Vertical	59	60	Spring	62-1CVC-V192	
				Lateral	80	80	Rigid	62-1CVC-R191	
			317	Vertical	600	600	Rigid	62-1CVC-R190	
				323	Lateral	60	30	Rigid	
			543		Vertical	400	400	Rigid	
					Vertical	102	80	Spring	
				Lateral	200	200	Rigid	62-1CVC-R198	
			540	Lateral	130	100	Rigid	62-1CVC-R189	
			903	Vertical	103	60	Spring	62-1CVC-V187	
			90Q	Vertical	222	50	Spring	62-1CVC-V188	
			906	Vertical	172	180	Spring	62-1CVC-V195	
90Z	Vertical	108	130	Spring	62-1CVC-V196				
1-8387A	E73-034R	CVCS	47W406-205	Vertical	912	850	Spring	62-1CVC-V148	
				Lateral	600	600	Rigid	62-1CVC-R149	
			105	Vertical	600	600	Rigid		
				Lateral	400	400	Rigid	62-1CVC-R147	
				Vertical	480	400	Rigid		
1-8387B	E73-034R	CVCS	47W406-205	Lateral	400	400	Rigid	62-1CVC-R141	
				Lateral	400	400	Rigid	62-1CVC-R142	
			Vertical	600	600	Rigid			
1-8388	E73-034R	CVCS	47W406-205	Lateral	560	560	Rigid	62-1CVC-R175	
				Vertical	550	420	Rigid	62-1CVC-R176	
			638	Vertical	11	14	Spring	62-1CVC-V179	
				Y259	Vertical	310	0	Spring	47A406-1-3
			26B	Lateral	520	520	Rigid	47A406-1-1	

TABLE 2

Valve Location No.	Valve MFG No.	System	Problem/D.P. No.	Direction	Maximum Load (Lb.)		Support Type	Support Dwg. No.	Support Fabricator				
					New	Old							
1-8403	E73-034R	CVCS	152	Vertical	337	600	Rigid	62-1CVC-257	BP, TVA				
				162	Lateral	97	400	Rigid		62-1CVC-R258			
				164	Vertical	249	400	Rigid					
				176	Vertical	524	600	Rigid		62-1CVC-R259			
					Vertical	362	600	Rigid		62-1CVC-R260			
					Lateral	396	800	Rigid		62-1CVC-R261			
				179	Vertical	194	400	Rigid		62-1CVC-R262			
					Lateral	591	3000	Rigid		62-1CVC-R263			
				184	Lateral	380	800	Rigid		62-1CVC-R264			
					Vertical	158	200	Rigid					
		186	Vertical	492	800	Rigid	62-1CVC-R265	BP, TVA					
1-8085	E73-034R	RCS	-08-10 EDS	5A	Vertical	905	1032	Spring	1-62A-290	EDS, TVA			
				8	Lateral	1284	0	Rigid	1-62A-291				
				9	Lateral	891	887	Rigid					
				12	Lateral	723	493	Snubber	1-62A-292				
				12	Lateral	1388	952	Rigid	1-62A-293				
				14	Vertical	568	316	Snubber	1-62A-294				
				17H	Lateral	1467	811	Snubber	1-62A-295				
					Vertical	1247	1146	Rigid					
													EDS, TVA
2-8383	E73-034B	CVCS	30A	Lateral	80	80	Rigid	62-2CVC-R183	BP, TVA				
				Vertical	115	120	Spring	62-2CVC-V184					
				516	Vertical	59	60	Spring		62-2CVC-V192			
					Lateral	80	80	Rigid		62-2CVC-R191			
				317	Vertical	600	600	Rigid		62-2CVC-R190			
				323	Lateral	60	30	Rigid		62-2CVC-R201			
					Vertical	400	400	Rigid					
				543	Vertical	102	80	Spring		62-2CVC-V199			
	Lateral	200	200	Rigid	62-2CVC-R198								

TABLE 2

Valve Location No.	Valve MFG No.	System	Problem/D.P. No.	Direction	Maximum Load (Lb.)		Support Type	Support Dwg. No.	Support Fabricator
					New	Old			
2-8383 (cont.)			540	Lateral	130	100	Rigid	62-2CVC-R189	BP, TVA
			903	Vertical	103	60	Spring	62-2CVC-V187	
			90Q	Vertical	222	50	Spring	62-2CVC-V188	
			906	Vertical	172	180	Spring	62-2CVC-V195	
			90Z	Vertical	108	130	Spring	62-2CVC-V196	
2-8387A	E73-034R	CVCS	10	Vertical	912	850	Spring	62-2CVC-V148	
			14	Lateral	600	600	Rigid	62-2CVC-R149	
			105	Vertical	600	600	Rigid	62-2CVC-R147	
				Lateral	400	400	Rigid		
				Vertical	480	400	Rigid		
2-8387B	E73-034R	CVCS	83	Lateral	400	400	Rigid	62-2CVC-R141	
			89	Lateral	400	400	Rigid	62-2CVC-R142	
				Vertical	600	600	Rigid		
2-8388	E73-034R	CVCS	246	Lateral	560	560	Rigid	62-2CVC-R175	BP, TVA TVA TVA TVA
				Vertical	550	420	Rigid	62-2CVC-R176	
			638	Vertical	11	14	Spring	62-2CVC-V179	
			Y259	Vertical	310	0	Spring	47A406-4-3	
			26B	Lateral	520	520	Rigid	47A406-4-1	
			249	Vertical	120	100	Rigid	47A406-4-2	
				Lateral	280	280	Rigid	47A435-25-1	
			805	Lateral	300	250	Rigid		
2-8403	E73-034R	CVCS	152	Vertical	337	600	Rigid	62-2CVC-257	BP, TVA
			162	Lateral	97	400	Rigid	62-2CVC-R258	
				Vertical	249	400	Rigid	62-2CVC-R259	
			164	Vertical	524	600	Rigid		
			176	Vertical	362	600	Rigid	62-2CVC-R260	
				Lateral	396	800	Rigid	62-2CVC-R261	
				Vertical	194	400	Rigid	62-2CVC-R262	
				Lateral	591	3000	Rigid	62-2CVC-R263	

TABLE 2

Valve Location No.	Valve MFG No.	System	Problem/ D.P. No.	Direction	Maximum Load (Lb.)		Support Type	Support Dwg. No.	Support Fabricator
					New	Old			
2-8403 (cont.)	E73-034R	CVCS/ RCS	184	Lateral	380	800	Rigid	62-2CVC-R262	BP, TVA
				Vertical	158	200	Rigid		
186			Vertical	492	800	Rigid	62-2CVC-R265	BP, TVA	
-08-10			Vertical	905	1032	Spring	2-62A-290	EDS, TVA	
EDS			Lateral	1284	0	Rigid	2-62A-291		
5A			Lateral	891	887	Rigid			
8			Lateral	723	493	Snubber	2-62A-292		
9			Lateral	1388	952	Rigid	2-62A-293		
12			Vertical	568	316	Snubber	2-62A-294		
12			Lateral	1467	811	Snubber	2-62A-295		
14	Vertical	1247	1146	Rigid		EDS, TVA			
17H									