

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

APR 25 1989

WBRD-50-390/86-47
WBRD-50-391/86-44

10 CFR 50.55(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of)
Tennessee Valley Authority) Docket Nos. 50-390
50-391

WATTS BAR NUCLEAR PLANT (WBN) UNITS 1 AND 2 - REDUNDANT OVERCURRENT PROTECTION FOR ELECTRICAL PENETRATION NO. 36 - WBRD-50-390/86-47 AND WBRD-50-391/86-44 - SUPPLEMENTAL FINAL REPORT

The subject deficiency was initially reported to NRC Region II Inspector Bob Carroll on April 15, 1986, in accordance with 10 CFR 50.55(e) as Significant Condition Reports (SCRs) WBN EEB 8630 and 8631. Our interim and final reports were submitted on May 15 and October 17, 1986.

In our final report it was stated that, as part of the corrective action for unit 1, necessary modification to complete the installation of fuses and wiring had been completed. This statement was made in error; in that, these modifications have not been completed. The required modifications are currently scheduled to be completed before fuel load of unit 1.

The enclosure lists the commitment made in this report.

If there are any questions, please telephone G. R. Ashley at (615) 365-8527.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


C. H. Fox, Jr., Vice President and
Nuclear Technical Director

Enclosure
cc: See page 2

8905030504 890425
FDR ADCK 05000390
S PDC

IEP
||

U.S. Nuclear Regulatory Commission

APR 25 1989

cc (Enclosure):

Ms. S. C. Black, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Ms. L. J. Watson, Acting Assistant Director
for Inspection Programs
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Record Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

U.S. Nuclear Regulatory Commission
Watts Bar Resident Inspector
P.O. Box 700
Spring City, Tennessee 37381

ENCLOSURE

LIST OF COMMITMENTS

The required modifications will be completed before fuel load of unit 1.