



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

William J. Museler
Site Vice President
Watts Bar Nuclear Plant

OCT 05 1992

WBRD-50-390/91-29
WBRD-50-391/91-29

10 CFR 50.55(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

WATTS BAR NUCLEAR PLANT (WBN) UNITS 1 AND 2 - PRESSURE LOCKING AND THERMAL BINDING OF GATE VALVES - WBRD-50-390/91-29 AND WBRD-50-391/91-29 - SCHEDULE REVISION

On November 13, 1991, TVA submitted a final report to NRC for the subject deficiency. The deficiency involved applicability of INPO SOER 84-7, "Pressure Locking and Thermal Binding of Gate Valves," to WBN Units 1 and 2. Unit 1 corrective actions included a commitment to perform valve specific evaluations, issue any required design change notices, and implement any required field modifications by September 28, 1992.

The Unit 1 valve specific evaluations were completed and Design Change Notice M-18044-A was issued on March 26, 1992. The design change notice called for field modifications to five valves in System 63, "Safety Injection System," and four valves in System 74, "Residual Heat Removal System."

140047
9210150042 921005
PDR ADCK 05000390
S PDR

JE27 1/0

OCT 05 1992

The purpose of this letter is to modify the date for implementing field changes to the affected Unit 1 gate valves from September 28, 1992 to prior to performing preoperational testing for Systems 63 and 74. This change was discussed with the Region II staff on September 28, 1992.

If there are any questions, please telephone P. L. Pace at (615) 365-1824.

Very truly yours,



William J. Museler

cc: INPO Record Center
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

NRC Resident Inspector
Watts Bar Nuclear Plant
P.O. Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323