



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

William J. Musser
Site Area President
Watts Bar Nuclear Plant

OCT 08 1992

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

WATTS BAR NUCLEAR PLANT (WBN) - CABLE PULL CALCULATION DEFICIENCIES -
SIGNIFICANT CORRECTIVE ACTION REPORT WBSA920041 - SECOND INTERIM REPORT

The purpose of this letter is notify the NRC of the delay in completing the substantial safety hazard evaluation of the condition identified by Significant Corrective Action Report (SCAR) WBSA920041.

TVA notified the NRC in a letter dated August 3, 1992 of a hardware safety impact review being conducted for the identified condition. The review progress to date is as follows: (1) The nineteen cables specifically identified in the subject SCAR have been evaluated and found to be acceptable. (2) Cable pull calculations for cables in 62 of 71 conduits identified in the extent of condition review were reviewed and found to be acceptable. The remaining items to be performed are as follows: (1) Further evaluation of the calculations for the remaining nine conduits. (2) An evaluation of five workplans in which missing cable pull calculations were identified during the extent of condition review.

The final substantial safety hazard evaluation for the subject deficiency should be completed by November 30, 1992. Appropriate NRC notifications required by 10 CFR 50.55(e) will be made at that time, if necessary.

200015

9210210017 921008
PDR ADDCK 05000390
S PDR

Handwritten signature/initials

U.S. Nuclear Regulatory Commission
Page 2

OCT 08 1992

If you have any questions, please telephone Paul Pace at (615) 365-1824.

Very truly yours,



William J. Museler *for*

cc: NRC Resident Inspector
Watts Bar Nuclear Plant
P.O. Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323