



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

William J. Museler
Site Vice President
Watts Bar Nuclear Plant

OCT 27 1992

CDR-50-390/91-36
CDR-50-391/91-36

10 CFR 50.55(e)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of)
Tennessee Valley Authority) Docket Nos. 50-390
50-391

WATTS BAR NUCLEAR PLANT (WBN) UNITS 1 AND 2 - POTENTIAL COMMON MODE FAILURE
OF VITAL CONTROL POWER SYSTEM SUPPLIES - WBRD-50-390/91-36 AND WBRD-50-
391/91-36 - COMMITMENT CLARIFICATION

The purpose of this letter is to provide clarification of a commitment made to NRC related to the subject construction deficiency report. The subject deficiency was initially reported to NRC Region II on August 29, 1991, in accordance with 10CFR50.55(e) as Significant Corrective Action Report (SCAR) WBSA910246. TVA submitted an interim report and a final report to NRC on September 27, 1991, and December 16, 1991, respectively.

In the final report to NRC, TVA stated, "TVA currently plans to install supply and return ducting from the 1/2 A-A 480 Volt Board Rooms to the 1/2 B-B 480 Volt Board Rooms." To provide clarification, TVA is changing this sentence to read, "TVA currently plans to add cooling from the "A" Train HVAC System to the "B" Train 480 Volt Board Rooms and from the "B" Train HVAC System to the "A" Train 480 Volt Board Rooms."

If there are any questions, please telephone P. L. Pace at (615) 365-1824.

Very truly yours,

William J. Museler

200800 Page 2
9211040030 921027
PDR ADOCK 05000390
S PDR

JE 27 / 10

U.S. Nuclear Regulatory Commission
Page 2

OCT 27 1992

cc: INPO Record Center
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

NRC Resident Inspector
Watts Bar Nuclear Plant
P.O. Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323