



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

March 19, 1985

Docket Nos: 50-390
and 50-391


APPLICANT: Tennessee Valley Authority
FACILITY: Watts Bar Nuclear Plant, Units 1 and 2
SUBJECT: SUMMARY OF MEETING TO DISCUSS FIRE PROTECTION CONCERNS

On March 7, 1985, representatives of the staff met to discuss fire protection concerns for the Watts Bar Nuclear Plant, Units 1 and 2. Attached is a list of attendees.

The staff expressed its concerns regarding the need to have the T^{cold} indication in the auxiliary control room (ACR). After discussing the advantages and disadvantages of using T^{saturation} in lieu of T^{cold} in the ACR, TVA proposed to provide justification that T^{saturation} could be used in the ACR satisfactorily to take the plant to cold shutdown. TVA was requested to consider previous tests, real events, steam generator stratification during low steaming rates, operator training and procedures.


With regard to the other indicators in the ACR for which TVA has requested deviations to Appendix R, the applicant was requested to provide verification that other instrumentation to be used in lieu of the steam generator wide range, RWST tank level, and CST tank level is directly isolable from a fire in the control room.

With regard to the concerns over the Ruskin Fire Damper issue, TVA was requested to state their position in writing.


Thomas J. Kenyon, Project Manager
Licensing Branch No. 4
Division of Licensing

Attachment:
As stated

cc: See next page

DESIGNATED ORIGINAL
Certified By 

8504010210 850319
PDR ADOCK 05000390
F PDR

WATTS BAR

Mr. H. G. Parris
Manager of Power
Tennessee Valley Authority
500A Chestnut Street, Tower II
Chattanooga, Tennessee 37401

cc: Herbert S. Sanger, Jr., Esq.
General Counsel
Tennessee Valley Authority
400 West Summit Hill Drive, E 11B 33
Knoxville, Tennessee 37902

Mr. D. Checchet
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. Ralph Shell
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. Donald L. Williams, Jr.
Tennessee Valley Authority
400 West Summit Hill Drive, W10B85
Knoxville, Tennessee 37902

Resident Inspector/Watts Bar NPS
c/o U.S. Nuclear Regulatory
Commission
Rt. 2 - Box 300
Spring City, Tennessee 37381

Ms. K. Mali
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

J. Nelson Grace, Regional Administrator
U.S. Nuclear Regulatory Commission,
Region II
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Mr. David Ellis
Tennessee Valley Authority
400 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Mr. Mark J. Burzynski
Tennessee Valley Authority
Watts Bar NP
P.O. Box 800
Spring City, Tennessee 37381

Attachment

FIRE PROTECTION MEETING

ATTENDEES

MARCH 7, 1985

<u>NAME</u>	<u>ORGANIZATION</u>
T. J. Kenyon	DL/LB #4
Jerry Wilson	ASB
O. D. Parr	ASB, Branch Chief
Berkely Buchanan	TVA
Gary L. Terpstra	TVA
Ralph E. Thompson	TVA
K. Mali	TVA
E. G. Adensam	NRC/DL/ LB #4
Peter Hearn	NRC/DSI/ASB
L. B. Marsh	NRC/DSI/RSB
D. Kubicki	NRC/ChEB