Docket Nos.: 50-390 and 50-391

OCT 2 3 1986

APPLICANT: Tennessee Valley Authority

FACILITY: Watts Bar Nuclear Plant, Units 1 and 2

SUBJECT: SUMMARY MEETING TO DISCUSS RTD BYPASS SYSTEM REMOVAL AT THE WATTS BAR NUCLEAR PLANT, UNITS 1 and 2

On October 14, 1986, representatives of NRC, TVA, and Westinghouse met to discuss TVA's proposal to remove the RTD bypass system at Watts Bar and replace it with a thermowell mounted RTD in conjunction with the Eagle 21 digital protection system. Enclosure (1) is a list of attendees and Enclosure (2) is a copy of TVA's presentation.

The meeting began with an overview of the planned modification of TVA and a discussion of the proposed licensing schedule. Westinghouse then presented a detailed plan of the mechanical and electronic modifications to the plant, and a discussion of the validation and verification program for the new system. TVA closed the meeting requesting feedback on the proposed licensing schedule presented during the meeting.

During a subsequent telecon with TVA, the staff stated that, if TVA meets their submittal schedule and provides full and complete responses in their submittals, the staff will make every attempt to meet the proposed licensing schedule. The staff reminded TVA that, although TVA issues have a high priority within the agency, Sequoyah reviews take precedence over Watts Bar. The staff stated it was concerned that the review of Sequoyah restart matters (scheduled during the same time frame of the RTD Bypass Modification Review) may impact TVA's submittal and NRC's review schedule of the modification. However, the staff believes that its review will not be the critical path item to implementation of this modification provided TVA meets their proposed schedule.

151

8610280240 861023 PDR ADOCK 05000390 A PDR T.J. Kenyon, Project Manager PWR Project Directorate #4 Division of PWR Licensing-A

cc:

w/o encl	
F. Rosa	J. Knight
S. Weiss	J. Wilson
J. Mauck	F. Burrows
P. Gill	H. Balujian
M. Branch	Ū

\*SEE PREVIOUS CONCURRENCE

Enclosure: As stated

PWR##/	*EICSB/DPWR-A
TKeryon rad	FRosa
10/ 1/86	10/ /86
$\mathcal{N}^{7}$	

PWR#4/DPWR-A BJYoungblood /86

Mr. C. C. Mason Tennessee Valley Authority

Watts Bar Nuclear Plant

### cc:

Mr. L. Tomasic Westinghouse Electric Corporation P.O. Box 355 Pittsburgh, Pennsylvania 15230

R. L. Gridley Tennessee Valley Authority 5N157B Lookout Place Chattanooga, Tennessee 37402-2801

J.A. Kirkebo ATTN: D.L. Williams Tennessee Valley Authority 400 West Summit Hill Drive, W12 A12 Knoxville, Tennessee 37902

Resident Inspector/Watts Bar NPS c/o U.S. Nuclear Regulatory Commission Rt. 2 - Box 700 Spring City, Tennessee 37381

Regional Administrator, Region II U.S. Nuclear Regulatory Commission, 101 Marietta Street, N.W., Suite 2900 Atlanta, Georgia 30323

J. A. McDonald Tennessee Valley Authority Watts Bar Nuclear Plant P.O. Box 800 Spring City, Tennessee 37381

George Toto Tennessee Valley Authority Watts Bar Nuclear Plant P.O. Box 800 Spring City, Tennessee 37381

### Enclosure (1)

### RTD Bypass Removal/Eagle 21 Modification

#### Name

### Organization

### Title

**TVA-WBNP** TVA-WBNP. NRC-PAD#4 NRC-PAD#4 NRC-EICSB NRC-PWR-A NRC-PWR-A Westinghouse I&C TVA-WBN NRC-PWR-A TVA-WBND NRC-PWR-A-RSB NRC/EICSB Westinghouse Project Manager TVA-WBND TVA-WBNP I&C **TVA-WBNP** Westinghouse NTSD/I&CS Westinghouse I&C Systems Licensing Westinghouse Nuclear Safety Engineer Westinghouse I&C Systems Licensing Westinghouse RTDBE Tech Lead TVA-WBNP Westinghouse Nuclear Safety NRC-EICSB NRC Resident Inspector

Reg. Lic. Manager Manager of Projects Director Watts Bar Project Mgr Chief Section Leader Elec. Engineer Senior Engineer Consultant Elec. Engineer Plant Manager Nuclear Engineer EICSB Section Leader

Mechanical Engineer Instr. Engineer RTDBE Project Manager I&CAE Manager Elec. Engineer

#### Elec. Engineer

Senior Engineer License Engineer TVA Lic. Engineer Elec. Engineer Watts Bar

### MEETING SUMMARY DISTRIBUTION

\* With enclosure

\*Docket File 🗲 NRC PDR L PDR NSIC PRC System PWR#4 Reading File TKenyon M. Duncan OGC J. Partlow E. Jordan B. Grimes

ACRS (10)

OCT 2 3 1986

- NRC Participants B.J. Youngblood
- T. Kenyon F. Rosa
- J. Knight
- J. Mauck
- F. Burrows
- H. Balukjian S. Weiss
- M. Branch

### bcc: Licensee & Service List

ENCLOSURE (2)

## MEETING WITH THE NRC STAFF OCTOBER 14, 1986 BETHESDA, MD.

## RTD BYPASS REMOVAL AND EAGLE 21 ELECTRONICS MODIFICATION TO WATTS BAR UNIT 1



### EXECUTIVE SUMMARY

#### WATTS BAR RTD BYPASS ELIMINATION/EAGLE 21 UPGRADE

#### INTRODUCTION

Improved electronics technology and accumulated operating plant experience has led to the development of a new design to replace the RID Bypass system for Reactor Coolant System (RCS) temperatures. The benefits attributable to the RID Bypass Elimination Modification fall into three primary areas: Reduced Radiation Exposure, Improved Availability, and Reduced Maintenance. As a result of removing the Bypass piping, Radiation Exposure to personnel can be reduced on the average by 80 manrems per outage. Availability can be improved by avoiding forced outages attributed to the present RID Bypass System. Maintenance Requirements can be reduced by eliminating hardware (e.g. valves and snubbers) which require periodic maintenance and inspection.

For the Watts Bar design, the EAGLE 21 family of qualified microprocessor based equipment is being utilized. The advantages of the EAGLE 21 electronics include: built-in-diagnostics to reduce trouble shooting time, self calibration to eliminate rack drift, and automatic testing to reduce surveillance test time.

The licensing effort which is ongoing for the South Texas Project Qualified Display Processing System (QDPS) includes the RID Bypass Elimination Modification utilizing EAGLE 21 family electronics. This commonality should expedite the Watts Bar RID Bypass Elimination licensing process.

#### BACKGROUND

The first generation of Westinghouse Pressurized Water Reactors were provided with single point temperature measurement instrumentation in both the hot and cold leg reactor coolant piping. Contrary to expected operating conditions, initial plant testing indicated that temperature gradients of 7 to 9 degrees F existed through the cross section of the hot leg. The single point hot leg temperature measurement in use was subject to significant error, thereby requiring a conservative uncertainty be used in the calculation of protection setpoints and in the overall plant safety analyses. This was viewed as an inappropriate use of available plant margin, and efforts were undertaken to improve the design. The solution to the non-uniform hot leg temperatures was the Resistance Temperature Device (RTD) Bypass System which obtained a representative sample of hot leg fluid and measured its' temperature. Cold leg temperature streaming was not found due to the mixing action of the Reactor Coolant Pump. The RTD Bypass System has three hot leg scoops located 120 degrees apart around the circumference of the hot leg to draw a representative sample of Reactor Coolant. This sample is piped to a manifold containing direct immersion RTDs which measure the coolant temperature. The same setup is applied to the cold leg, except that there is a single connection to the cold leg piping without a flow scoop.

The RID Bypass System is an effective method of accurately measuring RCS temperatures. However, the system piping location within the RCS loop

compartment creates a significant source of radiation exposure during plant maintenance. As with all piping systems, there is associated operability testing, periodic maintenance, and, unfortunately, unexpected unavailability.

Westinghouse has developed a new design which is an improvement over the existing RID Bypass System. The alternative is known as the RID Bypass Elimination Modification.

#### DESCRIPTION

یے سے میں سے میں میں میں میں میں میں میں ہے ا

### MECHANICAL

The mechanical modification removes the valves, piping, snubbers, and supports associated with the RID Bypass System and replaces them with thermowell mounted fast response RIDs which are installed directly into the Reactor Coolant Pipe. Mechanical modifications begin with the removal of the existing Bypass piping at each connection point to the Reactor Coolant System. The existing hot and cold leg penetrations are machined to accept RID thermowells. On the hot leg, the scoop tip will be removed to allow the thermowell to protrude directly into the flow stream. The thermowell is installed inside the modified scoop and the RID is installed within the thermowell. The crossover leg connection is capped and an additional cold leg boss, thermowell and RID are added as an installed spare.

#### ELECTRICAL

For the Watts Bar design, the EAGLE 21 family of qualified microprocessor based equipment is utilized to electronically average three hot leg RTD's to obtain a single hot leg average temperature (T HAVE). The system used to calculate T HAVE is referred to as the Temperature Averaging System (TAS). Since the Temperature Averaging System (TAS) becomes part of the Thermal Overpower and Overtemperature Protection System (Delta T / T AVG Protection) replacing the hot leg temperature signal previously measured by the bypass manifold RTD, all Delta T / T AVG Protection racks are being modernized.

The modular design of the EAGLE 21 electronics permits installation of the digital hardware into existing process racks. One rack per Protection Channel Set is configured primarily for Delta T / T AVG Protection. All analog hardware with the exception of the field termination blocks will be removed from these racks and be replaced with EAGLE 21 digital electronics.

### Verification and Validation (V&V)

Westinghouse introduced the concept of microprocessor based Protection Systems in the early 1970's on the Integrated Protection System (IPS) which was part of the RESAR 414 standard plant. The software verification program conducted on the prototype is documented in WCAP-9153 "414 Integrated Protection System Prototype Verification Program", and WCAP-9739 "Summary of Westinghouse Integrated Protection System Verification and Validation Program".

「日本」「「「「「「日本」」」」

《殺部》

Building upon the experience gained in performing software Verification and Validation on the IPS prototype and implementing the "lessons learned" from the Nuclear Regulatory Commission (NRC) audit process, a much improved V&V program was defined for the South Texas Qualified Display Processing System (QDPS). The "Design, Verification, and Validation Plan for the South Texas Project Qualified Display Processing System" was transmitted to the NRC in a letter from M. R. Wisenburg (Manager of Nuclear Licensing South Texas Project), to G. W. Knighton (NRC Chief Licensing Branch No. 3), dated September 24, 1985. To date, three NRC audits have been conducted on the South Texas QDPS V&V process with favorable results. A final closeout audit is scheduled for the week of November 17, 1986.

The V&V process to be implemented for Watts Bar RTD Bypass Elimination Modification is the same as the one conducted on the South Texas QDPS, modified only to the extent of refining the process to resolve NRC audit comments. Furthermore, the independent chief verifier assigned to the Watts Bar V&V program is the same individual who is currently completing the South Texas QDPS V&V program. It should also be noted that approximately 25% of the software modules required for the Watts Bar project have already been verified as part of the South Texas V&V program.

#### TRANSIENT ANALYSIS

Westinghouse will perform evaluations and analyses as necessary to verify that the accuracy and time response of the RID/thermowell/EAGLE 21 system are acceptable.

The primary impacts of the Watts Bar RTD Bypass Elimination Modification on the safety analyses result from the increase in RTD temperature uncertainty and response time associated with the replacement of the Rosemount RTDs currently used in the bypass loop with Rdf RTDs which will be installed in the thermowells.

The Rdf RIDs have a temperature uncertainty of 1.2 degrees F. This is an increase of 0.5 degrees F over the Rosemount RID temperature uncertainty of 0.7 degrees F. However, all FSAR Chapter 15 safety analyses conducted for Watts Bar have included an additional 2.5 degrees F temperature uncertainty. As a result, the additional temperature uncertainty of 0.5 degrees F for Rosemount RIDs is bounded and does not impact the overall system accuracy or the safety analyses. In addition, it should be noted that the change from Foxboro analog modules to EAGLE 21 equipment will, at a minimum maintain, and most likely improve the overall system accuracy.

The response time of the present Watts Bar RTD Bypass System is approximately 6.0 seconds. In comparison, the Fast Response Thermowell RTD System response time is 6.5 seconds. A 7.0 second response time will be conservatively assumed in the safety analyses. LICENSING DOCUMENTATION

The Watts Bar FSAR Chapters to be revised are as follows:

Chapter 5 "Reactor Coolant System" - is revised to include a design description of the RTD Bypass Elimination Modification.

Chapter 7 "Instrumentation and Controls" - is revised to include the EAGLE 21 electronics within the Reactor Trip System.

Chapter 15 "Accident Analysis" - is updated to incorporate the effects of the RTD Bypass Elimination Modification into the Accident Analysis.

Chapter 16 "Technical Specifications" - is revised to include any effects of the RTD Bypass Modification.

MEETING WITH THE NRC STAFF OCTOBER 14, 1986 BETHESDA, MD.

# RTD BYPASS REMOVAL AND EAGLE 21 ELECTRONICS MODIFICATION TO WATTS BAR UNIT 1



PURPOSE OF THE MEETING:

\* PROGRAMMATIC, MANAGEMENT OVERVIEW OF MODIFICATION

\* DISCUSS LICENSING STRATEGY TO SUPPORT MODIFICATION PRIOR TO FUEL LOAD FOR WATTS BAR UNIT ONE

\* TECHNICAL OVERVIEW OF MODIFICATION

.

Ξ



### AGENDA

\* INTRODUCTION

- PURPOSE

- AGENDA

\* OVERVIEW OF MODIFICATION

- BACKGROUND

- OPERATING EXPERIENCE

- PROPOSED MODIFICATION

- BENEFITS

\* LICENSING

DAVE KULISEK 1:00 - 1:15 MGR, WBN REGULATORY LICENSING

JERRY ERPENBACH 1:15 - 1:45 MGR, WBN PROJECT MANAGEMENT

DAVE KULISEK 1:45 - 2:15 MGR, WBN REGULATORY LICENSING

- COMPARISON WITH PREVIOUS LICENSING
- FSAR AND TECHNICAL SPECIFICATION CHANGES

- MECHANICAL - SENSOR CHANGES

- CHANNEL DIGITAL ELECTRONICS

- SCHEDULE

\* BREAK

2:15 - 2:30

\* SYSTEM DESCRIPTION

2:30 - 3:30

•.

RICK ETLING W RTDBE PRODUCT MANAGER

CARL VITALBO <u>W</u> EAGLE 21 TECHNICAL LEAD

- SOFTWARE V & V PROGRAM GLEN LANG <u>W</u> RTDBE/EAGLE 21 LICENSING

- SAFETY ANALYSIS JIM SECHRIST <u>W</u> TRANSIENT ANALYSIS

\* SUMMARY DAVE KULISEK 3:30 -MGR, WBN REGULATORY LICENSING

## OVERVIEW OF MODIFICATION .

## RTD BYPASS ELIMINATION

### JERRY ERPENBACH

=

:

MGR, WBN PROJECT MANAGEMENT

1





1 ( **1** ( **1** )



OPERATING EXPERIENCE WITH RTD BYPASS LOOP

O HAS BEEN VERY EFFECTIVE IN MEASUREMENT OF RCS TEMPERATURES

- O SIGNIFICANT OPERATIONAL DISADVANTAGES
  - MAINTENANCE REQUIRED DUE TO LEAKAGE FROM VALVES, FLANGES, AND MANIFOLDS
  - LEAKAGES ARE SOURCES OF LIQUID AND AIRBORNE CONTAMINATION
  - FORCED PLANT SHUTDOWNS DUE TO FAILURES OF VALVE STEMS OR VALVE PACKING
  - HIGH RADIATION EXPOSURES DUE TO CRUD TRAPS OF PIPING LAYOUT REQUIRES LOCAL SHIELDING
  - INACCESSIBILTY TO NEARBY EQUIPMENT DUE TO BYPASS LOOP PIPING, EXTENSIVE SUPPORTS, SNUBBERS, ETC
  - CALIBRATION AND MAINTENANCE OF PRESENT ELECTRONICS IS MANPOWER INTENSIVE

RTD BYPASS ELIMINATION MAJOR FEATURES

- THERMOWELL MOUNTED RTDS ARE INSTALLED IN EXISTING REACTOR COOLANT PIPE PENETRATIONS
  - ONE IN EACH HOT LEG SCOOP (TOTAL 3 PER HOT LEG)
  - ONE AT BYPASS PENETRATION TO EACH COLD LEG
- ADDITIONAL SPARE RTD INSTALLED AT NEW PENETRATION IN EACH COLD LEG
- RTD SIGNALS ARE ELECTRONICALLY AVERAGED TO PROVIDE THE THOT SIGNAL FOR USE BY PROTECTION AND CONTROL SYSTEMS

O ALL BYPASS LOOP PIPING AND SUPPORTS ARE REMOVED



### HOT LEG RTD SCOOP MODIFICATION



### EAGLE 21 MAJOR FEATURES

• MICROPROCESSOR BASED DIGITAL ELECTRONICS

• IMPROVED RELIABILITY

.

•

- IMPROVED TESTABILITY
- CHANGEOUT FROM ANALOG TO DIGITAL IS TRANSPARENT IN FORM, FIT, AND FUNCTION
- ANALOG MODULES FOR OTHER CHANNELS IN AFFECTED CABINETS ARE REPLACED WITH DIGITAL ELECTRONICS



Ξ

Existing Cabinet Installation of Eagle 21 Equipment

### RTD BYPASS ELIMINATION BENEFITS

### o REDUCED RADIATION EXPOSURE

- AVERAGE OF 80 MANREM PER YEAR ATTRIBUTED TO RTD BYPASS PIPING

### O REDUCED OUTAGE TIME

- VALVE FAILURES AND SYSTEM LEAKAGE FORCES UNPLANNED OUTAGES

### O REDUCED MAINTENANCE

.

- REDUCED NUMBER OF MECHANICAL COMPONENTS REQUIRING INSPECTION, TESTING, AND MAINTENANCE

EAGLE 21 BENEFITS

### • AUTOMATIC SURVEILLANCE TESTING

- REDUCE TECHNICIAN TEST TIME AND TESTING ERRORS
- AUTOMATICALLY DETERMINES IF ACCEPTANCE CRITERIA IS MET

#### O SELF CALIBRATION

\_

- MINIMIZES RACK DRIFT
- IMPROVES RACK ACCURACY

### • SELF DIAGNOSTICS

- SIMPLIFIES TROUBLESHOOTING
- PROVIDES IDENTIFICATION OF FAILURES AT THE PRINTED CIRCUIT BOARD LEVEL

### BENEFITS OF MODIFICATION

PRIOR TO FUEL LOAD VERSUS FIRST OUTAGE

### O SUBSTANTIAL MANREM AVOIDANCE DURING PIPING REMOVAL

### O FINANCIAL BENEFITS

- FIRST CYCLE SAVINGS OF \$100,000

• POTENTIAL FOR HIGHER FIRST CYCLE AVAILABILTY LICENSING

### RTD BYPASS ELIMINATION MODIFICATION

## DAVE KULISEK

\_

MGR, WBN REGULATORY LICENSING

### OVERALL PROGRAM ACTIVITIES

• PROCURE AND INSTALL SYSTEM

O TECHNICIAN TRAINING

O OPERATOR TRAINING

o LICENSING

-

-\_\_\_\_

• PROCEDURE UPDATES

O PRE-OPERATIONAL TESTING

COMPARISON TO SOUTH TEXAS PROJECT

### • MECHANICAL MODIFICATION

- SAME AS SOUTH TEXAS PROJECT

- SER ISSUED

Ξ

-

### O ELECTRICAL MODIFICATION

- SAME TECHNOLOGY AS SOUTH TEXAS PROJECT (EAGLE 21 FAMILY ELECTRONICS)
- ADDITIONAL AUTOMATIC TESTING FEATURE
- O VERIFICATION AND VALIDATION (V & V) PROGRAM ON SOFTWARE
  - SAME PROCESS AS SOUTH TEXAS PROJECT
  - ENHANCED BY FEEDBACK FROM NRC VIA SOUTH TEXAS PROJECT AUDIT REPORTS
  - SAME WESTINGHOUSE CHIEF VERIFIER
  - UTILIZES IDENTICAL AUTOMATED VERIFICATION TOOLS

- 25% SOFTWARE COMMONALITY

### FSAR MODIFICATIONS

O CHAPTER 5 - REACTOR COOLANT SYSTEM

- O REACTOR COOLANT SYSTEM PIPING
  - DESIGN DESCRIPTION
  - HOT LEG BYPASS MANIFOLD
  - COLD LEG BYPASS MANIFOLD
  - DIRECT IMMERSION RTDS
  - THERMOWELL MOUNTED RTDS IN RCS

O CHAPTER 7 - INSTRUMENTATION AND CONTROLS

O REACTOR TRIP SYSTEM

- SYSTEM DESCRIPTION

- OVERTEMPERATURE DELTA T TRIP
- OVERPOWER DELTA T TRIP
- COOLANT TEMPERATURE SENSOR ARRANGEMENT

O CHAPTER 15 - ACCIDENT ANALYSIS

- O UNCONTROLLED BANK WITHDRAWAL AT POWER
- O UNCONTROLLED BORON DILUTION
- O LOSS OF LOAD/TURBINE TRIP
- **o** RCS DEPRESSURIZATION

### O TECHNICAL SPECIFICATIONS

- O REACTOR TRIP SYSTEM INSTRUMENTATION
- O TIME CONSTANTS FOR OVERPOWER DELTA T AND OVERTEMPERATURE DELTA T
- o RESPONSE TIMES

OVERVIEW OF LICENSING SCHEDULE

• PHASED FSAR/TECHNICAL SPECIFICATION SUBMITTALS

• TECHNICAL PRE-MEETINGS BEFOR NRC AUDITS

O TWO NRC AUDITS ON APPLICATION OF V & V PROGRAM

c RESULTS IN JUNE 1, 1987 SER

### LICENSING SCHEDULE

s (e) e

М

	<u>ост.</u>	NOV.	DEC.	JAN.	FEB.	MAR.	APRIL	MAY	JUNE
1. TVA/NRC KICKOFF MTG	10/14								
2. SUBMIT FSAR CHAP 5&7 TO NRC FOR REVIEW (12 WKS Allocated for NRC REVIEW PROCESS)			12/1						
3. SUBMIT V&V PLAN TO NRC FOR Review (23 WKS Allocated for NRC Review Process)			12/29					•	
34. COMPLETE REVIEW OF FSAR CHAP 5&7 AND PROVIDE COMMENTS TO TVA				1/12					
5. SUBMIT FSAR CHAP 15 TO NRC FOR REVIEW (9 WKS Allocated for NRC REVIEW PROCESS)				1/26		·			
6. TVA/NRC FIRST AUDIT PRE-MEETING				1/26					
7. NRC AUDIT OF DESIGN PROCESS & APPLICATION OF V&V PLAN (FIRST AUDIT)					2/2				
8. RESOLVE NRC COMMENTS To FSAR CHAP 5&7					2/23				

### LICENSING SCHEDULE (CONTINUED)

 $\sim 10^{10}$ 

PF.

>9. COMPLETE REVIEW OF FSAR CHAP 15 & PROVIDE COMMENTS TO TVA 2/23   10. ISSUE AUDIT REPORTS ON DESIGN PROCESS & APPLICATION OF V&V PLAN 3/9   11. RESOLVE NRC COMMENTS TO FSAR CHAP 15 3/30   12. RESPOND TO FIRST AUDIT OPEN ITEMS 3/30   13. TVA/NRC FINAL AUDIT PRE-MEETING AND RESOLVE FIRST AUDIT COMMENTS 4/20   14. NRC AUDIT OF TEST PROCESS & TEST RESULTS (FINAL AUDIT) 4/27			oct.	NOV.	DEC.	JAN.	FEB.	MAR.	APRIL	MAY	JUNE
10. ISSUE AUDIT REPORTS ON DESIGN PROCESS & APPLICATION OF V&V PLAN3/911. RESOLVE NRC COMMENTS TO FSAR CHAP 153/3012. RESPOND TO FIRST AUDIT OPEN ITEMS3/3013. TVA/NRC FINAL AUDIT PRE-MEETING AND RESOLVE FIRST AUDIT COMMENTS4/2014. NRC AUDIT OF TEST PROCESS & TEST RESULTS (FINAL AUDIT)4/27	¥ 9.	COMPLETE REVIEW OF FSAR CHAP 15 & PROVIDE COMMENTS TO TVA					2/23				
11. RESOLVE NRC COMMENTS TO FSAR CHAP 15   3/30     12. RESPOND TO FIRST AUDIT OPEN ITEMS   3/30     13. TVA/NRC FINAL AUDIT PRE-MEETING AND RESOLVE FIRST AUDIT COMMENTS   4/20     14. NRC AUDIT OF TEST PROCESS & TEST RESULTS (FINAL AUDIT)   4/27	10.	ISSUE AUDIT REPORTS On design process & application of vev plan						3/9			
12. RESPOND TO FIRST AUDIT   3/30     OPEN ITEMS   4/20     13. TVA/NRC FINAL AUDIT   4/20     PRE-MEETING AND   4/20     RESOLVE FIRST AUDIT   4/20     COMMENTS   4/27     14. NRC AUDIT OF TEST   4/27     PROCESS & TEST RESULTS   4/27	11.	RESOLVE NRC COMMENTS						3/30			
13. TVA/NRC FINAL AUDIT   4/20     PREMEETING AND   4/20     RESOLVE FIRST AUDIT   4/20     COMMENTS   4/27     14. NRC AUDIT OF TEST   4/27     PROCESS & TEST RESULTS   4/27     (FINAL AUDIT)   4/27	12	RESPOND TO FIRST AUDIT						3/30	·		
14. NRC AUDIT OF TEST 4/27 PROCESS & TEST RESULTS (FINAL AUDIT)	13	. TVA/NRC FINAL AUDIT PRE-MEETING AND RESOLVE FIRST AUDIT COMMENTS							4/20		
	14	NRC AUDIT OF TEST PROCESS & TEST RESULTS (FINAL AUDIT)							4/27		

15. ISSUE SER

6/1

### SYSTEM TECHNICAL DESCRIPTION

- MECHANICAL - SENSOR CHANGES

- CHANNEL DIGITAL ELECTRONICS

- SOFTWARE V & V PROGRAM

ľ

- SAFETY ANALYSIS

RTD BYPASS ELIMINATION MODIFICATION

### MECHANICAL - SENSOR CHANGES

### RTD BYPASS ELIMINATION MODIFICATION

RICK ETLING

W RTDBE PRODUCT MANAGER

HOT LEG TEMPERATURE STREAMING BACKGROUND

- TEMPERATURE STREAMING: THE INCOMPLETE MIXING OF COOLANT LEAVING FUEL ASSEMBLIES AT DIFFERENT TEMPERATURES
- TEMPERATURE STREAMING FIRST DETECTED AT SAN ONOFRE AND CONNECTICUT YANKEE IN 1968
- O CONFIRMED BY SUBSEQUENT TESTING AT:
  - (i) R. E. GINNA
  - (ii) DAMPIERRE 3
  - (iii) MCGUIRE 1

PROBLEM SOLUTION

O RTD BYPASS SYSTEM DEVELOPED AND INSTALLED ON ALL SUBSEQUENT PLANTS

• COOLANT FROM THREE SAMPLE TAPS ON HOT LEG IS MIXED AND MEASURED WITH AN RTD IN A SMALL BYPASS PIPING LOOP AROUND STEAM GENERATORS

.

(i) MIXED SAMPLE PROVIDES AN ACCURATE MEASUREMENT OF HOT LEG TEMPERATURE

(ii) BYPASS LOOPS PROVIDE A MEANS OF REPLACING RTDS WITHOUT DRAINING THE RCS


. .



### RTD BYPASS SYSTEM OPERATION

### o SYSTEM HAS BEEN VERY EFFECTIVE IN MEASUREMENT OF COOLANT TEMPERATURES

#### O OPERATING EXPERIENCE

- (i) LEAKAGE OF VALVES, FLANGES AND MANIFOLDS REQUIRES AREA
  CLEANUP FOR MAINTENANCE
- (ii) FAILURE OF VALVE STEMS OR PACKING, EITHER INTERRUPTING BYPASS FLOW OR CAUSING EXCESSIVE RCS LEAKAGE, REQUIRING A PLANT SHUTDOWN TO CORRECT
- (iii) CRUD TRAPS IN BYPASS LOOP EQUIPMENT, INCREASING RADIATION LEVELS DURING OUTAGE, NEED FOR LOCAL SHIELDING

(iv) PIPING, SUPPORTS, SNUBBERS, INTERFERE WITH ACCESS TO OTHER COMPONENTS



## ALTERNATIVE TEMPERATURE MEASUREMENT SYSTEM

EMPLOYING FAST RESPONSE RTDS

O NEW SYSTEM ELIMINATES ALL BYPASS PIPING

APPLIES FAST RESPONSE THERMOWELL MOUNTED RTD'S RECENTLY
 QUALIFIED FOR PROTECTION FUNCTIONS

O NEW SYSTEM ADDRESSES TEMPERATURE STREAMING

MAJOR FEATURES

• FAST RESPONSE THERMOWELL MOUNTED RTDS ARE INSTALLED IN EXISTING REACTOR COOLANT PIPE PENETRATIONS

(i) ONE IN EACH HOT LEG SCOOP (TOTAL 3 PER HOT LEG)

(ii) ONE AT BYPASS PENETRATION TO EACH COLD LEG

- ADDITIONAL SPARE RTD INSTALLED AT NEW PENETRATION IN EACH
  COLD LEG
- SIGNALS FROM THE THREE HOT LEG RTDS ARE ELECTRONICALLY
  AVERAGED TO PROVIDE THE THOT SIGNAL FOR USE BY PROTECTION
  AND CONTROL SYSTEMS

O ALL BYPASS PIPING IS REMOVED



HOT LEG RTD SCOOP MODIFICATION

## Cold Leg Pipe Nozzle Modification

Machining Thermowell Installation RTD Insertion



# RTD Bypass Thermowell Insertion



WESTINGHOUSE PLANTS \_\_\_\_\_\_ INCORPORATING RTD BYPASS ELIMINATION

and the se

#### **o** MCGUIRE

O SOUTH TEXAS

O CATAWBA

OWATTS BAR

O BRYON

O BRAIDWOOD

O SHEARON HARRIS (MECHANICAL MODIFICATION ONLY)

## CHANNEL DIGITAL ELECTRONICS

### RTD BYPASS ELIMINATION MODIFICATION

CARL VITALBO

W EAGLE 21 TECHNICAL LEAD

## EAGLE-21 IMPLEMENTATION

. .



## EAGLE-21 DESIGN PHILOSOPHY



• Form, fit and function replacement



## EAGLE-21

## **Typical Analog Process Protection Channel**

. .

1



## EAGLE-21 IMPLEMENTATION

1

1 1 .





**Existing Cabinet** 



Existing Cabinet Installation of Eagle 21 Equipment



Front View Typical Rack Arrangement

.

.



TO SOLID STATE PROTECTION SYSTEM LOGIC (SEE STD. FUNCTIONAL DIAGRAMS, SHEET 5, PRIMARY COOLANT SYSTEM TRIP SIGNALS)

THERMAL OVERTEMPERATURE AND OVERPOWER PROTECTION BLOCK DIAGRAM

FIGHE 1



1.1

WATTS BAR

PROCESS PROTECTION SYSTEM



TEMPERATURE AVERAGING SYSTEM DIGITAL FLOW DIAGRAM

## EAGLE-21 ARCHITECTURE

1.1

I.



#### DIGITAL

#### TEMPERATURE AVERAGING SYSTEM

#### FEATURES

\* EXTENSIVE UTILIZATION OF MMI PARAMETER INPUTS IN ENGINEERING UNITS

- + SETPOINTS
- + TUNING CONSTANTS
- + RTD CALIBRATION COEFFICIENTS
- \* ON-LINE CALCULATION OF TEMPERATURE BIAS AS A FUNCTION OF POWER
- \* ANTICIPATORY INDICATION OF RTD FAILURE
- \* AUTOMATICALLY DETECTS AND REJECTS INPUT FROM FAILED RTD
- \* AUTOMATICALLY APPLIES TEMPERATURE BIAS INTO HOT LEG TEMPERATURE CALCULATION FOLLOWING AN RTD FAILURE
- \* ON-LINE CALIBRATION AND DIAGNOSTICS

## SOFTWARE V & V PROGRAM

,

## RTD BYPASS ELIMINATION MODIFICATION

GLEN LANG

W RTDBE/EAGLE 21 LICENSING

V & V PROGRAM

APPLICABLE STANDARDS

o ANSI/IEEE-ANS-7-4.3.2 - 1982

"APPLICATION CRITERIA FOR PROGRAMMABLE DIGITAL COMPUTER SYSTEMS IN SAFETY SYSTEMS OF NUCLEAR POWER GENERATING STATIONS"

o REGULATORY GUIDE 1.152

"CRITERIA FOR PROGRAMMABLE DIGITAL COMPUTER SYSTEM SOFTWARE IN SAFETY-RELATED SYSTEMS OF NUCLEAR POWER PLANTS"

o IEEE-603 - 1980

"IEEE STANDARD CRITERIA FOR SAFETY SYSTEMS FOR NUCLEAR POWER GENERATING STATIONS"

o REGULATORY GUIDE 1.153

"CRITERIA FOR POWER, INSTRUMENTATION, AND CONTROL PORTIONS OF SAFETY SYSTEMS"



#### DESIGN VERIFICATION AND VALIDATION PROCESS



SOUTH TEXAS EAGLE 21

WATTS BAR EAGLE 21 TH. TH2 TH3TC Pp Ou OL **TEMPERATURE** MISC. AVERAGING PROTECTION SYSTEM EAGLE 21 FUNCTIONS (TAS) SYSTEM NO TRIP + ∆T/Tavg CHANNELS  $\Delta$ T,Tavg BISTABLE LOGIC SOLID STATE TRIP CONTROL FOXBORO ANALOG PROTECTION SYSTEM FUNCTIONS CONTROL SYSTEM FUNCTIONS TRIP CONTROL

OUTPUTS

OUTPUTS

PROPOSED INITIAL AUDIT

 PRE-AUDIT TECHNICAL MEETING SCHEDULED FOR WEEK OF JANUARY 26, 1987

o AUDIT SCHEDULED FOR WEEK OF FEBRUARY 2, 1987

#### o SCOPE

- REVIEW APPLICATION OF VERIFICATION AND VALIDATION PLAN FOR WATTS BAR PROGRAM

- AUDIT DESIGN PROCESS

### PROPOSED FINAL AUDIT

----

O PRE-AUDIT TECHNICAL MEETING SCHEDULED FOR WEEK OF APRIL 20, 1987

O AUDIT FOR WEEK OF APRIL 27,1987

o SCOPE

, ...

- RESOLVE INITIAL AUDIT OPEN ITEMS

- CONDUCT "THREAD" CONCEPT OF VERIFICATION PROCESS

- CONDUCT "THREAD" CONCEPT OF VALIDATION PROCESS

### VERIFICATION AND VALIDATION PROGRAM

- UTILIZES SAME V&V PROCESS AS WAS IMPLEMENTED ON SOUTH TEXAS PROJECT QDPS
  - PROCESS SUPPLEMENTED WITH FEEDBACK FROM SOUTH TEXAS NRC AUDITS
  - WATTS BAR CHIEF VERIFIER SAME INDIVIDUAL AS USED ON SOUTH TEXAS PROJECT
  - SEVERAL VERIFIERS UTILIZED ON SOUTH TEXAS PROJECT WILL PERFORM VERIFICATION TESTS ON WATTS BAR
  - AUTOMATED TEST TOOLS
  - 25 PERCENT SOFTWARE COMMONALITY WITH SOUTH TEXAS

### SAFETY ANALYSIS

~

, , •

-

### RTD BYPASS ELIMINATION MODIFICATION

•

JIM SECHRIST

W TRANSIENT ANALYSIS

#### SAFETY ANALYSIS CONSIDERATIONS:

- RTD Accuracy
- Channel Response Time
- FSAR Chapter 15 Accident Analysis

#### RTD ACCURACY:

- RTD Temp Uncertainty (0.7°F --> 1.2°F)
- Current Analyses Assume Additional 2.5°F Temperature Uncertainty
- Digital System Accuracy ≥ Analog System Accuracy
- No Impact on Accident Analyses

#### CHANNEL RESPONSE TIME:

- Current Accident Analyses Assume 6 Seconds
- New Analyses Assume 7 Seconds
- Increased Response Time Delays Overtemperature Delta-T (OTDT)/Overpower Delta-T (OPDT) Trips
- Accident Analyses Affected

#### FSAR CHAPTER 15 ACCIDENT ANALYSIS

#### TRANSIENTS AFFECTED:

•	Uncontrolled Bank Withdrawal At Power	 OTDT	Trip
٠	Uncontrolled Boron Dilution	 OTDT	Trip
•	Loss of Load/Turbine Trip	 OTDT	Trip
•	RCS Depressurization	 OTDT	Trip