	20697-10 (3/30/06)
A CAL	CULATION SUMMARY SHEET (CSS)
Document Identifier <u>32 - 9049387 - 0</u>	01
Title North Anna Unit	s 1&2, Pressurizer Surge Nozzle Weld Overlay Analysis
PREPARED BY:	REVIEWED BY:
NAME Monika Sedlakova	NAME Lingyah Yen
SIGNATURE Monte fedlotra	SIGNATURE Lygh In
TITLE Engineer DATE	2/12/07 TITLE Advisory Engineer DATE 12/12/07
COST REF CENTER 41315 PAGE(S)	TM STATEMENT: 119 REVIEWER INDEPENDENCE TIM Wiger T.M. L.
,,,,,,,	NAME
This document is a non-proprietary version of from 32-9038239-002 is indicated by a pair of Dominion Power proprietary. The purpose of Nozzle Weld Overlay Design to the requirem The purpose of Revision 001 is to update no	of AREVA NP Document 32-9038239-002. The proprietary information removed of square brackets "()." The geometry and operating condition are of this calculation is to qualify the North Anna Units 1 & 2 Pressurizer Surge ments specified in Reference 13.7. n-proprietary version of AREVA NP Document 32-9038239-002.
Conclusion:	
The calculations demonstrate that the desig has met the stress and fatigue requirements Based on the loads and cycles specified in Pressurizer Surge Nozzle has a maximum fa to the ASME Code allowed maximum value of	n of the Surge Nozzle Weld Overlay for the North Anna Units 1 & 2 Pressurizer of the Design Code (Reference 13.1). References 13.8 and 13.16, the conservative fatigue analysis indicates that the atigue usage factor of () Years of operation (Reference 13.7) compared of 1.0.
Revision 001 is complete revision The total number of pages is 254 which are o	consisted of pages 1 to 250 and 4 inserted pages, 4a, 8a, 10a and 243a.
THE FOLLOWING COMPUTER CODES HAVE	BEEN USED IN THIS DOCUMENT: CODE/VERSION/REV

AREVA NP Inc., an AREVA and Siemens company

÷

ļ

• •	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	, PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

RECORD OF REVISIONS

Revision	Date	Pages/Sections Changed	Brief Description
000	02/2007	All	Original Release
001	12/2007	All Pages	Update non-proprietary version of AREVA NP Document 32-9038239-002.

Prepared by: M. Sedlakova Reviewed by: L. Yen

)

Date: 12/2007 · Date: 12/2007 Page 2

)

Δ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	, DOCUMENT NUMBER	PLANT ,	
AREVA	22 00 10207 001		NON-PROPRIETARY

TABLE OF CONTENTS

RECORD	OF REVISIONS
LIST OF	TABLES
LIST OF	FIGURES9
1. PURP	OSE11
1.1	INTRODUCTION11
1.2	SCOPE11
2. ANAL	YTICAL METHODOLOGY12
3. KEY A	ASSUMPTIONS13
4. DESIG	GN INPUT14
4.1	GEOMETRY14
4.2	FINITE ELEMENT MODEL15
4.3	MATERIALS
4.4	BOUNDARY CONDITIONS AND LOADS
4.4.1	Thermal analysis 19
4.4.2	Structural Analysis
5. EXTE	RNAL LOADS21
5.1	NOZZLE CROSS SECTION CHARACTERISTICS
5.2	APPLICABLE STRESS INTENSITY DUE TO EXTERNAL LOADS FOR PRIMARY + SECONDARY QUALIFICATION
6. DESIC	GN CONDITION
7. THER	MAL ANALYSIS42
8. STRU	CTURAL ANALYSIS
9. ASME	CODE CRITERIA69
9.1	ASME CODE PRIMARY STRESS INTENSITY (SI) CRITERIA
9.2	ASME CODE PRIMARY+SECONDARY STRESS INTENSITY (SI) CRITERIA70
9.2.1	Path Stress Evaluation
9.2.2	Primary + Secondary Stress Intensity Range Qualification (NB 3222.2)
9.2	.2.1 Summary of Stress Intensity Range Qualification
9.2.3	Simplified Elastic-Plastic Analysis (NB-3228.5)

Λ	NORTH ANNA UNITS 18	22, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
	DOCUMEN I' NUMBER	PLANI	NON PROPRIETARY
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY
9.2.3.	1 Primary + Secondary 3228.5(a))	y SI Range (Excluding thermal ber	nding stresses) (NB-
9.2.3.	2 Factor Ke (NB-3228	3.5(b))	
9.2.3.	3 Fatigue Usage Facto	r (NB-3228.5(c) and NB-3222.4)	
9.2.3.	4 Thermal Stress Ratel	het (NB-3228.5(d) and NB-3222.5) 90
9.2.3.	5 Temperature Limits	(NB-3228.5(e))	
9.2.3.	6 Minimum Strength F	Ratio (NB-3228.5(f))	
9.2.4	Fatigue Usage Factor C	Calculation	
10. RESULT	S SUMMARY/CONCI	USION	
11. SOFTWA	ARE VERIFICATION.	•••••••••••••••••••••••••••••••••••••••	107
12. COMPU	TER OUTPUT FILES.		
13. REFERE	ENCES		119
APPENDIX	A	••••••	
PATH STRE	ESSES FOR FRACTUR	E MECHANICS	120
A.1 PURPO	SE		
A.2 STRESS	5 AND TEMPERATUR	E EVALUATION	
APPENDIX	B		127
STRUCTUR	AL TIME POINTS OF	INTEREST	127
B.1 TIME P	OINTS OF INTEREST	USED FOR STRUCTURAL AN	ALYSIS 128
APPENDIX	С		
JUSTIFICA	TION OF INSUFFECI	ENT LENGTH OF WELD OVE	RLAY169
C.1 PURPO)SE		
C.2 ANALY	TICAL METHODOLO	DGY	
C.3 BOUND	OARY CONDITIONS		
C.4 RESUL	TS AND CONCLUSIO	NS	
APPENDIX	D		
RE-ANALY	SIS WITH INSURGE A	ND OUTSURGE TRANSIENT	173
D.1 PURPO	SE		
D.2 THERM	IAL ANALYSIS		
D.3 STRUC	TURAL ANALYSIS		
D.4 ASME (CODE CRITERIA		

Prepared by: M. Sedlakova Reviewed by: L. Yen

)

Date: 12/2007 Date: 12/2007 Page 4

	DOCUMENT NUMBER	PL ANT'	NON DOODDIETADI
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY
D.4.1 ASN	ME CODE PRIMARY S	TRESS INTENSITY (SI) CRITER	LIA181
D.4.2 ASM	MÈ CODE PRIMARY+S	ECONDARY STRESS INTENSI	TY (SI) CRITERIA 182
D.4.2.1	Path Stress Evaluation		
D.4.2.2	Primary+Secondary Stre	ess Intensity Range Qualification	
D.4.2	.2.1 Summary of Stress	Intensity Range Qualification	191
D.4.2.3	Simplified Elastic-Plasti	c Analysis (NB-3228.5)	
D.4.2	.3.1 Primary + Secondar 3228.5(a))	y SI Range (Excluding thermal be	nding stresses) (NB-
D.4.2	.3.2 Factor Ke (NB-3228	3.5(b))	197
D.4.2	.3.3 Fatigue Usage Facto	or (NB-3228.5(c) and NB-3222.4).	197
D.4.2	.3.4 Thermal Stress Rate	het (NB-3228.5(d) and NB-3222.5	5) 197
D.4.2	.3.5 Thermal Only Exter	nal Loading	
D.4.2.3.5 Temperature Limits (NB-3228.5(e))			
D.4.2.3.7 Minimum Strength Ratio (NB-3228.5(f))			
D.4.2.4 Fatigue Usage Factor Calculation			
D.5 SOFTW	ARE VERIFICATION	I	
D.6 COMPU	UTER OUTPUT FILES		
APPENDIX	Е	•••••••••••••••••••••••••••••••••••••••	231
NON-LINEA	AR ELASTIC-PLASTI	C ANALYSIS	231
E.1 PURPO	SE		232
E.2 NON-LI	INEAR ELASTIC-PLA	STIC ANALYSIS (NB-3228.4)	232
E.2.1 FIN	ITE ELEMENT MODEL	FOR ELASTIC-PLASTIC ANA	LYSIS233
E.2.2 DES	IGN CONDITION ANA	LYSIS	
E.2.3 THE	ERMAL TRANSIENT A	NALYSIS FOR IOSURGE TRAN	SIENT236
E.2.4 ELA	STIC-PLASTIC MATE	RIAL PROPERTIES	237
E.2.5 EXT	ERNAL LOADS		
E.2.6 RES	ULTS OF THE ELASTI	C-PLASTIC ANALYSIS	243
E.3 SOFTW	ARE VERIFICATION	[••••••••••••••••••••••••••••••••••••	249
E.4 COMPU	JTER OUTPUT FILES	••••••	249

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

A

í

Λ	NORTH ANNA UNITS 18	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

LIST OF TABLES

Table 5-1 Applicable External Loads	21
Table 5-2 Applicable Loads Due to Thermal Stratification	22
Table 5-3 Nozzle Cross Sectional Characteristics (Maximum WOL)	23
Table 5-4 Nozzle Cross Sectional Characteristics (Minimum WOL)	23
Table 5-5 Primary + Secondary SI Due to External Loads (Max WOL)	26
Table 5-6 Primary + Secondary SI Due to External Loads (Min WOL)	27
Table 5-7 Primary + Secondary SI Due to Thermal Stratification Load Case HU- WOL))(Max
Table 5-8 Primary + Secondary SI Due to Thermal Stratification Load Case HU- WOL))(Min
Table 5-9 Primary + Secondary SI Due to Thermal Stratification Load Case HU- WOL)) (Max
Table 5-10 Primary + Secondary SI Due to Thermal Stratification Load Case HU (WOL)) (Min 31
Table 5-11 Primary + Secondary SI Due to Thermal Stratification Load Case HU-(WOL))(Max
Table 5-12 Primary + Secondary SI Due to Thermal Stratification Load Case HU- WOL))(Min 33
Table 5-13 Primary + Secondary SI Due to Thermal Stratification Load Case HU- WOL))(Max
Table 5-14 Primary + Secondary SI Due to Thermal Stratification Load Case HU- WOL)) (Min 35
Table 5-15 Primary + Secondary SI Due to Thermal Stratification Load Case OP (WOL))(Max
Table 5-16 Primary + Secondary SI Due to Thermal Stratification Load Case OP (WOL))(Min
Table 7-1 Transients	42
Table 7-2 Nodes of Interest for Evaluation of Temperature Gradients	45
Table 7-3 Temperature Gradients of Interest	45
Table 9-1 Path Descriptions	
Table 9-2 Summary of Maximum Primary + Secondary SI Ranges for Membrane + Stresses (Maximum WOL)	Bending 75

• •	NORTH ANNA UNITS 18	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 9-3 Comparison of Maximum SI Range including External Loads to ASME Code 3*Sm Criteria (Maximum WOL)
Table 9-4 External Stress Added by Components (Maximum WOL)
Table 9-5 Summary of Maximum Primary + Secondary SI Ranges for Membrane + Bending Stresses (Minimum WOL)
Table 9-6 Comparison of Maximum SI Range including External Loads to ASME Code 3*Sm Criteria (Minimum WOL)
Table 9-7 External Stress Added by Components (Minimum WOL) 83
Table 9-8 Maximum WOL SI Ranges Minus Thermal Bending
Table 9-9 Minimum WOL SI Ranges Minus Thermal Bending 89
Table 9-10 Allowable Ranges of Thermal Stresses for Maximum WOL 91
Table 9-11 Allowable Ranges of Thermal Stresses for Minimum WOL
Table 9-12 Thermal M+B SI Range for Maximum WOL 92
Table 9-13 Thermal M+B SI Range for Minimum WOL94
Table 9-14 Stress Category and FSRF in Fatigue Evaluation 97
Table 10-1 Summary of Results ⁽¹⁾ 106
Table 11-1 Software Verification Files
Table 12-1 Computer Output and Input Files 108
Table A-1 Paths Description Min WOL 121
Table A-2 Stress and Temperature Result Files for Fracture Mechanics Evaluation
Table B-1 Structural Time Points of Interest for Plant Heatup and Cooldown-MAX WOL 129
Table B-2 Structural Time Points of Interest for Plant Loading and Unloading-MAX WOL130
Table B-3 Structural Time Points of Interest for 10% Step Load Increase-MAX WOL131
Table B-4 Structural Time Points of Interest for 10% Step Load Decrease-MAX WOL
Table B-5 Structural Time Points of Interest for Large Step Decrease In Load-MAX WOL133
Table B- 6 Structural Time Points of Interest for Loss of Load-MAX WOL 134
Table B- 7 Structural Time Points of Interest for Loss of Power-MAX WOL 135
Table B- 8 Structural Time Points of Interest for Loss of Flow-MAX WOL 136
Table B- 9 Structural Time Points of Interest for Feedwater Cycling at Hot Shutdown-MAX WOL 137
Table B- 10 Structural Time Points of Interest for Boron Concentration Equalization-MAX WOL

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
R	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table B-11 Structural Time Points of Interest for Reactor Trip with No Cooldown-MAX WOL138

Table B- 12 Structural Time Points of Interest for Reactor Trip with Cooldown but no Safety Injection-MAX WOL
Table B- 13 Structural Time Points of Interest for Reactor Trip with Cooldown and Safety Injection-MAX WOL 139
Table B- 14 Structural Time Points of Interest for Inadvertent Reactor Coolant System Depressurization-MAX WOL 140
Table B- 15 Structural Time Points of Interest for Control Rod Drop-MAX WOL 141
Table B- 16 Structural Time Points of Interest for Inadvertent Startup of an Inactive Loop-MAX WOL 142
Table B- 17 Structural Time Points of Interest for Inadvertent Safety Injection Actuation-MAX WOL
Table B- 18 Structural Time Points of Interest for Turbine Roll Test-MAX WOL
Table B- 19 Structural Time Points of Interest for Loop Out of Service Normal Loop Shutdown- MAX WOL 144
Table B- 20 Structural Time Points of Interest for Loop Out of Service Normal Loop Startup- MAX WOL 145
Table B- 21 Structural Time Points of Interest for RCS Cold Overpressurization-MAX WOL146
Table B- 22Structural Time Points of Interest for Plant Heatup and Cooldown-MIN WOL147
Table B-23 Structural Time Points of Interest for Plant Loading and Unloading-MIN WOL149
Table B- 24 Structural Time Points of Interest for 10% Step Load Increase-MIN WOL
Table B- 25Structural Time Points of Interest for 10% Step Load Decrease-MIN WOL151
Table B-26 Structural Time Points of Interest for Large Step Decrease In Load-MIN WOL152
Table B- 27 Structural Time Points of Interest for Loss of Load-MIN WOL153
Table B- 28 Structural Time Points of Interest for Loss of Power-MIN WOL 154
Table B- 29 Structural Time Points of Interest for Loss of Flow-MIN WOL 155
Table B- 30 Structural Time Points of Interest for Feedwater Cycling at Hot Shutdown-MIN WOL 156
Table B- 31 Structural Time Points of Interest for Boron Concentration Equalization-MIN WOL 157
Table B- 32 Structural Time Points of Interest for Reactor Trip with No Cooldown-MIN WOL158
Table B- 33 Structural Time Points of Interest for Reactor Trip with Cooldown but no Safety Injection-MIN WOL 159

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

North Anna Units 1 & 2

DOCUMENT NUMBER PLANT

32-9049387-001

NON-PROPRIETARY

Table B- 34 Structural Time Points of Interest for Reactor Trip with Cooldown and Safety Injection-MIN WOL 160
Table B- 35 Structural Time Points of Interest for Inadvertent Reactor Coolant System Depressurization-MIN WOL 161
Table B- 36 Structural Time Points of Interest for Control Rod Drop-MIN WOL
Table B- 37 Structural Time Points of Interest for Inadvertent Startup of an Inactive Loop-MIN WOL WOL 163
Table B- 38 Structural Time Points of Interest for Inadvertent Safety Injection Actuation-MIN WOL 164
Table B- 39 Structural Time Points of Interest for Turbine Roll Test-MIN WOL
Table B- 40 Structural Time Points of Interest for Loop Out of Service Normal Loop Shutdown- MIN WOL
Table B- 41 Structural Time Points of Interest for Loop Out of Service Normal Loop Startup- MIN WOL
Table B- 42 Structural Time Points of Interest for RCS Cold Overpressurization-MIN WOL .168
Table C- 1 Computer Output Files For Appendix C
Table D-1 Insurge & Outsurge Transients 174
Table D-2 IOSurge Transient ($\Delta t = \begin{bmatrix} \\ \\ \end{bmatrix}$
Table D-3 IOSurge110 Transient ($\Delta t = \begin{bmatrix} \\ \\ \end{bmatrix}$
Table D-4 Structural Time Points of Interest for Insurge/Outsurge Transient with Temperature Drop of
Table D-5 Structural Time Points of Interest for Insurge/Outsurge Transient with Temperature Drop of
Table D-6 Summary of Maximum Primary + Secondary SI Ranges for Membrane + Bending Stresses (Minimum WOL)
Table D-7 Comparison of Maximum SI Range including External Loads to ASME Code 3*Sm Criteria (Minimum WOL)
Table D-8 External Stress Added by Components (Minimum WOL) 186
Table D-9 Minimum WOL SI Ranges Minus Thermal Bending 192
Table D-9(Continued) Minimum WOL SI Ranges Minus Thermal Bending195
Table D-9(Continued) Minimum WOL SI Ranges Minus Thermal Bending196
Table D-10 Allowable Ranges of Thermal Stresses for Minimum WOL 198
Table D-11 Thermal M+B SI Range for Minimum WOL 199
Table D-12 Thermal External Loads 208

Prepared by: M. Sedlakova

Reviewed by: L. Yen

AREVA

Δ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table D-13 Thermal External Loads	208
Table D-12 Stress Category and FSRF in Fatigue Evaluation	210
Table D-13 PipeL Usage Factor Calculation	212
Table D-14 SEU_Weld Usage Factor Calculation	215
Table D-15 SEL_Wola Usage Factor Calculation	218
Table D-16 SEL_Welda Usage Factor Calculation	221
Table D-17 P_Wol Fatigue Usage Factor Calculation	223
Table D-18 Noz Fatigue Usage Factor Calculation	225
Table D-19 Sleeve Fatigue Usage Factor Calculation	227
Table D-20 Software Verification Files	229
Table D-21 Computer Output and Input Files	229
Table E-1 Elastic-Plastic Material Properties of	239
Table E-2 First Strain Values for Table E-1	239
Table E-3 Elastic-Plastic Material Properties of	239
Table E-4 External Loads	241
Table E-5 Time Points of Interest for 'IOSurge' Structural Elastic-Plastic Analysis	242
Table E-6 Maximum Principal Total Strain Ranges	244
Table E-7 Maximum Principal Strain Ranges and Calculated SI Ranges	247
Table E-8 Fatigue Usage Factor Calculation for Safe End	248
Table E-9 Fatigue Usage Factor Calculation for Thermal Sleeve	248
Table E-10 Software Verification Files	249
Table E-11 Computer Output and Input Files	249

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

A AREVA

PLANT North Anna Units 1 & 2

LIST OF FIGURES

Figure 4-1 Surge Nozzle Geometry with Weld Overlay
Figure 4-2 Finite Element Model of Surge Nozzle with Weld Overlay (Maximum WOL Shown)16
Figure 4-3 Finite Element Model – Detail View of SWOL Region (Maximum Configuration Shown)
Figure 4-4 Surfaces for Thermal Boundary Conditions20
Figure 5-1 Path Definitions for External Loading24
Figure 6-1 Deformed Shape versus Un-deformed Outline
Figure 6-2 Stress Intensity Contours at Design Condition (Maximum WOL Shown)40
Figure 6-3 Stress Intensity Contours at Design Condition Boundaries (Maximum WOL Shown)41
Figure 7-1 Location of Node Numbers for Evaluation of Temperature Gradients
Figure 7-2 Temperature and Temperature Gradients for Surge Plant Heatup/Cooldown Transients for Maximum WOL Configuration
Figure 7-3 Temperature and Temperature Gradients for Surge Plant Loading/Unloading Transients for Maximum WOL Configuration
Figure 7-4 Temperature and Temperature Gradients for Surge 10% Step Load Increase Transient for Maximum WOL Configuration
Figure 7-5 Temperature and Temperature Gradients for Surge 10% Step Load Decrease Transient for Maximum WOL Configuration
Figure 7-6 Temperature and Temperature Gradients for Surge Large Step Decrease in Load for Maximum WOL Configuration
Figure 7-7 Temperature and Temperature Gradients for Surge Loss of Load for Maximum WOL Configuration
Figure 7-8 Temperature and Temperature Gradients for Surge Loss of Power Transient for Maximum WOL Configuration
Figure 7-9 Temperature and Temperature Gradients for Surge Loss of Flow Transient for Maximum WOL Configuration
Figure 7-10 Temperature and Temperature Gradients for Surge Feedwater Cycling at Hot Shutdown Transient for Maximum WOL Configuration
Figure 7-11 Temperature and Temperature Gradients for Surge Boron Concentration Equalization Transient for Maximum WOL Configuration
Figure 7-12 Temperature and Temperature Gradients for Surge Reactor Trip with No Cooldown Transient for Maximum WOL Configuration

۸	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-13 Temperature and Temperature Gradients for Surge Reactor Trip with Cooldown but no Safety Injection Transient for Maximum WOL Configuration
Figure 7-14 Temperature and Temperature Gradients for Surge Reactor Trip with Cooldown and Safety Injection Transient for Maximum WOL Configuration
Figure 7-15 Temperature and Temperature Gradients for Surge Inadvertent Reactor Coolant System Depressurization Transient for Maximum WOL Configuration
Figure 7-16 Temperature and Temperature Gradients for Surge Control Rod Drop Transient for Maximum WOL Configuration
Figure 7-17 Temperature and Temperature Gradients for Surge Inadvertent Startup of an Inactive Loop Transient for Maximum WOL Configuration
Figure 7-18 Temperature and Temperature Gradients for Surge Inadvertent Safety Injection Actuation Transient for Maximum WOL Configuration
Figure 7-19 Temperature and Temperature Gradients for Surge Turbine Roll Test Transient for Maximum WOL Configuration
Figure 7-20 Temperature and Temperature Gradients for Surge Loop Out of Service Normal Loop Shutdown Transient for Maximum WOL Configuration
Figure 7-21 Temperature and Temperature Gradients for Surge Loop Out of Service Normal Loop Startup Transient for Maximum WOL Configuration
Figure 7-22 Temperature and Temperature Gradients for Surge RCS Cold Overpressurization for Maximum WOL Configuration
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation.72Figure 9-2 Path Locations in Nozzle used for Stress Evaluation.73Figure A-1 Paths Defined for Fracture Mechanics Evaluation.122Figure C-1 Stress Intensity Contour for the Thin Weld Overlay Configuration.172Figure D-1 Temperature and Temperature Gradient for IOSurge Transient.177Figure D-2 Temperature and Temperature Gradient for IOSurge110 Transient.178Figure E-1 3-D Finite Element Model.233
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation.72Figure 9-2 Path Locations in Nozzle used for Stress Evaluation.73Figure A-1 Paths Defined for Fracture Mechanics Evaluation.122Figure C-1 Stress Intensity Contour for the Thin Weld Overlay Configuration.172Figure D-1 Temperature and Temperature Gradient for IOSurge Transient.177Figure D-2 Temperature and Temperature Gradient for IOSurge110 Transient.178Figure E-1 3-D Finite Element Model.233Figure E-2 Stress Intensity Contours for 3-D Design Pressure Run.235
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation
Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure E-8 Strain Plots for Node #12507 and IOSurge Transient	
Figure E-9 Displacement Plots for Node #12507 and IOSurge Transient	245
Figure E-10 Strain Plots for Node #18575 and IOSurge Transient	246
Figure E-11 Displacement Plots for Node #18575 and IOSurge Transient	246

Prepared by: M. Sedlakova Reviewed by: L. Yen

·Z

۸	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

1. PURPOSE

1.1 INTRODUCTION

Primary water stress corrosion cracking (PWSCC) of Alloy 82/182 materials is a welldocumented phenomenon in the nuclear power. High temperature components, such as those associated with the pressurizer, have risk for PWSCC. Dominion Generation (Dominion) plans to mitigate the North Anna Units 1 and 2 pressurizer nozzle Alloy 82/182 dissimilar metal welds (DMW) with full structural weld overlays (SWOL) during the fall 2007 and spring 2007 refueling outages for Units 1 and 2, respectively. The planned mitigation using SWOL is a preemptive measure to reduce susceptibility of the DMW and the adjacent pipe/fitting to safe end welds to PWSCC.

1.2 SCOPE

The surge nozzle is located on the bottom of the pressurizer as a conduit for the surge line insurges and outsurges. The weld overlay is designed to cover both the Alloy 82/182 DM region and the austenitic stainless weld between the nozzle safe end and the piping. Application of weld overlays alters the local stress distribution. A detailed finite element analysis (FEA) is therefore conducted to investigate stress conditions under various operational transients. The results are summarized in this report to certify that criteria per ASME. Code Section III for Class 1 components, Reference 13.1, are satisfied for the surge nozzle with weld overlays.

The analysis is focused on the overlaid region for requirements on both stress distribution and fatigue failure criterion. The main scope of the analysis includes the surge line piping, the stainless steel weld between the safe end and the piping, the safe end, the DM weld between the safe end and the nozzle, the surge nozzle, SWOL, and the pressurizer lower head. In addition, post-processing of thermal and structural results is performed to provide data for fracture analysis of the surge nozzle (see Appendix A).

It should be noted that the original nozzle configuration without the Weld Overlay is not analyzed in this calculation. The application of the SWOL will increase the secondary stress due to thermal gradients and added discontinuities at the SWOL to Pipe, and SWOL to Nozzle junctures. The cumulative fatigue usage factors calculated in this document assume the Surge Nozzle SWOL has been in place since the plant conception. Therefore, the usage factors calculated will be higher than the actual usage factors based on summing Surge Nozzle's usage prior to SWOL and usage with the SWOL.

Prepared by: M. Sedlakova Reviewed by: L. Yen

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

2. ANALYTICAL METHODOLOGY

The general methodology of model development and stress analysis consists of:

- 1) Building a two-dimensional axisymmetric model of the Pressurizer Surge Nozzle. The model incorporates the geometry (of the adjacent lower head, nozzle, safe end, welds, weld overlay, and piping), appropriate materials, and boundary conditions. The 2-D Solid model is converted into a 2-D finite element model. There are two finite element models consisting of thermal and structural elements, respectively, to enable the thermal and structural analysis.
- 2) Applying the design conditions of pressure and temperature (as temperature affects the material properties only) to the structural finite element model and obtaining the deformation and stresses in the model. The deformation field is used to verify the correct behavior of the model and correct modeling of boundary and load conditions.
- 3) Applying the thermal loads resulting from the plant operating transients (in the form of transient temperatures and corresponding heat transfer coefficients versus time). Evaluating the results of the thermal analysis by examining the magnitude of temperature differences between key locations of the model. The time points of the maximum temperature gradient are those at which the maximum thermal stresses develop.
- 4) Applying the corresponding pressure and thermal loads (nodal temperature) at each time point identified in step 3 and other time points of analytical interest on the structural finite element model and obtaining the stress results.
- 5) Hand calculating the effects due to nozzle external loads and adding the resulting stresses to the stress results due to pressure and temperature effect.
- 6) Comparing the results to the ASME Code for acceptability.
- 7) Documenting stresses and temperatures for the fracture mechanics analysis of the surge nozzle weld overlay design.

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	NON PROPRINT A DIV
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

3. KEY ASSUMPTIONS

There are no major assumptions for this calculation. Minor assumptions are noted where applicable.

Date: 12/2007 Date: 12/2007

(

A

32-9049387-001

4. **DESIGN INPUT**

4.1 GEOMETRY

Major parts of the Surge Nozzle Weld Overlay are shown in Figure 4-1. The detailed dimensions of the surge nozzle design are shown in References 13.5 and 13.6 as noted.

Drossunizon I away Hand Inside Dadius to Dass Matel		
Pressurizer Lower Head Inside Radius to Base Mietal	_	
Pressurizer Lower Head Base Metal Thickness	=	
Pressurizer Lower Head and Nozzle Cladding Thickness	=	
Pipe ID	=	
Pipe OD	=	
Safe End Top OD	=	
Safe End Top ID	=	
Thermal Sleeve Weld ID	=	
Thermal Sleeve ID	=	
Thermal Sleeve OD	=	
Surge Nozzle ID	=	
Surge Nozzle OD at Weld	=	
Nozzle OD (near head)	=	
Nozzle OD (at nozzle to head weld)	=	
Max Weld Overlay Length	=	
Max Weld Overlay Thickness (at nozzle side)	=	
Min Weld Overlay Length	==	· · ·
Min Weld Overlay Thickness (at nozzle side)	=	

The model shown in Figure 4-1 simulates, in two-dimensional space, the surge nozzle, surge nozzle safe end, and part of adjacent pressurizer vessel closure head. Since the surge nozzle is radial with respect to the spherical head, an axisymmetric model is used. The modeled portion of pressurizer head extends to 30 degrees from the axis of symmetry. This is considered sufficient for the stresses and thermal gradients to attenuate.

(

A	NORTH ANNA UNITS 18	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PL ANT'	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY



4.2 FINITE ELEMENT MODEL

The finite element analysis in this document is performed using ANSYS 10.0 (Reference 13.10). The model was developed in ANSYSWORKBENCH 10.0 and is shown in Figure 4-2 and Figure 4-3. The output files documenting the Nozzle geometry are listed in Section 12. The element type chosen is the structural element PLANE183 (2-D 8-Node Structural Solid). This element type is converted to element PLANE77 (2-D 8-Node Thermal Solid) for the thermal analysis.

Prepared by: M. Sedlakova Reviewed by: L. Yen

Λ	NORTH ANNA UNITS 18	2, PRESSURIZER SURGE NOZZLE V	VELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY



· A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE V	WELD OVERLAY ANALYSIS
R	DOCUMEN I'NUMBER	PLANT	NON PROPRIETARY
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 4-3 Finite Element Model – Detail View of SWOL Region (Maximum Configuration Shown)

Prepared by: M. Sedlakova Reviewed by: L. Yen

AREVA NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS
DOCUMENT NUMBER
PLANT
32-9049387-001
North Anna Units 1 & 2
NON-PROPRIETARY

4.3 MATERIALS

Reference 13.7 provides the component material designations of various components:

Pressurizer Lower Head	
Surge Nozzle	
Nozzle to Upper Head Weld	
Safe End	
Nozzle to Safe End Weld	
Buttering Weld	
Thermal Sleeve	
Pipe	
Safe End to Pipe Weld	
Head Internal Cladding	
Weld Overlay	

The analysis herein uses the thermal properties – mean coefficient of thermal expansion (α), specific heat (C), thermal conductivity (k), and the mechanical properties – modulus of elasticity (E), Poisson's ratio (μ), density (ρ). The pertinent properties (thermal & structural) for these materials are listed in Reference 13.15.

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

i

Λ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

4.4 BOUNDARY CONDITIONS AND LOADS

4.4.1 Thermal analysis

During operation, the inside surfaces of the Pressurizer and the inside bore surfaces of the Surge Line Nozzle are in contact with the reactor coolant. Appropriate heat transfer coefficients and bulk temperatures versus time for each region shown in Figure 4-4 are applied on these surfaces. The reactor coolant temperature varies with time depending upon the service load condition that is being applied and has been defined thoroughly in Reference 13.16.

The outside surface of pressurizer head and surge nozzle is exposed to the ambient temperature in conjunction with a small HTC. An ambient temperature of 70°F is conservatively used for all time points in the thermal analysis. Reference 13.16 specifies that a small HTC of be used in the analysis.

4.4.2 Structural Analysis

Pressure is applied to all exposed interior surfaces of the Pressurizer Lower Head and Nozzle. The exterior surfaces of the Pressurizer Lower Head and Nozzle are not loaded by pressure. End Cap pressure is applied to the upper end of the Piping to represent the hydrostatic end load from the piping closure.

End Cap Pressure is calculated by multiplying Pressurizer Pressure by the quantity $\left(-\frac{d^2}{D^2-d^2}\right)$.

Where:

d = ID of the piping D = OD of the piping

The boundary conditions for the structural analysis are set to have zero displacement in the circumferential direction (from the nozzle axis) and at the plane of symmetry.

Coupling is not used in the structural analysis between the Safe End and Thermal Sleeve in the Thermal Sleeve Weld vicinity. Internal pressure, as discussed in Section 8, is applied to either side of the interface.

Prepared by: M. Sedlakova Reviewed by: L. Yen

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS
DOCUMENT NUMBER PLANT

AREVA DOCUMENT NUMBER

A

32-9049387-001

North Anna Units 1 & 2

NON-PROPRIETARY

Figure 4-4 Surfaces for Thermal Boundary Conditions

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007 Page 20

Λ	NORTH ANNA UNITS 18	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

5. EXTERNAL LOADS

Per Reference 13.16, the external forces and moments acting on the Surge Nozzle Safe End Weld location (Figure 5-1) are listed in Table 5-1. Table 5-2 lists the external loads due to Thermal Stratification only per Reference 13.8. These loads are defined in the local coordinate system with the "y" axis oriented along the nozzle axis of symmetry in the nozzle to pipe direction.

OBE + Thermal ⁽¹⁾	Fy (Axial) <i>lbs</i>	Fx lbs	Fz lbs	Fs (Shear) ⁽²⁾ <i>lbs</i>	Mtx (Torsional) in-lbs	Mx in-lbs	Mz in-lbs	Mb (Bending) ⁽³⁾ in-lbs
Unit 1 Piping	$\boldsymbol{\zeta}$. *		
Unit 2 Piping								
Vessel Spec.								
Enveloped Loads			I	1				厂

Table 5-1 Applicable External Loads

Note ⁽¹⁾: DW loads are not included in the tabulated values since this calculation is for the P+Q evaluation of the stress intensity range. Deadweight loads act at all time points of all transients, and therefore do not contribute to the stress intensity ranges. Hence their omission is appropriate

Note ⁽²⁾: Shear is calculated as the SRSS of Fx and Fz.

Note ⁽³⁾: Bending is calculated as the SRSS of Mx and Mz.

These loads are evaluated using hand calculation and the stresses due to these loads are added to the ANSYS results where appropriate for ASME evaluation.

Δ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 5-2 Applicable Loads Due to Thermal Stratification

Thermal Load Cases ⁽¹⁾	Plant Unit	Fy (Axial) <i>lbs</i>	Fx lbs	Fz Ibs	Fs (Shear) ⁽²⁾ <i>lbs</i>	Mtx (Torsional) in-lbs	Mx in-lbs	Mz in-lbs	Mb (Bending) ⁽³⁾ in-lbs
, .			·						
		. *	,	, ·					
						·		··	· ·.
			~1			;	· .		
► Note	⁽¹⁾ . Per Referen	ce 13.8						·	
Note Note Note	 ⁽¹⁾: Per Referen ⁽²⁾: Shear is calc ⁽³⁾: Bending is c 	ce 13.8 culated as th calculated as	e SRSS of the SRSS	Fx and Fz of Mx and	d Mz.				

Prepared by: M. Sedlakova Reviewed by: L. Yen

Date: 12/2007 Date: 12/2007

;

Α	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
K	DOCUMENI NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

5.1 NOZZLE CROSS SECTION CHARACTERISTICS

The nozzle geometric dimensions are specified in References 13.5 and 13.6. Based on these dimensions, the cross sectional characteristics (Table 5-3 and Table 5-4) are calculated for the locations depicted in Figure 5-1.

|--|

Poth Nama	D	d	I	SOD	SID	A	L
rath Name	[in]	[in]	[in ⁴]	[in ³]	[in ³]	[in ²]	[in]
PipeL		1		1			゛゛゛
P_Wol						.*	
SEU_Weld	Ŋ						П
SEU_Wol	T						
SEL_Wol							Π
SEL_Weld	1						Π
N_Wol				,			П
Noz	<u>ال</u>	· · · ·	1	1		I	、フ

Note ⁽¹⁾: For path lines PipeL and P_Wol, the stress intensity due to axial bending stress from external shear forces would reduce the stress intensity due to transient loads. Therefore, the vertical distances from path line SEU_Weld to PipeL and P_Wol are conservatively reduced to zero.

Doth Norma	D	d	I	SOD	SID	A .	L
rain Name	[in]	[in]	[in ⁴]	[in ³]	[in ³]	[in ²]	[in]
PipeL	$\boldsymbol{\boldsymbol{\wedge}}$	1	1	1			ノ
P_Wol	1				,		
SEU_Weld	,						
SEU_Wol	1						
SEL_Wol	1						
SEL_Weld	Π						
N_Wol	Π						
Noz		,					ノ

Table 5-4 Nozzle Cross Sectional Characteristics (Minimum WOL)

Note ⁽¹⁾: For path lines PipeL and P_Wol, the stress intensity due to axial bending stress from external shear forces would reduce the stress intensity due to transient loads. Therefore, the vertical distances from path line SEU_Weld to PipeL and P_Wol are conservatively reduced to zero.

Prepared by: M. Sedlakova Reviewed by: L. Yen

. ^	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS								
	DOCUMENT NUMBER	PLANT	NON PROPRIETADY						
AREVA	32-9049387-001	North Anna Units 1 & 2	NUN-PROPRIETARY						
Where:			· · · · · · ·						

- outside diameter D- inside diameter d $I = \frac{\pi}{64} \left(D^4 - d^4 \right)$ - moment of inertia $S_{OD} = \frac{I}{D/2}$ - section modulus of the nozzle - outside diameter $S_{ID} = \frac{I}{d/2}$ - section modulus of the nozzle - inside diameter $A=\frac{\pi \left(D^2-d^2\right)}{4}$ - cross-section area of the nozzle L - moment arm Figure 5-1 Path Definitions for External Loading

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS							
A	DOCUMENT NUMBER	PLANT						
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY					

5.2 APPLICABLE STRESS INTENSITY DUE TO EXTERNAL LOADS FOR PRIMARY + SECONDARY QUALIFICATION

The Surge Nozzle Weld Overlay is exposed to the external loads. The total stress intensities applicable for primary + secondary qualification due to these loads are calculated here.

The membrane stress due to internal pressure is not considered here, since this is already included in the ANSYS transient run. Thus only OBE and thermal operating external loads (TH) are applicable for calculation in this section.

The membrane + bending stress intensities due to external loads from Table 5-1 and due to thermal stratification only from Table 5-2 are calculated as follows:

 $\sigma_{ax_EX} = \frac{F_y}{A} - \text{axial membrane stress due to external axial force (F_y)}$ $\sigma_{ax_BM} = \frac{M_b}{S} - \text{axial bending stress due to external bending moment (M_b)}$ $\sigma_{ax_BF} = \frac{F_s \cdot L}{S} - \text{axial bending stress due to external shear force (F_s)}$ $\tau_{s_F_s} = \frac{F_s}{A} - \text{shear stress due to external shear force (F_s)}$ $\tau_{s_M_t} = \frac{M_{tx}}{2 \cdot S} - \text{shear stress due to external torsion moment (M_{tx})}$

- membrane + bending stress intensity range

where:

 $\operatorname{Sint} = \sqrt{\sigma_{ax}^2 + 4 \cdot \tau_s^2}$

 $\sigma_{ax_M+B} = \sigma_{ax_EX} + \sigma_{ax_MB} + \sigma_{ax_BF} - \text{axial membrane + bending stress}$ $\tau_s = \tau_{s_F_s} + \tau_{s_M_s}$

- shear stress due to external shear force and torsion moment

Α	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETAR				

The maximum stress intensities due to external loads (Thermal, OBE) are listed together with the stress components in Table 5-5 (Maximum WOL) and Table 5-6 (Minimum WOL). These stress intensities will be used in the ASME Code evaluation for primary + secondary stresses and fatigue in the nozzle regions (Section 9). Additional stress intensities due to thermal stratification only are listed together with the stress components in Tables 5-7 through 5-16 for each load case. These stress intensities will be included to account for subcycles of thermal stratification during fatigue evaluation (Section 9.2.4).

		Axi	al Stress			Shear Stress	3	M+B
Loading	σ _{ax_EX}	σ_{ax_BF}	σ _{ax_BM}	σ_{ax_M+B}	τ_{s_Fs}	τ _{s_Mt}	τ _s	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diame	eter							~
PipeL	7							
P_Wol								
SEU_Weld								
SEU_Wol								
SEL_Wol								
SEL_Weld]							
N_Wol	,				*			
Noz								
Outside Dian	n							
PipeL	1							
P_Wol	1							
SEU_Weld								_
SEU_Wol								
SEL_Wol	I							
SEL_Weld								
N_Wol								
Noz	Δ							

Δ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

Table 5-6 Primary + Secondary SI Due to External Loads (Min WOL)

		Axi	al Stress			Shear Stress	1	M+B
Loading	σ_{ax_EX}	$\sigma_{ax_{BF}}$	σ_{ax_BM}	σ _{ax_M+B}	τ _{s_Fs}	τ _{s_Mt}	τ _s	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diame	ter							~
PipeL	7							N
P_Wol								
SEU_Weld								
SEU_Wol								
SEL_Wol								·
SEL_Weld						•		
N_Wol								
Noz								
Outside Diam	e .							
PipeL								
P_Wol								
SEU_Weld]							
SEU_Wol								
SEL_Wol					,			
SEL_Weld								
N_Wol							•	ļ
Noz	7							· /

Prepared by: M. Sedlakova Reviewed by: L. Yen

Date: 12/2007 Date: 12/2007

ŧ

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

Table 5-7 Primary + Secondarv SI Due to Thermal Stratification Load Case HU-(Max WOL)

		Axi	al Stress			Shear Stress		M+B
Loading	σ_{ax_EX}	$\sigma_{ax_{BF}}$	σ _{ax_BM}	σ_{ax_M+B}	τ_{s_Fs}	τ _{s_Mt}	τ _s	Sint
	[ksi]	[ksi]	· [ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diamet	er							-
PipeL				3				
P_Wol	/			·				· · \
SEU_Weld								
SEU_Wol								
SEL_Wol	•							
SEL_Weld								
N_Wol								
Noz								
Outside Diar							•	
PipeL								
P_Wol								-
SEU_Weld	,							
SEU_Wol								
SEL_Wol	7							•
SEL_Weld							,	
N_Wol								
Noz	\mathbf{Z}							

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE	WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 5-8 Primary + Secondary SI Due to Thermal Stratification Load Case HU-()(Min WOL)

Loading		Axia	l Stress			Shear Stress	3	M+B
•	σ_{ax_EX}	$\sigma_{ax_{BF}}$	$\sigma_{ax_{BM}}$	σ _{ax_M+B}	τ _{s_Fs}	τ _{s_Mt}	τ _s	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diamet	er			. ••				~
PipeL				· · ·				· 7
P_Wol								~
SEU_Weld								ь.
SEU_Wol								, ,
SEL_Wol								
SEL_Weld								
N_Wol								
Noz		·			•			
Outside Diam								
PipeL								۰.
P_Wol								
SEU_Weld			<i>2</i>					
SEU_Wol								
SEL_Wol		,					я́.	
SEL_Weld			· .					
N_Wol	1							J
Noz	$\overline{7}$					•		

Prepared by: M. Sedlakova Reviewed by: L. Yen

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

Table 5-9 Primary + Secondary SI Due to Thermal Stratification Load Case HU () (Max WOL)

Loading		Axi	al Stress			Shear Stress		M+B
	$\sigma_{ax_{EX}}$	$\sigma_{ax_{BF}}$	σ _{ax_BM}	σ_{ax_M+B}	τ _{s_Fs}	τ _{s_Mι}	, τ _s .	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diamet	er							/
PipeL	7			,				
P_Wol				ţ				
SEU_Weld							,	
SEU_Wol								
SEL_Wol								
SEL_Weld								
N_Wol								
Noz					1			1.
Outside Diam								
PipeL								
P_Wol								
SEU_Weld								
SEU_Wol								
SEL_Wol								
SEL_Weld								
N_Wol								
Noz	7							_ /

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT						
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY					

Table 5-10 Primary + Secondary SI Due to Thermal Stratification Load Case HU-() (Min WOL)

Loading		Axia	al Stress			Shear Stress	,	M+B
•	σ _{ax_EX} [ksi]	σ _{ax_BF} [ksi]	σ _{ax_BM} [ksi]	σ _{ax_M+B} [ksi]	τ _{s_Fs} [ksi]	τ _{s_Mt} [ksi]	τ _s [ksi]	Sint [ksi]
Inside Diame	ter	·						
PipeL								
P_Wol	7					· .		
SEU_Weld	,							
SEU_Wol								
SEL_Wol								
SEL_Weld								
N_Wol						•		
Noz								
Outside Dian								
PipeL					· ·			
P_Wol								
SEU_Weld								,
SEU_Wol								
SEL_Wol								
SEL_Weld								
N_Wol								
Noz								
						•		

Prepared by: M. Sedlakova Reviewed by: L. Yen

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
AREVA	DOCUMENT NUMBER	PLANT					
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

Table 5-11 Primary + Secondary SI Due to Thermal Stratification Load Case HU-

Loading		Axia	al Stress			Shear Stress		M+B
	σ_{ax_EX}	$\sigma_{ax_{BF}}$	$\sigma_{ax_{BM}}$	σ _{ax_M+B}	τ_{s_Fs}	τ _{s_Mt}	τ _s	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diamet	er					,		
PipeL	7							
P_Wol								· · · · · ·
SEU_Weld								
SEU_Wol								
SEL_Wol								
SEL_Weld		×.					•	
N_Wol								
Noz								
Outside Diar								
PipeL								
P_Wol								
SEU_Weld								
SEU_Wol								1
SEL_Wol								
SEL_Weld			· ·					
N_Wol		•						
Noz	7		•					

Prepared by: M. Sedlakova Reviewed by: L. Yen

.

. 🔥	NORTH ANNA UNITS 1&	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
AREVA	DOCUMENI NUMBER	PLANI						
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY					

Table 5-12 Primary + Secondary SI Due to Thermal Stratification Load Case HU () (Min WOL)

Loading	Axial Stress				Shear Stress		M+B	
	σ_{ax_EX}	𝕶 _{ax_BF}	$\sigma_{ax_{BM}}$	σ_{ax_M+B}	τ_{s_Fs}	τ _{s_M1}	τ _s	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diamet	er					-		
PipeL	7							
P_Wol					e.			
SEU_Weld		,						
SEU_Wol								
SEL_Wol								•
SEL_Weld						4		
N_Wol			·					
Noz			2 V	. ·				
Outside Diam							•	
PipeL								
P_Wol								
·SEU_Weld								
SEU_Wol								
SEL_Wol								
SEL_Weld								۰.
N_Wol						••		
Noz	7				•			· /

Prepared by: M. Sedlakova Reviewed by: L. Yen
Λ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
R	DOCUMENT NUMBER	PLANT ·	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 5-13 Primary + Secondary SI Due to Thermal Stratification Load Case HU (Max WOL)

Loading		Axi	al Stress			Shear Stress	5	M+B
	σ_{ax_EX}	σ_{ax_BF}	$\sigma_{ax_{BM}}$	σ_{ax_M+B}	τ _{s_Fs}	τ _{s_Mt}	τ _s	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diamet	er							-
PipeL	7					· ·		
P_Wol								
SEU_Weld								
SEU_Wol								
SEL_Wol				•				
SEL_Weld								
N_Wol								
Noz								
Outside Dian								
PipeL								
P_Wol								
SEU_Weld								
SEU_Wol								
SEL_Wol								
SEL_Weld								
N_Wol								
Noz								

Α	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
	DOCUMENT NUMBER	PLANT			
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY		

Table 5-14 Primary + Secondary SI Due to Thermal Stratification Load Case HU (Min WOL)

Loading		Axia	al Stress			Shear Stress		M+B
	σ_{ax_EX}	σ_{ax_BF}	σ_{ax_BM}	σ_{ax_M+B}	τ _{s_Fs}	τ _{s_Mt}	τ _s	Sint
	[ksi]	[ksi].	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diamet	er							
PipeL	Z							
P_Wol	7							
SEU_Weld							,	
SEU_Wol								
SEL_Wol								
SEL_Weld			÷.					
N_Wol								
Noz		J						
Outside Diar								
PipeL								
P_Wol			}		•			
SEU_Weld								
SEU_Wol								
SEL_Wol								
SEL_Weld								
N_Wol								/
Noz								

.

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 5-15 Primary + Secondary SI Due to Thermal Stratification Load Case OP-()(Max WOL)

Loading		Axia	al Stress			Shear Stress	· · · · · · · · · · · · · · · · · · ·	M+B
	σ_{ax_EX}	σ_{ax_BF}	σ_{ax_BM}	σ _{ax_M+B}	τ_{s_Fs}	τ _{s_Mt}	τ,	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diamet	er							/
PipeL	7							N
P_Wol								
SEU_Weld								
SEU_Wol								
SEL_Wol								
SEL_Weld			-					
N_Wol								
Noz								
Outside Diar								
PipeL								
P_Wol								
SEU_Weld								• •
SEU_Wol								
SEL_Wol	,					•		
SEL_Weld				1				
N_Wol	•							
Noz	\mathbf{Z}							

Prepared by: M. Sedlakova Reviewed by: L. Yen

Λ.	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 5-16 Primary + Secondary SI Due to Thermal Stratification Load Case OP-(Min WOL)

Loading		Axi	al Stress		· · · · · · · · · · · · · · · · · · ·	Shear Stress	3	M+B
	σ_{ax_EX}	σ_{ax_BF}	σ_{ax_BM}	σ_{ax_M+B}	τ_{s_Fs}	τ _{s_Mt}	τ _s	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
Inside Diamet	er							/
PipeL	7	•						∇
P_Wol								
SEU_Weld								
SEU_Wol								
SEL_Wol							•	
SEL_Weld								
N_Wol				-				
Noz								
Outside Diar								
PipeL						`		
P_Wol								
SEU_Weld	,							
SEU_Wol								· !
SEL_Wol		•						
SEL_Weld								
N_Wol								/
Noz	$\overline{7}$							

Λ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	NON DECEMPTA DI
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

6. DESIGN CONDITION

The pressurizer assembly was designed to satisfy the ASME Code Criteria when operating at a pressure of () at temperature of () (Reference 13.8). These design conditions were simulated by setting a uniform temperature of () throughout the model (this temperature is only used to define material properties and not thermal expansion) and a uniform pressure of on all inside surfaces. The Lower end of the Surge Nozzle Piping has the pressure applied to represent the hydrostatic end load. Also, pressure is applied to the assumed boundary edge at the end of Surge Line Piping. The ANSYS output file for the design condition stress analysis is () for maximum and minimum WOL respectively.

Stress analysis of the model under design pressure case served two important purposes. It provides a basis for verification of the correct behavior of the model as well as boundary conditions. Stresses from the design pressure run are used to evaluate the primary stresses in the model in Section 9. Attenuation of stress effects at regions distant from the nozzle is also verified.

Figure 6-1 shows the deformed shape of the Maximum WOL model under the design pressure along with the outline of the un-deformed shape. The stress intensity contours developed in the Maximum WOL model under design pressure are shown in Figure 6-2 and Figure 6-3.

Prepared by: M. Sedlakova Reviewed by: L. Yen



Figure 6-1 Deformed Shape versus Un-deformed Outline

Date: 12/2007 Date: 12/2007

REVA	DOCUMENT NUMBER 32-9049387-001	PLANT North Anna Units 1 & 2	NON-PROPRIETA
			\sim
(· · ·	^
	А. А. А.		
	• •		
		· · · · ·	
-			
	λ.		
,			
l l			
\mathbf{X}			

Date: 12/2007 Date: 12/2007

Λ	NORTH ANNA UNITS 1&	22, PRESSURIZER SURGE NOZZLE	WELD OVERLAY ANALYSIS
	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY
		. ·	

Figure 6-3 Stress Intensity Contours at Design Condition Boundaries (Maximum WOL Shown)

Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
A	DOCUMENT NUMBER	PLANT	NON PROPRINT A DIV			
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY			

7. THERMAL ANALYSIS

The operating thermal loads are defined by the thermal transient conditions as contained in Reference 13.16. A summary of the applicable Service Level A (Normal) and Service Level B (Upset) transients including the applicable design cycles, is shown below in Table 7-1. The numbers of cycles listed below correspond to 60 years of pressurizer design life.

Transient ID Number	Operating Cycle	Name Abbreviation	Occurrences	Operating Condition
1	Unit heatup at HL surge nozzle	1		
2	Unit cooldown at HL surge nozzle	ſ	E	
3	Plant Loading at 5% power per minute			
4	Plant Unloading at 5% power per minute			Normal
5	10% step load increase			
6	10% step load decrease			
7	Large step decrease in load			
8	Loss of load		L	
9	Loss of power			Upset
10	Loss of flow in one loop			
11	Feedwater cycling at hot shutdown			Normal
12	Boron Concentration Equalization			Normai
13	Reactor trip with no cooldown			
14	Reactor trip with cooldown but no safety injection		Ľ	
15	Reactor trip with cooldown and safety injection			
16	Inadvertent reactor coolant system		Γ	Upset
10	depressurization			opoor
17	Inadvertent startup of an inactive loop		Ļ	
18	Control rod drop		· [
19	Inadvertent safety injection actuation		Ļ	
20	Steady state fluctuations ⁽¹⁾		Ĺ	Normal
21	Turbine roll test		L	Test
22	Loop out of service normal loop shutdown			Normal
23	Loop out of service normal loop startup			Normal
24	RCS cold overpressurization			Upset
25	Heatup and Cooldown Surge Flow Details H1-H6			Normal
	and C1-C7, Subcycles of Heatup and Cooldown		ŀ	
26	Thermal Stratifications			Normal

Table 7-1 Transients

Note: ⁽¹⁾ These small fluctuations create small stresses that are negligible compared to other transients.

Prepared by: M. Sedlakova Reviewed by: L. Yen

Λ.	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE V	VELD OVERLAY ANALYSIS
R	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

The Cooldown Transient was combined with the Heatup Transient. Only the times were changed to set zero mark at 27 hours for Cooldown. Similarly, the Plant Unloading transient was combined with Plant Loading with its start time set to 0.4444 hours. The detailed thermal loading due to these transients were applied to the thermal finite element model in the form of fluid and steam temperatures and HTC versus time.

The computer input files containing definition of these transients are:

The computer output files for the thermal analyses of the transients are:

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007

Λ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	. 32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

The results of the thermal analyses are evaluated by examining the magnitude of temperature differences between key locations of the model (see Figure 7-1). The time points of the maximum temperature gradient are those at which the maximum thermal stresses develop.

The computer output files that provide the temperatures at the selected locations are:

Added transients for insurge and outsurge are defined in Attachment 12 of Reference 13.8. The two added transients, IOSurge and IOSurge110 are described in Appendix D. All files and supporting information are presented in Section D.2.

^	NORTH ANNA UNITS 18	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

The temperature gradients between these key locations (See Figure 7-1) are also listed in the above output files. The Thermal gradient for each transient are plotted in Figure 7-2 through

Figure 7-22 for the maximum WOL configuration only. The minimum configuration thermal plots look very similar to those of the maximum. These figures are used only to show the trend. Specific data are taken from the computer output files.

Location Designation in ANSYS DT Files	Max WOL Node No.	Min WOL Node No.	Location Description
2	3145	2412	Mid thickness in Piping lower than SWOL region
3	3774	3480	Mid thickness in lower SWOL
4&6	6350	6105	Inside surface of Piping in SWOL Region
5	6193 .	5950	Outer surface of lower SWOL
7	6159	6001	Outer surface of SWOL horizontal with Pipe-to Safe End Weld
8	5135	4968	Inside surface of Nozzle above the Safe End-to- Nozzle Weld
9	6134	6073	Outer surface of SWOL horizontal with Location 8
10	5179	Not Analyzed	Inside surface of Nozzle at Mouth
11	4969	Not Analyzed	Outer surface of Nozzle at Nozzle-to-Head Transition

 Table 7-2 Nodes of Interest for Evaluation of Temperature Gradients

Table 7-9 Temperature Oradients of Interest	Table '	7-3	Temperature	Gradients	of Interest
---	---------	-----	-------------	-----------	-------------

Gradient Designation in ANSYS DT Files	Gradient Location	Gradient Description
21	2 to 3	Lower Piping to SWOL
22	4 to 5	Inside Piping to Outer SWOL
23	7 to 6	Inside Piping to Outer mid-SWOL
24	9 to 8	Outer SWOL to Nozzle Annulus Surface
25	11 to 10 _	Outer Nozzle-to-Head Transition to Inside Surface Nozzle Mouth

A	NORTH ANNA UNITS 18	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Note: Nodes were not selected at the nozzle mouth region in Minimum Weld Overlay. That area is far enough away from the weld overlay region



Δ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-2 Temperature and Temperature Gradients for Surge Plant Heatup/Cooldown Transients for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-3 Temperature and Temperature Gradients for Surge Plant Loading/Unloading Transients for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

$A \vdash$			
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-4 Temperature and Temperature Gradients for Surge 10% Step Load Increase Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNITS	3 1&2, PRESSURIZER SURGE NOZZLE WEL	D OVERLAY ANALYSIS
AREVA	document number 32-9049387-001	PLANT North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-5 Temperature and Temperature Gradients for Surge 10% Step Load Decrease Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNIT	TS 1&2, PRESSURIZER SURGE NOZZLE WEL	D OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-6 Temperature and Temperature Gradients for Surge Large Step Decrease in Load for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
·	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-7 Temperature and Temperature Gradients for Surge Loss of Load for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

Δ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-8 Temperature and Temperature Gradients for Surge Loss of Power Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-9 Temperature and Temperature Gradients for Surge Loss of Flow Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
·	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-10 Temperature and Temperature Gradients for Surge Feedwater Cycling at Hot Shutdown Transient for Maximum WOL Configuration

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-11 Temperature and Temperature Gradients for Surge Boron Concentration Equalization Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A		S 1&2, PRESSURIZER SURGE NOZZLE WELL	DOVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER	PLANT	
-	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-12 Temperature and Temperature Gradients for Surge Reactor Trip with No Cooldown Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNIT	IS 1&2, PRESSURIZER SURGE NOZZLE WEL	D OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

¢

Figure 7-13 Temperature and Temperature Gradients for Surge Reactor Trip with Cooldown but no Safety Injection Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY



Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNIT	S 1&2, PRESSURIZER SURGE NOZZLE WEL	D OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-15 Temperature and Temperature Gradients for Surge Inadvertent Reactor Coolant System Depressurization Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNIT	'S 1&2, PRESSURIZER SURGE NOZZLE WEL	D OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-16 Temperature and Temperature Gradients for Surge Control Rod Drop Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-17 Temperature and Temperature Gradients for Surge Inadvertent Startup of an Inactive Loop Transient for Maximum WOL Configuration

Date: 12/2007 Date: 12/2007

AREVA	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-18 Temperature and Temperature Gradients for Surge Inadvertent Safety Injection Actuation Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

Δ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-19 Temperature and Temperature Gradients for Surge Turbine Roll Test Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

Δ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-20 Temperature and Temperature Gradients for Surge Loop Out of Service Normal Loop Shutdown Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

AREVA	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-21 Temperature and Temperature Gradients for Surge Loop Out of Service Normal Loop Startup Transient for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007 Page 66

 \sim

Δ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Figure 7-22 Temperature and Temperature Gradients for Surge RCS Cold Overpressurization for Maximum WOL Configuration

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

Λ.	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

8. STRUCTURAL ANALYSIS

Stress analyses are performed at those time points which the maximum temperature gradients (maximum thermal stresses) in addition to those defining the transient in Reference 13.16. The nodal temperature at the particular time point is read into the structural model directly from the result file of the thermal analysis. The corresponding pressure is obtained through linear interpolation from appropriate tables listed in Reference 13.16. All time points of interest are also listed in Appendix B. The computer output files for the structural analyses are:



Added files for IOSurge and IOSurge110 transients added to account for the insurge and outsurge are documented in Appendix D, Section D.3.

Δ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT' NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

9. ASME CODE CRITERIA

The ASME Code stress analysis involves two basic sets of criteria:

- 1. Assure that failure does not occur due to application of the design loads.
- 2. Assure that failure does not occur due to repetitive loading.

In general, the Primary Stress Intensity criteria of the ASME Code (Reference 13.1) assure that the design is adequate for application of design loads.

Also, the ASME Code criteria for cumulative fatigue usage factor assure that the design is adequate for repetitive loading.

9.1 ASME CODE PRIMARY STRESS INTENSITY (SI) CRITERIA

Per NB-3213.8 of Reference 13.1, the primary stresses are those normal or shear stresses developed by an imposed loading such as internal pressure and external loadings. A thermal stress is not classified as a primary stress. The classification as well as the limit of primary stress intensity is specified in NB-3221 of Reference 13.1 for Design Conditions. The limit of primary stress intensity for Level B (Upset), Level C (Emergency), and Level D (Faulted) is specified in NB-3223, NB-3224, and NB-3225 of Reference 13.1, respectively.

As presented in Reference 13.14, the primary stress intensity criteria are the basic requirements in calculating the weld overlay size, which is under the assumption that a 360° circumferential flaw has grown completely through the original weld. Loading conditions in each service level have been considered in the weld overlay sizing calculation. The nozzle to piping region has been reinforced by the weld overlay since adding materials to the nozzle outside region relieves primary stress burden resulting from internal pressure and external loads. The overlay further reduces stress concentration by eliminating the outside surface discontinuity. Therefore, the primary stress intensity requirements for the surge nozzle, welds with overlay, safe end and piping have been satisfied for all service level loadings without the need for further evaluation.

Other related criteria include the minimum required pressure thickness (NB-3324 of Reference 13.1) and reinforcement area (NB-3330 of Reference 13.1), which were addressed in the original nozzle/pressurizer designs. Adding weld overlay will increase the nozzle wall thickness and therefore these requirements are satisfied.
~	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
X	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

9.2 ASME CODE PRIMARY+SECONDARY STRESS INTENSITY (SI) CRITERIA

As stated previously, the analyses of stresses for transient conditions are required to satisfy the requirements for the repetitive loadings. The following discussion describes the fatigue analysis process employed herein for the design.

Overall stress levels are reviewed and assessed to determine which model locations require detailed stress/fatigue analysis. The objective is to assure that:

1. The most severely stressed locations are evaluated.

2. The specified region is quantitatively qualified.

9.2.1 Path Stress Evaluation

The ANSYS Post Processor is used to tabulate the stresses along predetermined paths and classify them in accordance with the ASME Code Criteria (i.e., membrane, membrane plus bending, total). For paths that go through 2 materials partial paths are taken in addition to the free edge to free edge.

The paths are shown in Figure 9-1 and Figure 9-2 and are described in Table 9-1. For post processor calculation, the definitions of these paths are contained in the computer input files as follows:

Λ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE	WELD OVERLAY ANALYSIS
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 9-1 Path Descriptions

Path Name	Maximum	Maximum Weld Overlay		Weld Overlay
	Inside Node	Outside Node	Inside Node	Outside Node
PipeL	6289	6340	6172	6103
P_Wol	6290	6203	6216	5986
P_Wola	6290	6205	6216	5988
P Wolb	6205	6203	5988	5986
SEU_Weld	6426	6157	6244	6001
SEU_Welda	6426	6161	6244	16050
SEU_Weldb	6161	6157	16050	6001
SEU_Wol	6472	6213	6292	5947
SEU_Wola	6472	6209	6292	6012
SEU_Wolb	6209	6213	6012	5947
SEL_Wol	5230	6228	5060	5958
SEL Wola	5230	6226	5060	6038
SEL_Wolb	6226	6228	6038	5958
SEL_Weld	6437	6243	6255	6052
SEL Welda	6437	6240	6255	6054
SEL_Weldb	6240	6243	6054	6052
N_Wol	4935	6133	4803	6072
N_Wola	4935	5206	4803	5037
N_Wolb	5206	6133	5037	6072
Noz	4899	5039	4985	4868
NozL	5179	4969	NA	NA
Sleeve	5246	5249	5078	5081

٠.

· ∧	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE	WELD OVERLAY ANALYSIS
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Note: The full path is taken at the same location as the partial paths. The partial path name has the letter "a" or a "b" behind the full path name.

Figure 9-1 Path Locations in SWOL Region used for Stress Evaluation

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007





Λ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

9.2.2 Primary + Secondary Stress Intensity Range Qualification (NB 3222.2)

The ANSYS Post Processor was used to find the membrane + bending Stress Intensity Ranges and total Stress Intensity Ranges based on the method prescribed in paragraph NB-3216.2 of the ASME Code. The computer runs containing the results of the stress ranges calculation for membrane + bending, total stresses and associated usage factors are listed below. Additional transients added (IOSurge and IOSurge 110) are incorporated into computer runs listed in Appendix D, Section D.4.2.2. The Primary + Secondary qualifications presented in Appendix D supersede that presented in this and the following sections.



The membrane + bending stress ranges as determined in the stress range runs are conservatively combined by hand with the stresses due to external loads (calculated in Section 5.2) where appropriate. The maximum membrane + bending Stress Intensity Ranges are compared directly to the Primary + Secondary Stress Intensity Range criteria of the ASME Code. The summary of maximum membrane + bending Stress Intensity Ranges for maximum and minimum WOL configurations are tabulated in Table 9-2 through Table 9-6.

Note that the Zero Stress State (ZSS) is included in the ANSYS runs listed above.

Λ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 9-2 Summary of Maximum Primary + Secondary SI Ranges for Membrane +Bending Stresses (Maximum WOL)

	Transient Stresses		Applicable External Stresses		
Path	SI Range Inside Node [ksi]	SI Range Outside Node [ksi]	Maximum SI Inside Node [ksi]	Minimum SI Outside Node [ksi]	
PipeL					
P Wol					
P_Wola		*			
P_Wolb				· ·	
SEU_Weld					
SEU_Welda					
SEU_Weldb					
SEU_Wol					
SEU_Wola					
SEU_Wolb					
SEL_Wol					
SEL_Wola					
SEL_Wolb					
SEL_Weld	•				
SEL_Welda					
SEL_Weldb					
N_Wol			,		
N_Wola					
N_Wolb			,		
Noz					
NozL					
Sleeve				•	

Т

Table 9-3 Comparison of Maximum SI Range including External Loads to ASME Code 3*Sm Criteria (Maximum WOL)

	Transient + Ext	ernal Stresses	Allowable M+ 3*Sm ⁽¹⁾	-B SI Range	Material	
Path	SI Range Inside Node [ksi]	SI Range Outside Node [ksi]	Inside Node [ksi]	Outside Node [ksi]	Inside Node	Outside Node
PipeL						
P_Wol	7					
P_Wola		4				Γ
P_Wolb						
SEU_Weld						
SEU_Welda						
SEU_Weldb						[
SEU_Wol						[
SEU_Wola						ſ
SEU_Wolb		N				
SEL_Wol						~
SEL_Wola						Ť
SEL_Wolb						Ĩ
SEL_Weld						
SEL_Welda			·			
SEL_Weldb						
N_Wol						
N_Wola						
N_Wolb						ſ
Noz						ſ
NozL						
Sleeve						
						\sim
					•.)
•						
					i.	
,						
2 - A						
	,					·)

Date: 12/2007 Date: 12/2007

A		22, I RESOURCE NOZZEE W	ELD UVERLAT ANAL I SIS
AREVA	32_00/0297 001	PLANT North Anna Unita 1 & 2	NON-PROPRIETARY
	52-9049587-001	North Anna Units I & 2	
			· · ·
· · ·			A
			• · · · · · · · · · · · · · · · · · · ·
		·	
		. · · · · · · · · · · · · · · · · · · ·	· .
	· · ·		
	۰.		
		··· · ·	
			·.
		۲ ۲	
		•	
	. ·		
			•
			· · · · · · · · · · · · · · · · · · ·
·			
		•	
Prepared by: 1	M. Sedlakova	Date: 12/2007	Page 77

Г

ı

Т

٦

Λ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZLE	WELD OVERLAY ANALYSIS
X	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 9-4 External Stress Added by Components (Maximum WOL)

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY
·		, <u>I.,</u>	

 Table 9-4
 (Continued) External Stress Added by Components (Maximum WOL)



Table 9-5 Summary of Maximum Primary + Secondary SI Ranges for Membrane + Bending Stresses (Minimum WOL)

	Transient Stresses		Applicable Exter	rnal Stresses
Path	SI Range Inside Node [ksi]	SI Range Outside Node [ksi]	SI Range Inside Node [ksi]	SI Range Outside Node [ksi]
PipeL				
P_Wol	7			
P_Wola				
P_Wolb		н. — — — — — — — — — — — — — — — — — — —		
SEU_Weld				
SEU_Welda				·
SEU_Weldb				
SEU_Wol				
SEU_Wola				
SEU_Wolb				
SEL_Wol				4
SEL_Wola		4		
SEL_Wolb				
SEL_Weld	· .			
SEL_Welda				
SEL_Weldb			,	
N_Wol				
N_Wola		,		
N_Wolb				
Noz	\			
Sleeve				

Date: 12/2007 Date: 12/2007

Λ.	NORTH ANNA UNITS 1&	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
K	DOCUMENT NUMBER	PLANT ·		
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY	

Table 9-6 Comparison of Maximum SI Range including External Loads to ASMECode 3*Sm Criteria (Minimum WOL)

·····	Transient + Ex	ternal Stresses	Allowable M 3*Sm ⁽¹⁾	+B SI Range	Material	
Path	SI Range Inside Node [ksi]	SI Range Outside Node [ksi]	Inside Node [ksi]	Outside Node [ksi]	Outside Node	Inside Node
PipeL		· · · · · · · · · · · · · · · · · · ·				
P_Wol	4					
P_Wola	<u> </u>					_
P_Wolb	· ·					
SEU_Weld						
SEU_Welda						L
SEU_Weldb						
SEU_Wol						
SEU_Wola			· .			
SEU_Wolb					•	
SEL_Wol						
SEL_Wola	-11					
SEL_Wolb	-41					
SEL_Weld	- 4					
SEL_Welda	-11					·
SEL_Weldb						
N_Wol	-+					
N_Wola						
N_WOID	-11				`	
Noz	Ж					_ر
Sleeve						$ \rightarrow $
(
	,					
		:				
				· ,		
	· .					
					÷.,	
l)
					N	

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT		
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY	

Λ - ·	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
	DOCUMENT NUMBER	PLANT		
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY	

Table 9-7 External Stress Added by Components (Minimum WOL)

t

1

•	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT	NON DECENTION AND	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY	



(Continued) External Stress Added by Components (Minimum WOL)

Prepared by: M. Sedlakova Reviewed by: L. Yen

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT		
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY	

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT	NON DROBBIET ADI	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY	

9.2.2.1 Summary of Stress Intensity Range Qualification

Tables 9-3, 9-4, 9-6 and 9-7 show the maximum SI Range calculated and the allowable limits for both maximum and minimum weld overlay configurations. The following path locations for both configurations exceeded the allowable 3*Sm limit:

PipeL - inside and outside nodes (maximum and minimum WOL)

Sleeve - inside node (maximum WOL)

The ASME Code allows the 3*Sm limit to be exceeded under special conditions, one of them being that Simplified Elastic-Plastic Analysis (NB 3228.5) is used for fatigue analysis. See Section 9.2.3 for further qualifications.

9.2.3 Simplified Elastic-Plastic Analysis (NB-3228.5)

The maximum Primary + Secondary Stress Intensity criteria in Section 9.2.2 is not met for the locations determined in the Section 9.2.2.1. Therefore, the simplified elastic-plastic analysis for these locations is provided in this section.

The Primary + Secondary Stress Intensity range in the model may exceed $3*S_m$ if the requirements of the simplified elastic-plastic analysis are met. The requirements are:

9.2.3.1 Primary + Secondary SI Range (Excluding thermal bending stresses) (NB-3228.5(a))

The range of Primary + Secondary membrane + bending stress intensity, excluding thermal bending stresses, shall be ≤ 3 *Sm.

The SI ranges excluding thermal bending are calculated for the locations identified in Section 9.2.2.1. The membrane + bending ANSYS output files listed in Section 9.2.2 are used to find the stress components for membrane stress due to pressure and thermal conditions.

The bending stress due to pressure only is determined by multiplying the bending stress obtained from design linearization output files

with a pressure ratio. The ratio is based on the transient pressure at the time point of interest and design pressure. The ratioed bending stress is added to the membrane stress and external stress for determination of SI range without thermal bending effect.

The design condition is **()** The applied temperature affects only physical material properties, therefore the effect of thermal bending is considered to be negligible.

Tables 9-8 and 9-9 present the calculations and results for the maximum primary + secondary SI Ranges for membrane + bending – thermal bending stresses per NB-3228.5(a) for the maximum and minimum WOLs.

Ā	NORTH ANNA UNITS 1	&2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
K	DOCUMEN I NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 9-8 Maximum WOL SI Ranges Minus Thermal Bending

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
X	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 9-8 (Continued) Maximum WOL SI Ranges Minus Thermal Bending

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
R	DOCUMENT NUMBER	PLANT			
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY		

Table 9-9 Minimum WOL SI Ranges Minus Thermal Bending

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENI NUMBER	PLANT		
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY	

All SI Ranges listed in Tables 9-8 and 9-9 are less than the allowable stress, therefore the requirement of ASME NB-3228.5(a) has been met on all locations.

9.2.3.2 Factor Ke (NB-3228.5(b))

The values of S_a used for entering the design fatigue curve is multiplied by the factor K_c, where

$$K_e = 1.0 + \frac{1-n}{n \cdot (m-1)} \cdot \left(\frac{S_n}{3 \cdot S_m} - 1\right) \quad \text{for } 3 \cdot S_m < S_n < 3 \cdot m \cdot S_m$$
$$K_e = 1.0/n \quad \text{for } S_n \ge 3 \cdot m \cdot S_m$$

m = 1.7 for austenitic stainless steel from Table NB-3228.5 (b)-1 (Reference 13.1)

n = 0.3 for austenitic stainless steel from Table NB-3228.5 (b)-1 (Reference 13.1)

 S_m [ksi] (*a*) average temperature of the metal at the critical time points

S_n [ksi] Primary + Secondary membrane plus bending SI Range

The K_e factor is calculated for each SI Ranges over the $3S_m$ limit in the fatigue evaluation as documented in Section 9.2.4.

9.2.3.3 Fatigue Usage Factor (NB-3228.5(c) and NB-3222.4)

For fatigue usage factor evaluation see Section 9.2.4.

9.2.3.4 Thermal Stress Ratchet (NB-3228.5(d) and NB-3222.5)

Thermal Ratchet is considered for the locations listed in Section 9.2.2.1.

Some of these locations are parts of the local geometric discontinuities. The ASME Code requirements for thermal ratcheting are considered accurately only for cylindrical shells without discontinuities. On the other hand, the requirements for thermal ratcheting at discontinuities are considered to be "probably overly conservative" (Reference 13.12, page 207).

Maximum Allowable Range of Thermal Stress (NB-3222.5):

Tables 9-10 and 9-11 determine the maximum allowable ranges of thermal stresses in the piping and thermal sleeve. The values of allowable stresses are conservatively calculated based on the membrane stresses due to the design pressure **1**.

The "SINT" values are obtained from ANSYS output files () and).

NB-3222.5 only requires the SI Range to include thermal SI Ranges and those from the output files also contain pressure effects. The Thermal SI Ranges are calculated in Tables 9-12 and 9-13.

λ	NORTH ANNA UNITS 18	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
K	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Table 9-10 Allowable Ranges of Thermal Stresses for Maximum WOL

Path	SI Range ⁽³⁾	Average Temperature	Sm	1.5*Sm	Sy	SINT	x .	y'	Allowable SI Range
	[ksi]	[°F]	[ksi]	[ksi]	[ksi]	[ksi]	1		[ksi]
				• •					
								,	
					•			·	
-									
		•							ノ
Note ⁽¹⁾ : See T	able 9-4						· ·		

Note ⁽²⁾: See Table 9-3 Note ⁽³⁾: See Table 9-12

Table 9-11 Allowable Ranges of Thermal Stresses for Minimum WOL

Path	SI Range ⁽²⁾ [ksi]	Average TemperatureSm1.5*SmSy[°F][ksi][ksi]	SINT	x	у'	Allowable SI Range			
			[ksi]	[ksi]	[ksi]	[ksi]	1		[ksi]
<u>(</u>		· ·							
				•					
	11.07		· · ·						

Note ' ': See Table 9-7 Note ⁽²⁾: See Table 9-13

Where:

x = max. general membrane stress due to pressure ("SINT") divided by the yield strength $S_{y}^{(1)}$

$$y' = \frac{1}{x}$$
 for $0.0 < x < 0.5$; $y' = 4(1-x)$ for $0.5 < x < 1.0$

Maximum allowable range of thermal stress = $y' * S_{y}^{(1)}$

Note ⁽¹⁾: $1.5S_m$ is used instead of S_y. Per NB-3222.5, note 11, it is permissible to use $1.5S_m$ in this equation whenever it is greater than Sy.

The maximum SI Ranges of thermal stresses are less than the allowable stresses; therefore the requirement has been met.

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANI					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

Table 9-12 Thermal M+B SI Range for Maximum WOL

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANI					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

Table 9-12 (Continued) Thermal M+B SI Range for Maximum WOL

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS							
A	DOCUMENT NUMBER	PLANT						
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY					

Table 9-13 Thermal M+B SI Range for Minimum WOL

 	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
R	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

9.2.3.5 Temperature Limits (NB-3228.5(e))

The maximum temperature of the components is **(**) which does not exceed the maximum allowable temperatures listed in Table NB-3228.5(b)-1, Reference 13.1.

Therefore, the ASME Code requirement is met.

9.2.3.6 Minimum Strength Ratio (NB-3228.5(f))

The material shall have specified minimum yield strength to specified minimum tensile strength ratio of less then 0.80.

The S_y and S_u values at 70°F are obtained from Reference 13.15.

For Thermal Sleeve, Path 'Sleeve', \int Specified minimum yield strength, $S_y = 30 \text{ ksi } @70^\circ\text{F}$ Specified minimum tensile strength, $S_u = 75 \text{ ksi } @70^\circ\text{F}$ Ratio of $S_y/S_u = 0.4$

For Piping, Path 'PipeL', (Specified minimum yield strength, $S_y = 30 \text{ ksi } @70^{\circ}\text{F}$ Specified minimum tensile strength, $S_u = 75 \text{ ksi } @70^{\circ}\text{F}$ Ratio of $S_y/S_u = 0.4$

Therefore, the ASME Code requirement is met.

Λ	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

9.2.4 Fatigue Usage Factor Calculation

For consideration of fatigue usage, the Peak Stress Intensity Ranges are calculated. These values must include the total localized stresses.

The fatigue usage factor at a location is usually calculated based on the actual stress intensity range. However, at a geometric or material discontinuity, an unrealistic peak stress may result from the modeling approach, element type and mesh sizes. The total stress obtained from the finite element analysis may not be able to capture the actual stress condition. To account for the possible modeling inaccuracies, an FSRF is usually applied to the M+B stress intensity range for location experiencing the discontinuity.

The stress category used in fatigue evaluation, along with an appropriate FSRF, for each node is listed in Table 9-14. For path lines nearby the thermal sleeve weld (i.e., crevice), M+B stresses with a FSRF of 4.0 are applied. Per Reference 13.13 (p. 395), the FSRF for node on the inside and outside of the safe end component, outer nozzle, and pipe near WOL junction are based on a bounding taper angle.

Path Name	Inside Node	;	Outside Node		
	Stress Category	FSRF	Stress Category	FSRF	
PipeL	TOTAL	r n	M+B		
P_Wol	M+B		TOTAL		
P_Wola	M+B	1 0	TOTAL		
P_Wolb	TOTAL] []	TOTAL	TI - I	
SEU_Weld	M+B] []	TOTAL	TI · I	
SEU_Welda	M+B] []	M+B	Ţ	
SEU_Weldb	M+B	1 []	TOTAL		
SEU_Wol	M+B		TOTAL		
SEU_Wola	M+B] []	M+B		
SEU_Wolb	M+B	1 · 1	TOTAL	П	
SEL_Wol	M+B		TOTAL]] . [
SEL_Wola	M+B] [M+B	Π	
SEL_Wolb	M+B] []	TOTAL		
SEL_Weld	M+B	1 1	TOTAL	ΙΙ	
SEL_Welda	M+B] []	M+B		
SEL_Weldb	M+B] []	TOTAL ·		
N_Wol	TOTAL] П	TOTAL	Π	
N_Wola	TOTAL] [TOTAL		
N_Wolb	TOTAL] []	TOTAL	Π	
Noz	TOTAL] [M+B		
NozL	M+B	1 1	M+B	Π.	
TS	TOTAL	ヽノ	M+B	ኪ. /	

 Table 9-14 Stress Category and FSRF in Fatigue Evaluation

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
K	DOCUMENT NUMBER	PLANT	NON DRODDERTADI				
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

For the location determined to be critical, the corresponding external loads from Table 5-5 through Table 5-16 have been incorporated in the fatigue calculation. Using the SI ranges and cycles taken from the "fatigue" output files (see Section 12.0), the bounding external SI (including thermal stratification) have been added manually to the first cycles and the fatigue usage factor then recalculated. This method of adding the external SI to the transient SI is a conservative method as shown in the previous sections.

As stated in Table 5-30 of Reference 13.16, within the Heatup and Cooldown cycles there exist sub-cycles (minor cycles) at the beginning and end of the transients (major cycles) respectively.

The thermal stratification external loads are included in the fatigue calculation as independent sub-cycles. For each case the usage factor calculation is based upon the SI specified in Table 5-7 through Table 5-16 and the number of cycles for each case as stated in Reference 13.8.

The following pages contain the calculation of the cumulative fatigue usage factor for the points of interest. The usage factor includes Transients loading and all applicable external loadings. The calculation is performed separately for seven materials and different parts of model.

The critical locations are:

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Path Nan Node MATERI UTS (psi) E matl (p	PipeL (outside)	Max	imum W FSRF= TYPE: 3Sm= }	Veld Overla () High Alloy 49.1 E ratio =('	y / E curve' /	Outp 'E analysi	ut File:)
RANGE	TRANSIENTS WITH	REQ'D CYCLES	M+B SI	Salt=(M+] Ext. Load	3+Ext. Lo Ke	Salt	7/2 Ke x (E ratio) x S alt ksi	ALLOWABLE CYCLES	USAGE FACTOR
1	HU/RT_CDSI								
2	HU/RCOP	1							
3	HU/CD	1			,				
4	CD/SIA			'					
5	RCSD/SIA								
6	SIA/SUIL								
7	CRD/SIA								
8	CRD/LOP								
9	CRD/LOSLSD								
10	LOSLSD/RT_CDnSI		•					•	
11	LOL/RT_CDnSI						. 1		
12	RT_CDnSI/RT_noCD			,					
13	FCHSD/RT_noCD				÷				
14	FCHSD/LOF		•						
15	FCHSD/PL							•	
16	PL/PL								
17	LSDL/LSDL								
18	10SLdec/10SLdec				,		, · ·	• •	
19	BCE/TRT				•				•
20	BCE/UL								
21	10SLinc/BCE								
22	BCE/LOSLSU								
23	BCE/BCE	1							
24	HU-340	I							
25	HU-200	l ·							
26	HU-100								
27	HU-147	1							
28	OP-43	1							
	Sub-Cycle within HUCD							•	
		$\overline{}$				•		_	

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS							
A	DOCUMENT NUMBER	PLANT						
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY					



Note ⁽¹⁾: Ke factor calculation for this location is based on Total Stress. This is conservative because the Total stress range is higher than Membrane+Bending, resulting in a large usage factor.

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANI					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

Path Nan Node MATERI UTS (psi) E matl (p	ne SEL_Wola (insid	e) FS TY 3S	Maxi RF= PE: Hi $Sm= 40ESa$	mum V) gh Allo 7 ratio =	Veld (oy ('E cu +B+E:	Dverlay rve' / 'E a xt. Load)*	Output 1 nalysis')=1 14 *FSRF/2	File:)
RANGE	TRANSIENTS WITH	REQ'D M CYCLES	1+B SI 1	Ext. Load	Ke	Salt	Ke x (E ratio) x S alt ksi	ALLOWABLE CYCLES	USAGE FACTOR
1	HU/RT CDSI	<u> </u>	•	•	•		-		
2	HU/SIA	(
3	HU/SUIL					,			
4	HU/CD	•							
5	CD/RCSD								•
6	CD/RT_CDnSI	•							
7	CRD/RT_CDnSI							٠.	
8	FCHSD/RT_CDnSI				•			• ·	
9	FCHSD/LOL								
10	FCHSD/RT_noCD							,	· · · · · ·
11	FCHSD/RT_noCD								
12	FCHSD/LOF								
13	FCHSD/LSDL								
14	FCHSD/LOSLSD							•	
15	FCHSD/PL	ľ							
16	PL/RCOP								
17	PL/PL								
18	10SLdec/LOP	·							
19	10SLdec/10SLdec								
20	BCE/UL								
21	10SLinc/BCE	1							
22	BCE/LOSLSU								
23	BCE/TRT							ı	
24	BCE/BCE								
25	HU-340								
26	HU-200								
27	HU-100								
28	HU-147			,					
29	OP-43								
	Sub-Cycle within HUC								
	·····								

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT	· · · · · · · · · · · · · · · · · · ·				
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

Path Name Node MATERIAL: UTS (psi) = E matl (psi) =	SEL_Welda (inside)	Minimur	n Weld (FSRF= TYPE: 3Sm=	Dverlay () High Alloy 69.9 E ratio =('I Salt= (M+B	E curv +Ext	Output F we' / 'E anal Load)*FS	ile:)
RANGE	TRANSIENTS WITH	REQ'D CYCLES	M+B SI	Ext. Load	Ke	Salt	Ke x (E ratio) x S alt ksi	ALLOWABLE CYCLES	USAGE FACTOR
1	HU/LOP	7					· · · · · · · · · · · · · · · · · · ·	• • • • • • • • • • • • • • • • • • •	
2	BCE/HU	/							
3	BCE/CD								
4	BCE/RCOP								
5	LOL/RT_CDSI								
6	LOL/SIA			e				1	
7	FCHSD/RCSD								
8	FCHSD/LOL								
9	FCHSD/RT_CDnSI								
10	CRD/FCHSD								
11	FCHSD/LOF								
12	FCHSD/LOSLSD						*		
13	FCHSD/LSDL								•
14	FCHSD/RT_noCD								
15	IUSLdec/FCHSD					1			
16	IUSLdec/SUIL								
1/	IUSLdec/PL								
18	PL/PL								
19	IUSLINC/BCE								
20	BCE/LUSLSU								
21									
22									
23	LILL 340								
24	HU-200								
26	HU-100								_
20	HU_147								
28	OP_43								
20	Sub-Cycle within HUCD								
	Sub Cycle within HOCD	1							
		\rightarrow							

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY				

RANGE	TRANSIENTS WITH	REQ'D				I. Loau	TSKF/2		
4		CYCLES	M+B SI	Ext. Load	Ke	Salt	Ke x (E ratio) x S alt ksi	ALLOWABLE CYCLES	USAGE FACTOR
1	HU/RT_CDSI	7							
2	HU/CD	()			•				
3	CD/LOP								•
4	LOP/RCSD								
5	LOP/RCOP			•				•	
6	LOSLSD/SIA								
7	CRD/LOSLSD								
8	CRD/PL								
9	FCHSD/PL							·	
10	FCHSD/PL								
11	PL/SUIL								
12	PL/RT_CDnSI						•		
13 .	PL/PL						•		
14	10SLdec/LOF								
15	10SLdec/RT_noCD						• •	·	
16	10SLdec/TRT								
17	10SLdec/LOL								
18	10SLdec/UL						•		
19	BCE/UL								
20	10SLinc/BCE								
21	BCE/LOSLSU							•	
22	BCE/LSDL								
23	BCE/BCE						·		
24	HU-340								
25	HU-200								
26	HU-100								
27	HU-147								
28	OP-43								
S	Sub-Cycle within HUCD								
		$\boldsymbol{\mathcal{I}}$							1

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2 [.]	NON-PROPRIETARY



	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY


A	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

10. RESULTS SUMMARY/CONCLUSION

The fatigue calculation assumes that the Surge Nozzle WOL configuration has existed from the beginning of plant operation. The preceding calculations demonstrate that the design of the Surge. Nozzle Maximum and Minimum Weld Overlay for the North Anna Units 1 & 2 Pressurizers have met the stress and fatigue requirements of the Design Code (Reference 13.1).

Based on the loads and cycles specified in References 13.8 and 13.16, the conservative fatigue analysis indicated that the Pressurizer Surge Nozzle Weld Overlay design has a maximum fatigue factor of compared to the ASME Code allowed maximum value of 1.0. Therefore, the total usage for the Surge Nozzle is less than the allowable value of 1.0 for the total of 60 years of operation.

	Nozzle		Safe End t	o Nozzle	Weld	Sa	fe End		
	Calculated	Limit	IR ⁽²⁾	Calculated	Limit	IR ⁽²⁾	Calculated	Limit	IR ⁽²⁾
Primary SI Max. SI Range PL+Pb+Q [ksi] Fatigue Usage			Bound	ded by original a	analysis,	see Secti	on 9.1		
<u> </u>	Therm	al Sleev	'e	Safe End	to Pipe	Weld		Pipe	
	Calculated	Limit	IR ⁽²⁾	Calculated	Limit	IR ⁽²⁾	Calculated	Limit	IR ⁽²⁾
Primary SI		·	Bound	ded by original a	analysis,	see Secti	on 9.1		
Max. SI Range PL+Pb+Q [ksi] Fatigue Ulsage									
- Couge			Weld C	Overlav			1		2
	Calculate	ed		Limit	IF	x ⁽¹⁾	,		
Primary SI Max. SI Range PL+Pb+Q [ksi] Fatigue Usage	Bou	nded by	original ar	nalysis, see Sec	tion 9.1				

Table 10-1 Summary of Results⁽¹⁾

Note (1): Results from Appendix D and E qualifications that incorporate added insurge and outsurge transients replacing previous qualifications in Section 9.

Note ⁽²⁾: IR- Interaction Ration is defined as (Calculated Value / Limit) Note ⁽³⁾: See Table D-8.

Note ⁽⁴⁾: See Table D-7.



NON-PROPRIETARY

11. SOFTWARE VERIFICATION

The finite element analyses documented in this report were performed using ANSYS v10.0 software (Reference 13.10). The suitability and accuracy of use of ANSYS v10.0 was verified by performing the following verification runs (Table 11-1).

Table 11-1 Software Verification Files

Prepared by: M. Sedlakova Reviewed by: L. Yen



12. COMPUTER OUTPUT FILES

For list of fracture mechanics output files, see Appendix A. For list of output files for justification of insufficient Weld Overlay length, see Appendix C. For list of output files for Insurge/Outsurge Elastic Analysis, see Appendix D. For list of output files for Elastic-Plastic Analysis, see Appendix E.

Table 12-1 Computer Output and Input Files

AREVA	document number 32-9049387-001	PLAN North Anna L	Inits 1 & 2	NON-PROPRIE	ΓARY
			4		
		۰ .			
		•			•
		х. ,	, ···		
		•			
		· .	,		
	· ·	•			
			,		
	i i		· · · ·		2
		,	•	·	
·					

Prepared by: M. Sedlakova Reviewed by: L. Yen

	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

<u></u>	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

Ā	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

A	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

· /A	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	, DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY



A	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

A.	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	NON PROPRIETARY
AREVA	32-9049387-001	North Anna Units 1 & 2	NUN-PROPRIETARY



	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENTNUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY
·	· · · · ·		• · · · · · · · · · · · · · · · · · · ·

A	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZLE W	ELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY

ί

•

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
A	DOCUMENT NUMBER	PLANT	· · · · · · · · · · · · · · · · · · ·			
AREVA	22 0040297 001	North Anna Unita 1 fr 2	NON-PROPRIETARY			

13. REFERENCES

- 13.1 ASME Code, Section III, Division 1, "Boiler and Pressure Vessel Code", 2001 Edition including Addenda through 2003.
- 13.2 Oak Ridge National Laboratory Report ORNL/NUREG/TM-57, "Heat-to-Heat Variations of Total Strain (to 5%) at Discrete Stress Levels in Types 316 and 304 Stainless Steel from 24 to 316°C", prepared for the US NRC.
- 13.3 J. L. Rempe et al., "Light Water Reactor Lower Head Failure Analysis," NUREG/CR-5642 (EGG-2618), October 1993.
- 13.4 Not Used
- 13.5 AREVA Drawing 02-8016831C-003, "North Anna Pressurizer Surge Nozzle Design."
- 13.6 AREVA Drawing 02-8017167D-000, "North Anna Pressurizer Surge Nozzle Weld Overlay Design."
- 13.7 AREVA Document 51-9031151-003, "North Anna Pressurizer Nozzle Weld Overlays Technical Requirements."
- 13.8 AREVA Document 38-9034638-003, "Required Engineering Input for North Anna Pressurizer Weld Overlays, North Anna Power Station Units 1 & 2."
- 13.9 ANSYS Finite Element Computer Code, Version 10.0 Help Manual
- 13.10 "ANSYS" Finite Element Computer Code, Version 10.0, ANSYS, Inc. Canonsburg, Pa.
- 13.11 AREVA Document 38-9042859-000, Code Case N-740-1 (2-07-2007 Draft), "Dissimilar Metal Weld Overlay for Repair of Class 1, 2, and 3 Items, Section XI, Division 1." (Revision 000 of this document is the applicable revision for this project. This Code Case is not yet accepted by the NRC.)
- 13.12 "Companion Guide to the ASME Boiler & Pressure Vessel Code", Volume 1, ASME Press, New York, 2002.
- 13.13 John F. Harvey, "Theory and Design of Pressure Vessels," Second Edition, Van Nostran Reinhold, 1991.
- 13.14 AREVA Document 32-9034323-003, "North Anna Units 1 & 2 Pressurizer Weld Overlay Sizing Calculation Surge Nozzle."
- 13.15 AREVA Document 51-9038545-002, "Material Properties for North Anna Units 1 & 2 Pressurizer Nozzles."
- 13.16 AREVA Document 51-9036969-004, "Pressurizer Bounding Transients for North Anna Units 1 & 2."
- 13.17 ANSYS Finite Element Computer Code, Version 11.0 Help Manual
- 13.18 "ANSYS" Finite Element Computer Code, Version 11.0, ANSYS, Inc. Canonsburg, Pa.

Å	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
A	DOCUMENT NUMBER	PLANT			
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY		

APPENDIX A

PATH STRESSES FOR FRACTURE MECHANICS

6

~

A	1
A	
AREVA	

A.1 PURPOSE

The purpose of this appendix is to provide supplemental stress and thermal results of the transient analysis for a Fracture Mechanics Analysis of the surge nozzle weld overlay. The focus of the analysis is crack initiation and growth through both the Pipe to Safe End Weld and Nozzle to Safe End Weld. The Minimum Weld overlay represents the worst case scenario with a through-weld crack, therefore only the minimum WOL is included in this appendix.

A.2 STRESS AND TEMPERATURE EVALUATION

The ANSYS Post Processor is used to tabulate the stresses and temperatures along the predetermined paths for the Minimum Weld Overlay Configuration only. The paths are shown in Figure A-1 and described in Table A-1.

The definitions of these paths and post processing commands are contained in computer output file named, All output files used for fracture mechanics evaluation are listed in Table A-2.

Output File Path No.	Path Name	Inside Node No.	Outside Node No.	
1	SEUWELD	6244	6001	
2	SELWELD	6255	6052	
3	SEBUT	6297	15955	

Table A-1 Paths Description Min WOL

A AREVA	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
	DOCUMENT NUMBER	PLANT			
	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY		
7					

Figure A-1 Paths Defined for Fracture Mechanics Evaluation

Stresses along the path line are summarized at twelve points separated by an equal distance from the inside node to the outside node. At each point, the axial (longitudinal, S_y) stress and the temperature of the nozzle are given. The path point distances from the inside node are included in the output files listed in Table A-2 with "PathLocs" in their names. The stress and temperature result files for these locations are listed on Table A-2.

In addition, files with "_PathDisc" in their names, listed in Table A-2, provide path point distances from the inside node including the location at the dissimilar material interface for each path (two path points, one just before and one just after the material discontinuity, define the location of the material interface). No post processing are obtained at these path points; this information is provides for reference only.



Table A- 2 Stress and Temperature Result Files for Fracture MechanicsEvaluation

1

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
A	DOCUMENT NUMBER	PLANT			
AREVA	32-9049387-001	North Anna Units 1 & 2	NON-PROPRIETARY		

, ,	
· · ·	
· · · .	

ţ

			l
	• • • •		
• .			
	· · · · · · · · · · · · · · · · · · ·	· · · ·	
		· ·	
	· .		:
	ч.		
,	· .		

.

<i>.</i> , , , , , , , , , , , , , , , , , , ,	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
APEVA	DOCUMENT NUMBER	PLANT	NON-PROPRIETARY		
AREVA	32-9049387-001	North Anna Units I & 2			

Prepared by: M. Sedlakova Reviewed by: L. Yen

Date: 12/2007 Date: 12/2007 Page 126

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
A	DOCUMENT NUMBER	PLANT			
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY		

APPENDIX B

STRUCTURAL TIME POINTS OF INTEREST

Prepared by: M. Sedlakova Reviewed by: L. Yen

Date: 12/2007 Date: 12/2007 Page 127

B.1 TIME POINTS OF INTEREST USED FOR STRUCTURAL ANALYSIS

The following tables list all transient time points analyzed in the structural analysis of the Surge Nozzle. The time points have been selected based on localized extreme thermal gradients tabulated at the end of all "...Dt.out" thermal post processing computer files. The thermal extreme time points were merged with all time points defining the transients for the structural analysis. In the following tables, those time points marked with asterisks have been taken directly from the transient definition; all other points represent temperature gradient extreme time points.

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
AREVA	DOCUMENT NUMBER	PLANT	NON_PROPRIFTARV		
	32-9049387-001	NORTH ANNA UNITS 1 & 2			

Table B-1 Structural Time Points of Interest for Plant Heatup and Cooldown-MAX WOL

Time	Temperature [۴]	Press [psi]	Time	Temperature	Press [psi]	Time	Temperature	Press [psi]
0.00010*	7		23.69330*	7	<u> </u>	31.00240*	7	7
1.22290*	1		23 69334			31.00244		
1.31209			23.69343			31.00250		
1.40128			23.69360*	Í	ĺ	31 00270*	Í	1
2.11480*			23.71239			31 02136	•	
4.00000*			23.72780			31.03677		
4.00030*		(23.73125		1	31.04029		
4.04183			23.73470*			31.04380*	· · · · · ·	
4.08335			23.73500*			31.04410*		
4.16640*			24 15024	1		31.54330*		
4.16670*			24.56548			31.73559		
7.44280*			25.81120*			32.31246		
7.44310*			25.81124	1		33 46620*		l i
7.48463			25.81150*			33.46650*		
7.52615			25.83022			33.50881		
7.60920*			25.84563		1	33.52957		
7 60950*			25.84912			33.55033		
7.96808			25.85260*			33 63260*		
8.20713		1	25.85290*	1		33.63290*		
8.92428			26.31174			34.38500*		
10.00000*			26.69411			34.38530*		
18.00000*			27.00000*			34.41852		
19.00000*			27.00003			34 45174		
19.55320*			27.00010*			34.55140*		
19.55324			27.00014	1		34.55170*		
19.55333			27.00020			34.87490*		
19.55350*			27.00040*			34.87520*		
19 57239			27.01913	1. State 1.	1	34.87550*		
19.58266			27.03454			35 09710*		
19.59120			27.03802			35.09716		1
19.59460*	· ·		27.04150*			35.09720		
19.59490*		[]	27.04180*			35.09740*		
20.23744			27 43804			35.40100*		
21 73670*	1		27.83428		. H	40.93120*		
21.73674			29.02300*			40.93126	í í	
21.73683			29.02304			40.93150*	· · ·	
21.73700*	1		29.02310			40 93153		
21.75585		1	29.02330*			40.93166		
21.76613			29.04351	1		40.93180*		
21.77468			29 05995			41.15340*		ļ
21.77810*			29.06440*			41.15370*		
21.77840*]]	29.06470*			41.76480*		
22.54436	1]]	29,45224]]	42.33220*		·]
22.92734	l	J	29.83978	l	J	43.00000*		J
	-	Д	20.000,0	~				

Prepared by: M. Sedlakova Reviewed by: L. Yen

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
AREVA	DOCUMENT NUMBER 32-9049387-001	plant NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY	

Table B- 2 Structural Time Points of Interest for Plant Loading and Unloading-MAX WOL

Time	Temperature _[年]	Press [psi]	Time	Temperature [۴]	Press [psi]	\sim
0.00010*	\neg		0.46540*	-7	T	
0.00013			0.46541			
0.00020*			0.46545			
0.02780*			0.46549			
0.03058			0.46550*			
0.03927			0.47110			
0.04170*		ν.	0.49350*			
0 04530			0.52160*			
0.05970*			0.52250*			
0.05980*			0.55233			
0.07640*			0.58215			
0.09720*			0.76110*			
0.09894			0.77610*			
0.10068			0.78622			
0.10852			0.79255			
0.11375			0.79697			
0.11810*			0.80140*			
0.22780*	· · · · · ·		0_84430*			
0.30560*			0:84432			
0.31368			0.84432			
0.31714	ſ .		0.84433		Í	
0.32407			0.84438			
0.33330*	í [·]	Í	0.84439	1	[
0.33331			0.84440*			
0.33340*	· ·		0.87950*			
0.37500*			0.88570*	J		
0.38888			0.88844			
0.44440*			0,89006	ļ		
0 44447			0.89087			
0.44450*			0.89490]	
0 44460*			0.89700*			
0.45580*			0 89762			
0.45840*		ப	0.90320*		人	

с [.]

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT	NON PROPRIETADY	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIE I ARY	

Table B- 3 Structural Time Points of Interest for 10% Step Load Increase-MAX WOL

Time	Temperature	Press [psi]
0 00010*	7	\mathbf{T}
0 00310*		
0.00421		
0.00500*		
0.00592		
0.00628		
0.00720*		· ·
0.00730*		
0.00869		
0.00910*		
0.01970*		
0.02140*		
0.02313		
0.02690*		
0.03579		
0.04376		
0 04727		
0.04880*		1
0.05350*		
0.05360*	i	
0.05510*		
0.05558		
0 05650*		
0.06850		
0.09250*		L

ł

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT	NON DECEDIETADY	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2		

Table B- 4 Structural Time Points of Interest for 10% Step Load Decrease-MAX WOL

Time	Tem	oerature [℉]	Press [psi]	6
0.00010*	$\overline{}$			
0.00020*				
0.00310*				
0.00480*				
0.00696				
0.00760*				
0.00770*				
0.00785		V		
0.00790*				
0.00925				· 1
0.00987				
0.01017				
0.01220*				1 ·
0.01240*)		•	· • .
0.01430*				1
0.03203			-	
0.04250*				· .
0.04320				
0.04690				
0.04950*				
0.08310*				
0.08393				
0.08460				
0.08561				
0.08680*				
0.08728				
0.08776				
0.08982			2	
0.09160*				
0.09460*				
0.09470*				
0.09694				
0.10590*				L

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B-5 Structural Time Points of Interest for Large Step Decrease In Load-MAX WOL

Time	Temperature [뚜]	Press [psi]
0.00010*	7	7
0.00011		
0.00012	and the second	
0.00013		
0.00015		
0.00020*		
0.00210*		
0.00240*		
0.00294	· ·	
0.00510*		
0.00520*		[
0.00619		
0.00730*		
0.00830*		
0.00998		
0.01358		1
0.01478		
0.01670*		
0.01732		
0.01794		
0.02290*		
0.02353		
0 02686		
0.02920*	Î.	í
0.03184		
0.03340*	· ·	
0.04173		
0.09590*		
0.21160*		· .
0.22720*		
0.24080*		
0.26890*		
0.32624		
0.55560*		



Table B-6 Structural Time Points of Interest for Loss of Load-MAX WOL



Prepared by: M. Sedlakova Reviewed by: L. Yen

Α	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B-7 Structural Time Points of Interest for Loss of Power-MAX WOL

Time	Temperature	Press [psi]	
0.00010*	7		
0.00020*			
0.00110*			
0 00188	·		
0.00270*			
0.00280*			
0.00404			
0.00420*			
0.01674			
0.01870*			•
0.02480*			
0.02481			
0.02482			
0.02487			
0.02490*			
0.04309			
0.04538			
0.05000*			•
0.05259			
0.05435			
0.05788		-	
0.06940*			
0.08162			
0.08436			
0.08983			
0.09950*			
0.09960*			
0.14030*			
0.14819			
0.16735	· · · ·		
0.21920*			
0 28060*			•
0.37620*			,
0.43387		,	
0.49154			
0.77990*			
0.80690*			

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

AREVA

DOCUMENT NUMBER

Table B-8 Structural Time Points of Interest for Loss of Flow-MAX WOL

Time	Temperature	Press Ipsil
·····	[¶]	7
0.00010*	(
0.00020*		
0.00023		
0.00030		
0.00070*		
0.00083		
0.00100*		
0.00110*		
0 00114		
0 00118		
0.00170*		· ·
0.00203		
0.00217		
0.00250*		
0.00533	•	
0.00930*		
0.01047		
0.01210*		
0.01220*		
0.01274	· ·	
0.01400*		
0.01588		
0.01684		
0.01840*	1	
0.01954		
0.02070*		
0.02100*		

Prepared by: M. Sedlakova Reviewed by: L. Yen

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS A DOCUMENT NUMBER PLANT AREVA

32-9049387-001

NORTH ANNA UNITS 1 & 2

NON-PROPRIETARY

Table B-9 Structural Time Points of Interest for Feedwater Cycling at Hot Shutdown-MAX WOL

Time	Temperature	Press [psi]
0.00010*	$\overline{}$	
0.42780*		
0.42790*		:
0.44710*		
0 45432		
0.46514		
0 47055		
0 47597		
0.49040*		
0.63460*		
0.64410*		
0.64415		
0.64418		
0.64420*		
0.65870*		
0.66830		
0.67516		
0.68887		
0.69573		
0.70670*		
0.74040*		
1 20190*		
1.24357		
1.26440*		
1.26450*		
1.26920*	l l	
1.27724		
1.28046		
1.28850*		
2.00000*		L

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	NON PROPRIETARY
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIE I ARY

Table B- 10 Structural Time Points of Interest for Boron Concentration Equalization-MAX WOL







NORT	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA 32-	0049387-001	plant NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B-12 Structural Time Points of Interest for Reactor Trip with Cooldown but no Safety Injection-MAX WOL



Table B-13 Structural Time Points of Interest for Reactor Trip with Cooldown and Safety Injection-MAX WOL



Prepared by: M. Sedlakova Reviewed by: L. Yen

Date: 12/2007

Α	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	NON DRODDIET A DV
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	

Table B- 14 Structural Time Points of Interest for Inadvertent Reactor Coolant System Depressurization-MAX WOL

Time	Temperature	Press [psi]
0.00010*	7	
0.00020*		
0.00840*		
0.00960*		
0.00969		
0.00970*		
0.00974	1	. 1
0.01030*		
0.01060		
0.01135		
0.01371		
0.01390*		
0.01467		
0.02310*	·	
0.02311		
0.02314		
0.02320*		
0.02364		
0.02450*		
0.03220*		1
0.03990*		
0.05990		
0.27990*		
0.28134		
0.28483		
0.28541		
0.28630*		
0.29301		
0.33330*		
		ノ

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
AREVA	DOCUMENT NUMBER	PLANT	NON-PROPRIETARY
	32-9049387-001	NORTH ANNA UNITS I & 2	

Table B-15 Structural Time Points of Interest for Control Rod Drop-MAX WOL

Time	Temperature	Press [psi]
0.00007	7	\sim
0.00010*		
0.00016		
0.00022		
0.00100*		
0.00266		
0.00290*		
0.00593		
0.00810*		
0.00870*		
0.01140*		
0.01193	. :	
0.01320*		
0.01330*		1
0.01379		
0.01700*		1
0.02710		
0.02840*		,
0.03111		
0.03331		
0.03771		
0.04050*		
0.04140*		
0.04150*		×
0.04183	· · · ·	
0.04215		· •
0.04410*		レ

.

ч÷.
А	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
AREVA	DOCUMENT NUMBER	PLANT NORTH ANNA LINITS 1 & 2	NON-PROPRIETARY		
	32-3049387-001	HORTH AND A DIVISION OF A 2			

Table B- 16 Structural Time Points of Interest for Inadvertent Startup of an jInactive Loop-MAX WOL

	Temperature			
Time	[F] Press [psi]	Time	Temperature [F]	Press [psi]
0.00010*		0.02074	7	T
0.00020*		0 02120		
0.00160*		0.02211		
0_00340*		0.02293		
0.00400*		0.02330*		
0.00406		0.02397		
0.00410*		0 02447		
0.00480*		0.02597		
0.00510*		0.02730*		
0.00551		0.02806		
0.00571		0.02899		
0.00580*		0.02930		
0.00730*		0.03070*		
0.00770*		0.03104		
0.00870		0.03187	, ,	
0.01241		0.03410*		
0.01270*	· · ·	0 03486		
0.01323		0.03551		
0.01360		0.03616		
0.01505		0.03670*		
0.01670*		0.03693		
0.01850*		0.03716		
0.01860*		0 03749		
0.01890		0.03900*		
0.02010*		0.03910*	١	J

Date: 12/2007 Date: 12/2007

1

A	NORTH ANNA UNITS 1&2	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
A	DOCUMENT NUMBER	PLANT				
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY			

Table B- 17 Structural Time Points of Interest for Inadvertent Safety Injection Actuation-MAX WOL

Time	Temperature [۴]	Press [psi]
0.00010*	7	7
0.00260*		
0.00466		
0.01186		
0.01340*		
0.01341		
0.01344		
0 01349		
0.01350*		
0.01420*		
0.01423		
0.01480*	•	
0.02780*		
0.03411		·
0 03862		
0.04763		
0.05665		
0.09090*		
0.28620*		
0.28625		
0.28629		
0 28630*		
0 28841		
0.29016		
0.29080*		
0.29718		
0.31790		
0.32398	l	J
0.33330*		

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B-18 Structural Time Points of Interest for Turbine Roll Test-MAX WOL







Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 20 Structural Time Points of Interest for Loop Out of Service NormalLoop Startup-MAX WOL

Time	Temperature	Press [psi]
0.00010*	\mathcal{C}	$\overline{\mathbf{N}}$
0.00012		
0.00020*		
0.00029		
0.00130*		
0.00260*		
0.00270*		
0.00275		
0.00330*		1
0.00331		
0.00340*		
0.00365		1 ·
0.00720*	· · ·	
0.01050*		
0.01341		
0.01900*		
0 0192 9		
0.01999		
0.02190*		÷
0.02200*		
0.02243		
0.02840*		
0.05000*	/ .	
0.07334		
0.09001		·
0.10668		
0.16670*	-	ノ

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

AREVA

DOCUMENT NUMBER 32-9049387-001 plant NORTH ANNA UNITS 1 & 2

Table B- 21 Structural Time Points of Interest for RCS Cold Overpressurization-MAX WOL

Time	Temperature [۴]	Press [psi]
0.00010*	7	$\overline{}$
0.00020*		
0.00025		
0.00140*		
0.00150*		
0 00160*		
0.00161		
0.00170*		
0.00180*		
0.00181		
0.00190*		
0.00196		
0.00200*		4
0.00210*	,	
0 00220*		
0.00225		
0.00230*		
0.00240*		
0.00250*		
0.00259		
0.00260*		
0.00270*		
0.00280*		
0.00290*		
0.00300*		
0.00310*		
0.00320*		
0.00330*		
0.00340*		
0.00350*		
0.00360*		
0.00370*		
0.00380*]	~
0.00385		
0.00390*		

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
A	DOCUMENT NUMBER	PLANT			
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY		

Table B- 22 Structural Time Points of Interest for Plant Heatup and Cooldown-MIN WOL

Time	Temp [°F]	Press [psi]	Time	Temp [°F]	Press [psi]	Time	Temp [°F]	Press [psi]
0.00010*	7		23.70726	7		31.04380*	7	7
0.06124	(1	23.71240	(.		31.04410*		}
1.22290*		ł	23.71754			31.06906		
1.31209			23.73126			31.54330*		
2.11480*			23.73470*			31.92788		
4.00000*			23.73500*			33.46620*		
4.00030*			23.94262			33.46626		
4.04183			24.15024			33.46630		
4.16640*			25.39596			33.46650*		
4.16670*			25.81120*			33.50913		
4.82192			25.81150*	ſ		33.63260*		
5.47714			25.81698			33.63290*		
7.44280*			25.82509			33.85853		
7.44310*			25.83023			34.38500*		
7.48463			25.83537			34.38503		
7.60920*			-25.85260*			34.38509		
7.60950*			25.85290*			34.38530*	,	
7.84855			26.08232			34.41852		
7.96808			26.31174			34.55140*		
8.68523			27.00000*			34,55170*		
10.00000*			27.00010*			34.74562	•	
10.40000	1		27.00040*			34.87490*		
18.00000*	1		27.00588			34.87520*		1
18,20000			27.01400			34.87526		
19.00000*			27.01914			34.87529		
19.55320*			27.02427			34.87550*		
19.55350*			27.04150*			34.96539		
19.55898			27.04180*			35.09710*		
19.56726			27.23992			35.09716		
19.57754]		27.43804		•	35.09740*		
19.58268			28.62676			35.37832		· ·
19.59460*			29.02300*			35.40100*		
19.59490*			29.02330*		-	36.50704		
19.80908			29.02741			40.93120*		
20.02326	, in the second se	`	29.03571			40.93123		
21.73670*			29.04357			40.93126		
21.73700*			29.05179			40.93130		
21.74248			29.06440*			40.93150*		
21.75073			29.06470*			40.93180*		
21.75587			29.25847			40.97612		
21.76100			29.45224			41.15340*		
21.77128			30.22732			41.15356		
21.77810*			30.61486	- A.	14 M	41.15370*		
21.77840*			31.00240*			41.39814		
21.96989			31.00270*			41.76480*		
22.16138			31.00818	1		41.99176		
23.69330*			31.01623			42.33220*		
23.69360*	l i		31.02137	1		43.00000*		
	7				ノ			
Prepared	by: M. Sec	llakova		Date: 12/2	007	,	Page	147
Reviewed	d by: L.Ye	en		Date: 12/20	007			`

1

AREVA	DOCUMENT NUMBER 32-9049387-001		PLANT NORTH ANNA UNITS 1 & 2			NON-PROPRIETARY	
3.69908) 3	1.02651	•)		
				. ?			
			· .				

Prepared by: M. Sedlakova Reviewed by: L. Yen

Δ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 23 Structural Time Points of Interest for Plant Loading and Unloading-MIN WOL

Time	Temperature 	Press [psi]	Time	Temperature [°F]	Press [psi]
0.00010*	7		 0.46540*	7	T
0.00015			0.46549		1
0.00020*		· · · ·	0.46550*		
0.00572			0.49350*		
0.02283	•		0.50236		
0.02780*			0.52160*		
0.03336	•		0.52250*		
0.04170*			0.55233		
0.05970*			0.62192		
0.05980*			0.76110*		
0.07087			0.77610*		
0.07640*			0.78116		
0.09720*			0.78622		
0.09894	· ·		0.79255		
0.10330			0.80140*		
0.11810*			0.84430*		
0.22780*			0.84432		
0.23428			0.84432	;	
0.30560*			0.84433		3
0.31022			0.84438		
0.31368			0.84440*		1
0.31714	:		0.86646		
0.33330*			0.87950*		
0.33331			0.88012		·
0.33340*			0.88570*		
0.34033			0.88844		
0.37500*			0.88925		
0.44440*			0.89006		
0.44443			0.89167		
0.44450*			0.89700*		
0.44460*			0.89762		
0.45580*			0.89824		
0.45840*			0.90320*		
0.46124	<u> </u>	<u> </u>	 	<u> </u>	<u> </u>

Prepared by: M. Sedlakova Reviewed by: L. Yen

~	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT		
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY	

Table B- 24 Structural Time Points of Interest for 10% Step Load Increase-MIN WOL

Time	Temperature [°F]	Press [psi]
0.00010*	7	
0.00310*	1	
0.00421		
0.00500*		
0.00528		
0.00628		
0.00720*		
0.00730*		· · [
0.00910*		
0.01437		
0.01970*		
0.02140*		
0.02263		
0.02690*		
0.02836		
0.02982		
0.04880*		
0.05350*		
0.05360*		
0.05510*		
0.05558		
0.05650*		
0.06850		
0.08050		
0.09250*		7

Prepared by: M. Sedlakova Reviewed by: L. Yen

Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER	plant NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 25 Structural Time Points of Interest for 10% Step Load Decrease-MIN WOL

Time	Temperature	Press [psi]
0.00010*		$\boldsymbol{\mathcal{T}}$
0.00020*	· · · ·	
0.00310*		
0.00441		
0.00480*	· · ·	
0.00760*		
0.00768		•
0.00770*		
0.00785		
0.00790*		- I.
0.01220*		r -
0.01240*		
0.01430*		
0.02800		
0.03605		
0.03928		
0.04250*		
0.04950*		
0.08310*		
0.08359		
0.08393		
0.08460		
0.08680*		
0.08728		
0.09050	100 A. 100 A.	· · ·
0.09160*		
0.09460*	:	
0.09470*		
0.09694		
0.10590*		レ

Prepared by: M. Sedlakova Reviewed by: L. Yen

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

AREVA

DOCUMENT NUMBER 32-9049387-001

Table B- 26 Structural Time Points of Interest for Large Step Decrease In Load-MIN WOL



Prepared by: M. Sedlakova Reviewed by: L. Yen



Table B- 27 Structural Time Points of Interest for Loss of Load-MIN WOL



Prepared by: M. Sedlakova Reviewed by: L. Yen



Table B- 28 Structural Time Points of Interest for Loss of Power-MIN WOL

Time	Temperature [°F]	Press [psi]
0.00010*		~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~
0.00014		1
0.00020*		1
0.00110*	1	
0.00188		
0.00270*		
0.00280*		
0.00294		
0.00308		
0.00420*		
0.00783		
0.01674		
0.01870*		
0.02480*		
0.02484		
0.02485		
0.02490*		
0.02825		
0.04081		
0.04309		
0.04765		ļ
0.05000*		
0.06940*		
0.07341		
0.08162		
0.08436		
0.08710		
0.09950*		
0.09960*		
0.10774		
0.14030*		-
0.14819		
0.21920*		ł
0.28060*		
0.35435		
0.37620*		1
0.77990*		
0.79709	1	
0.80690*		ノ

A .	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 29 Structural Time Points of Interest for Loss of Flow-MIN WOL

Time	Temperature PFI	Press [psi]
0.00010*	7	∇
0.00020*		
0.00070*		
0.00083	•	
0.00100*		
0.00110*		
0.00118		
0.00140		
0.00170*		
0.00203		
0.00217		,
0.00250*		
0.00420	· .	
0.00533		
0.00930*		
0.01012		
0.01117		
0.01210*		1
0.01220*		
0.01400*		
0.01610		
0.01685		[
0.01716		
0.01840*		
0.02070*		. I
0.02100*	1	

Prepared by: M. Sedlakova Reviewed by: L. Yen

1

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

AREVA

DOCUMENT NUMBER 32-9049387-001 plant NORTH ANNA UNITS 1 & 2

Table B- 30 Structural Time Points of Interest for Feedwater Cycling at Hot Shutdown-MIN WOL

Time	Temperature	Press Insil
· · · · · · · · · · · · · · · · · · ·	PFI	(Par)
0.00010*	(
0.42780*		
0.42790*		
0.43310		
0.44710*		
0.45071		
0.45432		
0.45973	ľ	1
0.48138		
0.49040*		
0.63460*	ļ	1
0.64410*		
0.64415		
0.64420*		
0.65141		
0.65870*		
0.66350		
0.66830		
0.67516		· 1
0.70670*		
0.74040*		
0.95137		
1.20190*		
1.22013		
1.24357		
1.26440*		
1.26444		
1.26450*		
1.26920*		
1.27403		. 1
1.27724		
1.28046		1
1.28368		1
1.28850*		
1.43080		1
2.00000*		

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 31Structural Time Points of Interest for Boron ConcentrationEqualization-MIN WOL



Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	1
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 32 Structural Time Points of Interest for Reactor Trip with NoCooldown-MIN WOL

Time	Temperature 	Press [psi]
0.00007*	7	$\overline{\mathbf{T}}$
0.00010	1	
0.00180*		-
0.00232		
0.00358		
0.00700*		
0.00804		1. A.
0.00930		
0.00950*		
0.00960*		
0.01200*		
0.01240*		
0.01392		
0.01410*	1	1
0.01420*		
0.01428		1
0.01469		
0.01540*		[
0.02284	J	
0.02780*		2

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007 •

Á	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 33 Structural Time Points of Interest for Reactor Trip with Cooldown but no Safety Injection-MIN WOL

Time	Temperature °F]	Press [psi]
0.00010*	7	
0.00190*		· · ·]
0.00226		•
0.00509		
0.00550*		
0.00750*		1
0.01380*		
0.01387		
0.01480*		
0.01500*		
0.01588		
0.01767		
0.01800*		
0.01810*		
0.01818	· · · ·	ļ
0.01830*	· ·	· *
0.02780*	<u> </u>	

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT		
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY	

Table B- 34 Structural Time Points of Interest for Reactor Trip with Cooldown and Safety Injection-MIN WOL



Prepared by: M. Sedlakova Reviewed by: L. Yen

۸	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	NON BROBBIET A DV
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NUN-PROPRIETARY

Table B- 35 Structural Time Points of Interest for Inadvertent Reactor Coolant System Depressurization-MIN WOL

Time	Temperature FI	Press [psi]	
0.00007	7	\mathbf{T}	
0.00010*			
0.00012		1	
0.00012			
0.00020*			
0.00353			
0.00840*			
0.00960*	· ·	•	
0.00961			
0.00962			
0.00970*			
0.00974			
0.00989			•
0.01030*			
0.01180			
0.01371			
0.01390*			
0.02310*			
0.02313			
0.02320*			
0.02450*			
0.02714			
0.03220*			
0.03990*			
0.16990			
0.27990*			
0.28483			
0.28541	1		
0.28630*			
0.33330*			

Prepared by: M. Sedlakova Reviewed by: L. Yen

Α	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	_
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 36 Structural Time Points of Interest for Control Rod Drop-MIN WOL



Prepared by: M. Sedlakova Reviewed by: L. Yen

. · A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 37Structural Time Points of Interest for Inadvertent Startup of an
Inactive Loop-MIN WOL

Time	Temperature	Press [psi]
0.00010*	7	$\overline{\lambda}$
0.00020*		
0.00160*		
0.00340*		
0.00400*		
0.00401		
0.00410*		
0.00442		
0.00480*		
0.00510*		
0.00571		
0.00580*		
0.00730*		
0.00770*		
0.00870		
0.01013		
0.01270*		
0.01323		
0.01360		
0.01642		•
0.01670*		
0.01850*		
0.01860*		
0.018/5		
0.02010*		1
0.02120		
0.02330*		
0.02397		
0.02730*		
0.02806		
0.02930	,	
0.03070*		
0.03187		
0.03324		Į
0.03410*		
0.03486		
0.03583		
0.03670*		
0.03716		
0.03749		
0.03900*		.]'
0.03910*	- \	J

Prepared by: M. Sedlakova Reviewed by: L. Yen

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

Table B- 38 Structural Time Points of Interest for Inadvertent Safety Injection Actuation-MIN WOL

Time	Temperature [°F]	Press [psi]
0.00010*	(
0.00186		
0.00260*		
0.00466		
0.01243		
0.01340*		
0.01349		
0.01350*		
0.01420*		
0.01480*		
0.01889		
0.02780*		
0.03096		1
0.03411		. .
0.03862		
0.04312		
0.09090*		
0.14992		
0.28620*		
0.28625		
0.28630*		
0.28648		
0.28841		
0.28991		1
0.29016		
0.29080*		
0.30882	1	J
0.33330*		ノ

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 39 Structural Time Points of Interest for Turbine Roll Test-MIN WOL



Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A .	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS		
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table B- 40 Structural Time Points of Interest for Loop Out of Service Normal Loop Shutdown-MIN WOL



NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

DOCUMENT NUMBER AREVA 32-9049387-001

A

NORTH ANNA UNITS 1 & 2

PLANT

Table B- 41 Structural Time Points of Interest for Loop Out of Service Normal Loop Startup-MIN WOL

Time	Temperature [°F]	Press [psi]
0.00007	7	
0.00010*]
0.00012		
0.00020*		
0.00130*		
0.00260*		
0.00270*		1
0.00275		
0.00310		1
0.00330*		
0.00331	t.	1
0.00340*	· ·	
0.00365		
0.00391		
0.00460		
0.00720*		
0.00753		
0.01050*		
0.01220		
0.01341		
0.01803		
0.01900*		
0.02190*		
0.02200*		
0.02840*		1
0.03272		
0.05000*		
0.06167		
0.07334	1	
0.16670*		

Prepared by: M. Sedlakova Reviewed by: L. Yen

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

Table B- 42 Structural Time Points of Interest for RCS Cold Overpressurization-MIN WOL

Time	Temperature [°F]	Press [psi]
0.00010*	7	$\overline{\mathbf{T}}$
0.00020*		
0.00025		
0.00030		
0.00140*		
0.00150*		
0.00160*		
0.00170*		[
0.00180*		
0.00181		
0.00190*		
0.00194		
0.00200*		
0.00210*		
0.00220*		
0.00230*		
0.00240*		
0.00250*		
0.00260*		
0.00270*		
0.00277		
0.00280*		
0.00289		
0.00290*		
0.00300*		
0.00310*		
0.00320*		
0.00330*		ļ
0.00340*		
0.00350*		1
0.00351		
0.00360*		1
0.00370*		1
0.00380*	l	
0.00390*	<u> </u>	ノ

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

APPENDIX C

JUSTIFICATION OF INSUFFICIENT LENGTH OF WELD OVERLAY

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
AREVA	DOCUMENT NUMBER 32-9049387-001	plant (NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY			
			······			

C.1 PURPOSE

The purpose of this Appendix is to examine stress distribution in the North Anna Surge Nozzle components and to justify the deficient length of weld overlay on the nozzle side as it is calculated in Reference 13.14.

C.2 ANALYTICAL METHODOLOGY

By AREVA Document 38-9042859-000, Reference 13.11, the length of the weld overlay should extend at least $0.75\sqrt{(Rt_n)}$ beyond each end of the observed crack, where R and t_n are the outside radius and nominal wall thickness of the pipe prior to depositing the weld overlay. This requirement is to make sure that enough length is provided to attenuate stresses in case of stress concentration due to crack initiation. Because of the existing short length of the Surge Nozzle analyzed in the main body of this document, the above requirement was not satisfied and therefore shorter length for the weld overlay was used. The main focus of this Appendix is to look closely at the stress distribution for the Surge Nozzle thin weld overlay configuration under the conservative assumption of the total loss of buttering and weld between nozzle and safe end.

For this sake the finite element model for the thin weld overlay created in the main body of this document was tested under design pressure and external applied loads listed in Tables 6-7 through 6-9, Reference 13.16. The dead weight loads were taken from Table 1 of Reference 13.14. All the elements pertain to the weld and buttering between the safe end and nozzle body were eliminated. The modified geometry for this analysis is documented in these files: (Table 12-1). Also, it is important to note that since the model created in the main body of this document uses 2-D axisymmetric elements and some of the applied external loads are non-axisymmetric, special 2-D elements were needed to address this issue. Consequently, all the elements were changed to PLANE 83 which allows the application of non-axisymmetric loads on an axisymmetric model. The detailed description of this element is listed in ANSYS Manual, Reference 13.9.

C.3 BOUNDARY CONDITIONS

The geometric boundary conditions for the model remained the same as it is described in the main body of this document. The external loads are conservatively assumed to be applied at the top of the external pipe and their application to the model is described as follows:

First, unit loads are applied on the model, and in the second step, the unit loads are scaled and combined such that they are representative of the different external loads (DW, Design Pressure, Thermal (TH), and OBE) reported in Reference 13.16, Tables 6-7 through 6-9. Five different unit load cases are evaluated for the thin weld overlay configuration. 1) Unit, 1 kip, axial load, 2) Unit, 1 kip-in, torsion, 3) Unit, 1 kip, shear, 4) Unit, 1 kip-in, bending, 5) Unit, 1 ksi, pressure. All unit loads are applied at the end of the modeled external surge piping with an exception of the unit pressure load applied on the internal surfaces.

The unit axial, unit torsion and unit pressure load cases can be represented by the constant term of a harmonic function series in particular the Fourier series, Reference 13.9. The unit shear and unit bending load cases can be represented by the first harmonic, either symmetric cosine or antisymmetric sine function of the Fourier series Reference 13.9. While the unit bending moment can be described by a single harmonic load applied perpendicular to the cross section, the unit shear uniform lateral load is composed of two harmonic components applied in two

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
AREVA	DOCUMENT NUMBER	PLANT	NON-PROPRIETARY			
	32-9049387-001	NORTH ANNA UNITS I & 2				

perpendicular directions in the plane of the cross section, Reference 13.9. Since all load cases considered can be exactly represented by either the constant or first harmonic terms of the Fourier series, no Fourier series expansion of the non-axisymmetric loads is necessary. The ANSYS output of the unit external loads is contained in the output file

Due to the axisymmetry of the geometries only two load combinations need to be defined for each model (DW + Design Pressure + TH + OBE) and (DW + Design Pressure + TH - OBE). The shear and bending moment components are combined using the square root of the sum of the squares $Fs=\sqrt{(F_x^2 + F_z^2)}$ and for moment $Mb=\sqrt{(M_x^2 + M_z^2)}$ and since the first load combination produces higher stresses the stress intensity contour plot for this load combination is shown in Figure C-1. It is important to mention that the axial load here is considered to be Fy aligned to the axis of axisymmetry y. The stress output for the aforementioned load combinations is contained in output file

C.4 RESULTS AND CONCLUSIONS

It is clear from Figure C-1 that the existing length of the weld overlay provides enough material to attenuate the stresses (due to design pressure and external loads) effectively. It is important to note that the comparison with ASME Code limits are documented in the main body of this document and this Appendix is intended to only verify the stress attenuation under conservative assumption of losing the entire weld between safe end and nozzle.

Table C-1 Computer Output Files For Appendix C

A	NORTH ANNA UNITS 1& DOCUMENT NUMBER	2, PRESSURIZER SURGE NOZZLE PLANT	WELD OVERLAY ANALYSIS
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY
	_		

Figure C-1 Stress Intensity Contour for the Thin Weld Overlay Configuration

١

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

APPENDIX D

RE-ANALYSIS WITH INSURGE AND OUTSURGE TRANSIENT

~	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	YON DOODDET ADV
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

D.1 PURPOSE

The purpose of this Appendix is to incorporate the addition of an Insurge and Outsurge Transient to the analysis. The methodology, design input, external loads, Design Condition, and all existing transients presented in the main body of this calculation still remain valid.

This evaluation is limited to minimum weld overlay configuration only based on the review of the stress results between maximum and minimum configurations. The final results are very similar between the two configurations, and therefore, only minimum weld overlay configuration is used.

The elastic or simplified elastic-plastic approach is used in this Appendix. An elastic-plastic approach will be implemented at those locations not qualified in this Appendix, and the evaluation will be documented in Appendix E.

D.2 THERMAL ANALYSIS

All transients described in Section 7 are still applicable. The added transients for insurge and outsurge is defined in Attachment 12 of Reference 13.8. The insurge and outsurge transitions can be separated into two groups. One group is during HUCD Transient, and the other is during transients other than HUCD. The first group has a maximum temperature drop of \int_{1}^{1} , and the second group has maximum temperature drop of \int_{1}^{1} . The number of cycles are conservatively added for all the possible events and separated into these two groups as shown in the Table below.

Transient ID Number	Operating Cycle	Name Abbreviation	Occurrences	Operating Condition
27	Insurge/Outsurge Transient		Γ	Normal (HUCD)
28	Insurge/Outsurge Transient		ſ	Normal & Upset (Non-HUCD)

 Table D-1 Insurge & Outsurge Transients

Note (1): This transient only occurs during the HUCD Transient, and therefore it can only range with all other transients for cycles. The rest will only range within itself as subcycles.

The temperature and pressure profile of the two surge transients are developed based on Reference 13.8 and using the same approach to determine the HTC as Reference 13.16.

	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	· · ·
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-2 IOSurge Transient (Δt =

Time	Time	Fluid Temp Pzr	Fluid Temp Noz	Pressure	Flow Rate	HTC _{noz}	HTC _{annulus_eff}	HTC _{pzr}
hr	min	°F	°F	psia	gpm	Btu/hr ft ² .°F	Btu/hr·ft ² .°F	Btu/hr·ft ^{2.} °F
0.0001	0.001						(
0.0500	· 3.000	7 ·					· · · ·	
0.05001	3.001			•	·.			
0.0667	4.000				•			
0.3167	19.000							
0.3333	20.000				;			
0.3334	20.001						• •	
0.5000	30.000							
1.0000	60.000	II.						
2.0000	120.000				-	· •	• •	

Table D-3 IOSurge110 Transient (∆t =

]

Time	Time	Fluid Temp Pzr	Fluid Temp Noz	Pressure	Flow Rate	HTC _{noz}	HTC _{annulus_eff}	HTC _{pzr}
hr	min	°F	°F	psia	gpm	Btu/hr-ft ² .°F	Btu/hr·ft ² ·°F	Btu/hr <u>·ft²·</u> °F
0.000	0.001							
0.0500	3.000							
0.0500	3.001					•		
0.0667	4.000							· [
0.3167	19.000	· ·						Γ
0.3333	20.000							· · [
0.3334	20.001							Γ
0.5000	30.000	· ·		<i>.</i>				
1.0000	60.000		· ·		•	•	· ·	Г
2.0000	120.000		· · · · ·					

The detailed thermal loading due to these transients were applied to the thermal finite element model in the form of fluid and steam temperatures and HTC versus time.

A	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

The computer input files containing definition of these transients are:

The computer output files for the thermal analyses of the transients are:

The points on interests for temperature gradients are the same as illustrated in Table 7-2 and Figure 7-1. The results of the thermal analyses are evaluated by examining the magnitude of temperature differences between key locations of the model (see Figure 7-1). The time points of the maximum temperature gradient are those at which the maximum thermal stresses develop.

The computer output files that provide the temperatures at the selected locations are:




A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT		
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY	

D.3 STRUCTURAL ANALYSIS

Stress analyses are performed at those time points which the maximum temperature gradients (maximum thermal stresses) in addition to those defining the transient in Tables D-2 and D-3. The time points of interest are listed in the Tables below. In the following tables, those time points marked with asterisks have been taken directly from the transient definition; all other points represent temperature gradient extreme time points.

Table D-4 Structural Time Points of Interest for Insurge/Outsurge Transient withTemperature Drop of



 Table D-5 Structural Time Points of Interest for Insurge/Outsurge Transient with

 Temperature Drop of



Δ	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	NON BROBDIET ADV
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	

The nodal temperature at the particular time point is read into the structural model directly from the result file of the thermal analysis. The corresponding pressure is obtained through linear interpolation from appropriate tables listed in Tables D-2 and D-3. The computer output files for the structural analyses of the Insurge/Outsurge Transients are:

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT' NUMBER	PLANI	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

D.4 ASME CODE CRITERIA

The ASME Code stress analysis involves two basic sets of criteria:

1. Assure that failure does not occur due to application of the design loads.

2. Assure that failure does not occur due to repetitive loading.

In general, the Primary Stress Intensity criteria of the ASME Code (Reference 13.1) assure that the design is adequate for application of design loads.

Also, the ASME Code criteria for cumulative fatigue usage factor assure that the design is adequate for repetitive loading.

D.4.1 ASME CODE PRIMARY STRESS INTENSITY (SI) CRITERIA

As explained in Section 9.1, the nozzle configuration with structural weld overlay is qualified for primary stress consideration. Therefore, no primary stress evaluation is included in this Appendix.

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
AREVA	DOCUMENT NUMBER	PLANT NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY	
	52-90+9587-001		· · · · · · · · · · · · · · · · · · ·	

D.4.2 ASME CODE PRIMARY+SECONDARY STRESS INTENSITY (SI) CRITERIA

As stated previously, the analyses of stresses for transient conditions are required to satisfy the requirements for the repetitive loadings. The following discussion describes the fatigue analysis process employed herein for the design.

Overall stress levels are reviewed and assessed to determine which model locations require detailed stress/fatigue analysis. The objective is to assure that:

1. The most severely stressed locations are evaluated.

2. The specified region is quantitatively qualified.

D.4.2.1 Path Stress Evaluation

The ANSYS Post Processor is used to tabulate the stresses along predetermined paths and classify them in accordance with the ASME Code Criteria (i.e., membrane, membrane plus bending, total). For paths that go through 2 materials partial paths are taken in addition to the free edge to free edge.

For this analysis, the same paths for the minimum WOL are analyzed. The paths are shown in Figure 9-1 and Figure 9-2 and are described in Table 9-1.

~	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
AREVA	DOCUMENT NUMBER 32-9049387-001	plant NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY	

D.4.2.2 Primary+Secondary Stress Intensity Range Qualification

The ANSYS Post Processor was used to find the membrane + bending Stress Intensity Ranges and total Stress Intensity Ranges based on the method prescribed in paragraph NB-3216.2 of the ASME Code. The computer runs containing the results of the stress ranges calculation for membrane + bending, total stresses and associated usage factors are listed below.



The membrane + bending stress ranges as determined in the stress range runs are conservatively combined by hand with the stresses due to external loads (calculated in Section 5.2 of the main document) where appropriate. The maximum membrane + bending Stress Intensity Ranges are compared directly to the Primary + Secondary Stress Intensity Range criteria of the ASME Code. The summary of maximum membrane + bending Stress Intensity Ranges for the minimum WOL configuration is tabulated in Table D-6 through Table D-8.

Note that the Zero Stress State (ZSS) is included in the ANSYS runs listed above.

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANAL				
A	DOCUMENT NUMBER	PLANT			
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY		

Table D-6 Summary of Maximum Primary + Secondary SI Ranges for Membrane + Bending Stresses (Minimum WOL)

	Transient Stresses	w/ Surge	Applicable Externa	l Stresses
Path	SI Range Inside Node [ksi]	SI Range Outside Node [ksi]	SI Range Inside Node [ksi]	SI Range Outside Node _[ksi]
PipeL				
P Wol	$\overline{}$			$\overline{\mathbf{n}}$
P_Wola	\Box			П
P_Wolb				Π
SEU_Weld				П
SEU_Welda				· П
SEU_Weldb				
SEU_Wol		1		П
SEU_Wola .				· 🗌 😳 🔲
SEU_Wolb				Π
SEL_Wol				· []
SEL_Wola				. []
SEL_Wolb				
SEL_Weld				· · · ·
SEL_Welda				
SEL_Weldb				
N_Wol				
N_Wola				
N_Wolb	4			L
Noz				
Sleeve				

Note ⁽¹⁾: External stress at outside node of full path is conservatively used for the partial path node located at material interface.

	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-7 Comparison of Maximum SI Range including External Loads to ASMECode 3*Sm Criteria (Minimum WOL)

	Transient + Ex	ternal Stresses	Allowable M 3*S	I+B SI Range . Sm ⁽¹⁾	Mat	erial
Path	SI Range Inside Node [ksi]	SI Range Outside Node [ksi]	Inside Node [ksi]	Outside Node [ksi]	Outside Node	Inside Node
PipeL	1					
P_Wol	17					
P_Wola	T]					
_Wolb						
EU_Weld						
EU_Welda					•	
EU_Weldb						
EU_Wol						
EU_Wola						
EU_Wolb					•	
EL_Wol	1					• .
EL_Wola	1					·
EL_Wolb						
EL_Weld	<u> </u>				•	
EL_Welda	4					
EL_Weldb						
[_Wol						
[_Wola						
I_Wolb	Ц					
loz	Ц		,			
leeve						
ſ		. •)
		,			-	
			۰.			· · ·
		•				
						·
		~			· · ·	
1						
]						
						1
l						· · · J

Α	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

 Table D-8 External Stress Added by Components (Minimum WOL)

Α.	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT		
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY	

Table D-8

D-8 (Continued) External Stress Added by Components (Minimum WOL)

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS			
A	DOCUMENT NUMBER	PLANT		
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY	

Table D-8 (Continued) External Stress Added by Components (Minimum WOL)

(

ł

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-8 (Continued) External Stress Added by Components (Minimum WOL)

ì

~	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY



}

	LE WELD OVERLAY ANALYSIS		
APEVA	DOCUMENT NUMBER	PLANT	NON_PROPRIFTARV
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	

D.4.2.2.1 Summary of Stress Intensity Range Qualification

Tables D-7 and D-8 show the maximum SI Range calculated and the allowable limits for both maximum and minimum weld overlay configurations. The following path locations for both configurations exceeded the allowable 3*Sm limit:

PipeL – inside and outside nodes	SEU_Wola – inside and outside nodes
SEU_Welda – outside node	SEL_Wola – inside node
SEU_Wol – inside node	Sleeve – inside and outside node

The ASME Code allows the 3*Sm limit to be exceeded under special conditions, one of them being that Simplified Elastic-Plastic Analysis (NB 3228.5) is used for fatigue analysis. See Section D.4.2.3 for further qualifications.

D.4.2.3 Simplified Elastic-Plastic Analysis (NB-3228.5)

The maximum Primary + Secondary Stress Intensity criterion in Section D.4.2.2 is not met for the locations determined in the Section D.4.2.2.1. Therefore, the simplified elastic-plastic analysis for these locations is provided in this section.

The Primary + Secondary Stress Intensity range in the model may exceed $3*S_m$ if the requirements of the simplified elastic-plastic analysis are met. The requirements are:

D.4.2.3.1 Primary + Secondary SI Range (Excluding thermal bending stresses) (NB-3228.5(a))

The range of Primary + Secondary membrane + bending stress intensity, excluding thermal bending stresses, shall be ≤ 3 *Sm.

The SI ranges excluding thermal bending are calculated for the locations identified in Section D.4.2.2.1. The membrane + bending ANSYS output files listed in Section D.4.2.2 are used to find the stress components for membrane stress due to pressure and thermal conditions.

The bending stress due to pressure only is determined by multiplying the bending stress obtained from design linearization output files

with a pressure ratio. The ratio is based on the transient pressure at the time point of interest and design pressure. The ratioed bending stress is added to the membrane stress and external stress for determination of SI range without thermal bending effect.

The design condition is **C** The applied temperature affects only physical material properties, therefore the effect of thermal bending is considered to be negligible.

Tables D-9 presents the calculations and results for the maximum primary + secondary SI Ranges for membrane + bending - thermal bending stresses per NB-3228.5(a) for the minimum WOL.

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-9 Minimum WOL SI Ranges Minus Thermal Bending

Prepared by: M. Sedlakova Reviewed by: L. Yen

.

۸	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
A	DOCUMENT NUMBER	PLANI			
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY		

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
A	DOCUMENT NUMBER	PLANI			
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY		

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007 Page 195

٨	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

All SI Ranges listed in Tables D-4 are less than the allowable stress, therefore the requirement of ASME NB-3228.5(a) has been met on all locations.

. ·

А	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLA					
A	DOCUMENT NUMBER	PLANT				
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY			

D.4.2.3.2 Factor Ke (NB-3228.5(b))

The values of S_a used for entering the design fatigue curve is multiplied by the factor K_c, where

 $K_e = 1.0 + \frac{1-n}{n \cdot (m-1)} \left(\frac{S_n}{3 \cdot S_m} - 1 \right) \quad \text{for } 3 \cdot S_m < S_n < 3 \cdot m \cdot S_m$ $K_e = 1.0/n \quad \text{for } S_n \ge 3 \cdot m \cdot S_m$

m = 1.7 for austenitic stainless steel from Table NB-3228.5 (b)-1 (Reference 13.1)

n = 0.3 for austenitic stainless steel from Table NB-3228.5 (b)-1 (Reference 13.1)

 S_m [ksi] (a) average temperature of the metal at the critical time points

S_n [ksi] Primary + Secondary membrane plus bending SI Range

The K_e factor is calculated for each SI Ranges over the $3xS_m$ limit in the fatigue evaluation as documented in Section D.4.2.4.

D.4.2.3.3 Fatigue Usage Factor (NB-3228.5(c) and NB-3222.4)

For fatigue usage factor evaluation see Section D.4.2.4.

D.4.2.3.4 Thermal Stress Ratchet (NB-3228.5(d) and NB-3222.5)

Thermal Ratchet is considered for the locations listed in Section D.4.2.2.1.

Some of these locations are parts of the local geometric discontinuities. The ASME Code requirements for thermal ratcheting are considered accurately only for cylindrical shells without discontinuities. On the other hand, the requirements for thermal ratcheting at discontinuities are considered to be "probably overly conservative" (Reference 13.12, page 207).

Maximum Allowable Range of Thermal Stress (NB-3222.5):

Tables D-10 determines the maximum allowable ranges of thermal stresses in the piping and thermal sleeve. The values of allowable stresses are conservatively calculated based on the membrane stresses due to the design pressure **[**].

The "S1" values are obtained from ANSYS output files [_____] and

NB-3222.5 only requires the SI Range to include thermal SI Ranges and those from the output files also contain pressure effects. The Thermal SI Ranges are calculated in Tables D-11.

Table D-10 Allowable Ranges of Thermal Stresses for Minimum WOL

Path	SI Range ⁽¹⁾	Maximum Temperature ^{(2) (3)}	Sm	1.5*Sm	Sy	S1	x	у'	Allowable SI Range
	[ksi]	[°F]	[ksi]	[ksi]	[ksi]	[ksi]			[ksi]
						,		. *	
									•
te (1): See Table	D-11								

Note ⁽²⁾: See Table D-7 Note ⁽³⁾: See Table D-8

Where:

x = max. general membrane stress due to pressure ("S1") divided by the yield strength $S_y^{(1)}$

 $y' = \frac{1}{x}$ for 0.0 < x < 0.5; y' = 4(1-x) for 0.5 < x < 1.0

Maximum allowable range of thermal stress = $y' * S_{y}^{(1)}$

Note ⁽¹⁾: $1.5S_m$ is used instead of S_y . Per NB-3222.5, note 11, it is permissible to use $1.5S_m$ in this equation whenever it is greater than S_y .

The maximum SI Ranges of thermal stresses are less than the allowable stresses; therefore the requirement has been met.

· · · · · ·	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-11 Thermal M+B SI Range for Minimum WOL

j

· A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMEN I' NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Prepared by: M. Sedlakova Reviewed by: L. Yen

1



Ĭ,

Table D-11 (Continued) Thermal M+B SI Range for Minimum WOL

<i>A</i>	NORTH ANNA UNITS 1&2	, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	

AREVA

Table D-11 (Continued) Thermal M+B SI Range for Minimum WOL

· 🔥	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	NON DOODDET ADV
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIE I ARY

A	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

~	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Prepared by: M. Sedlakova Reviewed by: L. Yen

۸	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Α	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

D.4.2.3.5 Thermal Only External Loading

Seismic external loads are assumed to only occur during the steady state transient. Because the two transients ranging to create the maximum stress intensity are not the steady state condition, the OBE external loads can be excluded from the total stress intensity range. When the steady state condition (PLUL) ranges with another transient, the stress state is significantly less than the maximum stress intensity range such that even if OBE and Thermal external loads were combined with it, the total stress intensity would not govern. From Reference 13.16, the enveloped external loads due to Thermal loads only are:

 Table D-12
 Thermal External Loads

Thermal Loads	Fy (Axial) <i>kip</i>	Fx kip	Fz kip	Fs (Shear) ⁽¹⁾ <i>kip</i>	Mtx (Torsional) in- kip	Mx in- kip	Mz in- kip	Mb (Bending) ⁽²⁾ in- kip
						,)

Note ⁽¹⁾: Shear is calculated as the SRSS of Fx and Fz.

Note ⁽²⁾: Bending is calculated as the SRSS of Mx and Mz.

Using the dimensions and equations in presented in Section 5.1 and 5.2, the following external loads are found for path PipeL, outside diameter:

 Table D-13 Thermal External Loads

		Axia	al Stress			Shear Stress		M+B
Loading	σ_{ax_EX}	σ_{ax_BF}	σ_{ax_BM}	σ_{ax_M+B}	τ _{s_Fs}	τ _{s_Mt}	τ _s	Sint
	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]	[ksi]
								}

D.4.2.3.5 Temperature Limits (NB-3228.5(e))

The maximum temperature of the components is () which does not exceed the maximum allowable temperatures listed in Table NB-3228.5(b)-1, Reference 13.1.

Therefore, the ASME Code requirement is met.

D.4.2.3.7 Minimum Strength Ratio (NB-3228.5(f))

The material shall have specified minimum yield strength to specified minimum tensile strength ratio of less then 0.80.

The S_y and S_u values at 70°F are obtained from Reference 13.15.

For $f_{\rm specified minimum yield strength}$, $S_y = 30 \text{ ksi } @70^{\circ}\text{F}$ Specified minimum tensile strength, $S_u = 75 \text{ ksi } @70^{\circ}\text{F}$ Ratio of $S_y/S_u = 0.40$

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Specified minimum yield strength, $S_y = 30 \text{ ksi } @70^\circ \text{F}$ Specified minimum tensile strength, $S_u = 75 \text{ ksi } @70^\circ \text{F}$ Ratio of $S_y/S_u = 0.40$

Specified minimum yield strength, $S_y = 25 \text{ ksi } @70^\circ \text{F}$ Specified minimum tensile strength, $S_u = 65 \text{ ksi } @70^\circ \text{F}$ Ratio of $S_y/S_u = 0.38$

Specified minimum yield strength, $S_y = 30 \text{ ksi } @70^\circ \text{F}$ Specified minimum tensile strength, $S_u = 75 \text{ ksi } @70^\circ \text{F}$ Ratio of $S_y/S_u = 0.40$

Therefore, the ASME Code requirement is met.

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER	PLANT	NON-PROPRIETARY
	32-9049387-001	NORTH ANNA UNITS I & 2	

D.4.2.4 Fatigue Usage Factor Calculation

For consideration of fatigue usage, the Peak Stress Intensity Ranges are calculated. These values must include the total localized stresses.

The fatigue usage factor at a location is usually calculated based on the actual stress intensity range. However, at a geometric or material discontinuity, an unrealistic peak stress may result from the modeling approach, element type and mesh sizes. The total stress obtained from the finite element analysis may not be able to capture the actual stress condition. To account for the possible modeling inaccuracies, an FSRF is usually applied to the M+B stress intensity range for location experiencing the discontinuity.

The stress category used in fatigue evaluation, along with an appropriate FSRF, for each node is listed in Table D-12. For path lines nearby the thermal sleeve weld (i.e., crevice), M+B stresses with a FSRF of 4.0 are applied. Per Reference 13.13 (p. 395), the FSRF for node on the inside and outside of the safe end component, outer nozzle, and pipe near WOL junction are based on a bounding taper angle.

Path Nama	Inside Node	;	Outside Node		
ratii Ivante	Stress Category	FSRF	Stress Category	FSRF	
PipeL	TOTAL	r t	M+B		
P_Wol	M+B	1 [TOTAL	1	
P_Wola	M+B	1 [TOTAL		
P_Wolb	TOTAL	1 [TOTAL		
SEU_Weld	M+B ·	1	TOTAL		
SEU_Welda	M+B		M+B		
SEU_Weldb	M+B		TOTAL		
SEU_Wol	M+B	1 F	TOTAL		
SEU_Wola	M+B		M+B		
SEU_Wolb	M+B		TOTAL		
SEL_Wol	M+B	1 [TOTAL		
SEL_Wola	M+B		M+B		
SEL_Wolb	M+B	1 F	TOTAL		
SEL_Weld	M+B	1 [TOTAL		
SEL_Welda	M+B		M+B		
SEL_Weldb	M+B		TOTAL		
N_Wol	TOTAL		TOTAL		
N_Wola	TOTAL		TOTAL		
N_Wolb	TOTAL		TOTAL		
Noz	TOTAL	TOTAL			
TS	TOTAL		M+B		

Table D-12 Stress Category and FSRF in Fatigue Evaluation

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
A	DOCUMENT NUMBER	PLANI .	•			
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY			

For the location determined to be critical, the corresponding external loads from Table 5-5 through Table 5-16 have been incorporated in the fatigue calculation. Using the SI ranges and cycles taken from the "fatigue" output files (see Section 12), the bounding external SI (including thermal stratification) have been added manually to the first cycles and the fatigue usage factor then recalculated. This method of adding the external SI to the transient SI is a conservative method as shown in the previous sections.

The thermal stratification external loads are included in the fatigue calculation as independent sub-cyles. For each case the usage factor calculation is based upon the SI specified in Table 5-7 through Table 5-16 and the number of cycles for each case as stated in Reference 13.8.

The following pages contain the calculation of the cumulative fatigue usage factor for the points of interest. The usage factor includes Transient loading and all applicable external loadings. The calculation is performed separately for seven materials and different parts of model.

The critical locations are:

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
A	DOCUMENT NUMBER	PLANT				
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY			

Table D-13 PipeL Usage Factor Calculation

	Evaluation Title:	North Anna	- PZR Surge	Nozzle Weld	l Overlay	/ Analysis -	PipeL (Outside No	de, 6103)
	Reference Files:	(
	Material:							
	Туре:							
	UTS (ksi) =							
	E matl (psi) =						. ,	J
DANCE	το Ανειέντε Μυτυ	REQ'D		DEAKSI		(E ratio)	ALLOWABLE	USAGE
NUMBER	RANGE EXTREMES	CYCLES	E matl	RANGE	S alt	х	CYCLES	FACTOR
					ļ	<u>S alt</u>	<u>"N"</u>	<u>"U"</u>
11	'SIA'-'IOSurge_1'						,	
2	'HUCD_1'-'IOSurge_1'	1			•		•••	
3	'HUCD_1'-'RT_CDSI'							
· 4	'HUCD_1'-'RCOP'							
5	'HUCD_1'-'HUCD_2'							
6	'HUCD_2'-'IOSurge110_2'						•	
7	'RCSD'-'IOSurge_2'							
8	'SUIL'-'IOSurge110_2'							
9	'RT_CDnSI-'IOSurge_2'							
10	'RT_CDnSI-'IOSurge_2'							
11	'CRD'-'IOSurge110_2'							
12	'IOSurge_2'-'IOSurge110_2'							
13	'FCHSD'-'IOSurge110_2'							
14	'LOSLSD'-'IOSurge110_2'					-		
15	'LOF'-'IOSurge110 2'							
16	'IOSurge110_1'-'IOSurge110_2'							
17.	'LOP'-'IOSurge110_1'							
18	'LOL'-'IOSurge110_1'							
19	'RT_noCD'-'IOSurge110_1'						,	
20	'PLUL_1'-'IOSurge110_1'						v'	1
21	'PLUL_1'-'PLUL_1'							
22	'LSDL'-'LSDL'							
23	'10SLdec'-'10SLdec'							
24	'BCE'-'TRT'							
25	'BCE'-'PLUL_2'							×
26	'10SLinc'-'BCE'							
27	'BCE'-'LOSLSU'							
28	'BCE'-'BCE']			•			
29	HU-340	1						
30	HU-200	1						
31	HU-100	1						
32	HU-147	1						

NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS

AREVA

DOCUMENT NUMBER 32-9049387-001 plant NORTH ANNA UNITS 1 & 2

NON-PROPRIETARY

Table D-13 (Continued) PipeL Usage Factor Calculation

33	OP-43			
34	IO Surge Sub-Cycles			
35	Sub-Cycle within HUCD			
The 'Peak SI Range' = 'Memb + Bend' SI Ra				
Range 1, 'Memb + Bend' SI Range =				
Range 2, 'Mei	nb + Bend' SI Range =			
Range 3, 'Mer	nb + Bend' SI Range =			
Range 4, 'Mer	nb + Bend' SI Range =			
Range 5, 'Mer	nb + Bend' SI Range =			
Range 6, 'Mer	nb + Bend' SI Range =			
Range 7, 'Mei	nb + Bend' SI Range =			
Range 8, 'Mer	nb + Bend' SI Range =			
Range 9, 'Mer	nb + Bend' SI Range =			
Range 10, 'Me	emb + Bend' SI Range =			
Range 11, 'Me	emb + Bend' SI Range =			
Range 12, 'Me	emb + Bend' SI Range =			
Range 13, 'Me	emb + Bend' SI Range =			
Range 14, 'Me	emb + Bend' SI Range =			
Range 15, 'Me	emb + Bend' SI Range =			
Range 16, 'Me	emb + Bend' SI Range =			
Range 17, 'Me	emb + Bend' SI Range =			
Range 18, 'Me	emb + Bend' SI Range =			
Range 19, 'Me	emb + Bend' SI Range =			
Range 20, 'Me	mb + Bend' SI Range =			
Range 21, 'Me	emb + Bend' SI Range =			
Range 22, 'Me	mb + Bend' SI Range =			
Range 23, 'Me	mb + Bend' SI Range =			
Range 24, 'Me	mb + Bend' SI Range =			
Range 25, 'Me	mb + Bend' SI Range =			
Range 26, 'Me	mb + Bend' SI Range =			
Range 27, 'Me	mb + Bend' SI Range =			
Range 28, Me	mb + Bend' SI Range =			
Range 29, Me	mb + Bend' SI Range =			
Range 30, Me	mo + Bend' SI Kange =			
Range 31, Me	mo + Dend' SI Kange =			
Range 32, 'Me	mo + Bend' SI Kange =			
Kange 33, 'Me	mo + Bend' SI Range =			


Table D-13 (Continued) PipeL Usage Factor Calculation

Location	M+B Transient SI Range	Temp 1	Temp 2	Max. Temp.	Sm	External SI	Transient + External SI Range	EQ 1	EQ 2	Ke Factor
	ksi	°F	°F	°F	ksi	ksi	ksi			
	· .						•	•		
Note ()	": Max. Temperat	ture used to	find the Em	atl value						

Note ⁽²⁾: Thermal only external loads. See Section D.4.2.3.5.

Note ⁽³⁾: Equation 1 and 2 for Ke values are presented in Section D.4.2.3.2.

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-14 SEU_Weld Usage Factor Calculation

	Evaluation Title: Reference Files: Material:	North Ann	a - PZR Sur	ge Nozzle Wo	eld Overla	ay Analysis -	SEU_Weld (Inside	Node, 6244)
	Type:		•.					
	UTS (ksi) =	·						
	E matl (psi) =			·				
RANGE	TRANSIENTS WITH	REO'D		PEAK SI		(E ratio)	ALLOWABLE	USAGE
NUMBER	RANGE EXTREMES	CYCLES	E matl	RANGE	S alt	x	CYCLES	FACTOR
						<u>Salt</u>	<u>"N"</u>	
1	'RCSD'-'IOSurge_1'	\checkmark						\mathcal{F}
2	'LOL'-'IOSurge_1'							ł
3	'RT_CDnSI-'IOSurge_1'					. ,		
4	'RT_CDnSI-'RT_CDSI'		•				•	-
5	HUCD_T-'RT_CDnSI							
6	CKD'-'HUCD_I'							H
/								H
8	HUCD 2-SIA							H
10	HUCD 2' 'RT noCD'							H
10	IDCOPUERT mcCD							H
12	BT mcCD' IIOSuma 2'			1				H
12	VI OF JOSurge 2							H
14	'I SDI '-'IOSurge_2'							H
15								H
16	'FCHSD'-'LSDL'				· .			F
17	'FCHSD'-'LOSLSD'			ч. — •				H
18	'FCHSD'-'LOP'	· .				.•		H
19	'10SLdec'-'FCHSD'						· ·	
20	'10SLdec'-'IOSurge110 1'	1						H
21	'BCE'-'IOSurge110 1'	1						H
22	'TRT'-'IOSurge110 1'							h
23	'PLUL 1'-'IOSurge110 1'	1	· .					ľ
24	'PLUL 1'-'PLUL 1'	1						
25	'PLUL_2'-'IOSurge110 2'	1						ľ
26	'10SLinc'-'IOSurge110 2'	1						. I
	'IOSurge110_2'-	1						l l
27	'IOSurge110_2'					`		H
28	'LOSLSU'-'LOSLSU'	1						-
29	<u>HU-340</u>	1						
30	HU-200						•	-
31	HU-100			•		×		H
32	HU-147	Į			•			А
33	OP-43	$\boldsymbol{\mathcal{L}}$						

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

:

Α	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

	Table D-14 (Co	ontinued) SEU_weld Fatigue Usage Factor Calculation	
34	IOSurge Sub-Cycles		
35	Sub-Cycle within HUCD) I
The 'Peak S	I Range' = 'Memb + Bend' SI	Ran	
Range 1, 'M	emb + Bend' SI Range =		
Range 2, 'M	emb + Bend' SI Range =		
Range 3, 'M	emb + Bend' SI Range =		
Range 4, 'M	emb + Bend' SI Range =		
Range 5, 'M	emb + Bend' SI Range =		
Range 6, 'M	emb + Bend' SI Range =		
Range 7, 'M	emb + Bend' SI Range =		, ⁴⁷
Range 8, 'M	emb + Bend' SI Range =		
Range 9, 'M	emb + Bend' SI Range =		
Range 10, 'N	/lemb + Bend' SI Range =		
Range 11, 'N	/Iemb + Bend' SI Range =		
Range 12, 'N	/Iemb + Bend' SI Range =		
Range 13, 'N	/Iemb + Bend' SI Range =		
Range 14, 'N	/lemb + Bend' SI Range =		
Range 15, 'N	Aemb + Bend' SI Range =		
Range 16, 'N	/Iemb + Bend' SI Range =		
Range 17, 'N	Aemb + Bend' SI Range =	· ·	
Range 18, 'N	Aemb + Bend' SI Range =]
Range 19, 'N	Aemb + Bend' SI Range =	· · ·	1
Range 20, 'N	Aemb + Bend' SI Range =		
Range 21, 'N	Aemb + Bend' SI Range =		
Range 22, 'N	Aemb + Bend' SI Range =		
Range 23, 'N	Aemb + Bend' SI Range =		
Range 24, 'N	Aemb + Bend' SI Range =		ļ
Range 25, 'N	Aemb + Bend' SI Range =		
Range 26, 'N	Aemb + Bend' SI Range =		
Range 27, 'N	Aemb + Bend' SI Range =		
Kange 28, 'N	nemp + Bend' SI Kange =		ſ
Kange 29, 'N	nemp + Bend' Si Range =		
Kange 30, 'N	Aemb + Bend' SI Range =		
Kange 31, 'N	Aemb + Bend' SI Range =		(
Kange 32, 'N	Aemb + Bend' SI Kange =		J
Kange 33, 'N	Aemb + Bend' SI Range =		

A	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-14 (Continued) SEU_Weld Fatigue Usage Factor Calculation

Location	M+B Transient SI Range	Temp 1	Temp 2	Max Temp	Sm	External SI	Transient + External SI Range	EQ 1	EQ ⁻²	Ke Factor
	ksi	°F	°F	°F	ksi	ksi	ksi			
L	(1) -									' J

Note ⁽¹⁾: Equation 1 and 2 for Ke values are presented in Section D.4.2.3.2.

ţ

~	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER 32-9049387-001	plant NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-15 SEL_Wola Usage Factor Calculation

[Evaluation Title:	North Ann	a - PZR Surg	e Nozzle Weld	Overlay	v Analysis - S	EL_Wola (Inside)	Node, 5060)
	Reference Files:	(Y
	Material:							
	Туре:			-				
	UTS (ksi) =							
	<u>E matl (psi) =</u>	7						
RANGE NUMBER	TRANSIENTS WITH RANGE EXTREMES	REQ'D CYCLES	E matl	PEAK SI RANGE	S alt	(E ratio) x <u>S alt</u>	ALLOWABLE CYCLES <u>"N"</u>	USAGE FACTOR <u>"U"</u>
1	'HUCD_1'-'IOSurge_1'	7						
2	'RCSD'-'RT_CDSI'	1						N
· 3	'RCSD'-'SUIL'							ſ
4	'SIA'-'IOSurge_2'							1
5	'CRD'-'IOSurge 2'	1						
6	'FCHSD'-'IOSurge 2'	1						
7	'FCHSD'-'RT_CDnSI			•				Γ
8	'FCHSD'-'RT CDnSI	1						Ĩ
9	'FCHSD'-'LOL'							
10	'FCHSD'-'RT noCD'							-
11	'FCHSD'-'LOF'							
12	'FCHSD'-'LSDL'							· [
-13	'FCHSD'-'LOSLSD'							
.14	'FCHSD'-'PLUL_1'	1						
15	'HUCD_2'-'PLUL_1'	1						
16	'PLUL 1'-'RCOP'							1
17	'PLUL_1'-'IOSurge110_1'	j						
18	'10SLdec'-'IOSurge110 1'							
.19	'BCE'-'IOSurge110 1'							· 1
20	'BCE'-'LOP'							Ĩ
21	'PLUL 2'-'IOSurge110 2'							
22	'10SLinc'-'BCE']						
23	'BCE'-'LOSLSU'							
24	'TRT'-'IOSurge110 2'	1						
25	'BCE'-'IOSurge110_2'					r		
	'IOSurge110_2'-							Ĩ
26	'IOSurge110_2'	· ·						
27	HU-340							
. 28	HU-200		•					
29	HU-100							
30	HU-147	l						
31	OP-43	7						Д
		\sim						

A .	NORTH ANNA UNITS 1&	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
A	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	NORTH ANNA UNITS 1. & 2	NON-PROPRIETARY				

Table D-15 (Continued) SEL_Wola Usage Factor Calculation

. 34	IO Surge Sub-Cycles ⁽²⁾	
35	Sub-Cycle within HUCD	
The 'Peak S	SI Range' = 'Memb + Bend' SI Ra	
Range 1, 'N	1emb + Bend' SI Range =	
Range 2, 'N	1emb + Bend' SI Range ≈	
Range 3, 'N	1emb + Bend' SI Range =	
Range 4, 'N	1emb + Bend' SI Range =	
Range 5, 'N	1emb + Bend' SI Range =	
Range 6, 'N	1emb + Bend' SI Range =	
Range 7, 'N	1emb + Bend' SI Range =	
Range 8, 'N	1emb + Bend' SI Range =	
Range 9, 'N	1emb + Bend' SI Range =	
Range 10, '	Memb + Bend' SI Range =	
Range 11, '	Memb + Bend' SI Range =	
Range 12,	Memb + Bend' SI Range =	
Range 13, '	Memb + Bend' SI Range =	
Range 14, '	Memb + Bend' SI Range =	
Range 15, "	Memb + Bend' SI Range =	
Range 16, '	Memb + Bend' SI Range =	
Range 17, '	Memb + Bend' SI Range =	
Range 18,	Memb + Bend' SI Range =	
Range 19, 1	Memb + Bend' SI Range =	
Range 20, 1	Memb + Bend' SI Range =	
Range 21, 1	Memb + Bend' SI Range =	
Range $22, 1$	Memb + Bend' SI Range =	
Range 23, J	Memb + Bend' SI Range =	
Range 24, 1	Memb + Bend' SI Range =	
Range 25, 1	Memb + Bend' SI Range =	
Range 27	Memb + Bend' SI Pange -	
Range 28 1	Memb + Bend' SI Range =	
Range 20, 1	Memb + Bend' SI Range =	
Range 30 '	Memb + Bend' SI Range =	
Range 31. '	Memb + Bend' SI Range =	
		

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-15 (Continued) SEL_Wola Usage Factor Calculation

Location	M+B Transient SI Range	Temp 1	Temp 2	Max Temp.	Sm	External SI	Transient + External SI Range	EQ 1	EQ 2	Ke Factor
	ksi	°F	°F	°F	ksi	ksi	ksi			
										Ĵ
<u> </u>										

Note ⁽¹⁾: Max. Temperature used to find the E matl value.

Note ⁽²⁾: Plastic analysis is used to find the CFUF associated with the Insurge/Outsurge Subcycles. See Appendix E.

Note ⁽³⁾: Equations 1 and 2 for Ke values are presented in Section D.4.2.3.2.

Note ⁽⁴⁾: IOSurge Transient contributes a partial usage factor of when this transient ranges within itself (i.e., sub-cycles), see Section D.4.2.4 (last paragraph).

Because the total usage factor of **b** is above the allowable value 1.0, plastic analysis is performed for IOSurge Transient at this location (SEL_Wola) in Appendix E.

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY				

Table D-16 SEL_Welda Usage Factor Calculation

[North Ann	a - PZR Surg	e Nozzle Wel	d Overlay	Analysis - S	SEL_Welda (Inside	Node,
	Evaluation Title:	6103)						
	Reference Flies:							
	Material:							
	I ype: UTS (ksi) =		,		•			
	E matl (nsi) =	Į.						
			1	1 1		(E ratio)	ALLOWABLE	USAGE
RANGE NUMBER	TRANSIENTS WITH RANGE EXTREMES	REQ'D CYCLES	E matl	PEAK SI RANGE	S alt	x <u>S alt</u>	CYCLES <u>"N"</u>	FACTOR <u>"U"</u>
1	'HUCD_1'-'LOP'		•	• •				$\overline{\ }$
2	'BCE'-'HUCD_1'	7		·				
3	'BCE'-'HUCD_2'			· ·				
4	'LOL'-'IOSurge 1'	Π						
5	'RT CDnSI-'IOSurge 1'							
6	'RT_CDnSI-'IOSurge 1'	Π						
7	'BCE'-'IOSurge 2'	T.					·	
8	'BCE'-'RCOP'							
9	'RT CDnSI-'RT CDSI'		•					
10	'RT CDnSI-'SIA'	†	•					
11	'RCSD'-'SIA'	Ħ						
12	'CRD'-'SIA'	Ĩ						
13	'CRD'-'FCHSD'							
14	'FCHSD'-'LOF'							
15	'FCHSD'-'LOSLSD'							
16	'FCHSD'-'LSDL'		10					
17	'FCHSD'-'RT_noCD'							
18	'10SLdec'-'FCHSD'	Π						
19	'10SLdec'-'IOSurge110_1'							
20	'PLUL 1'-'IOSurge110 1'							
21	'BCE'-'IOSurge110_1'			•				
22	'BCE'-'SUIL'			6				
23	'PLUL_2'-'IOSurge110_2'			·				
24	'BCE'-'IOSurge110_2'							
25	'10SLinc'-'TRT'							
26	'LOSLSU'-'IOSurge110_2'			•				
27	'10SLinc'-'IOSurge110_2'	· ·						
	'IOSurge110_2'-						·	
28	'IOSurge110_2'	4						
29	HU-340	4						
30	HU-200	4						
31	HU-100	Ľ		·				ļ
32	HU-147							
Ē	repared by: M. Sedlako	va	Ľ	Date: 12/200	7		Page 221	_
F	Reviewed by: L. Yen		D	ate: 12/200	7			

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
A	DOCUMENT NUMBER	PLANT				
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY			

Table D-16 (Continued) SEL_Welda Usage Factor Calculation

ı

33	OP-43	
34	IO Surge Sub-Cycles	
35	Sub-Cycle within HUCD	
The 'Peak SI	Range' = 'Memb + Bend' SI Ran	
Range 1, 'Me	emb + Bend' SI Range =	
Range 2, 'Me	emb + Bend' SI Range =	
Range 3, 'Me	emb + Bend' SI Range =	
Range 4, 'Me	emb + Bend' SI Range =	
Range 5, 'Me	emb + Bend' SI Range =	
Range 6, 'Me	emb + Bend' SI Range =	
Range 7, 'Me	emb + Bend' SI Range =	
Range 8, 'Me	emb + Bend' SI Range =	
Range 9, 'Me	emb + Bend' SI Range =	· ·
Range 10, 'M	lemb + Bend' SI Range =	
Range 11, 'M	lemb + Bend' SI Range =	
Range 12, M	lemb + Bend' SI Range =	
Range 13, M	lemb + Bend' SI Range =	
Range 14, M	lemb + Bend' SI Range =	
Range 15, M	lemb + Bend' SI Range =	
Range 10, M	lenio + Bend SI Range =	
Range 18 'M	lemb + Bend' SI Range =	· · · · · · · · · · · · · · · · · · ·
Range 19 'M	emb + Bend' SI Range =	
Range 20, 'M	lemb + Bend' SI Range =	
Range 21, 'M	lemb + Bend' SI Range =	
Range 22. 'M	lemb + Bend' SI Range =	
Range 23, 'M	lemb + Bend' SI Range =	
Range 24, 'M	lemb + Bend' SI Range =	
Range 25, 'M	lemb + Bend' SI Range =	
Range 26, 'M	lemb + Bend' SI Range =	
Range 27, 'M	lemb + Bend' SI Range =	
Range 28, 'M	lemb + Bend' SI Range =	
Range 29, 'M	lemb + Bend' SI Range =	
Range 30, 'M	lemb + Bend' SI Range =	
Range 31, 'M	lemb + Bend' SI Range =	
Range 32, 'M	lemb + Bend' SI Range =	
Range 33, 'M	lemb + Bend' SI Range =	

	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS						
A	DOCUMENT NUMBER	PLANT					
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY				

Table D-17 P_Wol Fatigue Usage Factor Calculation

	Evaluation Title: Reference Files: Material: Type: UTS (ksi) = E matl (psi) =	North Ann	ıa - PZR Surg	ge Nozzle W	/eld Over	lay Analysis	s - P_Wol (Outside	Node, 5986)
RANGE NUMBER	TRANSIENTS WITH RANGE EXTREMES	REQ'D CYCLES	E matl	PEAK SI RANGE	S alt	(E ratio) x <u>S alt</u>	ALLOWABLE CYCLES <u>"N"</u>	USAGE FACTOR <u>"U"</u>
1	'LOP'-'IOSurge_1'		·					
2	'HUCD_1'-'IOSurge_1'	7					· •	
3	'HUCD_1'-'HUCD_1'							. í
4	'HUCD_2'-'LOSLSD'					:		
5	'BCE'-'HUCD_2'					· .		
6	'BCE'-'RT_CDSI'							
7	'BCE'-'RCOP'							
8	'BCE'-'IOSurge_2']						
9	'BCE'-'IOSurge_2'						•	
10	'BCE'-'RCSD'							
. 11	'BCE'-'SIA'							
12	'BCE'-'CRD'							
13	'BCE'-'FCHSD'						· •	
14	'BCE'-'IOSurge110_1'							
15	'10SLdec'-'IOSurge110_1'		•					
16	'LOL'-'IOSurge110_1'							
17	'LSDL'-'IOSurge110_1'							
18	'PLUL_1'-'IOSurge110_1'							
19	'PLUL_1'-'SUIL'							
20	'PLUL_1'-'RT_CDnSI							
21	'PLUL_1'-'PLUL_1'						· · ·	
22	'PLUL_2'-'TRT'							
23	'LOF'-'PLUL_2'							
24	'PLUL_2'-'RT_noCD'							
25	'PLUL_2'-'IOSurge110_2'	1						
26	'10SLinc'-'IOSurge110_2'						•	
27	'LOSLSU'-'IOSurge110_2'							
70	'IOSurge110_2'-				. · ·			
20	UI 240							
29	HIL200							
30	HIL100							
31	HU_147	{						A
52	<u></u>	\sim						

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
A	DOCUMENT NUMBER	PLANT				
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY			

Table D-17 (Continued) P Wol Fatigue Usage Factor Calculation

33	OP-43	V							
34	IOSurge Sub-Cycles	[
35 Sub-Cycle within HUCD									
The 'Peak SI I	Range' = 'Total' SI Range x Fatig								
Range 1, 'Tota	al' SI Range =								
Range 2, 'Tota	l' SI Range =								
Range 3, 'Tota	I' SI Range =								
Range 4, 'Tota	l' SI Range =								
Range 5, 'Tota	l' SI Range =								
Range 6, 'Tota	l' SI Range =								
Range 7, 'Tota	l' SI Range =								
Range 8, 'Tota	l' SI Range =								
Range 9, 'Tota	l' SI Range =								
Range 10, 'To	tal' SI Range =								
Range 11, 'To	tal' SI Range =								
Range 12, 'To	tal' SI Range =								
Range 13, 'To	tange 13, 'Total' SI Range =								
Range 14, 'To	al' SI Range =								
Range 15, 'To	al' SI Range =								
Range 16, 'Tot	al' SI Range =								
Range 17, 'Tot	al' SI Range =								
Range 18, 'Tot	al' SI Range =								
Range 19, 'Tot	al' SI Range =								
Range 20, 'Tot	al' SI Range =								
Range 21, 'Tot	al' SI Range =								
Range 22, 'Tot	al' SI Range =								
Range 23, 'Tot	al' SI Range =								
Range 24, 'Tot	al' SI Range =								
Range 25, 'Tot	al' SI Range =								
Range 26, 'Tot	Range 26, 'Total' SI Range =								
Range 27, 'Tot	al' SI Range =								
Range 28, 'Tot	al' SI Range =								
Range 29, 'Total' SI Range =									
Range 30, 'Total' SI Range =									
Range 31, 'Tot	al' SI Range =								
Range 32, 'Tot	al' SI Range =								
Range 33, 'Tot	al' SI Range =	1							

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS					
A	DOCUMENT NUMBER	PLANT				
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY			

Table D-18 Noz Fatigue Usage Factor Calculation

	Evaluation Title:	North Ann	a - PZR Sur	ge Nozzle W	eld Over	ay Analysis	- Noz (Outside No	de, 4868)
	Reference Files:	()
	Material:						· .	
	Туре:							
	UTS (ksi) =						•	
	<u> </u>			T				
RANGE	TRANSIENTS WITH	REO'D		PEAK	a 14	(E ratio)	ALLOWABLE	USAGE
NUMBER	RANGE EXTREMES	CYCLES	E mati	SI RANGE	S alt	X Solt	CYCLES	FACTOR
1	'HUCD 1'-'IOSurge 1'	~	•			<u> 5 aii</u>	· <u> </u>	
2	'HUCD 2'-'LOP'	7						
3	'HUCD 2'-'IOSurge110 2'							,
4	'RCOP'-'IOSurge110 2'							
5	'RT CDSI'-'IOSurge 2'							
6	'RCSD'-'IOSurge 2'							
7	'SIA'-'IOSurge_2'	-						
-	'IOSurge_2'-						,	
· <u> </u>	'IOSurge110_2'	_						
9	'FCHSD'-'IOSurge110_2'							
10	'CRD'-'IOSurge110_2'							
11	'IOSurge110_1'- 'IOSurge110_2'							
12	'LOSLSD'-'IOSurge110_1'							
13	'PLUL_1'-'IOSurge110_1'							•
14	'PLUL_1'-'PLUL_1'	· .						
15	'10SLdec'-'SUIL'							
16	'10SLdec'-'RT_CDnSI		•				· · ·	•
17	'10SLdec'-'TRT'							
18	'10SLdec'-'LOF'							
19	'10SLdec'-'RT_noCD'					,		
20	'10SLdec'-'PLUL_2'							
21	'PLUL_2'-'PLUL_2'							
22	'BCE'-'LOL'				. `			
23	'10SLinc'-'BCE'	_						
24	'BCE'-'LOSLSU'							
25	'BCE'-'LSDL'	1				•		
26	'BCE'-'BCE'	4						-
27 ·	<u>HU-</u> 340	4						
28	HU-200	4						
29	HU-100	4						
30	HU-147	7		F				
				r				

)

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	1
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-18 (Continued) Noz Fatigue Usage Factor Calculation

31	OP-43
32	IO Surge Sub-Cycles
33	Sub-Cycle within HUCD
The 'Peak SI I	Range' = 'Total' SI Range x Ke (
Range 1, 'Tota	al' SI Range =
Range 2, 'Tota	al' SI Range =
Range 3, 'Tota	al' SI Range =
Range 4, 'Tota	al' SI Range =
Range 5, 'Tota	al' SI Range =
Range 6, 'Tota	al' SI Range =
Range 7, 'Tota	al' SI Range =
Range 8, 'Tota	il' SI Range =
Range 9, 'Tota	il' SI Range =
Range 10, 'To	tal' SI Range =
Range 11, 'To	tal' SI Range =
Range 12, 'To	tal' SI Range =
Range 13, 'To	tal' SI Range =
Range 14, 'To	tal' SI Range =
Range 15, 'To	tal' SI Range =
Range 16, 'To	tal' SI Range =
Range 17, 'To	tal' SI Range =
Range 18, 'To	tal' SI Range =
Range 19, 'To	tal' SI Range =
Range 20, 'To	tal' SI Range =
Range 21, 'To	tal' SI Range =
Range 22, 'To	tal' SI Range =
Range 23, 'To	tal' SI Range =
Range 24, 'To	tal' SI Range =
Range 25, 'To	tal' SI Range =
Range 26, 'To	tal' SI Range =
Range 27, 'To	tal' SI Range =
Range 28, 'To	tal' SI Range =
Range 29, 'To	tal' SI Range =
Range 30, 'To	tal' SI Range =
Range 31, 'To	tal' SI Range =

	NORTH ANNA IDUITS 1&	DESSURIZER SURGE NO77	E WELD OVERLAV ANALYSIS	
A.	NORTH ANNA ONTI 5 10	Z, I KESSONIZEK SOKOE NOZE	LE WEED OVERENT MIMETOIS	Ľ
	DOCUMENT NUMBER	PLANT		
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY	

Table D-19 Sleeve Fatigue Usage Factor Calculation

	Evaluation Title: Reference Files: Material: Type: UTS (ksi) = E matl (psi) =	North Ann	a - PZR Surg	e Nozzle W	eld Overl	ay Analysis	- TS (Outside Nod	e, 5081)
RANGE NUMBER	TRANSIENTS WITH RANGE EXTREMES	REQ'D CYCLES	E matl	PEAK SI RANGE	`S alt	(E ratio) x <u>S alt</u>	ALLOWABLE CYCLES <u>"N"</u>	USAGE FACTOR <u>"U"</u>
1	'RCSD'-'IOSurge_1'			<u></u>		I	· · · · · · · · · · · · · · · · · · ·	
2	'HUCD_1'-'IOSurge_1'	7						
3	'HUCD_1'-'RT_CDSI'	-		•				
4	'HUCD_1'-'SUIL'			а.				
.5	'RCOP'-'IOSurge_2'				۰.			
6	'HUCD_2'-'IOSurge_2'							
7	'HUCD_2'-'RT_CDnSI							
8	'LOSLSD'-'SIA'							
9	'LOSLSD'-'RT_CDnSI							
10	'RT_CDnSI-'RT_CDnSI							
11	'FCHSD'-'LOL'	1 ·						
12	'CRD'-'FCHSD'							
13	'FCHSD'-'IOSurge110_2'		•					
14	'RT_noCD'-'IOSurge110_2'							
15	'LOF'-'IOSurge110_1'							
16	'IOSurge110_1'- 'IOSurge110_2'							
17	'LOP'-'IOSurge110_1'	~						
18	'LSDL'-'IOSurge110_1'							
19	'PLUL_1'-'IOSurge110_1'					,	r -	
20	'PLUL_1'-'PLUL_1'							
21	'10SLinc'-'PLUL_2'		•	,				
22	'LOSLSU'-'PLUL_2'							
23.	'PLUL_2'-'PLUL_2'		ч.,					
24	'10SLdec'-'10SLdec'		•					
25	'BCE'-'TRT'			•				
26	'BCE'-'BCE'	,					-	
27	IOSurge Sub-Cycles ⁽¹⁾		• •	•				
28	Sub-Cycle within HUCD					•		

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table D-19	(Continued) Sleeve Fatigue Usage Factor Calculation	
The 'Peak SI Range' = 'Memb + Bend' S	I Range x Fatigue Strength Reduction Factor (FSRF) x Ke (as needed)	
Range 1, 'Memb + Bend' SI Range =		
Range 2, 'Memb + Bend' SI Range =		
Range 3, 'Memb + Bend' SI Range =		
Range 4, 'Memb + Bend' SI Range =		
Range 5, 'Memb + Bend' SI Range =		
Range 6, 'Memb + Bend' SI Range =		
Range 7, 'Memb + Bend' SI Range =		
Range 8, 'Memb + Bend' ŠI Range =		
Range 9, 'Memb + Bend' SI Range =		1
Range 10, 'Memb + Bend' SI Range =		
Range 11, 'Memb + Bend' SI Range =		
Range 12, 'Memb + Bend' SI Range =		
Range 13, 'Memb + Bend' SI Range =		
Range 14, 'Memb + Bend' SI Range =		
Range 15, 'Memb + Bend' SI Range =		
Range 16, 'Memb + Bend' SI Range =		
Range 17, 'Memb + Bend' SI Range =		
Range 18, 'Memb + Bend' SI Range =		
Range 19, 'Memb + Bend' SI Range =		ļ
Range 20, 'Memb + Bend' SI Range =		
Range 21, 'Memb + Bend' SI Range =		
Range 22, 'Memb + Bend' SI Range =		
Range 23, 'Memb + Bend' SI Range =		
Range 24, 'Memb + Bend' SI Range =		
Range 25, 'Memb + Bend' SI Range =		
Range 26, 'Memb + Bend' SI Range =		

Location	M+B Transient SI Range	Temp 1	Temp 2	Max. Temp.	Sm	Transient + External SI Range	EQ 1	EQ 2	Ke Factor
	ksi	°F	°F	°F	ksi	ksi			
-{									}

Note (1): Plastic analysis is used to find the CFUF associated with the Insurge/Outsurge Subcycles. See Appendix E.

Note ⁽²⁾: Equations 1 and 2 for Ke values are presented in Section D.4.2.3.2.

Note ⁽³⁾: IOSurge Transient contributes a partial usage factor of sub-cycles), see Section D.4.2.4 (last paragraph).

when this transient ranges within itself (i.e.,

Because the total usage factor **b** is above allowable value 1.0, plastic analysis is performed for IOSurge Transient at this location (Thermal Sleeve path TS) in Appendix E.

Α	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

D.5 SOFTWARE VERIFICATION

The finite element analyses documented in this report were performed using ANSYS v11.0 software (References 13.17 and 13.18). The suitability and accuracy of use of ANSYS v11.0 was verified by performing the following verification runs (Table D-20).

Table D-20 Software Verification Files

D.6 COMPUTER OUTPUT FILES

Table D-21 Computer Output and Input Files

AREVA	NORTH ANNA UNITS 18 document number 32-9049387-001	22, PRESSURIZER SURGE NOZZL PLANT NORTH ANNA UNITS 1 & 2	E WELD OVERLAY ANALYSIS
			、
	\$\$ \$		
,			
		· ·	
	·		
			•

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	NON DOODDET ADV
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIE IARY

APPENDIX E

NON-LINEAR ELASTIC-PLASTIC ANALYSIS

A	NORTH ANNA UNITS 18	&2, PRESSURIZER SURGE NOZZL	E WELD OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER	plant NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY
			· · ·

E.1 PURPOSE

The purpose of this Appendix is to analyze several points on the Surge Nozzle using Non-Linear Elastic-Plastic Analysis that could not be qualified with Simplified Elastic-Plastic Analysis presented in Appendix D.

E.2 NON-LINEAR ELASTIC-PLASTIC ANALYSIS (NB-3228.4)

The analysis is based on the requirements and procedures specified in NB-3228.4 of Reference 13.1. As mentioned in Section D.4.2.4, the elastic-plastic analysis is performed for IOSurge Transient ($\Delta t = \int_{-\infty}^{\infty}$ for all the sub-cycles, and the locations which do not meet the ASME Section III elastic or simplified elastic-plastic criteria (Reference 13.1) are then evaluated in accordance with par. NB-3228.4 - Shakedown Analysis. The path locations evaluated with elastic-plastic approach are: SEL_Wola inside, and Sleeve outside.

Par. NB-3228.4 of Reference 13.1, states that the limits on Thermal Stress Ratchet in Shell (NB-3222.5) and Progressive Distortion of Non-Integral Connections (NB-3227.3) need not be satisfied at a specific location, if, at the location, the procedures of (a) through (c) are used. The shakedown of a structure is defined by NB-3213.34 of the same reference as the deformation response of the structure that after a few cycles of load application, ratcheting ceases and the subsequent structural response is elastic, or elastic-plastic, and progressive incremental inelastic deformation is absent.

NB-3228.4(a): In evaluating stresses for comparison with the remaining stress limits, the stresses shall be calculated on an elastic basis.

Since the stresses for comparison with the remaining stress limits are calculated on elastic basis as presented in previous sections. This requirement is satisfied.

NB-3228.4(b): In lieu of satisfying the specific requirements of NB-3221.2, NB-3222.2, NB-3222.5, and NB-3227.3 at a specific location, the structural action shall be calculated on a plastic basis, and the design shall be considered to be acceptable if the shakedown occurs (as opposed to continuing deformation).

A detailed finite element analysis is performed to verify that shakedown occurs when the surge nozzle is exposed to the IOSurge Transient along with the applicable external loads.

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

E.2.1 FINITE ELEMENT MODEL FOR ELASTIC-PLASTIC ANALYSIS

Since the plastic behavior of the material is time dependent, the external loads have to be applied directly to the FE model along with the thermal transient and pressure loads. The 2-D axisymmetric ANSYS FE model does not have 2-D elements for non-symmetric external loads application in the elastic-plastic analysis, therefore the 2-D model built in ANSYS WORKBENCH 11.0 was expanded into 180° symmetric 3-D model to perform the elastic-plastic analysis, as shown in Figure E-1.

The boundary conditions and the surface loading are similar to 2-D FE model (see Section 4.4) except symmetry boundary condition at the front face of the 180° FE model. The symmetry boundary condition is modeled by setting zero displacement normal to the plane of symmetry (UZ = 0). The FE model is meshed using the structural element SOLID186 (3-D 20-Node Structural Solid Element). This element is converted to the thermal element SOLID90 (3-D 20-Node Thermal Solid Element) for the thermal analysis.

Figure E-1 3-D Finite Element Model

~	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

The 3-D FE model including the elastic material properties obtained from Reference 13.15 is same as the 2-D FE model and is documented in the output file

For the following elastic-plastic structural analysis, the plastic material properties have to be added at the critical locations. The elastic-plastic material definition is documented in the output file

	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

E.2.2 DESIGN CONDITION ANALYSIS

To verify the correct behavior of the model as well as the correct settings of the boundary conditions, the structural run with Design pressure and Design temperature was performed and compared with the results of 2-D analysis (see Figure 6-2, Section 6). The stress intensity contour plot for the 3-D model under the Design Conditions is shown in Figure E-2. This Design Condition run is documented in the output file:

Figure E-2 Stress Intensity Contours for 3-D Design Pressure Run

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

E.2.3 THERMAL TRANSIENT ANALYSIS FOR IOSURGE TRANSIENT

The thermal loads and boundary conditions as described and specified in detail in Section 7 and Section D.2 were applied to the 3-D finite element model. Note that only transient IOSurge are evaluated in the elastic-plastic analysis. The thermal run of this transient is documented in the output file:

The thermal results were evaluated by examining the magnitude of temperature differences between key locations of the model. The approximately same node locations as shown in Figure 7-1 were selected for the thermal gradient determination. The output file documenting these nodal temperatures and temperature gradients: Based on the results documented in this file and temperature and temperature gradient plots (Figure E-3), it has been confirmed that 3-D model gives the same results as 2-D model. These corresponding results provide other verification between the 2-D and 3-D model behavior.

Figure E-3 Temperature and Temperature Gradients for IOSurge Transient

Δ	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIEȚARY

E.2.4 ELASTIC-PLASTIC MATERIAL PROPERTIES

Since the total SI ranges are below the $3S_m$ limit at locations in the surge nozzle material, the nozzle (and head) is still modeled with elastic material properties as before. Part of the pipe, remote from the weld overlay area, is also modeled with elastic material properties. The true

Multilinear Kinematic Hardening (KINH) material model was used. KINH options use the Besseling model, also called the sub-layer or overlay model, so that the Bauschinger effect is included. The ANSYS options of KINH allow to define enough stress-strain curves (total 40, 8 used) as well as the number of points per curve (total 20, 16 used). Note that only part of the surge nozzle assembly subjected to plastic deformation is modeled with elastic-plastic material properties, as shown in Figure E-4.

A	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER	plant NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Figure E-4 Elastic-Plastic Region of the Model

Table E-1 lists the data for the stress-strain curves for the materials at various temperatures given by Reference 13.2. Table E-2 tabulates the first strain values of the curve based on the Young's modulus taken from Reference 13.15.

А	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	. PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Table E-1 Elastic-Plastic Material Properties of

Strain	Stress [psi]							
[-]	700F	600F	500F	400F	300ፑ	200F	100年	70F
						·		
				,				
					ì			
						,		
	2							•
						.*		
							•	
							•	
							,	
					1	•		
		• '						
$\boldsymbol{\Sigma}$								_

Table E-2 First Strain Values for Table E-1

Temperature	700F	600ፑ	500F	400ፑ	300F	200ፑ	100 F	70F
Strain	(

Table E-3 lists three sets of Young's modulus, coefficients of thermal expansion and data of the stress-strain curves for per Reference 13.3.

Та	ble E-3 Elas	stic-Plastic I	Material Pro	operties of	· J	
Temperature [F]	75	5 ° F	620	ም .	980	ዋ
E [psi]						
α [10 ⁻⁶ in/in-۴]						
	Strain [-]	Stress [psi]	Strain [-]	Stress [psi]	Strain [-]	Stress [ps
	r					
						J
		~				
		6			1	
		•				
	l		`			
	A_					

A .	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENTNUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

E.2.5 EXTERNAL LOADS

External loads defined at the end of the safe end are transformed to the end of the modeled pipe as shown in Figure E-5. The transformed local loads are listed in Table E-4.



The following formulae are used in transforming the loads into the local coordinate system:

 $F_{xL} = F_x$ $F_{yL} = F_y$ $F_{zL} = F_z$ $M_{xL} = M_x - F_z \cdot L$ $M_{yL} = M_y$ $M_{zL} = M_z + F_x \cdot L$ where:

L = 10.9 in. is taken from the ANSYS FE model

The loads applied at the safe end are obtained from Reference 13.8 with proper transformation of coordinate systems and directions. The Dead Weight loadings are conservatively taken from Attachment 11 of Reference 13.8. The Thermal loadings under normal operation condition are taken from the UNSTR Condition in Attachment 9, page 7, of the same reference. The

Prepared by: M. Sedlakova Reviewed by: L. Yen

A	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANI	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

The enveloped loads are considered as the corresponding component forces and moments to the maximum resultant moment applied at the end of pipe among all stratification cases.

The resulting loads applied to the FE model are shown in Figure E-6. These local loads are applied to the model via surface-based constraints. The forces and moments are applied on a pilot node. This pilot node is the only target segment (TARGE170 element) on the target surface side. It is the master node of the MPC (multipoint constraint approach) equations. The bottom pipe cross-section area is the contact surface and contains the contact elements (CONTA174). The nodes of these elements are the slave nodes of the MPC equations. Options of these contact elements are for a force-distributed surface constraint. Since the FE model contains symmetry boundary conditions, the torsional moment, shear force in the "z" direction and bending moment in the "x" direction are not applicable. All three moments are then conservatively summed by SRSS as the bending moment acting in the "–z" direction as follows:

Shear force applied at the pilot node in the +x direction: $F_{shear} = \sqrt{F_{xL}^2 + F_{zL}^2}$

Bending moment applied at the pilot node in the -z direction: $M_{bending} = \sqrt{M_{xL}^2 + M_{yL}^2 + M_{zL}^2}$

Loads (absolute values)	F _{xL} [lbs]	F _{y∟} [lbs]	F _{z∟} [lbs]	M _{xL} [in-lbs]	M _{yL} [in-lbs]	M _{zL} [in-lbs]
Dead Weight	$\boldsymbol{\mathcal{C}}$					
Thermal						
Stratification			<u> </u>			

 Table E-4
 External Loads

Since only half of the geometry is modeled with symmetry condition, the above loads are divided by 2 when input in ANSYS.

A	NORTH ANNA UNITS 1	&2, PRESSURIZER SURGE NOZZL	E WELD OVERLAY ANALYSIS
AREVA	DOCUMENT NUMBER 32-9049387-001	plani NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

Figure E-6 External Loads at Pilot Node

The external loads are not constant during the evaluated transient time points. The evaluated transient time points along with the applied external loads are listed in Table E-5. Note that OBE is typically assumed to occur during the normal operating conditions at full power and therefore is not considered in these transients, which do not contain such as conditions. The Stratification (STR) loads are not applied at the time period during the Insurge/Outsurge. Dead Weight (DW) and Thermal (TH) loads are applied to all time points. The applied external loads and load combination is documented in the following iput file

Load Case	Time [hr]	Comment	External Load Combination
1	0.0001		DW+TH+STR
2	0.0500		DW+TH+STR
3	0.050653		DW+TH
4	0.0667		DW+TH
5	0.08413	:	DW+TH
6	0.09663		DW+TH
7	0.2		DW+TH
8	0.3167		DW+TH
9	0.3333		DW+TH
10	0.35		DW+TH
11	0.40		DW+TH
12	0.5		DW+TH+STR
13	0.783333		DW+TH+STR
14	1.0000		DW+TH+STR

Table E-5 Time Points of Interest for 'IOSurge' Structural Elastic-Plastic Analysis

А	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
ADEVA	DOCUMENT NUMBER	PLANT	NON_PROPRIFTARV
	32-9049387-001	NORTH ANNA UNITS 1 & 2	

E.2.6 RESULTS OF THE ELASTIC-PLASTIC ANALYSIS

The shakedown of a structure occurs if, after a few cycles of load application, ratcheting ceases. In order to inspect the shakedown of the surge nozzle, the new elastic-plastic IOSurge Transient was analyzed for 10 cycles in the structural runs. The stress analyses are performed for each cycle with time points of interest listed in Table E-5. Selected time points include time points corresponding to the critical parts of IOSurge Transient, maximum thermal gradients, and other intermediate time points. The number of time points in one cycle is adequate to ensure that the elastic-plastic analysis results are accurate and to ensure numerical stability in the model. The nodal temperature at the particular time point is read into the structural model directly from the result file of the thermal analysis. The FE model of the surge nozzle is then loaded by the internal pressure and external loads. The ANSYS output file documenting the structural run is:

Figure E-7 Nodes for Post-Processing of Elastic-Plastic Analysis

٨	NORTH ANNA UNITS 1&:	2, PRESSURIZER SURGE NOZZ	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

The figure below is extracted from Figure 9-1 for 2-D elastic analysis in the main document, and the nodes corresponding to the same locations are selected in the 3-D elastic-plastic analysis, as illustrated in Figure E-7. During the post-processing, the time histories of total strains are investigated at four locations. Two selected nodes are at the locations of the inside node of Path SEL_Wola and outside node of Path Sleeve. Nodes 180° from these two locations are also selected to ensure the worst conditions are captured due to the applied external loads.

Figure E-7 (continued) Nodes for Post-Processing of Elastic-Plastic Analysis

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007 Page 243a

A	NORTH ANNA UNITS 1&	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	· · ·
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

The maximum principal total strain ranges of each calculated cycle are listed in Table E-6. The principal total strain range calculation follows the same approach prescribed in NB-3216.2 of Reference 13.1 for total stress ranges. The total strain $\varepsilon_{ij}^{(t)}$ is the summation of elastic $\varepsilon_{ij}^{(e)}$ and plastic $\varepsilon_{ij}^{(p)}$ strains: $\varepsilon_{ij}^{(e)} = \varepsilon_{ij}^{(e)} + \varepsilon_{ij}^{(p)}$. Let ε_1 be the algebraically largest and ε_3 the algebraically smallest strain $(\varepsilon_1 \ge \varepsilon_2 \ge \varepsilon_3)$, the numerically (absolute) maximum principal strain is defined by $\varepsilon_{max} = \max(|\varepsilon_1|, |\varepsilon_2|)$. The maximum total principal strain range is then $\Delta \varepsilon_{max}^t = \max(|\Delta \varepsilon_1|, |\Delta \varepsilon_3|)$, where the range is taken between the components of the total strain. The principal strain range is calculated "after" taking the strain component range. The post-processing is documented in the output files: and the output files containing the calculated strain ranges for the selected nodes are the totlowing:

Table E-6	Maximum	Principal	Total	Strain	Ranges
-----------	---------	-----------	-------	--------	--------

Strain Ranges for IOSurge Transient							
Cycle	Node # 12507	Node # 18610	Node # 18719	Node # 18575			
1							
2							
3							
4				×			
5			٨				
6							
7							
8							
9			·	· .			
10		b umment i su muni	۰ ۱۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰۰				

A review of the strain time history indicates shakedown occurs at all investigated locations. Typical curves of the displacement and strain components versus time (node #12507 and #18575) are shown in Figure E-8 through Figure E-11. Stability of the structural response can be observed from these figures. The file documenting these printed outputs is:

The UZ, ε_{yz} , and ε_{xz} components are not shown since all selected nodes are located on the plane of symmetry where UZ displacement in the horizontal direction (see Figure E-6) is equal to zero and shear strains are relatively small in comparison with normal strains (ε_x , ε_y , and ε_z).

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSIS				
AREVA	DOCUMENT NUMBER	PLANT	NON-PROPRIFTARY		
	32-9049387-001	NORTH ANNA UNITS 1 & 2			



Figure E-9 Displacement Plots for Node #12507 and IOSurge Transient

Prepared by: M. Sedlakova Reviewed by: L. Yen Date: 12/2007 Date: 12/2007

A	NORTH ANNA UNITS 1&2, PRESSURIZER SURGE NOZZLE WELD OVERLAY ANALYSI					
AREVA	DOCUMENT NUMBER	NORT	plant H ANNA UNITS 1 & 2	NON-PROPRIETARY		
,	J2-70+7307-004					
/						
/						
			·			
			,			
				· · · ·		
			•	۲. 		
		1				
		×.	•			
L						
		· • •				
r -	igure E-10 Strain Pio	its for No	ວde #18575 and ເບະ	Surge Transient		
			· · ·	4.		
1						

Figure E-11 Displacement Plots for Node #18575 and IOSurge Transient

Δ	NORTH ANNA UNITS 1&2	2, PRESSURIZER SURGE NOZZI	LE WELD OVERLAY ANALYSIS
A	DOCUMENT NUMBER	PLANT	
AREVA	32-9049387-001	NORTH ANNA UNITS 1 & 2	NON-PROPRIETARY

NB-3228.4(c): In evaluating stresses for comparison with fatigue allowable, the numerically maximum principal total strain range shall be multiplied by one-half the modulus of elasticity of the material (Young's modulus) at the mean value of the temperature of the cycle. Since the internal cycles of the IOSurge Transient is excluded in the previous elastic analysis of inside node of Path SEL_Wola and outside node of Path Sleeve, the principal stress intensity ranges calculated from the total strain ranges in the elastic-plastic analysis shall be additionally considered for fatigue evaluation at these locations. In order to obtain the principal stress intensity ranges, the principal total strain ranges shall be multiplied by the factor $E_t (E_c/E_t) = E_c$, where E_t is the Young's modulus at the mean temperature of the cycle and E_c is the referenced Young's modulus of the fatigue curve (28.3 $\cdot 10^6$ psi for high alloy steel per Reference 13.1). The highest stress intensity ranges at the selected nodes within the 10 loading cycles during the elastic-plastic analysis are obtained and reviewed, and Table E-7 summarizes the maximum strain and stress results.

Nòde #	Maximum Strain Range (Table E-6, Path St	SI Range [ksi]		
12507		<u> </u>	ſ)
18719		<u> </u>	ι	
Node #	Maximum Strain Range (Table E-6, Slee	from Selected Nodes eve, outside)	SI Rang	e [ksi]
18610))
18575		J	<u> </u>	/

Table I	E-7	Maximum	Principal	Strain	Ranges	and	Calculated	SI	Ranges
					U				v

The maximum SI Ranges of are used in the fatigue usage calculation in Table E-8 and E-9. Since IOSurge Transient is critical only when it is ranging within itself, the number of sub-cycles accounted for in the elastic-plastic analysis is as discussed in Table D-1. The remaining can range with other transients and are accounted for in the elastic analysis in Appendix D.



Table E-8 Fatigue Usage Factor Calculation for Safe End



Table E-9 Fatigue Usage Factor Calculation for Thermal Sleeve

EVALUATION TITLE: North Anna - PZR Surge Nozzle Weld Overlay Analysis - Sleeve (outside)

See Table 10-1 in the main body of the calculation for summary of the total fatigue usage factors for all evaluated materials using elastic or elastic-plastics analysis.


E.3 SOFTWARE VERIFICATION

The finite element analyses documented in this report were performed using ANSYS v11.0 software (References 13.17 and 13.18). The suitability and accuracy of use of ANSYS v11.0 was verified by performing the following verification runs (Table E-10).



E.4 COMPUTER OUTPUT FILES

Table E-11 Computer Output and Input Files

A AREVA	NORTH ANNA UNITS 1 document number 32-9049387-001	&2, PRESSURIZER SURGE NOZZL PLANI NORTH ANNA UNITS 1 & 2	E WELD OVERLAY ANALYSIS NON-PROPRIETARY
\int			
	•.		•
			· · · · · · · · · · · · · · · · · · ·

Prepared by: M. Sedlakova Reviewed by: L. Yen